




- Caulking not completed around balcony brackets



- Sheet metal not covering building wrap in certain locations



- All the stair doors in the basement need to be unlocked at all times for emergency egress reasons.



- Trim end not finished in certain areas in stair wells.