



Technical drawing showing a cross-section of a parapet wall assembly. The drawing includes the following components and labels:

- T.O. PARAPET (Top of Parapet)
- DOBL. 2x TOP PLATES, STAGGER SPICES A MINIMUM OF 6'-0"
- 2x6 PARAPET FRAMING INTEGRAL w/ TRUSS DESIGN
- 2x6 BLOCKING w/ (4) 10d TOE NAILS INTO ROOF TRUSS EACH END OF WOOD BLOCKING
- EXTERIOR WALL SHEATHING, w/ INSULAT
- DOUBLE TOP PLATE
- 2x6 EXTERIOR BEARING WALL
- 5/8" GYP BOARD
- ROOF TRUSSES, SEE PLANS
- SIMPSON "H1" ANCHOR AT EACH
- 3/4" CDX PLYWOOD
- INSULATION SEE ARCH. PLANS
- ATTACH ROOF SHEATHING TO NAILER w/ 10d AT 6" o/c

PARALLEL ROOF SHEATHING  
 1/2"x6" JOISTS AT 32" o/c  
 ROOF FRAMING, SEE PLANS  
 SIMPSON H3 CLIP  
 2x NAILER w/ 1/2" DIAMETER SIMPSON T  
 HD AT 4'-0" o/c (3 5/8" MINIMUM EMBED)  
 BOND BEAM W/ (2) #5 x  
 CONTINUOUS  
 ATTACH SHEATHING TO 2x10  
 BLOCKING w/ 10d AT 6" o/c  
 INSULATION  
 (SEE ARCH. PLANS)  
 3/4" CDX PLYWOOD  
 WOOD ROOF TRUSSES,  
 SEE PLANS  
 CONT. 3 1/2"x6" BOLT TO MASONRY  
 w/ SIMPSON'S 1/2"x6" TITEN HD  
 SCREW ANCHORS AT 16" o/c  
 w/ SIMPSON BP 3/4-3HDG  
 BEARING PLATES (STAGGER TOP  
 AND BOTTOM)

3 1/2"x6" RIM BOARD w/ (3)  
16d NAILS AT EACH JOIST

3/4" CDX PLYWOOD

3 1/2"x6" JOISTS AT 32" o/c

TOE NAIL FLOOR JOIST TO DOUBLE  
TOP PLATE w/ (4) 10d EACH JOIST

TOE NAIL RIM BOARD TO DOUBLE TOP  
PLATE w/ 10d AT 7" o/c UNLESS NOTED  
OTHERWISE

DOUBLE TOP PLATE

DOBL. 2x TOP PLATES,  
STAGGER SPICES A  
MINIMUM OF 6'-0"

T.O. PARAPET

ATTACH ROOF SHEATHING TO  
BLOCKING w/ 10d NAILS AT 6"  
MAXIMUM

EXTERIOR WALL SHEATHING  
w/ INSULATION

6 ROOF FRAMING. JOISTS ON EXTERIOR BEARING WALL

[illegible]

**W**  
CAPITAL GROUP  
Developer: W Capital Group  
tylere@capitalgroupinc.com | 608.345.9848

**d**  
Architect: OpeningDesign  
316 W Washington Ave | Suite 675  
Madison, WI 53703  
ryan@openingdesign.com | 773.425.6456

**ROYAL CONSTRUCTION**  
General Contractor: ROYAL CONSTRUCTION  
3653 Greenway Street | Eau Claire, WI 54701  
jim@royalbuilt.com | 715.225.6377

**Cedar corporation**  
Civil Engineer: CEDAR CORPORATION  
604 Wilson Avenue | Menomonie, WI 54751  
kevin.oum@cedarcorp.com | 715.235.9081

**XC**  
Structural Engineer: XC Structural Engineering  
Calle Apolonio Morales, 628036 Madrid,  
perastotat@engineering-ye.com | +34 610 56 26 37

**Innovation Engineering Services Incorporated**  
Structural Engineer of Record: Innovation  
8729 Dale-Curtain Dr | Chippewa Falls, WI 54558  
kfrey@innovationebuilt.com

**Hovland's**  
Mechanical Engineer: HOVLAND'S HVAC  
10954 E. Melby Street | Chippewa Falls, WI 54729  
jhansen@hovlands-inc.com | 715.552.5595

**PRISM DESIGN**  
ELECTRICAL CONSULTANTS INC.  
Electrical Engineer: PRISM DESIGN ELECTRICAL CONSULTANTS INC.  
E8403 State Rd 88 | Monroeville, WI 54755  
nat@prismdesign-electrical.com | 715.971.0602

**TE TAILORED ENGINEERING**  
Plumbing Engineer: TAILORED ENGINEERING  
1600 Aspen Commons | Ste 210 | Middleton, WI 53562  
bnovack@tailoredeng.com | 608.209.7500