## EQUIPMENT AND APPLIANCES ON ROOFS OR ELEVATED STRUCTURES (IMC 306.6)

Where equipment requiring access and appliances are installed on roofs or elevated structures at a height exceeding 16 feet, such access shall be provided by a permament approved means of access, the extent of which shall be from grade or floor level to the equipment and appliances' level service space.

## GUARDS (IFGC 306.6)

Guards shall be provided where appliances or other components that require service and roof hatch openings are located within 10 feet of a roof edge or open side of a walking surface and such edge or open side is located more than 30 inches above the floor, roof or grade below.

