

July 16, 2015

**RECORD ONLY, NO LETTER SENT**

Designer CUST ID No. 1322626

Responsible Party

RYAN SCHULTZ  
OPENINGDESIGN  
312 W LAKESIDE ST  
MADISON WI 53715

**ADDITIONAL INFORMATION PHONE CALL**

**SITE:**

Xcel Sports Complex  
Pitzner Pkwy  
City of Jefferson  
Jefferson County

**FOR:**

Facility: 751266 XCEL SPORTS COMPLEX  
PITZNER PKWY

Identification Numbers
<b>Transaction ID No. 2565163</b>
<b>Site ID No. 813559</b>
Please refer to both identification numbers, above, in all correspondence with the agency.

Object Type: Building ICC Regulated Object ID No.: 1543519 Code Applies Date: 06/25/15  
Combined Footing & Foundation Review only & Permission to Start; Major Occupancy: Assembly; Type IIB Metal  
Frame Unprotected class of construction; New plan; 50,800 project sq ft; Completely Sprinklered; Occupancy: A-3  
Other Assembly Uses; Sprinkler Design: NFPA-13 Sprinkler

The submittal described above has been placed on **HOLD** and the review and approval is pending subject to receipt of the ADDITIONAL INFORMATION and accompany the resubmittal:

- SPS 361.31(2)(e) - Provide additional calculations or information to substantiate that the submitted plans conform to this code.
  - Please submit a more detailed site plan indicating distance to property lines, open area, etc. The building occupancy and building type would require the building to be unlimited and shall meet all requirements of IBC 507.6.
  - Please submit a floor plan.