

							Lighting Fixture	Schedule		
Type Mark	Stock Number	Туре	Location	Count	Manufacturer	Luminous Flux	Initial Color Temperature	Mounting	Accessories	URL
1	DI-0214	SUNRISE LED Light Bar	Clinic Entrance	10	Diode LED	270 lm	6300 K	At edge of eavedirected at building	Wet Location LED Connectors	http://www.diodeled.com/sunrise-led-light-bar/
1	DI-0214	SUNRISE LED Light Bar	Clinic Exit	7	Diode LED	270 lm	6300 K	At edge of eavedirected at building	Wet Location LED Connectors	http://www.diodeled.com/sunrise-led-light-bar/
1	DI-0214	SUNRISE LED Light Bar	Fitness Center Entrance	12	Diode LED	270 lm	6300 K	At edge of eavedirected at building	Wet Location LED Connectors	http://www.diodeled.com/sunrise-led-light-bar/
1	DI-0214	SUNRISE LED Light Bar	Xcel Entrance	12	Diode LED	270 lm	6300 K	At edge of eavedirected at building	Wet Location LED Connectors	http://www.diodeled.com/sunrise-led-light-bar/
2	CTKRV1A	The Caretaker LED	Loading	1	Cooper Lighting	5212 lm	5000 K	Wall Mounted - 10'-0" AFF	Small Acrylic Refractor (full cut-off shielding)	http://www.cooperindustries.com/content/public/en/lighting/products/area_site_lighting/_855683.html
2	CTKRV1A	The Caretaker LED	Parking Lot	24	Cooper Lighting	5212 lm	5000 K	(2) Fixtures Pole Mounted - 25'-0" AFF	Small Acrylic Refractor (full cut-off shielding)	http://www.cooperindustries.com/content/public/en/lighting/products/area_site_lighting/_855683.html









Lake Country Engineering 970 S. Silver Lake Street, Suite 105 Oconomowoc, WI 53066 Rob Davy robd@lce.biz (262) 569-933



Landscape
Ground Affects Landscaping, Inc.
W1526 Froelich Rd.
Sullivan, WI 53178
Tom Ball tom@groundaffectslandscaping.com 262.593.8400



OpeningDesign 312 W. Lakeside St Madison, WI 53715" Ryan Schultz ryan@openingdesign.com 773-425-6456



Structural ntrive 1608 S. Ashland Ave., #82002 Chicago, IL 60608 Steven Uecke s.uecke@ntrive.com 630-480-4120x101







Electrical Jefferson Current Electric 1473 S. Industrica Ave Jefferson, WI 53549 Ross Davis j.current.electric@att.net

920-674-6444





No.	Description	Date
	SITE PLAN REVIEW	05.13.2015
	PERMIT	08.18.2015
	IFC - OVERALL BUILDING	10.26.2015

Xcel Sports Complex

Site Lighting Details

10/26/2015 10:13:04 AM

C	
	CONCRETE SITE WALK
	SLOPE 1:12 MAX SLOPE 1:10 MAX SLOPE 1:10 MAX
В	IF PARKING ADJACENT TO CURB: ADA SIGNAGE PER • SEC. 502.7 • SEC. 703.6.3.1 FROM (A.117.1-2009)
	5' - 0" MIN. (MARKED ACCESS AISLE) ADA Curb Ramp 3/8" = 1'-0"