



ALSO, ALEX BAUSK'S PRELIMINARY PLAN HAD PIERS AT THESE LOCATIONS AS WELL
FILE (Sports_Complex\Structural\2D\Footings Preliminary.dwg)

CAN WE PULL THESE PIERS INWORD
TOWARD THE BUILDING SO THERE'S
NO JOGS ON THE EXTERIOR OF THE
FOUNDATION WALL? (TYPICAL AT ALL
EXTERIOR WALLS)

#5 Rebar @ 12" O.C. Each Way, Bottom Type

#4 Ties @ 12" O.C. Vert., With (4) #5 Vert., Piers Typ

[illegible]

5/13/2015 2:35:32 PM

