

P1
1/2" = 1'-0"



P2
1/2" = 1'-0"



P3
1/2" = 1'-0"



P4
1/2" = 1'-0"



P5
1/2" = 1'-0"



P5A
1/2" = 1'-0"



P5B
1/2" = 1'-0"



P5C
1/2" = 1'-0"



P6
1/2" = 1'-0"



P6A
1/2" = 1'-0"



P7
1/2" = 1'-0"



P8
1/2" = 1'-0"



P9
1/2" = 1'-0"

NOT USED

P10
1/2" = 1'-0"



P11
1/2" = 1'-0"



P11A
1/2" = 1'-0"



P12
1/2" = 1'-0"



P13
1/2" = 1'-0"



P13A
1/2" = 1'-0"

NOT USED

P13B
1/2" = 1'-0"



P14
1/2" = 1'-0"

PIER SCHEDULE					
MARK	VERTICAL REINF	PIER TIES	ELEV OF TOP OF PIER	ANCHOR BOLT	REMARKS
P1	(4) #6	(3) #3 @ 2" REST #3 @12"	99'-0"	(4) 3/4" Ø x 9" EMBED	-
P2	(4) #6	(3) #3 @ 2" REST #3 @12"	99'-0"	(4) 3/4" Ø x 9" EMBED	-
P3	(4) #6	(3) #3 @ 2" REST #3 @12"	99'-0"	(4) 3/4" Ø x 9" EMBED	-
P4	(4) #6	(3) #3 @ 2" REST #3 @12"	99'-0"	(4) 3/4" Ø x 9" EMBED	-
P5	(4) #6	(3) #3 @ 2" REST #3 @12"	99'-0"	(4) 3/4" Ø x 9" EMBED	-
P5A	(4) #6	(3) #3 @ 2" REST #3 @12"	99'-0"	(4) 3/4" Ø x 9" EMBED	-
P5B	(4) #6	(3) #3 @ 2" REST #3 @12"	99'-0"	(4) 3/4" Ø x 9" EMBED	-
P5C	(4) #6	(3) #3 @ 2" REST #3 @12"	99'-0"	(4) 3/4" Ø x 9" EMBED	-
P6	(4) #6	(3) #3 @ 2" REST #3 @12"	99'-0"	(4) 3/4" Ø x 9" EMBED	-
P6A	(4) #6	(3) #3 @ 2" REST #3 @12"	99'-0"	(4) 3/4" Ø x 9" EMBED	-
P7	(4) #6	(3) #3 @ 2" REST #3 @12"	99'-0"	(4) 1" Ø x 12" EMBED	-
P8	(6) #6	(3) #3 @ 2" REST #3 @12"	99'-0"	(4) 1" Ø x 12" EMBED	-
P9	(6) #6	(3) #3 @ 2" REST #3 @12"	99'-0"	(4) 1" Ø x 12" EMBED	-
P10					NOT IN USE
P11	(6) #6	(3) #3 @ 2" REST #3 @12"	99'-0"	(4) 3/4" Ø x 9" EMBED	-
P11A	(6) #6	(3) #3 @ 2" REST #3 @12"	99'-0"	(4) 3/4" Ø x 9" EMBED	-
P12	(6) #6	(3) #3 @ 2" REST #3 @12"	99'-0"	(4) 3/4" Ø x 9" EMBED	-
P13	(8) #6	(3) #3 @ 2" REST #3 @12"	99'-0"	(4) 1" Ø x 12" EMBED	-
P13A	(8) #6	(3) #3 @ 2" REST #3 @12"	99'-0"	(4) 1" Ø x 12" EMBED	-
P13B					NOT IN USE
P14	(6) #6	(3) #3 @ 2" REST #3 @12"	99'-0"	(4) 1" Ø x 12" EMBED	-

FOOTING SCHEDULE					fs = 3000 psf f'c = 3000 psi
	SIZE			REINFORCING	
MARK	L	S	D	LONG BARS	SHORT BARS
F5	5'-0"	5'-0"	1'-6"	6 #4	6 #4
F7	7'-0"	7'-0"	2'-0"	8 #5	8 #5
F8	8'-0"	8'-0"	1'-6"	9 #6	9 #6
F10	10'-0"	10'-0"	2'-0"	11 #5	11 #5
F11	11'-6"	11'-6"	2'-0"	13 #5	13 #5

Owner
4860 Highwood Circle
Middleton, Wisconsin 53562
Todd Goldbeck
todd@xcel.net
608-279-6960

General Contractor
Krause Custom Builders
N3897 Duck Creek Rd
Helenville, WI 53137
Toby Krause
tobykrause@gmail.com
920-285-6490

Civil
Lake Country Engineering
970 S. Silver Lake Street, Suite 105
Oconomowoc, WI 53066
Rob Davy robd@lce.biz
(262) 569-933

Landscape
Ground Affects Landscaping, Inc.
W1526 Froelich Rd.
Sullivan, WI 53178
Tom Ball
tom@groundaffectslandscaping.com
262.593.8400

Architect
OpeningDesign
312 W. Lakeside St
Madison, WI 53715*
Ryan Schultz
ryan@openingdesign.com
773-425-6456

Structural
ntrive
280 Shuman Blvd, Suite 270
Naperville, IL 60563
Steven Uecke
s.uecke@ntrive.com
630-480-4120x101

Metal Building Manufacturer
Foremost Buildings, Inc.
895 N Parkway Street
Jefferson WI 53549
Jim Horn
JimH@foremostbuildings.com
920-674-5028

HVAC
Lake Country Heating and Cooling
N8333 Hwy F
Oconomowoc, WI 53066
Jim Shuda
jim@lakecountryhvac.com
414-573-1047

Electrical
Jefferson Current Electric
1473 S. Industrica Ave
Jefferson, WI 53549
Ross Davis
j.current.electric@att.net
920-674-6444

Plumbing
Pelikan Plumbing
144 Main St
Sullivan, WI 53178
Mike Pelikan
pelikanplumbing@yahoo.com
262-593-2290

No.	Description	Date
	ISSUED FOR PERMIT	07.08.2015
	IFC - FOOTING AND FOUNDATION	07.29.2015
	REISSUED FOR REVISED REACTION	08.06.2015
	ADDED DIMENSIONS	08.10.2015

Xcel Sports Complex

SCHEDULES, BASE PLATE AND PIER DETAILS

Date 8/10/2015 3:34:10 PM

S-101

Scale As indicated