DIVISION OF INDUSTRY SERVICES
2331 SAN LUIS PL STE 150
GREEN BAY WI 54304
Contact Through Relay
http://dsps.wi.gov/programs/industry-services
www.wisconsin.gov
Scott Walker, Governor
Dave Ross, Secretary



August 31, 2015

CUST ID No. 1322626

RYAN SCHULTZ OPENINGDESIGN 312 W LAKESIDE ST MADISON WI 53715

REQUEST FOR ADDITIONAL INFORMATION

SITE:

Xcel Sports Complex Pitzner Pkwy City of Jefferson Jefferson County

FOR:

Facility: 751266 XCEL SPORTS COMPLEX

PITZNER PKWY

Identification Numbers

Transaction ID No. 2580428 Site ID No. 813559

Please refer to both identification numbers, above, in all correspondence with the agency.

Object Type: Building ICC Regulated Object ID No.: 1543519 Code Applies Date: 06/25/15

Major Occupancy: Assembly; Type IIB Metal Frame Unprotected class of construction; New plan; 50,800 project sq ft;

Occupancy: A-3 Other Assembly Uses; Sprinkler Design: NFPA-13 Sprinkler

The submittal described above has been placed on **HOLD** and the review and approval is pending subject to receipt of the ADDITIONAL INFORMATION and/or revised plans requested by this letter. Upon receipt of the additional information and/or revised plans, the plans will be reviewed for compliance to applicable Wisconsin Administrative Codes and Wisconsin Statutes.

The following must be corrected/revised and accompany the resubmittal:

Key Item(s)

- **IBC 602.2** Buildings of Types I and II construction shall have all beams, columns, exterior walls, interior partitions, floors & floor assemblies, roofs and roof assemblies of non-combustible materials other than as noted in Section 603, and elsewhere in this code. Refers to wall assemblies E2.A & E2.B. Also, please send information on the polycarbonate panels and Northwood Resin panels to verify non-combustibility. Additionally, see section IBC 1406.2.2, and plastics IBC section 2612.
- Revised plans are required to be submitted. The fee for a plan re-submittal received prior to a denial action is \$75 + \$100 submittal fee = \$175. Include either 4 revised plans or one revised plan & 3 updated index sheets showing plan sheet revision dates.
- **IBC 1015.1** Two exit or exit access doorways from any space are required when the occupant load of the space is greater than the values within Table 1015.1 when the common path of travel is greater than the limitations stated in Section 1014.3, and per other referenced sections. *Refers to Wrestling 122*.

RYAN SCHULTZ Page 2 8/31/2015

Our agency offers a number of worksheets and checklists for the Commercial Building Code at http://dsps.wi.gov/Documents/Industry%20Services/Forms/Commercial%20Buildings/Combined%20Worksheets%2 OInstructions%20 2009%20ICC .pdf that may assist you in preparing your submittal.

Send your re-submittal into the address listed above, unless otherwise noted, and the department will review the resubmittal within 5 working days of receipt date. Please include a copy of this letter with your resubmittal. Designer shall identify plan revisions by a readily discernible means such as shading, highlighting, hatching or clouding the changed areas prior to plan re-submittal. Failure to do so may delay review.

If the above requested information and/or plans are not received within 30 business days of the date of this correspondence, this submittal will be returned denied. No fees will be refunded, and a new fee, application form, and submittal of plans/specifications will be required should you desire to continue with this project. The code in effect at the time of new submittal would apply.

If you have any questions, after reading the above comments and related code sections cited, please call me at the telephone number below.

Sincerely,

Donald L Diedrick

Eng. Cons. Building Systems , Division of Industry Services (920) 492-5610, Fax: (920) 492-5604 , Mon-wed 6:30 AM-04:00 pm don.diedrick@wisconsin.gov

Fee Received \$

WiSMART code: 7648

cc: Steve Gothard, State Building Inspector, (608) 235-0568, Monday 7:45 A.M. - 4:30 P.M. Municipal Clerk City of Jefferson