



John Bel Edwards
GOVERNOR

Office of State Fire Marshal
8181 Independence Blvd. Baton Rouge, LA 70806
(225) 925-4911 (800) 256-5452 Fax (225) 925-4241



H. "Butch" Browning
FIRE MARSHAL

Cautionary Codes

Project Number:	AR-20-009286
Project Name:	103 ARNOULD BLVD

The items listed below are comments for informational purposes or identified requirements that will be verified upon final inspection by this office. These requirements need not be addressed back to the reviewer, however should be addressed prior to construction and inspection scheduling. Failure to comply with or otherwise address these items may affect final occupancy and use of the structure.

1	Scope of Work: This review applies to resubmittal to convert 1 tenant space back into to 2 tenant spaces. This single space suite 103 is mercantile class c. 2 remote exits provided.
2	A REVIEW FOR COMPLIANCE WITH THE FIRE PROTECTION AND EGRESS REQUIREMENTS OF CHAPTERS 9 AND 10 OF THE INTERNATIONAL BUILDING CODE IS INCLUDED IN THIS REVIEW. Review for compliance with all other requirements of the LOUISIANA STATE UNIFORM CONSTRUCTION CODE, in accordance with Act 12 of the 2005 First Extraordinary Session of the Louisiana Legislature, IS NOT INCLUDED IN THIS REVIEW. Contact the building official of the applicable political subdivision to coordinate compliance with these requirements. LRS 40:1730.23 mandates the enforcement of building codes by municipalities and parishes in Louisiana, as described by LRS 40:1730.28.
3	LRS 40:1731-(Effective 10/01/11) Provide access for persons with disabilities in accordance with the ADA-ABA Accessibility Guidelines, July 23, 2004 (also known as the 2010 Standards). This does not include a review for compliance with the Federal Americans with Disabilities (Civil Rights) Act of 1990. Compliance with state regulations and requirements does not guarantee compliance with federal law. ADA-ABA:404.2.7 Handles, pulls, latches, locks, and other operable parts on doors and gates shall comply with 309.4. Hardware shall not require tight grasping, tight pinching, or twisting of the wrist to operate.
4	101:7.2.1.2.3.2, 101:7.1.5.1, and IBC 1010.1.1 A doorway in a means of egress shall provide at least 32" in clear width (consider installing 36" wide doors) and at least 6'-8" in nominal height. Where a pair of doors is provided, at least one leaf shall comply with clear width requirement.
5	Modifications to the existing sprinkler system shall be in accordance with NFPA 13, 13R or 13D as applicable. ~ LRS 40:1574 Submit automatic sprinkler system shop drawings ON-LINE at https://lasfm.louisiana.gov/ . Such work shall not commence until shop drawings have been found to be in compliance with applicable codes by this office. LINK the associated "AR" (architectural project) submittal, or reference it in the PROJECT NAME. Note: See Interpretive Memorandums 2013-02 and 2013-03 for submittal requirements.