

ELECTRICAL RISER DIAGRAM
NO SCALE

- FEEDER SCHEDULE
- ① 4 - 3/0 THW CU, 2 1/2" C
 - ② 3 - #6, 1" C
 - ③ 4 - #6, 1 1/4" C
 - ④ 1/2" THW CU TO 3/4" * 1/2" COPPERCLAD GROUND ROD
 - ⑤ 4 - #6, 1 1/4" C
 - ⑥ 3/4" THW CU TO 3/4" * 1/2" COPPERCLAD GROUND ROD & BLD STEEL


ELECTRICAL NOTES

- 1 JUNCTION BOX ABOVE CEILING FOR FUTURE USE
- 2 EXIT SIGN LIGHT WITH BATTERY BACKUP, SINGLE FACE, 120V TYP W/ 2-P-3 LAMP
- 3 SINGLE CONDUIT OUTLET (20A, 120V) [TYPICAL]
- 4 SINGLE GANG BOX WITH 3/4" C HOMERUN TO TELEPHONE BACK BOARD [TYPICAL]
- 5 SAME AS TYPICAL, GND THROTER EXCEPT WITH BROWN 850 DUTY RATED BATTERY BULBOUT FOR 2 LAMP, REMAINING TWO LAMP SHALL BE TYP. SWITCHED
- 6 2" GND THROTER - 2 LAMP
- 7 D.S. ON UNIT ON ROOF - SEE MEAS. DRAWING
- 8 4 WIDE 18" TALL 1/4" THICK FLYWHEEL TEL. BACK BOARD
- 9 ELECTRICAL PANEL, 100A W/ 120/208V 3P 4W, 10,000 AC SURGE, W/ 100 AMP, 50 CTS
- 10 2" TEL. CONDUIT TENANT AS REQ'D BY SOUTH CENTRAL BELL
- 11 2" GND THROTER, 4 LAMP F40 CW 34 WATT, 120 VOLT, 1A-1N WITH 120' AGRIC. LING [TYPICAL]
- 12 SUPPLY DIST. INSTALLED PROTECTING SHOCK DETECTION WITH TAIL WITH SHOCKING TIME UNIT TO 5000 AMP/SEC / VOLT, SIGNAL, FIBER OPTIC 50A

LIGHTING FIXTURE SCHEDULE

NAME	DESCRIPTION	LAMPS	VOLTS	WATTAGE	WATTAGE	WATTAGE	CATALOG NO.
A	RECOMMENDED EXTERIOR DOWNLIGHT	70W/PM	120	RECESSED			
B	RECOMMENDED EXTERIOR DOWNLIGHT	100 A	120	WALL			
C	RECOMMENDED DOWNLIGHT	100 A	120	WALL			

ELECTRICAL PLAN
TYPICAL TENANT



SCALE 1/8" = 1'-0"

ADDITIONS TO
THE BOULEVARD SHOPPING CENTER
ANNOUNCING BOULEVARD
LAFAYETTE, LOUISIANA

GUILDRY
BEAZLEY
OSTEEN
ARCHITECTS

1 PROFESSIONAL CORPORATION
SUA 500 5614
P.O. BOX 1050
P.O. BOX 1177
LAFAYETTE, LOUISIANA 70506

DATE ISSUED	08/20/84
REVISION	11/18/84
DESIGNED BY	CL
CHECKED BY	CL
SCALE	1/8" = 1'-0"
NO.	92010B
REVISION	E101