

ABDALLA ENTERPRISES, LLC

135 B Arnould Blvd
Lafayette, LA 70506
337-288-5411

adam@adamabdalla.com

INCIDENT REPORT

****Property:**** On The Blvd Shopping Center

****Prepared by:**** Adam Abdalla, Property Manager (Abdalla Enterprises, LLC)

****Date:**** August 8, 2025

****Unit Affected:**** 135B Arnould Blvd – Belle Realty of Lafayette, LLC (Property Management Office)

****Incident Type:**** Identification of Recalled Flushmate Pressure-Assisted Toilet System

1. Description of Incident

During an inspection of the restroom facilities located within the Abdalla Enterprises office at 135B Arnould Blvd, a Sloan Flushmate pressure-assisted toilet system was identified. The tank label indicates the following:

- Model No: M-101526-F3
 - Serial No: 071007-F3K2-1175
 - Series No: 503
 - Date Code: July 10, 2007
-

2. Recall Verification

The identified unit is confirmed to be part of the Flushmate III Series 503 recall. According to the U.S. Consumer Product Safety Commission and Flushmate, units manufactured between October 14, 1997 and April 30, 2011 are at risk for pressure vessel failure. This model and serial number fall squarely within that range.

3. Immediate Action Taken

- The water supply to the unit was shut off.
 - The unit was depressurized to prevent further risk.
 - Warning signage was placed to prevent usage.
 - Tenant awareness and internal documentation initiated.
-

4. Recommended Next Steps

- Contact Flushmate Recall Center at 1-800-303-5123 or visit <https://recall.flushmate.com> to request a free repair kit.
 - Engage a licensed plumber to perform the repair or full replacement.
 - Retain all documentation and photos for future liability or insurance purposes.
-

5. Risk Assessment

Due to the potential for property damage or injury, this matter is considered urgent. The affected unit should remain out of service until resolved.

ABDALLA ENTERPRISES, LLC

135 B Arnould Blvd
Lafayette, LA 70506
337-288-5411
adam@adamabdalla.com

6. Contact Information

Adam Abdalla
Belle Realty of Lafayette, LLC
adam@belle-realty.com
337-288-5411 (cell)
337-769-1554
PO Box 62230
Lafayette, LA 70596
belle-realty.com

7. Attached Photo of Recalled Unit

