



Photoluminescent Egress Path Marking Components
IBC & IFC NYC LL26 & 2014 Construction Code



MEA/UL 1994 Listed Photoluminescent Egress Path Markings



In 2006, NYC Local Law 26 RS6-1 became a mandatory requirement to mark the stairwells of commercial high rise buildings. New York City 2014 Construction Code reaffirmed the stairwell markings and extended the requirement to all high rise occupancies except R-2.

Door Handle

50F-DH	MEA Listed
7760-DH	UL 1994 Listed

50F-DH



Left/Right L Step Marker 1" x 3" x 9"

50R-L1-32	MEA Listed
3450-L1-N-AS1	MEA Listed

Leading edge of steps and landings/door frame

7650-AS1-1	UL 1994 Listed
------------	----------------



50R-L1-32

MEA/UL 1994 Listed Photoluminescent Egress Path Markings



MEA Listed Materials


240-05-M	# 7500 SR
241-05-M	# 7500-F
239-05-M	# 7550-R
235-05-M	# 3450

UL 1994 Listed Materials

7760
7650
7812
7800

Perimeter Demarcation/Door Frame/ Handrail/Push Bar

7650-AS1-1	UL 1994 Listed
7760-AS1-1	UL 1994 Listed
50R-1x48-32	MEA Listed
7760-1-Roll-N	UL 1994 Listed
50F-1	MEA Listed
50F-2	MEA Listed



Obstacle

50F-1STP	MEA Listed
7760-STP-1-Roll-N	UL 1994 Listed
7760-STP-AS1-1	UL 1994 Listed
50F-1-STP-N-AS1	MEA Listed



MEA/UL 1994 Listed Photoluminescent Signage



MEA Listed
4.5" x 8"
Directional

Part No.	Description
50R-1SN-F	Directional Sign - Forward #7550 Glo Brite®
50R-1SN-UR	Directional Sign - Up Right #7550 Glo Brite®
50R-1SN-R	Directional Sign - Right #7550 Glo Brite®
50R-1SN-DR	Directional Sign - Down Right #7550 Glo Brite®
50R-1SN-D	Directional Sign - Down #7550 Glo Brite®
50R-1SN-DL	Directional Sign - Down Left #7550 Glo Brite®
50R-1SN-L	Directional Sign - Left #7550 Glo Brite®
50R-1SN-UL	Directional Sign - Up Left #7550 Glo Brite®



MEA Listed
4.5" x 13"
Exit

Part No.	Description
50R-2SN-R	Exit Sign - Right #7550 Glo Brite®
50R-2SN-L	Exit Sign - Left #7550 Glo Brite®



MEA Listed
7" x 16"
**Final Exit
Through Lobby**

Part No.	Description
50R-4SN-R	Exit Through Lobby Sign - Right #7550 Glo Brite®
50R-4SN-UR	Exit Through Lobby Sign - Up Right #7550 Glo Brite®
50R-4SN-L	Exit Through Lobby Sign - Left #7550 Glo Brite®
50R-4SN-UL	Exit Through Lobby Sign - Up Left #7550 Glo Brite®



MEA Listed
11" x 8"
Final Exit

Part No.	Description
50R-3SN-R	Final Exit Sign - Right #7550 Glo Brite®
50R-3SN-UR	Final Exit Sign - Up Right #7550 Glo Brite®
50R-3SN-L	Final Exit Sign - Left #7550 Glo Brite®
50R-3SN-UL	Final Exit Sign - Up Left #7550 Glo Brite®



MEA Listed
6.5" x 5.5"
Not An Exit

Part No.	Description
50R-5SN	Not An Exit Sign #7550 Glo Brite®



MEA Listed
9" x 8"
Wall Mount

Part No.	Description
50R-6SN-UR	Wall Mount Exit Sign - Up Right #7550 Glo Brite®
50R-6SN-R	Wall Mount Exit Sign - Right #7550 Glo Brite®
50R-6SN-DR	Wall Mount Exit Sign - Down Right #7550 Glo Brite®
50R-6SN-DL	Wall Mount Exit Sign - Down Left #7550 Glo Brite®
50R-6SN-L	Wall Mount Exit Sign - Left #7550 Glo Brite®
50R-6SN-UL	Wall Mount Exit Sign - Up Left #7550 Glo Brite®



UL 1994 Listed
13" x 18"
Floor Identification

Part No.	Description
ICC-7812-004-C	Stairwell & Floor Sign - Custom Legend #7812 Glo Brite®



UL 1994 Listed
8" x 8"
Running Man

Part No.	Description
ICC- 7812-009	Right Running Man Sign
ICC-7812-010	Left Running Man Sign