

CUSTOMER Test Customer Pvt Ltd		SITE Test Site	
GRADE M20	STRUCTURE Column C4	CASTING DATE 25 Jul 2026	COMPARED DESIGN OR20F207

STANDARDS FOLLOWED	
Sampling of Fresh Concrete	IS 1199 (1959)
Casting Location	Plant (cast during Plant QC, at batching plant)
Curing Method	Water Curing (IS 516)
Rate of Loading	140 kg/cm2 per minute
Compressive Strength of Concrete Cubes	IS 456:2000
Size of the Specimen	150 mm x 150 mm x 150 mm
Type of Failure	7-Day: Conical · 28-Day: Conical

TEST SUMMARY — 7 & 28 DAY AVERAGES		Meets characteristic strength f'ck (20.0 MPa)	
7-DAY AVG. 28.4 N/mm2	Load 400.0 kN Density 2,400 kg/m3	28-DAY AVG. 32.5 N/mm2	Load 470.0 kN Density 2,400 kg/m3

CUBE TEST ANALYSIS							
CUBE NO	DATE OF TEST	AGE (DAYS)	WEIGHT (KG)	DENSITY (KG/M3)	LOAD (KN)	STRENGTH (N/MM2)	AVERAGE (N/MM2)

CUSTOMER Test Customer Pvt Ltd			SITE Test Site			
GRADE M20	STRUCTURE Column C4		CASTING DATE 25 Jul 2026		COMPARED DESIGN OR20F207	

C1	01 Aug 2026	7	8.100	2,400	450.00	32.5	28.4
C2	01 Aug 2026	7	8.100	2,400	450.00	32.5	
C3	01 Aug 2026	7	8.100	2,400	450.00	32.5	
C4	01 Aug 2026	7	8.100	2,400	450.00	32.5	
C5	01 Aug 2026	7	8.100	2,400	450.00	32.5	
C6	01 Aug 2026	7	8.100	2,400	450.00	32.5	
C7	01 Aug 2026	7	8.100	2,400	450.00	32.5	
C8	01 Aug 2026	7	8.100	2,400	450.00	32.5	
C9	01 Aug 2026	7	8.100	2,400	450.00	32.5	
C10	01 Aug 2026	7	8.100	2,400	450.00	32.5	
C11	01 Aug 2026	7	8.100	2,400	450.00	32.5	
C12	01 Aug 2026	7	8.100	2,400	450.00	32.5	
C1	22 Aug 2026	28	8.100	2,400	450.00	32.5	32.5
C2	22 Aug 2026	28	8.100	2,400	450.00	32.5	
C3	22 Aug 2026	28	8.100	2,400	450.00	32.5	
C4	22 Aug 2026	28	8.100	2,400	450.00	32.5	
C5	22 Aug 2026	28	8.100	2,400	450.00	32.5	
C6	22 Aug 2026	28	8.100	2,400	450.00	32.5	
C7	22 Aug 2026	28	8.100	2,400	450.00	32.5	
C8	22 Aug 2026	28	8.100	2,400	450.00	32.5	
C9	22 Aug 2026	28	8.100	2,400	450.00	32.5	
C10	22 Aug 2026	28	8.100	2,400	450.00	32.5	
C11	22 Aug 2026	28	8.100	2,400	450.00	32.5	
C12	22 Aug 2026	28	8.100	2,400	450.00	32.5	

REMARKS
7-Day: OK · 28-Day: OK

Ravi
Tested By — Lab Technician

Checked By — QA/QC