

EXHIBIT ____ (DAC-1)
SCHEDULE 1

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC.

CLASS DEMAND STUDY -- ELECTRIC DEPARTMENT

YEAR 2023

CONSOLIDATED EDISON COMPANY OF NEW YORK

Class Demand Estimates
Analyzed by Customer Service Classification
Year 2023

Basis for Calculations

The class demand estimates presented in this exhibit are based upon studies of sample AMI test customers' interval data. These profile data have been extrapolated to the appropriate 2023 class populations obtained from billing records.

Sample test data are used to estimate class demands for Con Edison Service Classification Nos. 1, 2, 5, 5-TOD, 8, 8-TOD, 9, 9-TOD, 12, 12-TOD, and the following New York Power Authority (NYPA) customer categories: General Small, Traction (CIS Billed and TBIS Billed), Multiple Dwellings Redistribution, Multi Dwellings Redistribution-TOD, General Large, General Large-TOD, Multiple Dwelling Space Heating, Transit Authority Substation (CIS Billed and TBIS Billed), and New York City Public Buildings, and New York City Public Buildings-TOD.

Billing profile data for selected summer and winter peak days were used to calculate demands for Con Edison Service Classification No. 13-TOD. Street lighting demand calculations used reported total lamp wattages and burning hours schedules.

Sample Test Data

For the sampled classes, the test customers were selected by statistically sampling the class populations. Con Edison test customers were arranged and stratified according to annual or seasonal ranges. NYPA test customers were arranged and stratified by annual consumption. Test customer daily load profiles were retrieved for a complete annual period. Class test data were arranged according to the five summer and winter system peak days, with Saturdays, Sundays, and holidays excluded. Load characteristics were calculated for each stratum.

Application of Test Results

The load test summer and winter coincidence factors and load characteristics have been applied to the individual customers' non-coincident summer and winter (billing) demands for the year 2023 in the corresponding classes after each class' customers were arranged and stratified in the same manner as the test customers. Summation of the stratum load curves, extrapolated to class proportions for each class, produced summer and winter daily load profiles for that class at the customers' meters.

Development of Distribution System Efficiencies

An energy flow study was prepared for the year 2023, using the billed kilowatthours for each class. This study developed the estimated annual flow of energy through each of the components of the Company's transmission and distribution system to the customers' meters, taking into consideration cable and equipment losses and unaccounted-for-energy. Report 5 in this exhibit summarizes the results of that study and develops class distribution efficiencies related to the energy delivery paths.

The following is a brief explanation of terms employed in Report 5:

- HIGH TENSION stands for high tension energy distribution at voltages of 600 volts and above.
- LOW TENSION stands for low tension energy distribution at voltages below 600 volts.

Development of Total System Service Area Distribution Curves

Peak-day curves were prepared from 2023 integrated hourly system demands. The total system service area distribution curves were developed by averaging the system demand data for five selected summer weekdays and five selected winter weekdays. These data include the kilowatt input (including losses) to our entire transmission and distribution system, as metered at the system input level. It includes purchased power and a deduction for sales to other utilities.

In selecting the five specific summer and winter peak days to be averaged those with the highest one-hour net load were chosen. The data for all five days were averaged to rule out the effect of any unusual system conditions that might have occurred for short periods during any one of the selected days.

Class Loads at the System Input Level

Employing the class load curves at the customers' meters and the distribution efficiencies described above, class load curves for the summer and winter were developed as they appeared at the system input level. The sum of the class load curves at the system input level was determined for Con Edison Service Classifications Nos. 6, 13-TOD; and the following NYPA customer categories: , Street Lighting-Other, , Street Lighting-New York City, Transit Authority Substation (TBIS Billed),

This sum was subtracted from the curve representing the (summer or winter) total system service area distribution curve and the resultant curve was then compared to the sum of the class load curves at the system input level for Con Edison Service Classification Nos. 1, 2, 5, 5-TOD, 8, 8-TOD, 9, 9-TOD, 12, 12-TOD; Con Edison Company Load

represented by Service Classification No 99; and the following NYPA customer categories: General Small, Traction (CIS Billed and TBIS Billed), Multiple Dwellings Redistribution, General Large, Multiple Dwelling Space Heating, Transit Authority Substation (CIS Billed), New York City Public Buildings and New York City Public Buildings-TOD.

For sampled classes, a percentage adjustment factor was applied to the class demands for every half-hour. For those classes with sampled test data that were borrowed, an adjustment factor equal to two times the above mentioned factor was applied. The sum of the 'adjusted classes' and the 'fully metered' classes exactly equaled the total system service area distribution curve.

Four-Hour Class Non-Coincident Peak Demands and System Summer Peak Responsibility Demands

After developing the class load profile curves for the summer and winter as described above, the numerical half-hour demand values from the curves were examined. Four-hour class non-coincident peak demands for the summer and winter and four-hour system summer peak responsibility demands (for summer half-hours ending 2:30 PM to 6:00 PM) were calculated from these values. The four-hour figures were obtained by averaging eight consecutive half-hour demands. The four-hour demand figures are shown in Report 6.

Description of Reports

Report 2 - Sample Test Customer Data

This report shows a summary of load research data by stratum for each service classification for the summer and winter periods.

Report 3 - Estimated Class Demand Data

This report shows a summary of class population data by stratum for each service classification for the summer and winter periods.

Report 4 - Estimated Class Demand Data

This report shows a summary of class demand responsibilities by stratum for each service classification for the summer and winter periods. Demands at the customer and at the system input level are shown.

Report 5 - Class Kilowatthour Data - Sales and Distributed

This report shows the annual kilowatthours registered at the customers' meters and at the system input level by distribution delivery system for each service classification. Distribution efficiencies are also shown for each service classification.

Report 6 - Class Demand Summary

This report shows a summary of the class demand responsibilities for the summer and winter periods.

Report 6A - Low Tension Non-Coincident Kilowatt Based on Low Tension Kilowatthour

This report shows the development of low tension non-coincident demands based on total non-coincident demands and low tension kilowatthours.

Report 7 - Analysis of Kilowatthour Flow by Delivery System

This report traces the annual kilowatthour flow by class from the customers' meters through the various delivery systems, back to the system input level.

Report 8 - Analysis of Class 4 Hour Non-Coincident Peak Demand by Delivery System

This report traces the class four-hour non-coincident peak demands for the summer and the winter periods, through the various delivery systems, back to the system input level.

Index for Individual Class Demand Reports 2, 3, and 4
For Each Service Classification and Grouping

		Page No.
S.C. No 1	Residential and Religious	1 to 3
S.C. No 2	General Small	4 to 6
S.C. No 5	Traction	7 to 9
S.C. No 5-TOD	Traction-TOD	10 to 12
S.C. No 6	Public & Private Street Lighting	13 to 15
S.C. No 8	Multiple Dwellings Redistribution	16 to 18
S.C. No 8-TOD	Multiple Dwellings Redistribution-TOD	19 to 21
S.C. No 9	General Large	22 to 24
S.C. No 9-TOD	General Large-TOD	25 to 27
S.C. No 12	Multiple Dwelling Space Heating	28 to 30
S.C. No 12-TOD	Multiple Dwelling Space Heating-TOD	31 to 33
S.C. No 13-TOD	Bulk Power Housing Developments-TOD	34 to 36
NYP&A	General Small	37 to 39
NYP&A	Traction	40 to 42
NYP&A	Street Lighting-Other	43 to 45
NYP&A	Multiple Dwellings Redistribution	46 to 48
NYP&A	Multiple Dwellings Redistribution-TOD	49 to 51
NYP&A	General Large	52 to 54
NYP&A	General Large-TOD	55 to 57
NYP&A	Street Lighting-NYC	58 to 60
NYP&A	Multiple Dwelling Space Heating	61 to 63
NYP&A	Transit Authority Substation	64 to 66
NYP&A	NYC Public Buildings	67 to 69
NYP&A	NYC Public Buildings-TOD	70 to 72
CON&ED	Company Use	73 to 75

Index for Summary Reports 5, 6, 6A, 7, and 8

		<u>Page No.</u>
Report 5	Class Kilowatthour Data - Sales and Distributed	5-1 to 5-5
Report 6	Class Demand Summary	6-1 to 6-5
Report 6A	Low Tension Non-Coincident Kilowatt Based on Low Tension Kilowatthour	6A-1 to 6A-5
Report 7	Analysis of Kilowatthour Flow by Delivery System	7-1 to 7-5
Report 8	Analysis of Class 4 Hour Non-Coincident Peak Demand by Delivery System	8-1 to 8-4

Exhibit ____ (DAC-1)
Schedule 1

Consolidated Edison Company of New York, Inc.

Work Papers for the 2023 Class Demand Study

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 2 - SAMPLE TEST CUSTOMER DATA
CLASS - SC01 - Summer - 2023

LINE NO	SAMPLE STRATA	STRATIFICATION VARIABLE Annual kWh		NO OF TEST CUSTOMERS	STRAT VAR AVG PER TEST CUST	AVG NON-COIN kW PER CUST	AVG COIN kW PER CUST	COINCIDENCE FACTOR PERCENTAGE
		LOW (3)	HIGH (4)					
(1)	(2)			(5)	(6)	(7)	(8)	(9)
1	Residential A	0	3,209	2,787	2,009	1.719	0.661	38.4526
2	Stratum B	3,210	4,810	1,654	3,960	2.666	1.220	45.7614
3	Stratum C	4,811	6,927	1,443	5,754	3.511	1.624	46.2546
4	Stratum D	6,928	10,870	1,199	8,535	4.846	2.380	49.1127
5	Stratum E	10,871	100,000	889	21,606	16.236	9.162	56.4302
6	Stratum F	100,001	999,999,999	306	253,761	155.979	118.476	75.9564
7	01-Residential			8,278				
8	SC01			8,278				

Footnotes:

COL (9): EQUAL TO 100 * (COL (8) / COL (7))

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 3 - ESTIMATED CLASS DEMAND DATA
CLASS - SC01 - Summer - 2023

LINE NO	SAMPLE STRATA	STRATIFICATION VARIABLE Annual kWh		EST AVG NO OF CUSTS	TOTAL ANNUAL kWh	AVG ANNUAL USE PER CUST	EST NON-COIN kW PER CUST	EST POPUL NON-COIN kW	COINCIDENCE FACTOR PERCENTAGE	EST POPUL COIN kW FOR INDIVIDUAL STRATA
(1)	(2)	LOW (3)	HIGH (4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)
1	Residential A	0	3,209	1,512,728	2,961,263,556	1,958	1.797	2,718,372	38.4526	1,045,285
2	Stratum B	3,210	4,810	655,374	2,587,634,095	3,948	2.973	1,948,427	45.7614	891,627
3	Stratum C	4,811	6,927	437,847	2,517,662,715	5,750	3.926	1,718,987	46.2546	795,111
4	Stratum D	6,928	10,870	297,460	2,529,037,703	8,502	5.255	1,563,152	49.1127	767,706
5	Stratum E	10,871	100,000	151,118	2,569,633,055	17,004	9.923	1,499,544	56.4302	846,196
6	Stratum F	100,001	999,999,999	1,109	296,303,665	267,181	93.952	104,193	75.9564	79,141
7	01-Residential			3,055,636	13,461,534,789			9,552,675		4,425,066
8	SC01			3,055,636	13,461,534,789			9,552,675		4,425,066

Footnotes:

COL (7): EQUAL TO COL (6) / COL (5)

COL (8): FOR NON-DEMAND METERED CLASSES, FROM RELATIONSHIP OF SAMPLED ENERGY AND DEMAND VALUES, APPLIED TO POPULATION ENERGY USAGE

COL (9): EQUAL TO COLS (5) * (8) OR BILLING DEMAND

COL (10): FROM REPORT 2

COL (11): EQUAL TO COL (9) * (COL (10) / 100)

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 4 - ESTIMATED CLASS DEMAND DATA
CLASS - SC01 - Summer - 2023

LINE NO	SAMPLE STRATA	STRATIFICATION VARIABLE Annual kWh		HALF HOUR kW AT TIME OF CLASS PEAK UNADJ AT CUST	4 HOUR DEMANDS-kW				
					UNADJUSTED AT THE CUSTOMER	ADJUSTED AT THE CUSTOMER	UNADJUSTED AT SYSTEM INPUT	ADJUSTED AT SYSTEM INPUT	SYSTEM PEAK RESPBLTY
		LOW (3)	HIGH (4)						
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)
1	Residential A	0	3,209	1,045,285	1,006,192	937,555	1,078,449	1,004,882	814,132
2	Stratum B	3,210	4,810	891,627	865,074	806,075	927,196	863,960	734,086
3	Stratum C	4,811	6,927	795,111	787,818	734,123	844,392	786,842	732,306
4	Stratum D	6,928	10,870	746,323	751,155	699,973	805,097	750,239	734,666
5	Stratum E	10,871	100,000	767,591	763,368	711,343	818,186	762,425	826,675
6	Stratum F	100,001	999,999,999	56,036	58,114	54,158	62,287	58,047	72,208
7	01-Residential			4,301,973	4,231,721	3,943,227	4,535,607	4,226,395	3,914,073
8	SC01			4,301,973	4,231,721	3,943,227	4,535,607	4,226,395	3,914,073

Footnotes:

COL (5): CLASS PEAK AT 9:00pm

COL (6): CLASS 4 HOUR PEAK FROM 6:30pm-10:00pm

COL (7): ADJUSTED SUM OF COMPONENT LOADS EQUALS SYSTEM LOADS

COL (8): EQUAL TO (COL (6) / EFFICIENCY FACTOR OF 93.300000000) * 100

COL (9): EQUAL TO (COL (7) / EFFICIENCY FACTOR OF 93.300000000) * 100

COL (10): SYSTEM PEAK RESPONSIBILITY FROM 2:30pm-6:00pm

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 2 - SAMPLE TEST CUSTOMER DATA
CLASS - SC02 - Summer - 2023

LINE NO	SAMPLE STRATA	STRATIFICATION VARIABLE Annual kWh		NO OF TEST CUSTOMERS	STRAT VAR AVG PER TEST CUST	AVG NON-COIN kW PER CUST	AVG COIN kW PER CUST	COINCIDENCE FACTOR PERCENTAGE
		LOW (3)	HIGH (4)					
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)
1	GenSm A	0	5,814	4,235	2,291	1.517	0.463	30.5208
2	Stratum B	5,815	13,675	1,099	8,841	3.928	2.041	51.9603
3	Stratum C	13,676	999,999,999	451	25,418	7.027	5.073	72.1930
4	02-GenSmall			5,785				
5	SC02			5,785				

Footnotes:

COL (9): EQUAL TO 100 * (COL (8) / COL (7))

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 3 - ESTIMATED CLASS DEMAND DATA
CLASS - SC02 - Summer - 2023

LINE NO	SAMPLE STRATA	STRATIFICATION VARIABLE Annual kWh		EST AVG NO OF CUSTS	TOTAL ANNUAL kWh	AVG ANNUAL USE PER CUST	EST NON-COIN kW PER CUST	EST POPUL NON-COIN kW	COINCIDENCE FACTOR PERCENTAGE	EST POPUL COIN kW FOR INDIVIDUAL STRATA
(1)	(2)	LOW (3)	HIGH (4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)
1	GenSm A	0	5,814	332,114	731,898,990	2,204	1.561	518,430	30.5208	158,229
2	Stratum B	5,815	13,675	88,710	763,937,875	8,612	3.954	350,759	51.9603	182,255
3	Stratum C	13,676	999,999,999	30,974	790,417,379	25,519	6.066	187,888	72.1930	135,642
4	02-GenSmall			451,798	2,286,254,244			1,057,077		476,126
5	SC02			451,798	2,286,254,244			1,057,077		476,126

Footnotes:

COL (7): EQUAL TO COL (6) / COL (5)

COL (8): FOR NON-DEMAND METERED CLASSES, FROM RELATIONSHIP OF SAMPLED ENERGY AND DEMAND VALUES, APPLIED TO POPULATION ENERGY USAGE

COL (9): EQUAL TO COLS (5) * (8) OR BILLING DEMAND

COL (10): FROM REPORT 2

COL (11): EQUAL TO COL (9) * (COL (10) / 100)

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 4 - ESTIMATED CLASS DEMAND DATA
CLASS - SC02 - Summer - 2023

LINE NO	SAMPLE STRATA	STRATIFICATION VARIABLE		HALF HOUR kW AT TIME OF CLASS PEAK UNADJ AT CUST	4 HOUR DEMANDS-kW				
		Annual kWh			UNADJUSTED AT THE CUSTOMER	ADJUSTED AT THE CUSTOMER	UNADJUSTED AT SYSTEM INPUT	ADJUSTED AT SYSTEM INPUT	SYSTEM PEAK RESPBLTY
		LOW (3)	HIGH (4)						
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)
1	GenSm A	0	5,814	158,229	156,819	144,589	168,080	154,972	154,573
2	Stratum B	5,815	13,675	181,878	178,938	164,976	191,788	176,824	175,340
3	Stratum C	13,676	999,999,999	134,856	134,774	124,258	144,452	133,182	133,140
4	02-GenSmall			474,963	470,531	433,823	504,320	464,978	463,053
5	SC02			474,963	470,531	433,823	504,320	464,978	463,053

Footnotes:

COL (5): CLASS PEAK AT 3:00pm

COL (6): CLASS 4 HOUR PEAK FROM 1:30pm-5:00pm

COL (7): ADJUSTED SUM OF COMPONENT LOADS EQUALS SYSTEM LOADS

COL (8): EQUAL TO (COL (6) / EFFICIENCY FACTOR OF 93.300000000) * 100

COL (9): EQUAL TO (COL (7) / EFFICIENCY FACTOR OF 93.300000000) * 100

COL (10): SYSTEM PEAK RESPONSIBILITY FROM 2:30pm-6:00pm

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 2 - SAMPLE TEST CUSTOMER DATA
CLASS - SC05 - Summer - 2023

LINE NO	SAMPLE STRATA	STRATIFICATION VARIABLE Annual kWh		NO OF TEST CUSTOMERS	STRAT VAR AVG PER TEST CUST	AVG NON-COIN kW PER CUST	AVG COIN kW PER CUST	COINCIDENCE FACTOR PERCENTAGE
		LOW (3)	HIGH (4)					
(1)	(2)			(5)	(6)	(7)	(8)	(9)
1	SC 05 CV	0	999,999,999	6	77,868	12.644	8.163	64.5603
2	05-Traction CV			6				
3	SC05			6				

Footnotes:

COL (9): EQUAL TO 100 * (COL (8) / COL (7))

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 3 - ESTIMATED CLASS DEMAND DATA
CLASS - SC05 - Summer - 2023

LINE NO	SAMPLE STRATA	STRATIFICATION VARIABLE Annual kWh		EST AVG NO OF CUSTS	TOTAL ANNUAL kWh	AVG ANNUAL USE PER CUST	EST NON-COIN kW PER CUST	EST POPUL NON-COIN kW	COINCIDENCE FACTOR PERCENTAGE	EST POPUL COIN kW FOR INDIVIDUAL STRATA
		LOW (3)	HIGH (4)							
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)
1	SC 05 CV	0	999,999,999	8	652,826	81,603		90	64.5603	58
2	05-Traction CV			8	652,826			90		58
3	SC05			8	652,826			90		58

Footnotes:

COL (7): EQUAL TO COL (6) / COL (5)

COL (8): FOR NON-DEMAND METERED CLASSES, FROM RELATIONSHIP OF SAMPLED ENERGY AND DEMAND VALUES, APPLIED TO POPULATION ENERGY USAGE

COL (9): EQUAL TO COLS (5) * (8) OR BILLING DEMAND

COL (10): FROM REPORT 2

COL (11): EQUAL TO COL (9) * (COL (10) / 100)

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 4 - ESTIMATED CLASS DEMAND DATA
CLASS - SC05 - Summer - 2023

LINE NO	SAMPLE STRATA	STRATIFICATION VARIABLE		HALF HOUR kW AT TIME OF CLASS PEAK UNADJ AT CUST	4 HOUR DEMANDS-kW					SYSTEM PEAK RESPBLTY
		Annual kWh			UNADJUSTED AT THE CUSTOMER	ADJUSTED AT THE CUSTOMER	UNADJUSTED AT SYSTEM INPUT	ADJUSTED AT SYSTEM INPUT		
		LOW	HIGH							
		(3)	(4)							
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)	
1	SC 05 CV	0	999,999,999	58	56	52	60	56	55	
2	05-Traction CV			58	56	52	60	56	55	
3	SC05			58	56	52	60	56	55	

Footnotes:

COL (5): CLASS PEAK AT 3:30pm

COL (6): CLASS 4 HOUR PEAK FROM 2:00pm-5:30pm

COL (7): ADJUSTED SUM OF COMPONENT LOADS EQUALS SYSTEM LOADS

COL (8): EQUAL TO (COL (6) / EFFICIENCY FACTOR OF 93.300000000) * 100

COL (9): EQUAL TO (COL (7) / EFFICIENCY FACTOR OF 93.300000000) * 100

COL (10): SYSTEM PEAK RESPONSIBILITY FROM 2:30pm-6:00pm

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 2 - SAMPLE TEST CUSTOMER DATA
CLASS - SC05 TOD - Summer - 2023

LINE NO	SAMPLE STRATA	STRATIFICATION VARIABLE Annual kWh		NO OF TEST CUSTOMERS	STRAT VAR AVG PER TEST CUST	AVG NON-COIN kW PER CUST	AVG COIN kW PER CUST	COINCIDENCE FACTOR PERCENTAGE
		LOW (3)	HIGH (4)					
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)
1	SC 05 TD	0	999,999,999	4	22,411,204	4,023.294	3,097.926	76.9997
2	05-Traction TOD			4				
3	SC05 TOD			4				

Footnotes:

COL (9): EQUAL TO 100 * (COL (8) / COL (7))

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 3 - ESTIMATED CLASS DEMAND DATA
CLASS - SC05 TOD - Summer - 2023

LINE NO	SAMPLE STRATA	STRATIFICATION VARIABLE Annual kWh		EST AVG NO OF CUSTS	TOTAL ANNUAL kWh	AVG ANNUAL USE PER CUST	EST NON-COIN kW PER CUST	EST POPUL NON-COIN kW	COINCIDENCE FACTOR PERCENTAGE	EST POPUL COIN kW FOR INDIVIDUAL STRATA
		LOW (3)	HIGH (4)							
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)
1	SC 05 TD	0	999,999,999	5	97,007,684	19,401,537		19,319	76.9997	14,876
2	05-Traction TOD			5	97,007,684			19,319		14,876
3	SC05 TOD			5	97,007,684			19,319		14,876

Footnotes:

COL (7): EQUAL TO COL (6) / COL (5)

COL (8): FOR NON-DEMAND METERED CLASSES, FROM RELATIONSHIP OF SAMPLED ENERGY AND DEMAND VALUES, APPLIED TO POPULATION ENERGY USAGE

COL (9): EQUAL TO COLS (5) * (8) OR BILLING DEMAND

COL (10): FROM REPORT 2

COL (11): EQUAL TO COL (9) * (COL (10) / 100)

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 4 - ESTIMATED CLASS DEMAND DATA
CLASS - SC05 TOD - Summer - 2023

LINE NO	SAMPLE STRATA	4 HOUR DEMANDS-kW							
		STRATIFICATION VARIABLE		HALF HOUR kW AT TIME OF CLASS PEAK UNADJ AT CUST	UNADJUSTED AT THE CUSTOMER	ADJUSTED AT THE CUSTOMER	UNADJUSTED AT SYSTEM INPUT	ADJUSTED AT SYSTEM INPUT	SYSTEM PEAK RESPBLTY
		Annual kWh							
		LOW (3)	HIGH (4)						
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)
1	SC 05 TD	0	999,999,999	14,729	14,561	13,638	15,421	14,444	14,317
2	05-Traction TOD			14,729	14,561	13,638	15,421	14,444	14,317
3	SC05 TOD			14,729	14,561	13,638	15,421	14,444	14,317

Footnotes:

COL (5): CLASS PEAK AT 12:00pm

COL (6): CLASS 4 HOUR PEAK FROM 9:00pm-12:30am

COL (7): ADJUSTED SUM OF COMPONENT LOADS EQUALS SYSTEM LOADS

COL (8): EQUAL TO (COL (6) / EFFICIENCY FACTOR OF 94.421864752) * 100

COL (9): EQUAL TO (COL (7) / EFFICIENCY FACTOR OF 94.421864752) * 100

COL (10): SYSTEM PEAK RESPONSIBILITY FROM 2:30pm-6:00pm

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 2 - SAMPLE TEST CUSTOMER DATA
CLASS - SC06 - Summer - 2023

LINE NO	SAMPLE STRATA	STRATIFICATION VARIABLE Annual kWh		NO OF TEST CUSTOMERS	STRAT VAR AVG PER TEST CUST	AVG NON-COIN kW PER CUST	AVG COIN kW PER CUST	COINCIDENCE FACTOR PERCENTAGE
		LOW (3)	HIGH (4)					
(1)	(2)			(5)	(6)	(7)	(8)	(9)
1	PubPriv SL	0	999,999,999	2	7,175	865.998	865.304	99.9199
2	06-PubPrivSL			2				
3	SC06			2				

Footnotes:

COL (9): EQUAL TO 100 * (COL (8) / COL (7))

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 3 - ESTIMATED CLASS DEMAND DATA
CLASS - SC06 - Summer - 2023

LINE NO	SAMPLE STRATA	STRATIFICATION VARIABLE Annual kWh		EST AVG NO OF CUSTS	TOTAL ANNUAL kWh	AVG ANNUAL USE PER CUST	EST NON-COIN kW PER CUST	EST POPUL NON-COIN kW	COINCIDENCE FACTOR PERCENTAGE	EST POPUL COIN kW FOR INDIVIDUAL STRATA
(1)	(2)	LOW (3)	HIGH (4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)
1	PubPriv SL	0	999,999,999	3,380	7,288,356	2,156	0.439	1,484	99.9199	1,483
2	06-PubPrivSL			3,380	7,288,356			1,484		1,483
3	SC06			3,380	7,288,356			1,484		1,483

Footnotes:

COL (7): EQUAL TO COL (6) / COL (5)

COL (8): FOR NON-DEMAND METERED CLASSES, FROM RELATIONSHIP OF SAMPLED ENERGY AND DEMAND VALUES, APPLIED TO POPULATION ENERGY USAGE

COL (9): EQUAL TO COLS (5) * (8) OR BILLING DEMAND

COL (10): FROM REPORT 2

COL (11): EQUAL TO COL (9) * (COL (10) / 100)

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 4 - ESTIMATED CLASS DEMAND DATA
CLASS - SC06 - Summer - 2023

LINE NO	SAMPLE STRATA	4 HOUR DEMANDS-kW							
		STRATIFICATION VARIABLE		HALF HOUR kW AT TIME OF CLASS PEAK UNADJ AT CUST	UNADJUSTED AT THE CUSTOMER	ADJUSTED AT THE CUSTOMER	UNADJUSTED AT SYSTEM INPUT	ADJUSTED AT SYSTEM INPUT	SYSTEM PEAK RESPBLTY
		Annual kWh							
		LOW (3)	HIGH (4)						
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)
1	PubPriv SL	0	999,999,999	1,483	1,479	1,479	1,585	1,585	3
2	06-PubPrivSL			1,483	1,479	1,479	1,585	1,585	3
3	SC06			1,483	1,479	1,479	1,585	1,585	3

Footnotes:

COL (5): CLASS PEAK AT 9:00pm

COL (6): CLASS 4 HOUR PEAK FROM 9:00pm-12:30am

COL (7): ADJUSTED SUM OF COMPONENT LOADS EQUALS SYSTEM LOADS

COL (8): EQUAL TO (COL (6) / EFFICIENCY FACTOR OF 93.300000000) * 100

COL (9): EQUAL TO (COL (7) / EFFICIENCY FACTOR OF 93.300000000) * 100

COL (10): SYSTEM PEAK RESPONSIBILITY FROM 2:30pm-6:00pm

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 2 - SAMPLE TEST CUSTOMER DATA
CLASS - SC08 - Summer - 2023

LINE NO	SAMPLE STRATA	STRATIFICATION VARIABLE		NO OF TEST CUSTOMERS	STRAT VAR AVG PER TEST CUST	AVG NON-COIN kW PER CUST	AVG COIN kW PER CUST	COINCIDENCE FACTOR PERCENTAGE
		Avg Jun-Sep kW (A-D)						
		Max Jan-Dec kW (MHP)						
(1)	(2)	LOW (3)	HIGH (4)	(5)	(6)	(7)	(8)	(9)
1	Mult Dwell CV A	0	120	522	60	86.532	81.392	94.0600
2	Stratum B	121	220	227	168	177.557	171.687	96.6940
3	Stratum C	221	340	130	276	294.095	284.919	96.8799
4	Stratum D	341	999,999,999	74	382	9,299.257	8,593.502	92.4106
5	Stratum M	500	999,999,999	89	698	11,138.050	11,471.204	102.9911
6	08-MDWL-RED CV			1,042				
7	SC08			1,042				

Footnotes:

COL (9): EQUAL TO 100 * (COL (8) / COL (7))

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 3 - ESTIMATED CLASS DEMAND DATA
CLASS - SC08 - Summer - 2023

LINE NO	SAMPLE STRATA	STRATIFICATION VARIABLE		EST AVG NO OF CUSTS	TOTAL ANNUAL kWh	AVG ANNUAL USE PER CUST	EST NON-COIN kW PER CUST	EST POPUL NON-COIN kW	COINCIDENCE FACTOR PERCENTAGE	EST POPUL COIN kW FOR INDIVIDUAL STRATA
		Avg Jun-Sep kW (A-D) Max Jan-Dec kW (MHP)								
(1)	(2)	LOW (3)	HIGH (4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)
1	Mult Dwell CV A	0	120	816	199,824,898	244,883		55,415	94.0600	52,123
2	Stratum B	121	220	470	327,412,571	696,622		86,533	96.6940	83,672
3	Stratum C	221	340	243	281,394,654	1,158,003		74,057	96.8799	71,746
4	Stratum D	341	999,999,999	106	179,013,576	1,688,807		44,400	92.4106	41,030
5	Stratum M	500	999,999,999	200	501,904,504	2,509,523		126,079	102.9911	129,850
6	08-MDWL-RED CV			1,835	1,489,550,203			386,484		378,421
7	SC08			1,835	1,489,550,203			386,484		378,421

Footnotes:

COL (7): EQUAL TO COL (6) / COL (5)

COL (8): FOR NON-DEMAND METERED CLASSES, FROM RELATIONSHIP OF SAMPLED ENERGY AND DEMAND VALUES, APPLIED TO POPULATION ENERGY USAGE

COL (9): EQUAL TO COLS (5) * (8) OR BILLING DEMAND

COL (10): FROM REPORT 2

COL (11): EQUAL TO COL (9) * (COL (10) / 100)

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 4 - ESTIMATED CLASS DEMAND DATA
CLASS - SC08 - Summer - 2023

LINE NO	SAMPLE STRATA	4 HOUR DEMANDS-kW							
		STRATIFICATION VARIABLE		HALF HOUR kW AT TIME OF CLASS PEAK UNADJ AT CUST	UNADJUSTED AT THE CUSTOMER	ADJUSTED AT THE CUSTOMER	UNADJUSTED AT SYSTEM INPUT	ADJUSTED AT SYSTEM INPUT	SYSTEM PEAK RESPBLTY
		Avg Jun-Sep kW (A-D)	Max Jan-Dec kW (MHP)						
(1)	(2)	LOW (3)	HIGH (4)	(5)	(6)	(7)	(8)	(9)	(10)
1	Mult Dwell CV A	0	120	50,931	51,419	47,934	55,112	51,376	48,261
2	Stratum B	121	220	82,673	82,769	77,159	88,712	82,700	79,007
3	Stratum C	221	340	71,196	71,154	66,332	76,264	71,096	68,350
4	Stratum D	341	999,999,999	40,745	40,452	37,710	43,356	40,418	38,410
5	Stratum M	500	999,999,999	126,056	123,807	115,424	132,697	123,713	126,597
6	08-MDWL-RED CV			371,601	369,601	344,559	396,141	369,303	360,625
7	SC08			371,601	369,601	344,559	396,141	369,303	360,625

Footnotes:

COL (5): CLASS PEAK AT 6:30pm

COL (6): CLASS 4 HOUR PEAK FROM 5:30pm-9:00pm

COL (7): ADJUSTED SUM OF COMPONENT LOADS EQUALS SYSTEM LOADS

COL (8): EQUAL TO (COL (6) / EFFICIENCY FACTOR OF 93.300000000) * 100

COL (9): EQUAL TO (COL (7) / EFFICIENCY FACTOR OF 93.300000000) * 100

COL (10): SYSTEM PEAK RESPONSIBILITY FROM 2:30pm-6:00pm

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 2 - SAMPLE TEST CUSTOMER DATA
CLASS - SC08 TOD - Summer - 2023

LINE NO	SAMPLE STRATA	STRATIFICATION VARIABLE Annual kWh		NO OF TEST CUSTOMERS	STRAT VAR AVG PER TEST CUST	AVG NON-COIN kW PER CUST	AVG COIN kW PER CUST	COINCIDENCE FACTOR PERCENTAGE
		LOW (3)	HIGH (4)					
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)
1	Mult Dwell TOD	0	999,999,999	21	6,086,085	1,389.339	1,382.001	99.4718
2	08-MDWL-RED TOD			21				
3	SC08 TOD			21				

Footnotes:

COL (9): EQUAL TO 100 * (COL (8) / COL (7))

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 3 - ESTIMATED CLASS DEMAND DATA
CLASS - SC08 TOD - Summer - 2023

LINE NO	SAMPLE STRATA	STRATIFICATION VARIABLE Annual kWh		EST AVG NO OF CUSTS	TOTAL ANNUAL kWh	AVG ANNUAL USE PER CUST	EST NON-COIN kW PER CUST	EST POPUL NON-COIN kW	COINCIDENCE FACTOR PERCENTAGE	EST POPUL COIN kW FOR INDIVIDUAL STRATA
		LOW (3)	HIGH (4)							
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)
1	Mult Dwell TOD	0	999,999,999	21	127,807,785	6,086,085		29,997	99.4718	29,839
2	08-MDWL-RED TOD			21	127,807,785			29,997		29,839
3	SC08 TOD			21	127,807,785			29,997		29,839

Footnotes:

COL (7): EQUAL TO COL (6) / COL (5)

COL (8): FOR NON-DEMAND METERED CLASSES, FROM RELATIONSHIP OF SAMPLED ENERGY AND DEMAND VALUES, APPLIED TO POPULATION ENERGY USAGE

COL (9): EQUAL TO COLS (5) * (8) OR BILLING DEMAND

COL (10): FROM REPORT 2

COL (11): EQUAL TO COL (9) * (COL (10) / 100)

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 4 - ESTIMATED CLASS DEMAND DATA
CLASS - SC08 TOD - Summer - 2023

LINE NO	SAMPLE STRATA	4 HOUR DEMANDS-kW							
		STRATIFICATION VARIABLE		HALF HOUR kW AT TIME OF CLASS PEAK UNADJ AT CUST	UNADJUSTED AT THE CUSTOMER	ADJUSTED AT THE CUSTOMER	UNADJUSTED AT SYSTEM INPUT	ADJUSTED AT SYSTEM INPUT	SYSTEM PEAK RESPBLTY
		Annual kWh							
		LOW (3)	HIGH (4)						
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)
1	Mult Dwell TOD	0	999,999,999	29,722	29,612	27,597	31,738	29,579	28,682
2	08-MDWL-RED TOD			29,722	29,612	27,597	31,738	29,579	28,682
3	SC08 TOD			29,722	29,612	27,597	31,738	29,579	28,682

Footnotes:

COL (5): CLASS PEAK AT 7:30pm

COL (6): CLASS 4 HOUR PEAK FROM 6:00pm-9:30pm

COL (7): ADJUSTED SUM OF COMPONENT LOADS EQUALS SYSTEM LOADS

COL (8): EQUAL TO (COL (6) / EFFICIENCY FACTOR OF 93.300000000) * 100

COL (9): EQUAL TO (COL (7) / EFFICIENCY FACTOR OF 93.300000000) * 100

COL (10): SYSTEM PEAK RESPONSIBILITY FROM 2:30pm-6:00pm

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 2 - SAMPLE TEST CUSTOMER DATA
CLASS - SC09 - Summer - 2023

LINE NO	SAMPLE STRATA	STRATIFICATION VARIABLE		NO OF TEST CUSTOMERS	STRAT VAR		AVG NON-COIN kW PER CUST	AVG COIN kW PER CUST	COINCIDENCE FACTOR PERCENTAGE
		Avg Jun-Sep kW (A-E)			AVG PER TEST CUST				
		Max Jan-Dec kW (MHP)							
(1)	(2)	LOW (3)	HIGH (4)	(5)	(6)	(7)	(8)	(9)	
1	GenLg CV A		0	17	1,847	10	9.480	6.415	67.6688
2	Stratum B		18	33	974	24	22.369	16.822	75.2023
3	Stratum C		34	70	453	47	46.476	37.476	80.6352
4	Stratum D		71	200	366	116	116.155	98.884	85.1311
5	Stratum E		201	999,999,999	191	297	298.791	275.507	92.2073
6	Stratum M		500	999,999,999	183	721	631.968	580.013	91.7789
7	09-GenLarge CV				4,014				
8	SC09				4,014				

Footnotes:

COL (9): EQUAL TO 100 * (COL (8) / COL (7))

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 3 - ESTIMATED CLASS DEMAND DATA
CLASS - SC09 - Summer - 2023

LINE NO	SAMPLE STRATA	STRATIFICATION VARIABLE		EST AVG NO OF CUSTS	TOTAL ANNUAL kWh	AVG ANNUAL USE PER CUST	EST NON-COIN kW PER CUST	EST POPUL NON-COIN kW	COINCIDENCE FACTOR PERCENTAGE	EST POPUL COIN kW FOR INDIVIDUAL STRATA
		Avg Jun-Sep kW Max Jan-Dec kW	(A-E) (MHP)							
(1)	(2)	LOW (3)	HIGH (4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)
1	GenLg CV A	0	17	79,928	2,574,678,696	32,212		782,358	67.6688	529,412
2	Stratum B	18	33	30,678	2,546,865,648	83,019		756,450	75.2023	568,868
3	Stratum C	34	70	15,312	2,763,669,343	180,490		751,501	80.6352	605,974
4	Stratum D	71	200	7,218	3,576,290,706	495,468		865,551	85.1311	736,853
5	Stratum E	201	999,999,999	2,118	2,878,756,946	1,359,186		662,910	92.2073	611,251
6	Stratum M	500	999,999,999	1,018	3,262,002,070	3,204,324		754,464	91.7789	692,439
7	09-GenLarge CV			136,272	17,602,263,409			4,573,234		3,744,797
8	SC09			136,272	17,602,263,409			4,573,234		3,744,797

Footnotes:

COL (7): EQUAL TO COL (6) / COL (5)

COL (8): FOR NON-DEMAND METERED CLASSES, FROM RELATIONSHIP OF SAMPLED ENERGY AND DEMAND VALUES, APPLIED TO POPULATION ENERGY USAGE

COL (9): EQUAL TO COLS (5) * (8) OR BILLING DEMAND

COL (10): FROM REPORT 2

COL (11): EQUAL TO COL (9) * (COL (10) / 100)

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 4 - ESTIMATED CLASS DEMAND DATA
CLASS - SC09 - Summer - 2023

LINE NO	SAMPLE STRATA	4 HOUR DEMANDS-kW							
		STRATIFICATION VARIABLE		HALF HOUR kW AT TIME OF CLASS PEAK UNADJ AT CUST	UNADJUSTED AT THE CUSTOMER	ADJUSTED AT THE CUSTOMER	UNADJUSTED AT SYSTEM INPUT	ADJUSTED AT SYSTEM INPUT	SYSTEM PEAK RESPBLTY
		Avg Jun-Sep kW (A-E) Max Jan-Dec kW (MHP)							
(1)	(2)	LOW (3)	HIGH (4)	(5)	(6)	(7)	(8)	(9)	(10)
1	GenLg CV A	0	17	526,101	523,170	480,979	560,708	515,490	503,097
2	Stratum B	18	33	566,859	562,783	517,413	603,164	554,539	542,971
3	Stratum C	34	70	600,539	597,657	549,460	640,539	588,885	579,022
4	Stratum D	71	200	732,282	727,697	668,997	779,910	716,998	704,415
5	Stratum E	201	999,999,999	605,147	604,006	555,297	647,344	595,140	585,054
6	Stratum M	500	999,999,999	689,476	685,486	630,191	734,671	675,408	663,796
7	09-GenLarge CV			3,720,404	3,700,799	3,402,337	3,966,336	3,646,460	3,578,355
8	SC09			3,720,404	3,700,799	3,402,337	3,966,336	3,646,460	3,578,355

Footnotes:

COL (5): CLASS PEAK AT 3:00pm

COL (6): CLASS 4 HOUR PEAK FROM 1:00pm-4:30pm

COL (7): ADJUSTED SUM OF COMPONENT LOADS EQUALS SYSTEM LOADS

COL (8): EQUAL TO (COL (6) / EFFICIENCY FACTOR OF 93.305229864) * 100

COL (9): EQUAL TO (COL (7) / EFFICIENCY FACTOR OF 93.305229864) * 100

COL (10): SYSTEM PEAK RESPONSIBILITY FROM 2:30pm-6:00pm

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 2 - SAMPLE TEST CUSTOMER DATA
CLASS - SC09 TOD - Summer - 2023

LINE NO	SAMPLE STRATA	STRATIFICATION VARIABLE Annual kWh		NO OF TEST CUSTOMERS	STRAT VAR AVG PER TEST CUST	AVG NON-COIN kW PER CUST	AVG COIN kW PER CUST	COINCIDENCE FACTOR PERCENTAGE
		LOW (3)	HIGH (4)					
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)
1	GenLg TOD	0	999,999,999	686	9,988,773	3,268.960	2,969.006	90.8242
2	09-GenLarge TOD			686				
3	SC09 TOD			686				

Footnotes:

COL (9): EQUAL TO 100 * (COL (8) / COL (7))

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 3 - ESTIMATED CLASS DEMAND DATA
CLASS - SC09 TOD - Summer - 2023

LINE NO	SAMPLE STRATA	STRATIFICATION VARIABLE Annual kWh		EST AVG NO OF CUSTS	TOTAL ANNUAL kWh	AVG ANNUAL USE PER CUST	EST NON-COIN kW PER CUST	EST POPUL NON-COIN kW	COINCIDENCE FACTOR PERCENTAGE	EST POPUL COIN kW FOR INDIVIDUAL STRATA
		LOW (3)	HIGH (4)							
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)
1	GenLg TOD	0	999,999,999	689	6,925,170,992	10,051,046		1,493,690	90.8242	1,356,632
2	09-GenLarge TOD			689	6,925,170,992			1,493,690		1,356,632
3	SC09 TOD			689	6,925,170,992			1,493,690		1,356,632

Footnotes:

COL (7): EQUAL TO COL (6) / COL (5)

COL (8): FOR NON-DEMAND METERED CLASSES, FROM RELATIONSHIP OF SAMPLED ENERGY AND DEMAND VALUES, APPLIED TO POPULATION ENERGY USAGE

COL (9): EQUAL TO COLS (5) * (8) OR BILLING DEMAND

COL (10): FROM REPORT 2

COL (11): EQUAL TO COL (9) * (COL (10) / 100)

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 4 - ESTIMATED CLASS DEMAND DATA
CLASS - SC09 TOD - Summer - 2023

LINE NO	SAMPLE STRATA	STRATIFICATION VARIABLE		HALF HOUR kW AT TIME OF CLASS PEAK UNADJ AT CUST	4 HOUR DEMANDS-kW				
		Annual kWh			UNADJUSTED AT THE CUSTOMER	ADJUSTED AT THE CUSTOMER	UNADJUSTED AT SYSTEM INPUT	ADJUSTED AT SYSTEM INPUT	SYSTEM PEAK RESPBLTY
		LOW (3)	HIGH (4)						
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)
1	GenLg TOD	0	999,999,999	1,356,632	1,331,284	1,227,362	1,422,644	1,311,589	1,300,953
2	09-GenLarge TOD			1,356,632	1,331,284	1,227,362	1,422,644	1,311,589	1,300,953
3	SC09 TOD			1,356,632	1,331,284	1,227,362	1,422,644	1,311,589	1,300,953

Footnotes:

COL (5): CLASS PEAK AT 2:30pm

COL (6): CLASS 4 HOUR PEAK FROM 1:30pm-5:00pm

COL (7): ADJUSTED SUM OF COMPONENT LOADS EQUALS SYSTEM LOADS

COL (8): EQUAL TO (COL (6) / EFFICIENCY FACTOR OF 93.578186750) * 100

COL (9): EQUAL TO (COL (7) / EFFICIENCY FACTOR OF 93.578186750) * 100

COL (10): SYSTEM PEAK RESPONSIBILITY FROM 2:30pm-6:00pm

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 2 - SAMPLE TEST CUSTOMER DATA
CLASS - SC12 - Summer - 2023

LINE NO	SAMPLE STRATA	STRATIFICATION VARIABLE		NO OF TEST CUSTOMERS	STRAT VAR AVG PER TEST CUST	AVG NON-COIN kW PER CUST	AVG COIN kW PER CUST	COINCIDENCE FACTOR PERCENTAGE
		Sum Nov-Feb kWh (A) Max Jan-Dec kW (MHP)						
(1)	(2)	LOW (3)	HIGH (4)	(5)	(6)	(7)	(8)	(9)
1	Mult Dwell SpH CV A	0	999,999,999	329	57,555	25.250	19.371	76.7168
2	Stratum M	500	999,999,999	30	798	388.885	385.255	99.0666
3	12-MDWL-SPHT CV			359				
4	SC12			359				

Footnotes:

COL (9): EQUAL TO 100 * (COL (8) / COL (7))

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 3 - ESTIMATED CLASS DEMAND DATA
CLASS - SC12 - Summer - 2023

LINE NO	SAMPLE STRATA	STRATIFICATION VARIABLE		EST AVG NO OF CUSTS	TOTAL ANNUAL kWh	AVG ANNUAL USE PER CUST	EST NON-COIN kW PER CUST	EST POPUL NON-COIN kW	COINCIDENCE FACTOR PERCENTAGE	EST POPUL COIN kW FOR INDIVIDUAL STRATA
		Sum Nov-Feb kWh (A) Max Jan-Dec kW (MHP)								
(1)	(2)	LOW (3)	HIGH (4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)
1	Mult Dwell SpH CV A	0	999,999,999	395	47,663,207	120,666		9,034	76.7168	6,931
2	Stratum M	500	999,999,999	35	82,644,750	2,361,279		12,380	99.0666	12,264
3	12-MDWL-SPHT CV			430	130,307,957			21,414		19,195
4	SC12			430	130,307,957			21,414		19,195

Footnotes:

COL (7): EQUAL TO COL (6) / COL (5)

COL (8): FOR NON-DEMAND METERED CLASSES, FROM RELATIONSHIP OF SAMPLED ENERGY AND DEMAND VALUES, APPLIED TO POPULATION ENERGY USAGE

COL (9): EQUAL TO COLS (5) * (8) OR BILLING DEMAND

COL (10): FROM REPORT 2

COL (11): EQUAL TO COL (9) * (COL (10) / 100)

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 4 - ESTIMATED CLASS DEMAND DATA
CLASS - SC12 - Summer - 2023

LINE NO	SAMPLE STRATA	4 HOUR DEMANDS-kW							
		STRATIFICATION VARIABLE		HALF HOUR kW AT TIME OF CLASS PEAK UNADJ AT CUST	UNADJUSTED AT THE CUSTOMER	ADJUSTED AT THE CUSTOMER	UNADJUSTED AT SYSTEM INPUT	ADJUSTED AT SYSTEM INPUT	SYSTEM PEAK RESPBLTY
		Sum Nov-Feb kWh (A)							
		Max Jan-Dec kW (MHP)							
		LOW	HIGH						
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)
1	Mult Dwell SpH CV A	0	999,999,999	6,898	6,869	6,402	7,362	6,861	6,621
2	Stratum M	500	999,999,999	12,135	12,172	11,344	13,046	12,159	11,789
3	12-MDWL-SPHT CV			19,033	19,041	17,746	20,408	19,020	18,410
4	SC12			19,033	19,041	17,746	20,408	19,020	18,410

Footnotes:

COL (5): CLASS PEAK AT 6:30pm

COL (6): CLASS 4 HOUR PEAK FROM 6:00pm-9:30pm

COL (7): ADJUSTED SUM OF COMPONENT LOADS EQUALS SYSTEM LOADS

COL (8): EQUAL TO (COL (6) / EFFICIENCY FACTOR OF 93.300000000) * 100

COL (9): EQUAL TO (COL (7) / EFFICIENCY FACTOR OF 93.300000000) * 100

COL (10): SYSTEM PEAK RESPONSIBILITY FROM 2:30pm-6:00pm

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 2 - SAMPLE TEST CUSTOMER DATA
CLASS - SC12 TOD - Summer - 2023

LINE NO	SAMPLE STRATA	STRATIFICATION VARIABLE Annual kWh		NO OF TEST CUSTOMERS	STRAT VAR AVG PER TEST CUST	AVG NON-COIN kW PER CUST	AVG COIN kW PER CUST	COINCIDENCE FACTOR PERCENTAGE
		LOW (3)	HIGH (4)					
(1)	(2)			(5)	(6)	(7)	(8)	(9)
1	Mult Dwell SpH TOD	0	999,999,999	26	6,125,243	913.787	917.440	100.3998
2	12-MDWL-SPHT TOD			26				
3	SC12 TOD			26				

Footnotes:

COL (9): EQUAL TO 100 * (COL (8) / COL (7))

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 3 - ESTIMATED CLASS DEMAND DATA
CLASS - SC12 TOD - Summer - 2023

LINE NO	SAMPLE STRATA	STRATIFICATION VARIABLE Annual kWh		EST AVG NO OF CUSTS	TOTAL ANNUAL kWh	AVG ANNUAL USE PER CUST	EST NON-COIN kW PER CUST	EST POPUL NON-COIN kW	COINCIDENCE FACTOR PERCENTAGE	EST POPUL COIN kW FOR INDIVIDUAL STRATA
		LOW (3)	HIGH (4)							
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)
1	Mult Dwell SpH TOD	0	999,999,999	27	166,411,069	6,163,373		25,978	100.3998	26,082
2	12-MDWL-SPHT TOD			27	166,411,069			25,978		26,082
3	SC12 TOD			27	166,411,069			25,978		26,082

Footnotes:

COL (7): EQUAL TO COL (6) / COL (5)

COL (8): FOR NON-DEMAND METERED CLASSES, FROM RELATIONSHIP OF SAMPLED ENERGY AND DEMAND VALUES, APPLIED TO POPULATION ENERGY USAGE

COL (9): EQUAL TO COLS (5) * (8) OR BILLING DEMAND

COL (10): FROM REPORT 2

COL (11): EQUAL TO COL (9) * (COL (10) / 100)

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 4 - ESTIMATED CLASS DEMAND DATA
CLASS - SC12 TOD - Summer - 2023

LINE NO	SAMPLE STRATA	4 HOUR DEMANDS-kW							
		STRATIFICATION VARIABLE		HALF HOUR kW AT TIME OF CLASS PEAK UNADJ AT CUST	UNADJUSTED AT THE CUSTOMER	ADJUSTED AT THE CUSTOMER	UNADJUSTED AT SYSTEM INPUT	ADJUSTED AT SYSTEM INPUT	SYSTEM PEAK RESPBLTY
		Annual kWh							
		LOW (3)	HIGH (4)						
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)
1	Mult Dwell SpH TOD	0	999,999,999	25,950	25,506	23,771	27,338	25,478	24,598
2	12-MDWL-SPHT TOD			25,950	25,506	23,771	27,338	25,478	24,598
3	SC12 TOD			25,950	25,506	23,771	27,338	25,478	24,598

Footnotes:

COL (5): CLASS PEAK AT 7:30pm

COL (6): CLASS 4 HOUR PEAK FROM 6:00pm-9:30pm

COL (7): ADJUSTED SUM OF COMPONENT LOADS EQUALS SYSTEM LOADS

COL (8): EQUAL TO (COL (6) / EFFICIENCY FACTOR OF 93.300000000) * 100

COL (9): EQUAL TO (COL (7) / EFFICIENCY FACTOR OF 93.300000000) * 100

COL (10): SYSTEM PEAK RESPONSIBILITY FROM 2:30pm-6:00pm

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 2 - SAMPLE TEST CUSTOMER DATA
CLASS - SC13 TOD - Summer - 2023

LINE NO	SAMPLE STRATA	STRATIFICATION VARIABLE Annual kWh		NO OF TEST CUSTOMERS	STRAT VAR AVG PER TEST CUST	AVG NON-COIN kW PER CUST	AVG COIN kW PER CUST	COINCIDENCE FACTOR PERCENTAGE
		LOW (3)	HIGH (4)					
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)
1	Bulk Pwr TOD	0	999,999,999	1	9,111,700	10,543.000	160.000	1.5176
2	13-Bulk Pwr TOD			1				
3	SC13 TOD			1				

Footnotes:

COL (9): EQUAL TO 100 * (COL (8) / COL (7))

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 3 - ESTIMATED CLASS DEMAND DATA
CLASS - SC13 TOD - Summer - 2023

LINE NO	SAMPLE STRATA	STRATIFICATION VARIABLE Annual kWh		EST AVG NO OF CUSTS	TOTAL ANNUAL kWh	AVG ANNUAL USE PER CUST	EST NON-COIN kW PER CUST	EST POPUL NON-COIN kW	COINCIDENCE FACTOR PERCENTAGE	EST POPUL COIN kW FOR INDIVIDUAL STRATA
		LOW (3)	HIGH (4)							
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)
1	Bulk Pwr TOD	0	999,999,999	1	16,515,100	16,515,100		8,748	1.5176	133
2	13-Bulk Pwr TOD			1	16,515,100			8,748		133
3	SC13 TOD			1	16,515,100			8,748		133

Footnotes:

COL (7): EQUAL TO COL (6) / COL (5)

COL (8): FOR NON-DEMAND METERED CLASSES, FROM RELATIONSHIP OF SAMPLED ENERGY AND DEMAND VALUES, APPLIED TO POPULATION ENERGY USAGE

COL (9): EQUAL TO COLS (5) * (8) OR BILLING DEMAND

COL (10): FROM REPORT 2

COL (11): EQUAL TO COL (9) * (COL (10) / 100)

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 4 - ESTIMATED CLASS DEMAND DATA
CLASS - SC13 TOD - Summer - 2023

LINE NO	SAMPLE STRATA	4 HOUR DEMANDS-kW							
		STRATIFICATION VARIABLE		HALF HOUR kW AT TIME OF CLASS PEAK UNADJ AT CUST	UNADJUSTED AT THE CUSTOMER	ADJUSTED AT THE CUSTOMER	UNADJUSTED AT SYSTEM INPUT	ADJUSTED AT SYSTEM INPUT	SYSTEM PEAK RESPBLTY
		Annual kWh							
		LOW (3)	HIGH (4)						
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)
1	Bulk Pwr TOD	0	999,999,999	133	45	45	47	47	45
2	13-Bulk Pwr TOD			133	45	45	47	47	45
3	SC13 TOD			133	45	45	47	47	45

Footnotes:

COL (5): CLASS PEAK AT 5:30pm

COL (6): CLASS 4 HOUR PEAK FROM 4:00pm-7:30pm

COL (7): ADJUSTED SUM OF COMPONENT LOADS EQUALS SYSTEM LOADS

COL (8): EQUAL TO (COL (6) / EFFICIENCY FACTOR OF 94.600000000) * 100

COL (9): EQUAL TO (COL (7) / EFFICIENCY FACTOR OF 94.600000000) * 100

COL (10): SYSTEM PEAK RESPONSIBILITY FROM 2:30pm-6:00pm

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 2 - SAMPLE TEST CUSTOMER DATA
CLASS - SC62 - Summer - 2023

LINE NO	SAMPLE STRATA	STRATIFICATION VARIABLE Annual kWh		NO OF TEST CUSTOMERS	STRAT VAR AVG PER TEST CUST	AVG NON-COIN kW PER CUST	AVG COIN kW PER CUST	COINCIDENCE FACTOR PERCENTAGE
		LOW (3)	HIGH (4)					
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)
1	GenSm	0	999,999,999	606	9,004	2.087	1.078	51.6531
2	62-GenSmall			606				
3	SC62			606				

Footnotes:

COL (9): EQUAL TO 100 * (COL (8) / COL (7))

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 3 - ESTIMATED CLASS DEMAND DATA
CLASS - SC62 - Summer - 2023

LINE NO	SAMPLE STRATA	STRATIFICATION VARIABLE Annual kWh		EST AVG NO OF CUSTS	TOTAL ANNUAL kWh	AVG ANNUAL USE PER CUST	EST NON-COIN kW PER CUST	EST POPUL NON-COIN kW	COINCIDENCE FACTOR PERCENTAGE	EST POPUL COIN kW FOR INDIVIDUAL STRATA
(1)	(2)	LOW (3)	HIGH (4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)
1	GenSm	0	999,999,999	2,322	17,957,237	7,734	1.711	3,973	51.6531	2,052
2	62-GemSmall			2,322	17,957,237			3,973		2,052
3	SC62			2,322	17,957,237			3,973		2,052

Footnotes:

COL (7): EQUAL TO COL (6) / COL (5)

COL (8): FOR NON-DEMAND METERED CLASSES, FROM RELATIONSHIP OF SAMPLED ENERGY AND DEMAND VALUES, APPLIED TO POPULATION ENERGY USAGE

COL (9): EQUAL TO COLS (5) * (8) OR BILLING DEMAND

COL (10): FROM REPORT 2

COL (11): EQUAL TO COL (9) * (COL (10) / 100)

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 4 - ESTIMATED CLASS DEMAND DATA
CLASS - SC62 - Summer - 2023

LINE NO	SAMPLE STRATA	4 HOUR DEMANDS-kW							
		STRATIFICATION VARIABLE		HALF HOUR kW AT TIME OF CLASS PEAK UNADJ AT CUST	UNADJUSTED AT THE CUSTOMER	ADJUSTED AT THE CUSTOMER	UNADJUSTED AT SYSTEM INPUT	ADJUSTED AT SYSTEM INPUT	SYSTEM PEAK RESPBLTY
		Annual kWh							
		LOW (3)	HIGH (4)						
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)
1	GenSm	0	999,999,999	2,051	2,002	1,869	2,146	2,003	1,932
2	62-GemSmall			2,051	2,002	1,869	2,146	2,003	1,932
3	SC62			2,051	2,002	1,869	2,146	2,003	1,932

Footnotes:

COL (5): CLASS PEAK AT 8:30pm

COL (6): CLASS 4 HOUR PEAK FROM 8:00pm-11:30pm

COL (7): ADJUSTED SUM OF COMPONENT LOADS EQUALS SYSTEM LOADS

COL (8): EQUAL TO (COL (6) / EFFICIENCY FACTOR OF 93.300000000) * 100

COL (9): EQUAL TO (COL (7) / EFFICIENCY FACTOR OF 93.300000000) * 100

COL (10): SYSTEM PEAK RESPONSIBILITY FROM 2:30pm-6:00pm

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 2 - SAMPLE TEST CUSTOMER DATA
CLASS - SC65 - Summer - 2023

LINE NO	SAMPLE STRATA	STRATIFICATION VARIABLE Annual kWh		NO OF TEST CUSTOMERS	STRAT VAR AVG PER TEST CUST	AVG NON-COIN kW PER CUST	AVG COIN kW PER CUST	COINCIDENCE FACTOR PERCENTAGE
		LOW (3)	HIGH (4)					
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)
1	Traction CIS A	0	364,720	353	149,917	29.558	17.691	59.8518
2	Stratum B	364,721	1,108,160	69	551,935	76.009	67.010	88.1606
3	Stratum C	1,108,161	999,999,999	36	2,254,521	360.781	314.555	87.1872
4	65-Traction CIS			458				
5	TBIS LIRR	0	999,999,999	37	5,758,318	1,812.337	1,020.579	56.3129
6	TBIS MetNo	0	999,999,999	43	6,092,380	2,113.624	1,377.458	65.1704
7	TBIS SIRTOA	0	999,999,999	5	6,177,255	1,066.320	777.781	72.9407
8	65-Traction TBIS			85				
9	SC65			543				

Footnotes:

COL (9): EQUAL TO 100 * (COL (8) / COL (7))

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 3 - ESTIMATED CLASS DEMAND DATA
CLASS - SC65 - Summer - 2023

LINE NO	SAMPLE STRATA	STRATIFICATION VARIABLE Annual kWh		EST AVG NO OF CUSTS	TOTAL ANNUAL kWh	AVG ANNUAL USE PER CUST	EST NON-COIN kW PER CUST	EST POPUL NON-COIN kW	COINCIDENCE FACTOR PERCENTAGE	EST POPUL COIN kW FOR INDIVIDUAL STRATA
(1)	(2)	LOW (3)	HIGH (4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)
1	Traction CIS A	0	364,720	646	91,377,260	141,451		20,017	59.8518	11,981
2	Stratum B	364,721	1,108,160	203	108,445,733	534,215		15,200	88.1606	13,400
3	Stratum C	1,108,161	999,999,999	48	96,243,570	2,005,074		16,433	87.1872	14,327
4	65-Traction CIS			897	296,066,563			51,650		39,708
5	TBIS LIRR	0	999,999,999	41	244,519,531	5,963,891		54,201	56.3129	30,522
6	TBIS MetNo	0	999,999,999	45	304,171,664	6,759,370		69,400	65.1704	45,228
7	TBIS SIRTOA	0	999,999,999	7	25,980,560	3,711,509		4,721	72.9407	3,444
8	65-Traction TBIS			93	574,671,755			128,322		79,194
9	SC65			990	870,738,318			179,972		118,902

Footnotes:

COL (7): EQUAL TO COL (6) / COL (5)

COL (8): FOR NON-DEMAND METERED CLASSES, FROM RELATIONSHIP OF SAMPLED ENERGY AND DEMAND VALUES, APPLIED TO POPULATION ENERGY USAGE

COL (9): EQUAL TO COLS (5) * (8) OR BILLING DEMAND

COL (10): FROM REPORT 2

COL (11): EQUAL TO COL (9) * (COL (10) / 100)

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 4 - ESTIMATED CLASS DEMAND DATA
CLASS - SC65 - Summer - 2023

LINE NO	SAMPLE STRATA	STRATIFICATION VARIABLE		HALF HOUR kW AT TIME OF CLASS PEAK UNADJ AT CUST	4 HOUR DEMANDS-kW					SYSTEM PEAK RESPBLTY
		Annual kWh			UNADJUSTED AT THE CUSTOMER	ADJUSTED AT THE CUSTOMER	UNADJUSTED AT SYSTEM INPUT	ADJUSTED AT SYSTEM INPUT		
		LOW	HIGH							
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)	
1	Traction CIS A	0	364,720	11,610	11,650	10,859	12,373	11,534	11,474	
2	Stratum B	364,721	1,108,160	13,250	13,230	12,332	14,051	13,098	13,123	
3	Stratum C	1,108,161	999,999,999	14,214	14,155	13,194	15,034	14,014	14,014	
4	65-Traction CIS			39,074	39,035	36,385	41,458	38,646	38,611	
5	TBIS LIRR	0	999,999,999	30,508	27,681	25,808	29,400	27,411	25,352	
6	TBIS MetNo	0	999,999,999	44,731	38,635	36,027	41,034	38,264	32,442	
7	TBIS SIRTOA	0	999,999,999	3,106	3,042	2,836	3,230	3,012	2,526	
8	65-Traction TBIS			78,345	69,358	64,671	73,664	68,687	60,320	
9	SC65			117,419	108,393	101,056	115,122	107,333	98,931	

Footnotes:

COL (5): CLASS PEAK AT 6:00pm

COL (6): CLASS 4 HOUR PEAK FROM 4:30pm-8:00pm

COL (7): ADJUSTED SUM OF COMPONENT LOADS EQUALS SYSTEM LOADS

COL (8): EQUAL TO (COL (6) / EFFICIENCY FACTOR OF 94.153931177) * 100

COL (9): EQUAL TO (COL (7) / EFFICIENCY FACTOR OF 94.153931177) * 100

COL (10): SYSTEM PEAK RESPONSIBILITY FROM 2:30pm-6:00pm

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 2 - SAMPLE TEST CUSTOMER DATA
CLASS - SC66 - Summer - 2023

LINE NO	SAMPLE STRATA	STRATIFICATION VARIABLE Annual kWh		NO OF TEST CUSTOMERS	STRAT VAR AVG PER TEST CUST	AVG NON-COIN kW PER CUST	AVG COIN kW PER CUST	COINCIDENCE FACTOR PERCENTAGE
		LOW (3)	HIGH (4)					
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)
1	West SL	0	999,999,999	3	9,954,445	2,100.310	2,099.848	99.9780
2	66-WestSL			3				
3	SC66			3				

Footnotes:

COL (9): EQUAL TO 100 * (COL (8) / COL (7))

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 3 - ESTIMATED CLASS DEMAND DATA
CLASS - SC66 - Summer - 2023

LINE NO	SAMPLE STRATA	STRATIFICATION VARIABLE Annual kWh		EST AVG NO OF CUSTS	TOTAL ANNUAL kWh	AVG ANNUAL USE PER CUST	EST NON-COIN kW PER CUST	EST POPUL NON-COIN kW	COINCIDENCE FACTOR PERCENTAGE	EST POPUL COIN kW FOR INDIVIDUAL STRATA
(1)	(2)	LOW (3)	HIGH (4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)
1	West SL	0	999,999,999	1	29,967,952	29,967,952	6637.892	6,638	99.9780	6,637
2	66-WestSL			1	29,967,952			6,638		6,637
3	SC66			1	29,967,952			6,638		6,637

Footnotes:

COL (7): EQUAL TO COL (6) / COL (5)

COL (8): FOR NON-DEMAND METERED CLASSES, FROM RELATIONSHIP OF SAMPLED ENERGY AND DEMAND VALUES, APPLIED TO POPULATION ENERGY USAGE

COL (9): EQUAL TO COLS (5) * (8) OR BILLING DEMAND

COL (10): FROM REPORT 2

COL (11): EQUAL TO COL (9) * (COL (10) / 100)

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 4 - ESTIMATED CLASS DEMAND DATA
CLASS - SC66 - Summer - 2023

LINE NO	SAMPLE STRATA	4 HOUR DEMANDS-kW							
		STRATIFICATION VARIABLE		HALF HOUR kW AT TIME OF CLASS PEAK UNADJ AT CUST	UNADJUSTED AT THE CUSTOMER	ADJUSTED AT THE CUSTOMER	UNADJUSTED AT SYSTEM INPUT	ADJUSTED AT SYSTEM INPUT	SYSTEM PEAK RESPBLTY
		Annual kWh							
		LOW (3)	HIGH (4)						
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)
1	West SL	0	999,999,999	6,637	6,632	6,632	7,109	7,109	754
2	66-WestSL			6,637	6,632	6,632	7,109	7,109	754
3	SC66			6,637	6,632	6,632	7,109	7,109	754

Footnotes:

COL (5): CLASS PEAK AT 9:00pm

COL (6): CLASS 4 HOUR PEAK FROM 9:00pm-12:30am

COL (7): ADJUSTED SUM OF COMPONENT LOADS EQUALS SYSTEM LOADS

COL (8): EQUAL TO (COL (6) / EFFICIENCY FACTOR OF 93.300000000) * 100

COL (9): EQUAL TO (COL (7) / EFFICIENCY FACTOR OF 93.300000000) * 100

COL (10): SYSTEM PEAK RESPONSIBILITY FROM 2:30pm-6:00pm

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 2 - SAMPLE TEST CUSTOMER DATA
CLASS - SC68 - Summer - 2023

LINE NO	SAMPLE STRATA	STRATIFICATION VARIABLE Annual kWh		NO OF TEST CUSTOMERS	STRAT VAR AVG PER TEST CUST	AVG NON-COIN kW PER CUST	AVG COIN kW PER CUST	COINCIDENCE FACTOR PERCENTAGE
		LOW (3)	HIGH (4)					
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)
1	MultDw CV A	0	798,800	42	418,116	89.531	88.517	98.8674
2	Stratum B	798,801	1,215,000	21	975,553	204.245	204.570	100.1591
3	Stratum C	1,215,001	1,867,600	23	1,521,312	354.899	320.135	90.2045
4	Stratum D	1,867,601	3,656,000	31	2,552,232	527.926	536.925	101.7046
5	Stratum E	3,656,001	999,999,999	5	5,008,373	1,103.185	1,128.933	102.3340
6	68-MultDw CV			122				
7	SC68			122				

Footnotes:

COL (9): EQUAL TO 100 * (COL (8) / COL (7))

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 3 - ESTIMATED CLASS DEMAND DATA
CLASS - SC68 - Summer - 2023

LINE NO	SAMPLE STRATA	STRATIFICATION VARIABLE Annual kWh		EST AVG NO OF CUSTS	TOTAL ANNUAL kWh	AVG ANNUAL USE PER CUST	EST NON-COIN kW PER CUST	EST POPUL NON-COIN kW	COINCIDENCE FACTOR PERCENTAGE	EST POPUL COIN kW FOR INDIVIDUAL STRATA
(1)	(2)	LOW (3)	HIGH (4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)
1	MultDw CV A	0	798,800	214	89,862,372	419,918		20,519	98.8674	20,287
2	Stratum B	798,801	1,215,000	105	102,270,345	974,003		23,127	100.1591	23,164
3	Stratum C	1,215,001	1,867,600	72	106,152,121	1,474,335		23,640	90.2045	21,324
4	Stratum D	1,867,601	3,656,000	42	109,906,763	2,616,828		24,198	101.7046	24,610
5	Stratum E	3,656,001	999,999,999	18	100,937,264	5,607,626		22,091	102.3340	22,607
6	68-MultDw CV			451	509,128,865			113,575		111,992
7	SC68			451	509,128,865			113,575		111,992

Footnotes:

COL (7): EQUAL TO COL (6) / COL (5)

COL (8): FOR NON-DEMAND METERED CLASSES, FROM RELATIONSHIP OF SAMPLED ENERGY AND DEMAND VALUES, APPLIED TO POPULATION ENERGY USAGE

COL (9): EQUAL TO COLS (5) * (8) OR BILLING DEMAND

COL (10): FROM REPORT 2

COL (11): EQUAL TO COL (9) * (COL (10) / 100)

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 4 - ESTIMATED CLASS DEMAND DATA
CLASS - SC68 - Summer - 2023

LINE NO	SAMPLE STRATA	STRATIFICATION VARIABLE		HALF HOUR kW AT TIME OF CLASS PEAK UNADJ AT CUST	4 HOUR DEMANDS-kW				
		Annual kWh			UNADJUSTED AT THE CUSTOMER	ADJUSTED AT THE CUSTOMER	UNADJUSTED AT SYSTEM INPUT	ADJUSTED AT SYSTEM INPUT	SYSTEM PEAK RESPBLTY
		LOW	HIGH						
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)
1	MultDw CV A	0	798,800	20,287	20,083	18,714	21,514	20,047	19,163
2	Stratum B	798,801	1,215,000	23,164	22,956	21,391	24,591	22,915	22,050
3	Stratum C	1,215,001	1,867,600	21,324	21,146	19,705	22,653	21,109	20,109
4	Stratum D	1,867,601	3,656,000	24,610	24,408	22,744	26,146	24,364	23,004
5	Stratum E	3,656,001	999,999,999	22,607	22,430	20,901	24,027	22,390	21,557
6	68-MultDw CV			111,992	111,023	103,455	118,931	110,825	105,883
7	SC68			111,992	111,023	103,455	118,931	110,825	105,883

Footnotes:

COL (5): CLASS PEAK AT 8:30pm

COL (6): CLASS 4 HOUR PEAK FROM 6:30pm-10:00pm

COL (7): ADJUSTED SUM OF COMPONENT LOADS EQUALS SYSTEM LOADS

COL (8): EQUAL TO (COL (6) / EFFICIENCY FACTOR OF 93.350763896) * 100

COL (9): EQUAL TO (COL (7) / EFFICIENCY FACTOR OF 93.350763896) * 100

COL (10): SYSTEM PEAK RESPONSIBILITY FROM 2:30pm-6:00pm

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 2 - SAMPLE TEST CUSTOMER DATA
CLASS - SC68 TOD - Summer - 2023

LINE NO	SAMPLE STRATA	STRATIFICATION VARIABLE Annual kWh		NO OF TEST CUSTOMERS	STRAT VAR AVG PER TEST CUST	AVG NON-COIN kW PER CUST	AVG COIN kW PER CUST	COINCIDENCE FACTOR PERCENTAGE
		LOW (3)	HIGH (4)					
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)
1	MultDw TOD	0	999,999,999	58	7,856,517	1,691.023	1,743.229	103.0872
2	68-MultDw TOD			58				
3	SC68 TOD			58				

Footnotes:

COL (9): EQUAL TO 100 * (COL (8) / COL (7))

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 3 - ESTIMATED CLASS DEMAND DATA
CLASS - SC68 TOD - Summer - 2023

LINE NO	SAMPLE STRATA	STRATIFICATION VARIABLE Annual kWh		EST AVG NO OF CUSTS	TOTAL ANNUAL kWh	AVG ANNUAL USE PER CUST	EST NON-COIN kW PER CUST	EST POPUL NON-COIN kW	COINCIDENCE FACTOR PERCENTAGE	EST POPUL COIN kW FOR INDIVIDUAL STRATA
(1)	(2)	LOW (3)	HIGH (4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)
1	MultDw TOD	0	999,999,999	57	464,250,850	8,144,752		103,686	103.0872	106,887
2	68-MultDw TOD			57	464,250,850			103,686		106,887
3	SC68 TOD			57	464,250,850			103,686		106,887

Footnotes:

COL (7): EQUAL TO COL (6) / COL (5)

COL (8): FOR NON-DEMAND METERED CLASSES, FROM RELATIONSHIP OF SAMPLED ENERGY AND DEMAND VALUES, APPLIED TO POPULATION ENERGY USAGE

COL (9): EQUAL TO COLS (5) * (8) OR BILLING DEMAND

COL (10): FROM REPORT 2

COL (11): EQUAL TO COL (9) * (COL (10) / 100)

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 4 - ESTIMATED CLASS DEMAND DATA
CLASS - SC68 TOD - Summer - 2023

LINE NO	SAMPLE STRATA	STRATIFICATION VARIABLE		HALF HOUR kW AT TIME OF CLASS PEAK UNADJ AT CUST	4 HOUR DEMANDS-kW				
		Annual kWh			UNADJUSTED AT THE CUSTOMER	ADJUSTED AT THE CUSTOMER	UNADJUSTED AT SYSTEM INPUT	ADJUSTED AT SYSTEM INPUT	SYSTEM PEAK RESPBLTY
		LOW (3)	HIGH (4)						
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)
1	MultDw TOD	0	999,999,999	106,887	105,932	98,712	113,539	105,800	100,763
2	68-MultDw TOD			106,887	105,932	98,712	113,539	105,800	100,763
3	SC68 TOD			106,887	105,932	98,712	113,539	105,800	100,763

Footnotes:

COL (5): CLASS PEAK AT 8:30pm

COL (6): CLASS 4 HOUR PEAK FROM 6:30pm-10:00pm

COL (7): ADJUSTED SUM OF COMPONENT LOADS EQUALS SYSTEM LOADS

COL (8): EQUAL TO (COL (6) / EFFICIENCY FACTOR OF 93.300000000) * 100

COL (9): EQUAL TO (COL (7) / EFFICIENCY FACTOR OF 93.300000000) * 100

COL (10): SYSTEM PEAK RESPONSIBILITY FROM 2:30pm-6:00pm

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 2 - SAMPLE TEST CUSTOMER DATA
CLASS - SC69 - Summer - 2023

LINE NO	SAMPLE STRATA	STRATIFICATION VARIABLE Annual kWh		NO OF TEST CUSTOMERS	STRAT VAR AVG PER TEST CUST	AVG NON-COIN kW PER CUST	AVG COIN kW PER CUST	COINCIDENCE FACTOR PERCENTAGE
		LOW (3)	HIGH (4)					
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)
1	GenLg CV A	0	206,120	610	71,149	22.467	13.525	60.1994
2	Stratum B	206,121	545,600	264	332,659	83.424	70.805	84.8737
3	Stratum C	545,601	1,254,800	160	802,983	195.825	181.075	92.4678
4	Stratum D	1,254,801	3,034,400	95	1,911,436	428.841	380.374	88.6981
5	Stratum E	3,034,401	999,999,999	36	4,656,695	841.658	746.344	88.6754
6	69-GenLg CV			1,165				
7	SC69			1,165				

Footnotes:

COL (9): EQUAL TO 100 * (COL (8) / COL (7))

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 3 - ESTIMATED CLASS DEMAND DATA
CLASS - SC69 - Summer - 2023

LINE NO	SAMPLE STRATA	STRATIFICATION VARIABLE Annual kWh		EST AVG NO OF CUSTS	TOTAL ANNUAL kWh	AVG ANNUAL USE PER CUST	EST NON-COIN kW PER CUST	EST POPUL NON-COIN kW	COINCIDENCE FACTOR PERCENTAGE	EST POPUL COIN kW FOR INDIVIDUAL STRATA
(1)	(2)	LOW (3)	HIGH (4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)
1	GenLg CV A	0	206,120	1,462	101,119,085	69,165		30,630	60.1994	18,439
2	Stratum B	206,121	545,600	363	120,107,099	330,874		29,935	84.8737	25,407
3	Stratum C	545,601	1,254,800	180	145,404,917	807,805		36,412	92.4678	33,669
4	Stratum D	1,254,801	3,034,400	98	187,346,012	1,911,694		42,884	88.6981	38,037
5	Stratum E	3,034,401	999,999,999	37	182,595,444	4,935,012		34,404	88.6754	30,508
6	69-GenLg CV			2,140	736,572,557			174,265		146,060
7	SC69			2,140	736,572,557			174,265		146,060

Footnotes:

COL (7): EQUAL TO COL (6) / COL (5)

COL (8): FOR NON-DEMAND METERED CLASSES, FROM RELATIONSHIP OF SAMPLED ENERGY AND DEMAND VALUES, APPLIED TO POPULATION ENERGY USAGE

COL (9): EQUAL TO COLS (5) * (8) OR BILLING DEMAND

COL (10): FROM REPORT 2

COL (11): EQUAL TO COL (9) * (COL (10) / 100)

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 4 - ESTIMATED CLASS DEMAND DATA
CLASS - SC69 - Summer - 2023

LINE NO	SAMPLE STRATA	STRATIFICATION VARIABLE		HALF HOUR kW AT TIME OF CLASS PEAK UNADJ AT CUST	4 HOUR DEMANDS-kW					SYSTEM PEAK RESPBLTY
		Annual kWh			UNADJUSTED AT THE CUSTOMER	ADJUSTED AT THE CUSTOMER	UNADJUSTED AT SYSTEM INPUT	ADJUSTED AT SYSTEM INPUT		
		LOW (3)	HIGH (4)							
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)	
1	GenLg CV A	0	206,120	18,439	18,156	16,570	19,440	17,741	17,025	
2	Stratum B	206,121	545,600	25,407	25,098	22,904	26,872	24,523	22,513	
3	Stratum C	545,601	1,254,800	33,630	33,355	30,438	35,713	32,590	29,460	
4	Stratum D	1,254,801	3,034,400	37,906	37,563	34,279	40,219	36,703	34,603	
5	Stratum E	3,034,401	999,999,999	30,299	30,383	27,726	32,531	29,687	29,255	
6	69-GenLg CV			145,681	144,555	131,917	154,775	141,244	132,856	
7	SC69			145,681	144,555	131,917	154,775	141,244	132,856	

Footnotes:

COL (5): CLASS PEAK AT 2:00pm

COL (6): CLASS 4 HOUR PEAK FROM 11:30am-3:00pm

COL (7): ADJUSTED SUM OF COMPONENT LOADS EQUALS SYSTEM LOADS

COL (8): EQUAL TO (COL (6) / EFFICIENCY FACTOR OF 93.396698444) * 100

COL (9): EQUAL TO (COL (7) / EFFICIENCY FACTOR OF 93.396698444) * 100

COL (10): SYSTEM PEAK RESPONSIBILITY FROM 2:30pm-6:00pm

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 2 - SAMPLE TEST CUSTOMER DATA
CLASS - SC69 TOD - Summer - 2023

LINE NO	SAMPLE STRATA	STRATIFICATION VARIABLE Annual kWh		NO OF TEST CUSTOMERS	STRAT VAR AVG PER TEST CUST	AVG NON-COIN kW PER CUST	AVG COIN kW PER CUST	COINCIDENCE FACTOR PERCENTAGE
		LOW (3)	HIGH (4)					
(1)	(2)			(5)	(6)	(7)	(8)	(9)
1	GenLg TOD A	0	20,388,000	42	8,785,354	1,961.075	1,594.158	81.2900
2	Stratum B	20,388,001	999,999,999	8	49,679,181	9,191.750	8,896.764	96.7908
3	Stratum C	0	999,999,999	2	160,622,126	21,510.020	20,187.645	93.8523
4	69-GenLg TOD			52				
5	SC69 TOD			52				

Footnotes:

COL (9): EQUAL TO 100 * (COL (8) / COL (7))

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 3 - ESTIMATED CLASS DEMAND DATA
CLASS - SC69 TOD - Summer - 2023

LINE NO	SAMPLE STRATA	STRATIFICATION VARIABLE Annual kWh		EST AVG NO OF CUSTS	TOTAL ANNUAL kWh	AVG ANNUAL USE PER CUST	EST NON-COIN kW PER CUST	EST POPUL NON-COIN kW	COINCIDENCE FACTOR PERCENTAGE	EST POPUL COIN kW FOR INDIVIDUAL STRATA
(1)	(2)	LOW (3)	HIGH (4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)
1	GenLg TOD A	0	20,388,000	42	370,325,114	8,817,265		78,448	81.2900	63,770
2	Stratum B	20,388,001	999,999,999	11	546,839,836	49,712,712		102,534	96.7908	99,243
3	Stratum C	0	999,999,999	2	323,940,565	161,970,283		44,091	93.8523	41,380
4	69-GenLg TOD			55	1,241,105,515			225,073		204,393
5	SC69 TOD			55	1,241,105,515			225,073		204,393

Footnotes:

COL (7): EQUAL TO COL (6) / COL (5)

COL (8): FOR NON-DEMAND METERED CLASSES, FROM RELATIONSHIP OF SAMPLED ENERGY AND DEMAND VALUES, APPLIED TO POPULATION ENERGY USAGE

COL (9): EQUAL TO COLS (5) * (8) OR BILLING DEMAND

COL (10): FROM REPORT 2

COL (11): EQUAL TO COL (9) * (COL (10) / 100)

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 4 - ESTIMATED CLASS DEMAND DATA
CLASS - SC69 TOD - Summer - 2023

LINE NO	SAMPLE STRATA	STRATIFICATION VARIABLE		HALF HOUR kW AT TIME OF CLASS PEAK UNADJ AT CUST	4 HOUR DEMANDS-kW				
		Annual kWh			UNADJUSTED AT THE CUSTOMER	ADJUSTED AT THE CUSTOMER	UNADJUSTED AT SYSTEM INPUT	ADJUSTED AT SYSTEM INPUT	SYSTEM PEAK RESPBLTY
		LOW (3)	HIGH (4)						
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)
1	GenLg TOD A	0	20,388,000	63,073	63,072	57,984	66,856	61,463	60,602
2	Stratum B	20,388,001	999,999,999	99,056	98,395	90,461	104,299	95,889	95,361
3	Stratum C	0	999,999,999	41,118	40,727	40,727	43,171	43,171	43,577
4	69-GenLg TOD			203,247	202,194	189,172	214,326	200,523	199,540
5	SC69 TOD			203,247	202,194	189,172	214,326	200,523	199,540

Footnotes:

COL (5): CLASS PEAK AT 3:00pm

COL (6): CLASS 4 HOUR PEAK FROM 1:00pm-4:30pm

COL (7): ADJUSTED SUM OF COMPONENT LOADS EQUALS SYSTEM LOADS

COL (8): EQUAL TO (COL (6) / EFFICIENCY FACTOR OF 94.339932216) * 100

COL (9): EQUAL TO (COL (7) / EFFICIENCY FACTOR OF 94.339932216) * 100

COL (10): SYSTEM PEAK RESPONSIBILITY FROM 2:30pm-6:00pm

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 2 - SAMPLE TEST CUSTOMER DATA
CLASS - SC80 - Summer - 2023

LINE NO	SAMPLE STRATA	STRATIFICATION VARIABLE Annual kWh		NO OF TEST CUSTOMERS	STRAT VAR AVG PER TEST CUST	AVG NON-COIN kW PER CUST	AVG COIN kW PER CUST	COINCIDENCE FACTOR PERCENTAGE
		LOW (3)	HIGH (4)					
(1)	(2)			(5)	(6)	(7)	(8)	(9)
1	NYC SL	0	999,999,999	3	61,377,605	11,887.781	11,882.260	99.9536
2	80-NYC SL			3				
3	SC80			3				

Footnotes:

COL (9): EQUAL TO 100 * (COL (8) / COL (7))

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 3 - ESTIMATED CLASS DEMAND DATA
CLASS - SC80 - Summer - 2023

LINE NO	SAMPLE STRATA	STRATIFICATION VARIABLE Annual kWh		EST AVG NO OF CUSTS	TOTAL ANNUAL kWh	AVG ANNUAL USE PER CUST	EST NON-COIN kW PER CUST	EST POPUL NON-COIN kW	COINCIDENCE FACTOR PERCENTAGE	EST POPUL COIN kW FOR INDIVIDUAL STRATA
(1)	(2)	LOW (3)	HIGH (4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)
1	NYC SL	0	999,999,999	5	159,943,666	31,988,733		33,639	99.9536	33,623
2	80-NYC SL			5	159,943,666			33,639		33,623
3	SC80			5	159,943,666			33,639		33,623

Footnotes:

COL (7): EQUAL TO COL (6) / COL (5)

COL (8): FOR NON-DEMAND METERED CLASSES, FROM RELATIONSHIP OF SAMPLED ENERGY AND DEMAND VALUES, APPLIED TO POPULATION ENERGY USAGE

COL (9): EQUAL TO COLS (5) * (8) OR BILLING DEMAND

COL (10): FROM REPORT 2

COL (11): EQUAL TO COL (9) * (COL (10) / 100)

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 4 - ESTIMATED CLASS DEMAND DATA
CLASS - SC80 - Summer - 2023

LINE NO	SAMPLE STRATA	STRATIFICATION VARIABLE		HALF HOUR kW AT TIME OF CLASS PEAK UNADJ AT CUST	4 HOUR DEMANDS-kW				
		Annual kWh			UNADJUSTED AT THE CUSTOMER	ADJUSTED AT THE CUSTOMER	UNADJUSTED AT SYSTEM INPUT	ADJUSTED AT SYSTEM INPUT	SYSTEM PEAK RESPBLTY
		LOW	HIGH						
		(3)	(4)						
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)
1	NYC SL	0	999,999,999	33,623	33,564	33,564	35,974	35,974	8,310
2	80-NYC SL			33,623	33,564	33,564	35,974	35,974	8,310
3	SC80			33,623	33,564	33,564	35,974	35,974	8,310

Footnotes:

COL (5): CLASS PEAK AT 9:00pm

COL (6): CLASS 4 HOUR PEAK FROM 9:00pm-12:30am

COL (7): ADJUSTED SUM OF COMPONENT LOADS EQUALS SYSTEM LOADS

COL (8): EQUAL TO (COL (6) / EFFICIENCY FACTOR OF 93.300000000) * 100

COL (9): EQUAL TO (COL (7) / EFFICIENCY FACTOR OF 93.300000000) * 100

COL (10): SYSTEM PEAK RESPONSIBILITY FROM 2:30pm-6:00pm

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 2 - SAMPLE TEST CUSTOMER DATA
CLASS - SC82 - Summer - 2023

LINE NO	SAMPLE STRATA	STRATIFICATION VARIABLE Annual kWh		NO OF TEST CUSTOMERS	STRAT VAR AVG PER TEST CUST	AVG NON-COIN kW PER CUST	AVG COIN kW PER CUST	COINCIDENCE FACTOR PERCENTAGE
		LOW (3)	HIGH (4)					
(1)	(2)			(5)	(6)	(7)	(8)	(9)
1	MultDwHt	0	999,999,999	2	2,399,696	291.960	299.136	102.4579
2	82-MultDwHt			2				
3	SC82			2				

Footnotes:

COL (9): EQUAL TO 100 * (COL (8) / COL (7))

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 3 - ESTIMATED CLASS DEMAND DATA
CLASS - SC82 - Summer - 2023

LINE NO	SAMPLE STRATA	STRATIFICATION VARIABLE Annual kWh		EST AVG NO OF CUSTS	TOTAL ANNUAL kWh	AVG ANNUAL USE PER CUST	EST NON-COIN kW PER CUST	EST POPUL NON-COIN kW	COINCIDENCE FACTOR PERCENTAGE	EST POPUL COIN kW FOR INDIVIDUAL STRATA
(1)	(2)	LOW (3)	HIGH (4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)
1	MultDwHt	0	999,999,999	3	6,419,842	2,139,947		829	102.4579	849
2	82-MultDwHt			3	6,419,842			829		849
3	SC82			3	6,419,842			829		849

Footnotes:

COL (7): EQUAL TO COL (6) / COL (5)

COL (8): FOR NON-DEMAND METERED CLASSES, FROM RELATIONSHIP OF SAMPLED ENERGY AND DEMAND VALUES, APPLIED TO POPULATION ENERGY USAGE

COL (9): EQUAL TO COLS (5) * (8) OR BILLING DEMAND

COL (10): FROM REPORT 2

COL (11): EQUAL TO COL (9) * (COL (10) / 100)

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 4 - ESTIMATED CLASS DEMAND DATA
CLASS - SC82 - Summer - 2023

LINE NO	SAMPLE STRATA	4 HOUR DEMANDS-kW							
		STRATIFICATION VARIABLE		HALF HOUR kW AT TIME OF CLASS PEAK UNADJ AT CUST	UNADJUSTED AT THE CUSTOMER	ADJUSTED AT THE CUSTOMER	UNADJUSTED AT SYSTEM INPUT	ADJUSTED AT SYSTEM INPUT	SYSTEM PEAK RESPBLTY
		Annual kWh							
		LOW (3)	HIGH (4)						
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)
1	MultDwHt	0	999,999,999	849	840	783	901	839	822
2	82-MultDwHt			849	840	783	901	839	822
3	SC82			849	840	783	901	839	822

Footnotes:

COL (5): CLASS PEAK AT 8:30pm

COL (6): CLASS 4 HOUR PEAK FROM 6:30pm-10:00pm

COL (7): ADJUSTED SUM OF COMPONENT LOADS EQUALS SYSTEM LOADS

COL (8): EQUAL TO (COL (6) / EFFICIENCY FACTOR OF 93.300000000) * 100

COL (9): EQUAL TO (COL (7) / EFFICIENCY FACTOR OF 93.300000000) * 100

COL (10): SYSTEM PEAK RESPONSIBILITY FROM 2:30pm-6:00pm

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 2 - SAMPLE TEST CUSTOMER DATA
CLASS - SC85 - Summer - 2023

LINE NO	SAMPLE STRATA	STRATIFICATION VARIABLE Annual kWh		NO OF TEST CUSTOMERS	STRAT VAR AVG PER TEST CUST	AVG NON-COIN kW PER CUST	AVG COIN kW PER CUST	COINCIDENCE FACTOR PERCENTAGE
		LOW (3)	HIGH (4)					
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)
1	Substn CIS A	0	57,744	145	22,030	6.951	3.401	48.9282
2	Stratum B	57,745	142,640	49	84,990	16.052	11.250	70.0847
3	Stratum C	142,641	999,999,999	13	386,724	62.207	55.396	89.0511
4	85-Substn CIS			207				
5	Substn TBIS	0	999,999,999	213	7,368,084	2,002.137	1,504.692	75.1543
6	85-Substn TBIS			213				
7	SC85			420				

Footnotes:

COL (9): EQUAL TO 100 * (COL (8) / COL (7))

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 3 - ESTIMATED CLASS DEMAND DATA
CLASS - SC85 - Summer - 2023

LINE NO	SAMPLE STRATA	STRATIFICATION VARIABLE Annual kWh		EST AVG NO OF CUSTS	TOTAL ANNUAL kWh	AVG ANNUAL USE PER CUST	EST NON-COIN kW PER CUST	EST POPUL NON-COIN kW	COINCIDENCE FACTOR PERCENTAGE	EST POPUL COIN kW FOR INDIVIDUAL STRATA
		LOW (3)	HIGH (4)							
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)
1	Substn CIS A	0	57,744	154	3,244,951	21,071		1,080	48.9282	528
2	Stratum B	57,745	142,640	49	4,164,525	84,990		810	70.0847	568
3	Stratum C	142,641	999,999,999	14	5,230,776	373,627		841	89.0511	749
4	85-Substn CIS			217	12,640,252			2,731		1,845
5	Substn TBIS	0	999,999,999	219	1,544,954,400	7,054,586		333,736	75.1543	250,817
6	85-Substn TBIS			219	1,544,954,400			333,736		250,817
7	SC85			436	1,557,594,652			336,467		252,662

Footnotes:

COL (7): EQUAL TO COL (6) / COL (5)

COL (8): FOR NON-DEMAND METERED CLASSES, FROM RELATIONSHIP OF SAMPLED ENERGY AND DEMAND VALUES, APPLIED TO POPULATION ENERGY USAGE

COL (9): EQUAL TO COLS (5) * (8) OR BILLING DEMAND

COL (10): FROM REPORT 2

COL (11): EQUAL TO COL (9) * (COL (10) / 100)

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 4 - ESTIMATED CLASS DEMAND DATA
CLASS - SC85 - Summer - 2023

LINE NO	SAMPLE STRATA	STRATIFICATION VARIABLE		HALF HOUR kW AT TIME OF CLASS PEAK UNADJ AT CUST	4 HOUR DEMANDS-kW				
		Annual kWh			UNADJUSTED AT THE CUSTOMER	ADJUSTED AT THE CUSTOMER	UNADJUSTED AT SYSTEM INPUT	ADJUSTED AT SYSTEM INPUT	SYSTEM PEAK RESPBLTY
		LOW	HIGH						
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)
1	Substn CIS A	0	57,744	468	474	442	501	467	469
2	Stratum B	57,745	142,640	522	526	490	556	519	526
3	Stratum C	142,641	999,999,999	698	703	655	743	693	709
4	85-Substn CIS			1,688	1,703	1,587	1,800	1,679	1,704
5	Substn TBIS	0	999,999,999	250,817	238,532	238,532	252,176	252,176	242,895
6	85-Substn TBIS			250,817	238,532	238,532	252,176	252,176	242,895
7	SC85			252,505	240,235	240,119	253,976	253,855	244,599

Footnotes:

COL (5): CLASS PEAK AT 5:30pm

COL (6): CLASS 4 HOUR PEAK FROM 4:00pm-7:30pm

COL (7): ADJUSTED SUM OF COMPONENT LOADS EQUALS SYSTEM LOADS

COL (8): EQUAL TO (COL (6) / EFFICIENCY FACTOR OF 94.589304389) * 100

COL (9): EQUAL TO (COL (7) / EFFICIENCY FACTOR OF 94.589304389) * 100

COL (10): SYSTEM PEAK RESPONSIBILITY FROM 2:30pm-6:00pm

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 2 - SAMPLE TEST CUSTOMER DATA
CLASS - SC91 - Summer - 2023

LINE NO	SAMPLE STRATA	STRATIFICATION VARIABLE Annual kWh		NO OF TEST CUSTOMERS	STRAT VAR AVG PER TEST CUST	AVG NON-COIN kW PER CUST	AVG COIN kW PER CUST	COINCIDENCE FACTOR PERCENTAGE
		LOW (3)	HIGH (4)					
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)
1	NYCPB CV A	0	428,640	572	116,769	41.925	34.186	81.5408
2	Stratum B	428,641	886,800	288	617,922	336.530	322.613	95.8646
3	Stratum C	886,801	1,847,200	213	1,267,416	361.113	339.736	94.0802
4	Stratum D	1,847,201	6,145,600	108	2,865,429	603.694	567.868	94.0655
5	Stratum E	6,145,601	999,999,999	5	6,890,307	1,113.288	1,060.361	95.2459
6	91-NYCPB CV			1,186				
7	ElecHtSch A	0	999,999,999	13	527,410	101.095	86.422	85.4859
8	93-ElecHtSch			13				
9	PollCntl CV	0	999,999,999	1	201,594	66.984	29.184	43.5686
10	98-PollCntl CV			1				
11	SC91			1,200				

Footnotes:

COL (9): EQUAL TO 100 * (COL (8) / COL (7))

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 3 - ESTIMATED CLASS DEMAND DATA
CLASS - SC91 - Summer - 2023

LINE NO	SAMPLE STRATA	STRATIFICATION VARIABLE Annual kWh		EST AVG NO OF CUSTS	TOTAL ANNUAL kWh	AVG ANNUAL USE PER CUST	EST NON-COIN kW PER CUST	EST POPUL NON-COIN kW	COINCIDENCE FACTOR PERCENTAGE	EST POPUL COIN kW FOR INDIVIDUAL STRATA
(1)	(2)	LOW (3)	HIGH (4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)
1	NYCPB CV A	0	428,640	3,507	377,410,791	107,616		127,485	81.5408	103,952
2	Stratum B	428,641	886,800	744	456,073,802	613,002		155,103	95.8646	148,689
3	Stratum C	886,801	1,847,200	416	518,896,590	1,247,348		151,436	94.0802	142,471
4	Stratum D	1,847,201	6,145,600	165	461,284,484	2,795,664		102,027	94.0655	95,972
5	Stratum E	6,145,601	999,999,999	5	34,583,599	6,916,720		5,574	95.2459	5,309
6	91-NYCPB CV			4,837	1,848,249,266			541,625		496,393
7	ElecHtSch A	0	999,999,999	13	6,856,329	527,410		1,342	85.4859	1,147
8	93-ElecHtSch			13	6,856,329			1,342		1,147
9	PollCntl CV	0	999,999,999	1	201,594	201,594		67	43.5686	29
10	98-PollCntl CV			1	201,594			67		29
11	SC91			4,851	1,855,307,189			543,034		497,569

Footnotes:

COL (7): EQUAL TO COL (6) / COL (5)

COL (8): FOR NON-DEMAND METERED CLASSES, FROM RELATIONSHIP OF SAMPLED ENERGY AND DEMAND VALUES, APPLIED TO POPULATION ENERGY USAGE

COL (9): EQUAL TO COLS (5) * (8) OR BILLING DEMAND

COL (10): FROM REPORT 2

COL (11): EQUAL TO COL (9) * (COL (10) / 100)

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 4 - ESTIMATED CLASS DEMAND DATA
CLASS - SC91 - Summer - 2023

LINE NO	SAMPLE STRATA	STRATIFICATION VARIABLE		HALF HOUR kW AT TIME OF CLASS PEAK UNADJ AT CUST	4 HOUR DEMANDS-kW				
		Annual kWh			UNADJUSTED AT THE CUSTOMER	ADJUSTED AT THE CUSTOMER	UNADJUSTED AT SYSTEM INPUT	ADJUSTED AT SYSTEM INPUT	SYSTEM PEAK RESPBLTY
		LOW	HIGH						
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)
1	NYCPB CV A	0	428,640	102,614	102,917	93,721	110,283	100,428	80,312
2	Stratum B	428,641	886,800	148,689	146,185	133,127	156,647	142,655	125,375
3	Stratum C	886,801	1,847,200	140,667	141,206	128,590	151,311	137,792	117,752
4	Stratum D	1,847,201	6,145,600	95,507	95,305	86,791	102,125	93,002	87,295
5	Stratum E	6,145,601	999,999,999	5,252	5,275	5,275	5,653	5,653	5,478
6	91-NYCPB CV			492,729	490,888	447,504	526,019	479,530	416,212
7	ElecHtSch A	0	999,999,999	1,093	1,120	1,120	1,200	1,200	1,074
8	93-ElecHtSch			1,093	1,120	1,120	1,200	1,200	1,074
9	PollCntl CV	0	999,999,999	19	19	19	21	21	24
10	98-PollCntl CV			19	19	19	21	21	24
11	SC91			493,841	492,027	448,643	527,240	480,751	417,310

Footnotes:

COL (5): CLASS PEAK AT 2:00pm

COL (6): CLASS 4 HOUR PEAK FROM 11:00am-2:30pm

COL (7): ADJUSTED SUM OF COMPONENT LOADS EQUALS SYSTEM LOADS

COL (8): EQUAL TO (COL (6) / EFFICIENCY FACTOR OF 93.321464488) * 100

COL (9): EQUAL TO (COL (7) / EFFICIENCY FACTOR OF 93.321464488) * 100

COL (10): SYSTEM PEAK RESPONSIBILITY FROM 2:30pm-6:00pm

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 2 - SAMPLE TEST CUSTOMER DATA
CLASS - SC91 TOD - Summer - 2023

LINE NO	SAMPLE STRATA	STRATIFICATION VARIABLE Annual kWh		NO OF TEST CUSTOMERS	STRAT VAR AVG PER TEST CUST	AVG NON-COIN kW PER CUST	AVG COIN kW PER CUST	COINCIDENCE FACTOR PERCENTAGE
		LOW (3)	HIGH (4)					
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)
1	NYCPB TOD	0	999,999,999	89	11,283,390	2,278.482	2,221.910	97.5171
2	91-NYCPB TOD			89				
3	PollCntl TOD	0	999,999,999	8	53,600,749	8,607.600	6,316.848	73.3869
4	98-PollCntl TOD			8				
5	SC91 TOD			97				

Footnotes:

COL (9): EQUAL TO 100 * (COL (8) / COL (7))

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 3 - ESTIMATED CLASS DEMAND DATA
CLASS - SC91 TOD - Summer - 2023

LINE NO	SAMPLE STRATA	STRATIFICATION VARIABLE Annual kWh		EST AVG NO OF CUSTS	TOTAL ANNUAL kWh	AVG ANNUAL USE PER CUST	EST NON-COIN kW PER CUST	EST POPUL NON-COIN kW	COINCIDENCE FACTOR PERCENTAGE	EST POPUL COIN kW FOR INDIVIDUAL STRATA
		LOW (3)	HIGH (4)							
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)
1	NYCPB TOD	0	999,999,999	94	1,067,080,538	11,351,921		214,998	97.5171	209,660
2	91-NYCPB TOD			94	1,067,080,538			214,998		209,660
3	PollCntl TOD	0	999,999,999	15	658,561,997	43,904,133		102,213	73.3869	75,011
4	98-PollCntl TOD			15	658,561,997			102,213		75,011
5	SC91 TOD			109	1,725,642,535			317,211		284,671

Footnotes:

COL (7): EQUAL TO COL (6) / COL (5)

COL (8): FOR NON-DEMAND METERED CLASSES, FROM RELATIONSHIP OF SAMPLED ENERGY AND DEMAND VALUES, APPLIED TO POPULATION ENERGY USAGE

COL (9): EQUAL TO COLS (5) * (8) OR BILLING DEMAND

COL (10): FROM REPORT 2

COL (11): EQUAL TO COL (9) * (COL (10) / 100)

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 4 - ESTIMATED CLASS DEMAND DATA
CLASS - SC91 TOD - Summer - 2023

LINE NO	SAMPLE STRATA	STRATIFICATION VARIABLE		HALF HOUR kW AT TIME OF CLASS PEAK UNADJ AT CUST	4 HOUR DEMANDS-kW				
		Annual kWh			UNADJUSTED AT THE CUSTOMER	ADJUSTED AT THE CUSTOMER	UNADJUSTED AT SYSTEM INPUT	ADJUSTED AT SYSTEM INPUT	SYSTEM PEAK RESPBLTY
		LOW (3)	HIGH (4)						
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)
1	NYCPB TOD	0	999,999,999	206,519	208,090	190,317	221,739	202,801	196,959
2	91-NYCPB TOD			206,519	208,090	190,317	221,739	202,801	196,959
3	PollCntl TOD	0	999,999,999	72,229	72,639	66,436	77,404	70,794	71,033
4	98-PollCntl TOD			72,229	72,639	66,436	77,404	70,794	71,033
5	SC91 TOD			278,748	280,729	256,753	299,143	273,595	267,992

Footnotes:

COL (5): CLASS PEAK AT 3:00pm

COL (6): CLASS 4 HOUR PEAK FROM 12:00pm-3:30pm

COL (7): ADJUSTED SUM OF COMPONENT LOADS EQUALS SYSTEM LOADS

COL (8): EQUAL TO (COL (6) / EFFICIENCY FACTOR OF 93.844547166) * 100

COL (9): EQUAL TO (COL (7) / EFFICIENCY FACTOR OF 93.844547166) * 100

COL (10): SYSTEM PEAK RESPONSIBILITY FROM 2:30pm-6:00pm

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 2 - SAMPLE TEST CUSTOMER DATA
CLASS - SC99 - Summer - 2023

LINE NO	SAMPLE STRATA	STRATIFICATION VARIABLE Annual kWh		NO OF TEST CUSTOMERS	STRAT VAR AVG PER TEST CUST	AVG NON-COIN kW PER CUST	AVG COIN kW PER CUST	COINCIDENCE FACTOR PERCENTAGE
		LOW (3)	HIGH (4)					
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)
1		0	999,999,999	151	405,737	71.414	61.990	86.8037
2	99-CON ED ACCT			151				
3	SC99			151				

Footnotes:

COL (9): EQUAL TO 100 * (COL (8) / COL (7))

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 3 - ESTIMATED CLASS DEMAND DATA
CLASS - SC99 - Summer - 2023

LINE NO	SAMPLE STRATA	STRATIFICATION VARIABLE Annual kWh		EST AVG NO OF CUSTS	TOTAL ANNUAL kWh	AVG ANNUAL USE PER CUST	EST NON-COIN kW PER CUST	EST POPUL NON-COIN kW	COINCIDENCE FACTOR PERCENTAGE	EST POPUL COIN kW FOR INDIVIDUAL STRATA
(1)	(2)	LOW (3)	HIGH (4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)
1		0	999,999,999	214	74,342,825	347,396		13,156	86.8037	11,420
2	99-CON ED ACCT			214	74,342,825			13,156		11,420
3	SC99			214	74,342,825			13,156		11,420

Footnotes:

COL (7): EQUAL TO COL (6) / COL (5)

COL (8): FOR NON-DEMAND METERED CLASSES, FROM RELATIONSHIP OF SAMPLED ENERGY AND DEMAND VALUES, APPLIED TO POPULATION ENERGY USAGE

COL (9): EQUAL TO COLS (5) * (8) OR BILLING DEMAND

COL (10): FROM REPORT 2

COL (11): EQUAL TO COL (9) * (COL (10) / 100)

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 4 - ESTIMATED CLASS DEMAND DATA
CLASS - SC99 - Summer - 2023

LINE NO	SAMPLE STRATA	STRATIFICATION VARIABLE		HALF HOUR kW AT TIME OF CLASS PEAK UNADJ AT CUST	4 HOUR DEMANDS-kW				
		Annual kWh			UNADJUSTED AT THE CUSTOMER	ADJUSTED AT THE CUSTOMER	UNADJUSTED AT SYSTEM INPUT	ADJUSTED AT SYSTEM INPUT	SYSTEM PEAK RESPBLTY
		LOW	HIGH						
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)
1		0	999,999,999	11,409	11,310	10,344	12,122	11,087	10,822
2	99-CON ED ACCT			11,409	11,310	10,344	12,122	11,087	10,822
3	SC99			11,409	11,310	10,344	12,122	11,087	10,822

Footnotes:

COL (5): CLASS PEAK AT 1:30pm

COL (6): CLASS 4 HOUR PEAK FROM 12:00pm-3:30pm

COL (7): ADJUSTED SUM OF COMPONENT LOADS EQUALS SYSTEM LOADS

COL (8): EQUAL TO (COL (6) / EFFICIENCY FACTOR OF 93.300000000) * 100

COL (9): EQUAL TO (COL (7) / EFFICIENCY FACTOR OF 93.300000000) * 100

COL (10): SYSTEM PEAK RESPONSIBILITY FROM 2:30pm-6:00pm

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 2 - SAMPLE TEST CUSTOMER DATA
CLASS - SC01 - Winter - 2023

LINE NO	SAMPLE STRATA	STRATIFICATION VARIABLE Annual kWh		NO OF TEST CUSTOMERS	STRAT VAR AVG PER TEST CUST	AVG NON-COIN kW PER CUST	AVG COIN kW PER CUST	COINCIDENCE FACTOR PERCENTAGE
		LOW (3)	HIGH (4)					
(1)	(2)			(5)	(6)	(7)	(8)	(9)
1	Residential A	0	3,209	2,792	2,007	1.277	0.307	24.0407
2	Stratum B	3,210	4,810	1,655	3,960	1.989	0.576	28.9593
3	Stratum C	4,811	6,927	1,444	5,754	2.632	0.839	31.8769
4	Stratum D	6,928	10,870	1,198	8,536	3.714	1.287	34.6527
5	Stratum E	10,871	100,000	887	21,498	11.302	5.608	49.6195
6	Stratum F	100,001	999,999,999	310	250,987	155.284	76.367	49.1789
7	01-Residential			8,286				
8	SC01			8,286				

Footnotes:

COL (9): EQUAL TO 100 * (COL (8) / COL (7))

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 3 - ESTIMATED CLASS DEMAND DATA
CLASS - SC01 - Winter - 2023

LINE NO	SAMPLE STRATA	STRATIFICATION VARIABLE Annual kWh		EST AVG NO OF CUSTS	TOTAL ANNUAL kWh	AVG ANNUAL USE PER CUST	EST NON-COIN kW PER CUST	EST POPUL NON-COIN kW	COINCIDENCE FACTOR PERCENTAGE	EST POPUL COIN kW FOR INDIVIDUAL STRATA
(1)	(2)	LOW (3)	HIGH (4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)
1	Residential A	0	3,209	1,512,728	2,961,263,556	1,958	1.232	1,863,681	24.0407	448,042
2	Stratum B	3,210	4,810	655,374	2,587,634,095	3,948	2.006	1,314,680	28.9593	380,722
3	Stratum C	4,811	6,927	437,847	2,517,662,715	5,750	2.706	1,184,814	31.8769	377,682
4	Stratum D	6,928	10,870	297,460	2,529,037,703	8,502	3.818	1,135,702	34.6527	393,551
5	Stratum E	10,871	100,000	151,118	2,569,633,055	17,004	5.731	866,057	49.6195	429,733
6	Stratum F	100,001	999,999,999	1,109	296,303,665	267,181	71.526	79,322	49.1789	39,010
7	01-Residential			3,055,636	13,461,534,789			6,444,256		2,068,740
8	SC01			3,055,636	13,461,534,789			6,444,256		2,068,740

Footnotes:

COL (7): EQUAL TO COL (6) / COL (5)

COL (8): FOR NON-DEMAND METERED CLASSES, FROM RELATIONSHIP OF SAMPLED ENERGY AND DEMAND VALUES, APPLIED TO POPULATION ENERGY USAGE

COL (9): EQUAL TO COLS (5) * (8) OR BILLING DEMAND

COL (10): FROM REPORT 2

COL (11): EQUAL TO COL (9) * (COL (10) / 100)

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 4 - ESTIMATED CLASS DEMAND DATA
CLASS - SC01 - Winter - 2023

LINE NO	SAMPLE STRATA	STRATIFICATION VARIABLE		HALF HOUR kW AT TIME OF CLASS PEAK UNADJ AT CUST	4 HOUR DEMANDS-kW				
		Annual kWh			UNADJUSTED AT THE CUSTOMER	ADJUSTED AT THE CUSTOMER	UNADJUSTED AT SYSTEM INPUT	ADJUSTED AT SYSTEM INPUT	SYSTEM PEAK RESPBLTY
		LOW	HIGH						
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)
1	Residential A	0	3,209	446,475	437,455	444,563	468,869	476,488	438,572
2	Stratum B	3,210	4,810	380,320	373,264	379,332	400,069	406,573	372,879
3	Stratum C	4,811	6,927	376,481	370,747	376,768	397,371	403,824	377,751
4	Stratum D	6,928	10,870	393,040	386,942	393,228	414,729	421,466	394,834
5	Stratum E	10,871	100,000	429,733	419,989	426,813	450,148	457,463	430,625
6	Stratum F	100,001	999,999,999	33,020	32,466	32,991	34,797	35,360	37,936
7	01-Residential			2,059,069	2,020,863	2,053,695	2,165,983	2,201,174	2,052,597
8	SC01			2,059,069	2,020,863	2,053,695	2,165,983	2,201,174	2,052,597

Footnotes:

COL (5): CLASS PEAK AT 8:30pm

COL (6): CLASS 4 HOUR PEAK FROM 6:30pm-10:00pm

COL (7): ADJUSTED SUM OF COMPONENT LOADS EQUALS SYSTEM LOADS

COL (8): EQUAL TO (COL (6) / EFFICIENCY FACTOR OF 93.300000000) * 100

COL (9): EQUAL TO (COL (7) / EFFICIENCY FACTOR OF 93.300000000) * 100

COL (10): SYSTEM PEAK RESPONSIBILITY FROM 4:30pm-8:00pm

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 2 - SAMPLE TEST CUSTOMER DATA
CLASS - SC02 - Winter - 2023

LINE NO	SAMPLE STRATA	STRATIFICATION VARIABLE Annual kWh		NO OF TEST CUSTOMERS	STRAT VAR AVG PER TEST CUST	AVG NON-COIN kW PER CUST	AVG COIN kW PER CUST	COINCIDENCE FACTOR PERCENTAGE
		LOW (3)	HIGH (4)					
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)
1	GenSm A	0	5,814	4,247	2,286	1.446	0.373	25.7953
2	Stratum B	5,815	13,675	1,099	8,841	4.080	1.690	41.4216
3	Stratum C	13,676	999,999,999	455	25,479	12.957	5.714	44.0997
4	02-GenSmall			5,801				
5	SC02			5,801				

Footnotes:

COL (9): EQUAL TO 100 * (COL (8) / COL (7))

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 3 - ESTIMATED CLASS DEMAND DATA
CLASS - SC02 - Winter - 2023

LINE NO	SAMPLE STRATA	STRATIFICATION VARIABLE Annual kWh		EST AVG NO OF CUSTS	TOTAL ANNUAL kWh	AVG ANNUAL USE PER CUST	EST NON-COIN kW PER CUST	EST POPUL NON-COIN kW	COINCIDENCE FACTOR PERCENTAGE	EST POPUL COIN kW FOR INDIVIDUAL STRATA
(1)	(2)	LOW (3)	HIGH (4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)
1	GenSm A	0	5,814	332,114	731,898,990	2,204	1.388	460,974	25.7953	118,910
2	Stratum B	5,815	13,675	88,710	763,937,875	8,612	3.686	326,985	41.4216	135,442
3	Stratum C	13,676	999,999,999	30,974	790,417,379	25,519	7.140	221,154	44.0997	97,528
4	02-GenSmall			451,798	2,286,254,244			1,009,113		351,880
5	SC02			451,798	2,286,254,244			1,009,113		351,880

Footnotes:

COL (7): EQUAL TO COL (6) / COL (5)

COL (8): FOR NON-DEMAND METERED CLASSES, FROM RELATIONSHIP OF SAMPLED ENERGY AND DEMAND VALUES, APPLIED TO POPULATION ENERGY USAGE

COL (9): EQUAL TO COLS (5) * (8) OR BILLING DEMAND

COL (10): FROM REPORT 2

COL (11): EQUAL TO COL (9) * (COL (10) / 100)

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 4 - ESTIMATED CLASS DEMAND DATA
CLASS - SC02 - Winter - 2023

LINE NO	SAMPLE STRATA	STRATIFICATION VARIABLE		HALF HOUR kW AT TIME OF CLASS PEAK UNADJ AT CUST	4 HOUR DEMANDS-kW					SYSTEM PEAK RESPBLTY
		Annual kWh			UNADJUSTED AT THE CUSTOMER	ADJUSTED AT THE CUSTOMER	UNADJUSTED AT SYSTEM INPUT	ADJUSTED AT SYSTEM INPUT		
		LOW	HIGH							
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)	
1	GenSm A	0	5,814	110,787	112,287	112,049	120,350	120,095	124,482	
2	Stratum B	5,815	13,675	134,805	131,703	131,408	141,161	140,845	133,703	
3	Stratum C	13,676	999,999,999	95,396	90,204	89,982	96,681	96,444	88,700	
4	02-GenSmall			340,988	334,194	333,439	358,192	357,384	346,885	
5	SC02			340,988	334,194	333,439	358,192	357,384	346,885	

Footnotes:

COL (5): CLASS PEAK AT 3:30pm

COL (6): CLASS 4 HOUR PEAK FROM 2:00pm-5:30pm

COL (7): ADJUSTED SUM OF COMPONENT LOADS EQUALS SYSTEM LOADS

COL (8): EQUAL TO (COL (6) / EFFICIENCY FACTOR OF 93.300000000) * 100

COL (9): EQUAL TO (COL (7) / EFFICIENCY FACTOR OF 93.300000000) * 100

COL (10): SYSTEM PEAK RESPONSIBILITY FROM 4:30pm-8:00pm

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 2 - SAMPLE TEST CUSTOMER DATA
CLASS - SC05 - Winter - 2023

LINE NO	SAMPLE STRATA	STRATIFICATION VARIABLE Annual kWh		NO OF TEST CUSTOMERS	STRAT VAR AVG PER TEST CUST	AVG NON-COIN kW PER CUST	AVG COIN kW PER CUST	COINCIDENCE FACTOR PERCENTAGE
		LOW (3)	HIGH (4)		(6)	(7)	(8)	(9)
1	SC 05 CV	0	999,999,999	6	77,868	18.799	14.285	75.9881
2	05-Traction CV			6				
3	SC05			6				

Footnotes:

COL (9): EQUAL TO 100 * (COL (8) / COL (7))

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 3 - ESTIMATED CLASS DEMAND DATA
CLASS - SC05 - Winter - 2023

LINE NO	SAMPLE STRATA	STRATIFICATION VARIABLE Annual kWh		EST AVG NO OF CUSTS	TOTAL ANNUAL kWh	AVG ANNUAL USE PER CUST	EST NON-COIN kW PER CUST	EST POPUL NON-COIN kW	COINCIDENCE FACTOR PERCENTAGE	EST POPUL COIN kW FOR INDIVIDUAL STRATA
		LOW (3)	HIGH (4)							
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)
1	SC 05 CV	0	999,999,999	8	652,826	81,603		165	75.9881	125
2	05-Traction CV			8	652,826			165		125
3	SC05			8	652,826			165		125

Footnotes:

COL (7): EQUAL TO COL (6) / COL (5)

COL (8): FOR NON-DEMAND METERED CLASSES, FROM RELATIONSHIP OF SAMPLED ENERGY AND DEMAND VALUES, APPLIED TO POPULATION ENERGY USAGE

COL (9): EQUAL TO COLS (5) * (8) OR BILLING DEMAND

COL (10): FROM REPORT 2

COL (11): EQUAL TO COL (9) * (COL (10) / 100)

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 4 - ESTIMATED CLASS DEMAND DATA
CLASS - SC05 - Winter - 2023

LINE NO	SAMPLE STRATA	4 HOUR DEMANDS-kW							
		STRATIFICATION VARIABLE		HALF HOUR kW AT TIME OF CLASS PEAK UNADJ AT CUST	UNADJUSTED AT THE CUSTOMER	ADJUSTED AT THE CUSTOMER	UNADJUSTED AT SYSTEM INPUT	ADJUSTED AT SYSTEM INPUT	SYSTEM PEAK RESPBLTY
		Annual kWh							
		LOW (3)	HIGH (4)						
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)
1	SC 05 CV	0	999,999,999	125	122	125	131	134	124
2	05-Traction CV			125	122	125	131	134	124
3	SC05			125	122	125	131	134	124

Footnotes:

COL (5): CLASS PEAK AT 10:30pm
COL (6): CLASS 4 HOUR PEAK FROM 8:00pm-11:30pm
COL (7): ADJUSTED SUM OF COMPONENT LOADS EQUALS SYSTEM LOADS
COL (8): EQUAL TO (COL (6) / EFFICIENCY FACTOR OF 93.300000000) * 100
COL (9): EQUAL TO (COL (7) / EFFICIENCY FACTOR OF 93.300000000) * 100
COL (10): SYSTEM PEAK RESPONSIBILITY FROM 4:30pm-8:00pm

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 2 - SAMPLE TEST CUSTOMER DATA
CLASS - SC05 TOD - Winter - 2023

LINE NO	SAMPLE STRATA	STRATIFICATION VARIABLE Annual kWh		NO OF TEST CUSTOMERS	STRAT VAR AVG PER TEST CUST	AVG NON-COIN kW PER CUST	AVG COIN kW PER CUST	COINCIDENCE FACTOR PERCENTAGE
		LOW (3)	HIGH (4)					
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)
1	SC 05 TD	0	999,999,999	4	22,411,204	3,555.494	2,919.241	82.1051
2	05-Traction TOD			4				
3	SC05 TOD			4				

Footnotes:

COL (9): EQUAL TO 100 * (COL (8) / COL (7))

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 3 - ESTIMATED CLASS DEMAND DATA
CLASS - SC05 TOD - Winter - 2023

LINE NO	SAMPLE STRATA	STRATIFICATION VARIABLE Annual kWh		EST AVG NO OF CUSTS	TOTAL ANNUAL kWh	AVG ANNUAL USE PER CUST	EST NON-COIN kW PER CUST	EST POPUL NON-COIN kW	COINCIDENCE FACTOR PERCENTAGE	EST POPUL COIN kW FOR INDIVIDUAL STRATA
		LOW (3)	HIGH (4)							
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)
1	SC 05 TD	0	999,999,999	5	97,007,684	19,401,537		19,067	82.1051	15,655
2	05-Traction TOD			5	97,007,684			19,067		15,655
3	SC05 TOD			5	97,007,684			19,067		15,655

Footnotes:

COL (7): EQUAL TO COL (6) / COL (5)

COL (8): FOR NON-DEMAND METERED CLASSES, FROM RELATIONSHIP OF SAMPLED ENERGY AND DEMAND VALUES, APPLIED TO POPULATION ENERGY USAGE

COL (9): EQUAL TO COLS (5) * (8) OR BILLING DEMAND

COL (10): FROM REPORT 2

COL (11): EQUAL TO COL (9) * (COL (10) / 100)

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 4 - ESTIMATED CLASS DEMAND DATA
CLASS - SC05 TOD - Winter - 2023

LINE NO	SAMPLE STRATA	STRATIFICATION VARIABLE		HALF HOUR kW AT TIME OF CLASS PEAK UNADJ AT CUST	4 HOUR DEMANDS-kW					SYSTEM PEAK RESPBLTY
		Annual kWh			UNADJUSTED AT THE CUSTOMER	ADJUSTED AT THE CUSTOMER	UNADJUSTED AT SYSTEM INPUT	ADJUSTED AT SYSTEM INPUT		
		LOW	HIGH							
		(3)	(4)							
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)	
1	SC 05 TD	0	999,999,999	15,300	15,335	15,532	16,241	16,450	15,859	
2	05-Traction TOD			15,300	15,335	15,532	16,241	16,450	15,859	
3	SC05 TOD			15,300	15,335	15,532	16,241	16,450	15,859	

Footnotes:

COL (5): CLASS PEAK AT 12:30am

COL (6): CLASS 4 HOUR PEAK FROM 12:30am-4:00am

COL (7): ADJUSTED SUM OF COMPONENT LOADS EQUALS SYSTEM LOADS

COL (8): EQUAL TO (COL (6) / EFFICIENCY FACTOR OF 94.421864752) * 100

COL (9): EQUAL TO (COL (7) / EFFICIENCY FACTOR OF 94.421864752) * 100

COL (10): SYSTEM PEAK RESPONSIBILITY FROM 4:30pm-8:00pm

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 2 - SAMPLE TEST CUSTOMER DATA
CLASS - SC06 - Winter - 2023

LINE NO	SAMPLE STRATA	STRATIFICATION VARIABLE Annual kWh		NO OF TEST CUSTOMERS	STRAT VAR AVG PER TEST CUST	AVG NON-COIN kW PER CUST	AVG COIN kW PER CUST	COINCIDENCE FACTOR PERCENTAGE
		LOW (3)	HIGH (4)					
(1)	(2)			(5)	(6)	(7)	(8)	(9)
1	PubPriv SL	0	999,999,999	2	7,175	862.806	864.006	100.1391
2	06-PubPrivSL			2				
3	SC06			2				

Footnotes:

COL (9): EQUAL TO 100 * (COL (8) / COL (7))

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 3 - ESTIMATED CLASS DEMAND DATA
CLASS - SC06 - Winter - 2023

LINE NO	SAMPLE STRATA	STRATIFICATION VARIABLE Annual kWh		EST AVG NO OF CUSTS	TOTAL ANNUAL kWh	AVG ANNUAL USE PER CUST	EST NON-COIN kW PER CUST	EST POPUL NON-COIN kW	COINCIDENCE FACTOR PERCENTAGE	EST POPUL COIN kW FOR INDIVIDUAL STRATA
(1)	(2)	LOW (3)	HIGH (4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)
1	PubPriv SL	0	999,999,999	3,380	7,288,356	2,156	0.550	1,859	100.1391	1,862
2	06-PubPrivSL			3,380	7,288,356			1,859		1,862
3	SC06			3,380	7,288,356			1,859		1,862

Footnotes:

COL (7): EQUAL TO COL (6) / COL (5)

COL (8): FOR NON-DEMAND METERED CLASSES, FROM RELATIONSHIP OF SAMPLED ENERGY AND DEMAND VALUES, APPLIED TO POPULATION ENERGY USAGE

COL (9): EQUAL TO COLS (5) * (8) OR BILLING DEMAND

COL (10): FROM REPORT 2

COL (11): EQUAL TO COL (9) * (COL (10) / 100)

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 4 - ESTIMATED CLASS DEMAND DATA
CLASS - SC06 - Winter - 2023

LINE NO	SAMPLE STRATA	4 HOUR DEMANDS-kW							
		STRATIFICATION VARIABLE		HALF HOUR kW AT TIME OF CLASS PEAK UNADJ AT CUST	UNADJUSTED AT THE CUSTOMER	ADJUSTED AT THE CUSTOMER	UNADJUSTED AT SYSTEM INPUT	ADJUSTED AT SYSTEM INPUT	SYSTEM PEAK RESPBLTY
		Annual kWh							
		LOW (3)	HIGH (4)						
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)
1	PubPriv SL	0	999,999,999	1,862	1,860	1,860	1,994	1,994	1,885
2	06-PubPrivSL			1,862	1,860	1,860	1,994	1,994	1,885
3	SC06			1,862	1,860	1,860	1,994	1,994	1,885

Footnotes:

COL (5): CLASS PEAK AT 8:00pm

COL (6): CLASS 4 HOUR PEAK FROM 6:30pm-10:00pm

COL (7): ADJUSTED SUM OF COMPONENT LOADS EQUALS SYSTEM LOADS

COL (8): EQUAL TO (COL (6) / EFFICIENCY FACTOR OF 93.300000000) * 100

COL (9): EQUAL TO (COL (7) / EFFICIENCY FACTOR OF 93.300000000) * 100

COL (10): SYSTEM PEAK RESPONSIBILITY FROM 4:30pm-8:00pm

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 2 - SAMPLE TEST CUSTOMER DATA
CLASS - SC08 - Winter - 2023

LINE NO	SAMPLE STRATA	STRATIFICATION VARIABLE		NO OF TEST CUSTOMERS	STRAT VAR AVG PER TEST CUST	AVG NON-COIN kW PER CUST	AVG COIN kW PER CUST	COINCIDENCE FACTOR PERCENTAGE
		Avg Jun-Sep kW (A-D)						
		Max Jan-Dec kW (MHP)						
(1)	(2)	LOW (3)	HIGH (4)	(5)	(6)	(7)	(8)	(9)
1	Mult Dwell CV A	0	120	522	60	53.196	43.849	82.4291
2	Stratum B	121	220	227	168	104.642	90.638	86.6172
3	Stratum C	221	340	130	276	167.900	143.456	85.4413
4	Stratum D	341	999,999,999	74	382	6,217.372	4,414.053	70.9955
5	Stratum M	500	999,999,999	89	697	6,581.560	6,081.539	92.4027
6	08-MDWL-RED CV			1,042				
7	SC08			1,042				

Footnotes:

COL (9): EQUAL TO 100 * (COL (8) / COL (7))

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 3 - ESTIMATED CLASS DEMAND DATA
CLASS - SC08 - Winter - 2023

LINE NO	SAMPLE STRATA	STRATIFICATION VARIABLE		EST AVG NO OF CUSTS	TOTAL ANNUAL kWh	AVG ANNUAL USE PER CUST	EST NON-COIN kW PER CUST	EST POPUL NON-COIN kW	COINCIDENCE FACTOR PERCENTAGE	EST POPUL COIN kW FOR INDIVIDUAL STRATA
		Avg Jun-Sep kW (A-D) Max Jan-Dec kW (MHP)								
(1)	(2)	LOW (3)	HIGH (4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)
1	Mult Dwell CV A	0	120	816	199,824,898	244,883		34,682	82.4291	28,588
2	Stratum B	121	220	470	327,412,571	696,622		51,358	86.6172	44,485
3	Stratum C	221	340	243	281,394,654	1,158,003		41,949	85.4413	35,842
4	Stratum D	341	999,999,999	106	179,013,576	1,688,807		26,631	70.9955	18,907
5	Stratum M	500	999,999,999	200	501,904,504	2,509,523		72,758	92.4027	67,230
6	08-MDWL-RED CV			1,835	1,489,550,203			227,378		195,052
7	SC08			1,835	1,489,550,203			227,378		195,052

Footnotes:

COL (7): EQUAL TO COL (6) / COL (5)

COL (8): FOR NON-DEMAND METERED CLASSES, FROM RELATIONSHIP OF SAMPLED ENERGY AND DEMAND VALUES, APPLIED TO POPULATION ENERGY USAGE

COL (9): EQUAL TO COLS (5) * (8) OR BILLING DEMAND

COL (10): FROM REPORT 2

COL (11): EQUAL TO COL (9) * (COL (10) / 100)

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 4 - ESTIMATED CLASS DEMAND DATA
CLASS - SC08 - Winter - 2023

LINE NO	SAMPLE STRATA	4 HOUR DEMANDS-kW							
		STRATIFICATION VARIABLE		HALF HOUR kW AT TIME OF CLASS PEAK UNADJ AT CUST	UNADJUSTED AT THE CUSTOMER	ADJUSTED AT THE CUSTOMER	UNADJUSTED AT SYSTEM INPUT	ADJUSTED AT SYSTEM INPUT	SYSTEM PEAK RESPBLTY
		Avg Jun-Sep kW (A-D)	Max Jan-Dec kW (MHP)						
(1)	(2)	LOW (3)	HIGH (4)	(5)	(6)	(7)	(8)	(9)	(10)
1	Mult Dwell CV A	0	120	28,508	28,163	28,588	30,185	30,641	29,562
2	Stratum B	121	220	43,861	43,845	44,507	46,993	47,703	45,929
3	Stratum C	221	340	35,358	35,373	35,908	37,913	38,486	37,140
4	Stratum D	341	999,999,999	18,290	18,368	18,646	19,687	19,985	19,037
5	Stratum M	500	999,999,999	67,230	64,260	65,227	68,874	69,911	69,882
6	08-MDWL-RED CV			193,247	190,009	192,876	203,652	206,726	201,550
7	SC08			193,247	190,009	192,876	203,652	206,726	201,550

Footnotes:

COL (5): CLASS PEAK AT 6:30pm

COL (6): CLASS 4 HOUR PEAK FROM 6:00pm-9:30pm

COL (7): ADJUSTED SUM OF COMPONENT LOADS EQUALS SYSTEM LOADS

COL (8): EQUAL TO (COL (6) / EFFICIENCY FACTOR OF 93.300000000) * 100

COL (9): EQUAL TO (COL (7) / EFFICIENCY FACTOR OF 93.300000000) * 100

COL (10): SYSTEM PEAK RESPONSIBILITY FROM 4:30pm-8:00pm

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 2 - SAMPLE TEST CUSTOMER DATA
CLASS - SC08 TOD - Winter - 2023

LINE NO	SAMPLE STRATA	STRATIFICATION VARIABLE Annual kWh		NO OF TEST CUSTOMERS	STRAT VAR AVG PER TEST CUST	AVG NON-COIN kW PER CUST	AVG COIN kW PER CUST	COINCIDENCE FACTOR PERCENTAGE
		LOW (3)	HIGH (4)					
(1)	(2)			(5)	(6)	(7)	(8)	(9)
1	Mult Dwell TOD	0	999,999,999	21	6,086,085	798.320	739.389	92.6181
2	08-MDWL-RED TOD			21				
3	SC08 TOD			21				

Footnotes:

COL (9): EQUAL TO 100 * (COL (8) / COL (7))

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 3 - ESTIMATED CLASS DEMAND DATA
CLASS - SC08 TOD - Winter - 2023

LINE NO	SAMPLE STRATA	STRATIFICATION VARIABLE Annual kWh		EST AVG NO OF CUSTS	TOTAL ANNUAL kWh	AVG ANNUAL USE PER CUST	EST NON-COIN kW PER CUST	EST POPUL NON-COIN kW	COINCIDENCE FACTOR PERCENTAGE	EST POPUL COIN kW FOR INDIVIDUAL STRATA
		LOW (3)	HIGH (4)							
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)
1	Mult Dwell TOD	0	999,999,999	21	127,807,785	6,086,085		17,293	92.6181	16,016
2	08-MDWL-RED TOD			21	127,807,785			17,293		16,016
3	SC08 TOD			21	127,807,785			17,293		16,016

Footnotes:

COL (7): EQUAL TO COL (6) / COL (5)

COL (8): FOR NON-DEMAND METERED CLASSES, FROM RELATIONSHIP OF SAMPLED ENERGY AND DEMAND VALUES, APPLIED TO POPULATION ENERGY USAGE

COL (9): EQUAL TO COLS (5) * (8) OR BILLING DEMAND

COL (10): FROM REPORT 2

COL (11): EQUAL TO COL (9) * (COL (10) / 100)

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 4 - ESTIMATED CLASS DEMAND DATA
CLASS - SC08 TOD - Winter - 2023

LINE NO	SAMPLE STRATA	STRATIFICATION VARIABLE		HALF HOUR kW AT TIME OF CLASS PEAK UNADJ AT CUST	4 HOUR DEMANDS-kW					SYSTEM PEAK RESPBLTY
		Annual kWh			UNADJUSTED AT THE CUSTOMER	ADJUSTED AT THE CUSTOMER	UNADJUSTED AT SYSTEM INPUT	ADJUSTED AT SYSTEM INPUT		
		LOW	HIGH							
		(3)	(4)							
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)	
1	Mult Dwell TOD	0	999,999,999	16,016	15,793	16,032	16,927	17,183	16,776	
2	08-MDWL-RED TOD			16,016	15,793	16,032	16,927	17,183	16,776	
3	SC08 TOD			16,016	15,793	16,032	16,927	17,183	16,776	

Footnotes:

COL (5): CLASS PEAK AT 7:30pm

COL (6): CLASS 4 HOUR PEAK FROM 6:00pm-9:30pm

COL (7): ADJUSTED SUM OF COMPONENT LOADS EQUALS SYSTEM LOADS

COL (8): EQUAL TO (COL (6) / EFFICIENCY FACTOR OF 93.300000000) * 100

COL (9): EQUAL TO (COL (7) / EFFICIENCY FACTOR OF 93.300000000) * 100

COL (10): SYSTEM PEAK RESPONSIBILITY FROM 4:30pm-8:00pm

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 2 - SAMPLE TEST CUSTOMER DATA
CLASS - SC09 - Winter - 2023

LINE NO	SAMPLE STRATA	STRATIFICATION VARIABLE		NO OF TEST CUSTOMERS	STRAT VAR	AVG NON-COIN kW PER CUST	AVG COIN kW PER CUST	COINCIDENCE FACTOR PERCENTAGE	
		Avg Jun-Sep kW (A-E)			AVG PER				
		Max Jan-Dec kW (MHP)			TEST CUST				
(1)	(2)	LOW (3)	HIGH (4)	(5)	(6)	(7)	(8)	(9)	
1	GenLg CV A		0	17	1,854	10	9.163	5.203	56.7827
2	Stratum B		18	33	975	24	18.942	11.593	61.2026
3	Stratum C		34	70	453	47	41.801	26.086	62.4052
4	Stratum D		71	200	366	116	93.766	68.332	72.8750
5	Stratum E		201	999,999,999	191	298	220.064	179.522	81.5772
6	Stratum M		500	999,999,999	183	720	471.839	395.115	83.7394
7	09-GenLarge CV				4,022				
8	SC09				4,022				

Footnotes:

COL (9): EQUAL TO 100 * (COL (8) / COL (7))

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 3 - ESTIMATED CLASS DEMAND DATA
CLASS - SC09 - Winter - 2023

LINE NO	SAMPLE STRATA	STRATIFICATION VARIABLE		EST AVG NO OF CUSTS	TOTAL ANNUAL kWh	AVG ANNUAL USE PER CUST	EST NON-COIN kW PER CUST	EST POPUL NON-COIN kW	COINCIDENCE FACTOR PERCENTAGE	EST POPUL COIN kW FOR INDIVIDUAL STRATA
		Avg Jun-Sep kW (A-E) Max Jan-Dec kW (MHP)								
(1)	(2)	LOW (3)	HIGH (4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)
1	GenLg CV A	0	17	79,928	2,574,678,696	32,212		800,912	56.7827	454,779
2	Stratum B	18	33	30,678	2,546,865,648	83,019		631,528	61.2026	386,512
3	Stratum C	34	70	15,312	2,763,669,343	180,490		617,722	62.4052	385,491
4	Stratum D	71	200	7,218	3,576,290,706	495,468		688,764	72.8750	501,937
5	Stratum E	201	999,999,999	2,118	2,878,756,946	1,359,186		478,623	81.5772	390,447
6	Stratum M	500	999,999,999	1,018	3,262,002,070	3,204,324		558,623	83.7394	467,788
7	09-GenLarge CV			136,272	17,602,263,409			3,776,172		2,586,954
8	SC09			136,272	17,602,263,409			3,776,172		2,586,954

Footnotes:

COL (7): EQUAL TO COL (6) / COL (5)

COL (8): FOR NON-DEMAND METERED CLASSES, FROM RELATIONSHIP OF SAMPLED ENERGY AND DEMAND VALUES, APPLIED TO POPULATION ENERGY USAGE

COL (9): EQUAL TO COLS (5) * (8) OR BILLING DEMAND

COL (10): FROM REPORT 2

COL (11): EQUAL TO COL (9) * (COL (10) / 100)

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 4 - ESTIMATED CLASS DEMAND DATA
CLASS - SC09 - Winter - 2023

LINE NO	SAMPLE STRATA	4 HOUR DEMANDS-kW							
		STRATIFICATION VARIABLE		HALF HOUR kW AT TIME OF CLASS PEAK UNADJ AT CUST	UNADJUSTED AT THE CUSTOMER	ADJUSTED AT THE CUSTOMER	UNADJUSTED AT SYSTEM INPUT	ADJUSTED AT SYSTEM INPUT	SYSTEM PEAK RESPBLTY
		Avg Jun-Sep kW (A-E)	Max Jan-Dec kW (MHP)						
		LOW (3)	HIGH (4)						
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)
1	GenLg CV A	0	17	453,123	452,243	450,153	484,692	482,452	447,148
2	Stratum B	18	33	386,512	384,230	382,456	411,799	409,897	384,600
3	Stratum C	34	70	383,200	381,546	379,779	408,923	407,029	389,569
4	Stratum D	71	200	495,475	493,815	491,516	529,247	526,783	505,079
5	Stratum E	201	999,999,999	388,702	388,512	386,720	416,388	414,467	400,744
6	Stratum M	500	999,999,999	463,697	463,260	461,113	496,500	494,199	469,724
7	09-GenLarge CV			2,570,709	2,563,606	2,551,737	2,747,549	2,734,827	2,596,864
8	SC09			2,570,709	2,563,606	2,551,737	2,747,549	2,734,827	2,596,864

Footnotes:

COL (5): CLASS PEAK AT 2:30pm

COL (6): CLASS 4 HOUR PEAK FROM 1:00pm-4:30pm

COL (7): ADJUSTED SUM OF COMPONENT LOADS EQUALS SYSTEM LOADS

COL (8): EQUAL TO (COL (6) / EFFICIENCY FACTOR OF 93.305229864) * 100

COL (9): EQUAL TO (COL (7) / EFFICIENCY FACTOR OF 93.305229864) * 100

COL (10): SYSTEM PEAK RESPONSIBILITY FROM 4:30pm-8:00pm

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 2 - SAMPLE TEST CUSTOMER DATA
CLASS - SC09 TOD - Winter - 2023

LINE NO	SAMPLE STRATA	STRATIFICATION VARIABLE Annual kWh		NO OF TEST CUSTOMERS	STRAT VAR AVG PER TEST CUST	AVG NON-COIN kW PER CUST	AVG COIN kW PER CUST	COINCIDENCE FACTOR PERCENTAGE
		LOW (3)	HIGH (4)					
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)
1	GenLg TOD	0	999,999,999	686	9,998,964	2,605.797	2,161.599	82.9535
2	09-GenLarge TOD			686				
3	SC09 TOD			686				

Footnotes:

COL (9): EQUAL TO 100 * (COL (8) / COL (7))

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 3 - ESTIMATED CLASS DEMAND DATA
CLASS - SC09 TOD - Winter - 2023

LINE NO	SAMPLE STRATA	STRATIFICATION VARIABLE Annual kWh		EST AVG NO OF CUSTS	TOTAL ANNUAL kWh	AVG ANNUAL USE PER CUST	EST NON-COIN kW PER CUST	EST POPUL NON-COIN kW	COINCIDENCE FACTOR PERCENTAGE	EST POPUL COIN kW FOR INDIVIDUAL STRATA
(1)	(2)	LOW (3)	HIGH (4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)
1	GenLg TOD	0	999,999,999	689	6,925,170,992	10,051,046		1,085,194	82.9535	900,206
2	09-GenLarge TOD			689	6,925,170,992			1,085,194		900,206
3	SC09 TOD			689	6,925,170,992			1,085,194		900,206

Footnotes:

COL (7): EQUAL TO COL (6) / COL (5)

COL (8): FOR NON-DEMAND METERED CLASSES, FROM RELATIONSHIP OF SAMPLED ENERGY AND DEMAND VALUES, APPLIED TO POPULATION ENERGY USAGE

COL (9): EQUAL TO COLS (5) * (8) OR BILLING DEMAND

COL (10): FROM REPORT 2

COL (11): EQUAL TO COL (9) * (COL (10) / 100)

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 4 - ESTIMATED CLASS DEMAND DATA
CLASS - SC09 TOD - Winter - 2023

LINE NO	SAMPLE STRATA	STRATIFICATION VARIABLE		HALF HOUR kW AT TIME OF CLASS PEAK UNADJ AT CUST	4 HOUR DEMANDS-kW				
		Annual kWh			UNADJUSTED AT THE CUSTOMER	ADJUSTED AT THE CUSTOMER	UNADJUSTED AT SYSTEM INPUT	ADJUSTED AT SYSTEM INPUT	SYSTEM PEAK RESPBLTY
		LOW	HIGH						
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)
1	GenLg TOD	0	999,999,999	900,206	895,103	890,970	956,530	952,113	890,445
2	09-GenLarge TOD			900,206	895,103	890,970	956,530	952,113	890,445
3	SC09 TOD			900,206	895,103	890,970	956,530	952,113	890,445

Footnotes:

COL (5): CLASS PEAK AT 2:30pm

COL (6): CLASS 4 HOUR PEAK FROM 1:00pm-4:30pm

COL (7): ADJUSTED SUM OF COMPONENT LOADS EQUALS SYSTEM LOADS

COL (8): EQUAL TO (COL (6) / EFFICIENCY FACTOR OF 93.578186750) * 100

COL (9): EQUAL TO (COL (7) / EFFICIENCY FACTOR OF 93.578186750) * 100

COL (10): SYSTEM PEAK RESPONSIBILITY FROM 4:30pm-8:00pm

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 2 - SAMPLE TEST CUSTOMER DATA
CLASS - SC12 - Winter - 2023

LINE NO	SAMPLE STRATA	STRATIFICATION VARIABLE		NO OF TEST CUSTOMERS	STRAT VAR AVG PER TEST CUST	AVG NON-COIN kW PER CUST	AVG COIN kW PER CUST	COINCIDENCE FACTOR PERCENTAGE
		Sum Nov-Feb kWh (A)						
		Max Jan-Dec kW (MHP)						
		LOW	HIGH					
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)
1	Mult Dwell SpH CV A	0	999,999,999	330	56,332	33.298	26.455	79.4492
2	Stratum M	500	999,999,999	30	798	578.386	568.543	98.2982
3	12-MDWL-SPHT CV			360				
4	SC12			360				

Footnotes:

COL (9): EQUAL TO 100 * (COL (8) / COL (7))

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 3 - ESTIMATED CLASS DEMAND DATA
CLASS - SC12 - Winter - 2023

LINE NO	SAMPLE STRATA	STRATIFICATION VARIABLE		EST AVG NO OF CUSTS	TOTAL ANNUAL kWh	AVG ANNUAL USE PER CUST	EST NON-COIN kW PER CUST	EST POPUL NON-COIN kW	COINCIDENCE FACTOR PERCENTAGE	EST POPUL COIN kW FOR INDIVIDUAL STRATA
		Sum Nov-Feb kWh (A)								
		Max Jan-Dec kW (MHP)								
(1)	(2)	LOW (3)	HIGH (4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)
1	Mult Dwell SpH CV A	0	999,999,999	395	47,663,207	120,666		12,318	79.4492	9,787
2	Stratum M	500	999,999,999	35	82,644,750	2,361,279		19,237	98.2982	18,910
3	12-MDWL-SPHT CV			430	130,307,957			31,555		28,697
4	SC12			430	130,307,957			31,555		28,697

Footnotes:

COL (7): EQUAL TO COL (6) / COL (5)

COL (8): FOR NON-DEMAND METERED CLASSES, FROM RELATIONSHIP OF SAMPLED ENERGY AND DEMAND VALUES, APPLIED TO POPULATION ENERGY USAGE

COL (9): EQUAL TO COLS (5) * (8) OR BILLING DEMAND

COL (10): FROM REPORT 2

COL (11): EQUAL TO COL (9) * (COL (10) / 100)

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 4 - ESTIMATED CLASS DEMAND DATA
CLASS - SC12 - Winter - 2023

LINE NO	SAMPLE STRATA	4 HOUR DEMANDS-kW							
		STRATIFICATION VARIABLE		HALF HOUR kW AT TIME OF CLASS PEAK UNADJ AT CUST	UNADJUSTED AT THE CUSTOMER	ADJUSTED AT THE CUSTOMER	UNADJUSTED AT SYSTEM INPUT	ADJUSTED AT SYSTEM INPUT	SYSTEM PEAK RESPBLTY
		Sum Nov-Feb kWh (A)							
		Max Jan-Dec kW (MHP)							
		LOW (3)	HIGH (4)						
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)
1	Mult Dwell SpH CV A	0	999,999,999	9,764	9,669	9,826	10,364	10,532	10,154
2	Stratum M	500	999,999,999	18,910	18,747	19,052	20,094	20,420	19,653
3	12-MDWL-SPHT CV			28,674	28,416	28,878	30,458	30,952	29,807
4	SC12			28,674	28,416	28,878	30,458	30,952	29,807

Footnotes:

COL (5): CLASS PEAK AT 8:00pm

COL (6): CLASS 4 HOUR PEAK FROM 6:30pm-10:00pm

COL (7): ADJUSTED SUM OF COMPONENT LOADS EQUALS SYSTEM LOADS

COL (8): EQUAL TO (COL (6) / EFFICIENCY FACTOR OF 93.300000000) * 100

COL (9): EQUAL TO (COL (7) / EFFICIENCY FACTOR OF 93.300000000) * 100

COL (10): SYSTEM PEAK RESPONSIBILITY FROM 4:30pm-8:00pm

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 2 - SAMPLE TEST CUSTOMER DATA
CLASS - SC12 TOD - Winter - 2023

LINE NO	SAMPLE STRATA	STRATIFICATION VARIABLE Annual kWh		NO OF TEST CUSTOMERS	STRAT VAR AVG PER TEST CUST	AVG NON-COIN kW PER CUST	AVG COIN kW PER CUST	COINCIDENCE FACTOR PERCENTAGE
		LOW (3)	HIGH (4)					
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)
1	Mult Dwell SpH TOD	0	999,999,999	26	6,125,243	1,388.381	1,398.169	100.7050
2	12-MDWL-SPHT TOD			26				
3	SC12 TOD			26				

Footnotes:

COL (9): EQUAL TO 100 * (COL (8) / COL (7))

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 3 - ESTIMATED CLASS DEMAND DATA
CLASS - SC12 TOD - Winter - 2023

LINE NO	SAMPLE STRATA	STRATIFICATION VARIABLE Annual kWh		EST AVG NO OF CUSTS	TOTAL ANNUAL kWh	AVG ANNUAL USE PER CUST	EST NON-COIN kW PER CUST	EST POPUL NON-COIN kW	COINCIDENCE FACTOR PERCENTAGE	EST POPUL COIN kW FOR INDIVIDUAL STRATA
		LOW (3)	HIGH (4)							
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)
1	Mult Dwell SpH TOD	0	999,999,999	27	166,411,069	6,163,373		42,899	100.7050	43,201
2	12-MDWL-SPHT TOD			27	166,411,069			42,899		43,201
3	SC12 TOD			27	166,411,069			42,899		43,201

Footnotes:

COL (7): EQUAL TO COL (6) / COL (5)

COL (8): FOR NON-DEMAND METERED CLASSES, FROM RELATIONSHIP OF SAMPLED ENERGY AND DEMAND VALUES, APPLIED TO POPULATION ENERGY USAGE

COL (9): EQUAL TO COLS (5) * (8) OR BILLING DEMAND

COL (10): FROM REPORT 2

COL (11): EQUAL TO COL (9) * (COL (10) / 100)

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 4 - ESTIMATED CLASS DEMAND DATA
CLASS - SC12 TOD - Winter - 2023

LINE NO	SAMPLE STRATA	4 HOUR DEMANDS-kW							
		STRATIFICATION VARIABLE		HALF HOUR kW AT TIME OF CLASS PEAK UNADJ AT CUST	UNADJUSTED AT THE CUSTOMER	ADJUSTED AT THE CUSTOMER	UNADJUSTED AT SYSTEM INPUT	ADJUSTED AT SYSTEM INPUT	SYSTEM PEAK RESPBLTY
		Annual kWh							
		LOW (3)	HIGH (4)						
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)
1	Mult Dwell SpH TOD	0	999,999,999	43,201	42,031	42,749	45,050	45,819	43,701
2	12-MDWL-SPHT TOD			43,201	42,031	42,749	45,050	45,819	43,701
3	SC12 TOD			43,201	42,031	42,749	45,050	45,819	43,701

Footnotes:

COL (5): CLASS PEAK AT 8:00pm
COL (6): CLASS 4 HOUR PEAK FROM 7:00pm-10:30pm
COL (7): ADJUSTED SUM OF COMPONENT LOADS EQUALS SYSTEM LOADS
COL (8): EQUAL TO (COL (6) / EFFICIENCY FACTOR OF 93.300000000) * 100
COL (9): EQUAL TO (COL (7) / EFFICIENCY FACTOR OF 93.300000000) * 100
COL (10): SYSTEM PEAK RESPONSIBILITY FROM 4:30pm-8:00pm

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 2 - SAMPLE TEST CUSTOMER DATA
CLASS - SC13 TOD - Winter - 2023

LINE NO	SAMPLE STRATA	STRATIFICATION VARIABLE Annual kWh		NO OF TEST CUSTOMERS	STRAT VAR AVG PER TEST CUST	AVG NON-COIN kW PER CUST	AVG COIN kW PER CUST	COINCIDENCE FACTOR PERCENTAGE
		LOW (3)	HIGH (4)					
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)
1	Bulk Pwr TOD	0	999,999,999	1	9,111,700	8,090.000	2,130.400	26.3337
2	13-Bulk Pwr TOD			1				
3	SC13 TOD			1				

Footnotes:

COL (9): EQUAL TO 100 * (COL (8) / COL (7))

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 3 - ESTIMATED CLASS DEMAND DATA
CLASS - SC13 TOD - Winter - 2023

LINE NO	SAMPLE STRATA	STRATIFICATION VARIABLE Annual kWh		EST AVG NO OF CUSTS	TOTAL ANNUAL kWh	AVG ANNUAL USE PER CUST	EST NON-COIN kW PER CUST	EST POPUL NON-COIN kW	COINCIDENCE FACTOR PERCENTAGE	EST POPUL COIN kW FOR INDIVIDUAL STRATA
		LOW (3)	HIGH (4)							
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)
1	Bulk Pwr TOD	0	999,999,999	1	16,515,100	16,515,100		17,306	26.3337	4,557
2	13-Bulk Pwr TOD			1	16,515,100			17,306		4,557
3	SC13 TOD			1	16,515,100			17,306		4,557

Footnotes:

COL (7): EQUAL TO COL (6) / COL (5)

COL (8): FOR NON-DEMAND METERED CLASSES, FROM RELATIONSHIP OF SAMPLED ENERGY AND DEMAND VALUES, APPLIED TO POPULATION ENERGY USAGE

COL (9): EQUAL TO COLS (5) * (8) OR BILLING DEMAND

COL (10): FROM REPORT 2

COL (11): EQUAL TO COL (9) * (COL (10) / 100)

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 4 - ESTIMATED CLASS DEMAND DATA
CLASS - SC13 TOD - Winter - 2023

LINE NO	SAMPLE STRATA	4 HOUR DEMANDS-kW							
		STRATIFICATION VARIABLE		HALF HOUR kW AT TIME OF CLASS PEAK UNADJ AT CUST	UNADJUSTED AT THE CUSTOMER	ADJUSTED AT THE CUSTOMER	UNADJUSTED AT SYSTEM INPUT	ADJUSTED AT SYSTEM INPUT	SYSTEM PEAK RESPBLTY
		Annual kWh							
		LOW (3)	HIGH (4)						
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)
1	Bulk Pwr TOD	0	999,999,999	4,557	4,218	4,218	4,459	4,459	3,936
2	13-Bulk Pwr TOD			4,557	4,218	4,218	4,459	4,459	3,936
3	SC13 TOD			4,557	4,218	4,218	4,459	4,459	3,936

Footnotes:

COL (5): CLASS PEAK AT 8:00pm

COL (6): CLASS 4 HOUR PEAK FROM 6:00pm-9:30pm

COL (7): ADJUSTED SUM OF COMPONENT LOADS EQUALS SYSTEM LOADS

COL (8): EQUAL TO (COL (6) / EFFICIENCY FACTOR OF 94.600000000) * 100

COL (9): EQUAL TO (COL (7) / EFFICIENCY FACTOR OF 94.600000000) * 100

COL (10): SYSTEM PEAK RESPONSIBILITY FROM 4:30pm-8:00pm

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 2 - SAMPLE TEST CUSTOMER DATA
CLASS - SC62 - Winter - 2023

LINE NO	SAMPLE STRATA	STRATIFICATION VARIABLE Annual kWh		NO OF TEST CUSTOMERS	STRAT VAR AVG PER TEST CUST	AVG NON-COIN kW PER CUST	AVG COIN kW PER CUST	COINCIDENCE FACTOR PERCENTAGE
		LOW (3)	HIGH (4)					
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)
1	GenSm	0	999,999,999	610	8,942	2.001	1.294	64.6677
2	62-GemSmall			610				
3	SC62			610				

Footnotes:

COL (9): EQUAL TO 100 * (COL (8) / COL (7))

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 3 - ESTIMATED CLASS DEMAND DATA
CLASS - SC62 - Winter - 2023

LINE NO	SAMPLE STRATA	STRATIFICATION VARIABLE Annual kWh		EST AVG NO OF CUSTS	TOTAL ANNUAL kWh	AVG ANNUAL USE PER CUST	EST NON-COIN kW PER CUST	EST POPUL NON-COIN kW	COINCIDENCE FACTOR PERCENTAGE	EST POPUL COIN kW FOR INDIVIDUAL STRATA
(1)	(2)	LOW (3)	HIGH (4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)
1	GenSm	0	999,999,999	2,322	17,957,237	7,734	2.140	4,969	64.6677	3,213
2	62-GemSmall			2,322	17,957,237			4,969		3,213
3	SC62			2,322	17,957,237			4,969		3,213

Footnotes:

COL (7): EQUAL TO COL (6) / COL (5)

COL (8): FOR NON-DEMAND METERED CLASSES, FROM RELATIONSHIP OF SAMPLED ENERGY AND DEMAND VALUES, APPLIED TO POPULATION ENERGY USAGE

COL (9): EQUAL TO COLS (5) * (8) OR BILLING DEMAND

COL (10): FROM REPORT 2

COL (11): EQUAL TO COL (9) * (COL (10) / 100)

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 4 - ESTIMATED CLASS DEMAND DATA
CLASS - SC62 - Winter - 2023

LINE NO	SAMPLE STRATA	4 HOUR DEMANDS-kW							
		STRATIFICATION VARIABLE		HALF HOUR kW AT TIME OF CLASS PEAK UNADJ AT CUST	UNADJUSTED AT THE CUSTOMER	ADJUSTED AT THE CUSTOMER	UNADJUSTED AT SYSTEM INPUT	ADJUSTED AT SYSTEM INPUT	SYSTEM PEAK RESPBLTY
		Annual kWh							
		LOW (3)	HIGH (4)						
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)
1	GenSm	0	999,999,999	3,213	3,198	3,250	3,428	3,483	3,397
2	62-GemSmall			3,213	3,198	3,250	3,428	3,483	3,397
3	SC62			3,213	3,198	3,250	3,428	3,483	3,397

Footnotes:

COL (5): CLASS PEAK AT 7:00pm

COL (6): CLASS 4 HOUR PEAK FROM 6:30pm-10:00pm

COL (7): ADJUSTED SUM OF COMPONENT LOADS EQUALS SYSTEM LOADS

COL (8): EQUAL TO (COL (6) / EFFICIENCY FACTOR OF 93.300000000) * 100

COL (9): EQUAL TO (COL (7) / EFFICIENCY FACTOR OF 93.300000000) * 100

COL (10): SYSTEM PEAK RESPONSIBILITY FROM 4:30pm-8:00pm

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 2 - SAMPLE TEST CUSTOMER DATA
CLASS - SC65 - Winter - 2023

LINE NO	SAMPLE STRATA	STRATIFICATION VARIABLE Annual kWh		NO OF TEST CUSTOMERS	STRAT VAR AVG PER TEST CUST	AVG NON-COIN kW PER CUST	AVG COIN kW PER CUST	COINCIDENCE FACTOR PERCENTAGE
		LOW (3)	HIGH (4)					
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)
1	Traction CIS A	0	364,720	356	149,731	32.635	20.202	61.9029
2	Stratum B	364,721	1,108,160	69	552,735	85.020	71.339	83.9085
3	Stratum C	1,108,161	999,999,999	36	2,268,321	345.005	294.590	85.3872
4	65-Traction CIS			461				
5	TBIS LIRR	0	999,999,999	37	5,758,318	1,655.058	1,069.422	64.6154
6	TBIS MetNo	0	999,999,999	44	6,026,694	1,757.650	1,256.891	71.5097
7	TBIS SIRTOA	0	999,999,999	5	6,177,255	1,061.551	927.349	87.3579
8	65-Traction TBIS			86				
9	SC65			547				

Footnotes:

COL (9): EQUAL TO 100 * (COL (8) / COL (7))

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 3 - ESTIMATED CLASS DEMAND DATA
CLASS - SC65 - Winter - 2023

LINE NO	SAMPLE STRATA	STRATIFICATION VARIABLE Annual kWh		EST AVG NO OF CUSTS	TOTAL ANNUAL kWh	AVG ANNUAL USE PER CUST	EST NON-COIN kW PER CUST	EST POPUL NON-COIN kW	COINCIDENCE FACTOR PERCENTAGE	EST POPUL COIN kW FOR INDIVIDUAL STRATA
(1)	(2)	LOW (3)	HIGH (4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)
1	Traction CIS A	0	364,720	646	91,377,260	141,451		22,042	61.9029	13,645
2	Stratum B	364,721	1,108,160	203	108,445,733	534,215		17,240	83.9085	14,466
3	Stratum C	1,108,161	999,999,999	48	96,243,570	2,005,074		15,621	85.3872	13,338
4	65-Traction CIS			897	296,066,563			54,903		41,449
5	TBIS LIRR	0	999,999,999	41	244,519,531	5,963,891		46,810	64.6154	30,246
6	TBIS MetNo	0	999,999,999	45	304,171,664	6,759,370		64,515	71.5097	46,134
7	TBIS SIRTOA	0	999,999,999	7	25,980,560	3,711,509		4,846	87.3579	4,233
8	65-Traction TBIS			93	574,671,755			116,171		80,613
9	SC65			990	870,738,318			171,074		122,062

Footnotes:

COL (7): EQUAL TO COL (6) / COL (5)

COL (8): FOR NON-DEMAND METERED CLASSES, FROM RELATIONSHIP OF SAMPLED ENERGY AND DEMAND VALUES, APPLIED TO POPULATION ENERGY USAGE

COL (9): EQUAL TO COLS (5) * (8) OR BILLING DEMAND

COL (10): FROM REPORT 2

COL (11): EQUAL TO COL (9) * (COL (10) / 100)

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 4 - ESTIMATED CLASS DEMAND DATA
CLASS - SC65 - Winter - 2023

LINE NO	SAMPLE STRATA	STRATIFICATION VARIABLE		HALF HOUR kW AT TIME OF CLASS PEAK UNADJ AT CUST	4 HOUR DEMANDS-kW					SYSTEM PEAK RESPBLTY
		Annual kWh			UNADJUSTED AT THE CUSTOMER	ADJUSTED AT THE CUSTOMER	UNADJUSTED AT SYSTEM INPUT	ADJUSTED AT SYSTEM INPUT		
		LOW	HIGH							
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)	
1	Traction CIS A	0	364,720	13,597	13,443	13,566	14,278	14,408	14,408	
2	Stratum B	364,721	1,108,160	14,397	14,353	14,483	15,244	15,383	15,383	
3	Stratum C	1,108,161	999,999,999	13,289	13,174	13,294	13,992	14,119	14,119	
4	65-Traction CIS			41,283	40,970	41,343	43,514	43,910	43,910	
5	TBIS LIRR	0	999,999,999	30,246	26,854	27,088	28,521	28,770	28,770	
6	TBIS MetNo	0	999,999,999	46,134	39,762	40,117	42,231	42,608	42,608	
7	TBIS SIRTOA	0	999,999,999	3,811	3,763	3,799	3,997	4,035	4,035	
8	65-Traction TBIS			80,191	70,379	71,004	74,749	75,413	75,413	
9	SC65			121,474	111,349	112,347	118,263	119,323	119,323	

Footnotes:

COL (5): CLASS PEAK AT 6:00pm

COL (6): CLASS 4 HOUR PEAK FROM 4:30pm-8:00pm

COL (7): ADJUSTED SUM OF COMPONENT LOADS EQUALS SYSTEM LOADS

COL (8): EQUAL TO (COL (6) / EFFICIENCY FACTOR OF 94.153931177) * 100

COL (9): EQUAL TO (COL (7) / EFFICIENCY FACTOR OF 94.153931177) * 100

COL (10): SYSTEM PEAK RESPONSIBILITY FROM 4:30pm-8:00pm

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 2 - SAMPLE TEST CUSTOMER DATA
CLASS - SC66 - Winter - 2023

LINE NO	SAMPLE STRATA	STRATIFICATION VARIABLE Annual kWh		NO OF TEST CUSTOMERS	STRAT VAR AVG PER TEST CUST	AVG NON-COIN kW PER CUST	AVG COIN kW PER CUST	COINCIDENCE FACTOR PERCENTAGE
		LOW (3)	HIGH (4)					
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)
1	West SL	0	999,999,999	3	9,954,445	2,098.182	2,098.983	100.0382
2	66-WestSL			3				
3	SC66			3				

Footnotes:

COL (9): EQUAL TO 100 * (COL (8) / COL (7))

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 3 - ESTIMATED CLASS DEMAND DATA
CLASS - SC66 - Winter - 2023

LINE NO	SAMPLE STRATA	STRATIFICATION VARIABLE Annual kWh		EST AVG NO OF CUSTS	TOTAL ANNUAL kWh	AVG ANNUAL USE PER CUST	EST NON-COIN kW PER CUST	EST POPUL NON-COIN kW	COINCIDENCE FACTOR PERCENTAGE	EST POPUL COIN kW FOR INDIVIDUAL STRATA
(1)	(2)	LOW (3)	HIGH (4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)
1	West SL	0	999,999,999	1	29,967,952	29,967,952	6033.086	6,033	100.0382	6,035
2	66-WestSL			1	29,967,952			6,033		6,035
3	SC66			1	29,967,952			6,033		6,035

Footnotes:

COL (7): EQUAL TO COL (6) / COL (5)

COL (8): FOR NON-DEMAND METERED CLASSES, FROM RELATIONSHIP OF SAMPLED ENERGY AND DEMAND VALUES, APPLIED TO POPULATION ENERGY USAGE

COL (9): EQUAL TO COLS (5) * (8) OR BILLING DEMAND

COL (10): FROM REPORT 2

COL (11): EQUAL TO COL (9) * (COL (10) / 100)

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 4 - ESTIMATED CLASS DEMAND DATA
CLASS - SC66 - Winter - 2023

LINE NO	SAMPLE STRATA	STRATIFICATION VARIABLE		HALF HOUR kW AT TIME OF CLASS PEAK UNADJ AT CUST	4 HOUR DEMANDS-kW					SYSTEM PEAK RESPBLTY
		Annual kWh			UNADJUSTED AT THE CUSTOMER	ADJUSTED AT THE CUSTOMER	UNADJUSTED AT SYSTEM INPUT	ADJUSTED AT SYSTEM INPUT		
		LOW	HIGH							
		(3)	(4)							
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)	
1	West SL	0	999,999,999	6,035	6,034	6,034	6,467	6,467	6,153	
2	66-WestSL			6,035	6,034	6,034	6,467	6,467	6,153	
3	SC66			6,035	6,034	6,034	6,467	6,467	6,153	

Footnotes:

COL (5): CLASS PEAK AT 8:00pm

COL (6): CLASS 4 HOUR PEAK FROM 6:30pm-10:00pm

COL (7): ADJUSTED SUM OF COMPONENT LOADS EQUALS SYSTEM LOADS

COL (8): EQUAL TO (COL (6) / EFFICIENCY FACTOR OF 93.300000000) * 100

COL (9): EQUAL TO (COL (7) / EFFICIENCY FACTOR OF 93.300000000) * 100

COL (10): SYSTEM PEAK RESPONSIBILITY FROM 4:30pm-8:00pm

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 2 - SAMPLE TEST CUSTOMER DATA
CLASS - SC68 - Winter - 2023

LINE NO	SAMPLE STRATA	STRATIFICATION VARIABLE Annual kWh		NO OF TEST CUSTOMERS	STRAT VAR AVG PER TEST CUST	AVG NON-COIN kW PER CUST	AVG COIN kW PER CUST	COINCIDENCE FACTOR PERCENTAGE
		LOW (3)	HIGH (4)					
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)
1	MultDw CV A	0	798,800	43	413,184	62.670	51.532	82.2275
2	Stratum B	798,801	1,215,000	21	978,766	136.597	110.755	81.0816
3	Stratum C	1,215,001	1,867,600	23	1,533,990	258.213	244.344	94.6289
4	Stratum D	1,867,601	3,656,000	31	2,568,963	351.062	298.194	84.9406
5	Stratum E	3,656,001	999,999,999	5	5,008,373	787.537	722.359	91.7238
6	68-MultDw CV			123				
7	SC68			123				

Footnotes:

COL (9): EQUAL TO 100 * (COL (8) / COL (7))

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 3 - ESTIMATED CLASS DEMAND DATA
CLASS - SC68 - Winter - 2023

LINE NO	SAMPLE STRATA	STRATIFICATION VARIABLE Annual kWh		EST AVG NO OF CUSTS	TOTAL ANNUAL kWh	AVG ANNUAL USE PER CUST	EST NON-COIN kW PER CUST	EST POPUL NON-COIN kW	COINCIDENCE FACTOR PERCENTAGE	EST POPUL COIN kW FOR INDIVIDUAL STRATA
(1)	(2)	LOW (3)	HIGH (4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)
1	MultDw CV A	0	798,800	214	89,862,372	419,918		14,388	82.2275	11,831
2	Stratum B	798,801	1,215,000	105	102,270,345	974,003		15,253	81.0816	12,367
3	Stratum C	1,215,001	1,867,600	72	106,152,121	1,474,335		15,428	94.6289	14,599
4	Stratum D	1,867,601	3,656,000	42	109,906,763	2,616,828		15,389	84.9406	13,072
5	Stratum E	3,656,001	999,999,999	18	100,937,264	5,607,626		13,701	91.7238	12,567
6	68-MultDw CV			451	509,128,865			74,159		64,436
7	SC68			451	509,128,865			74,159		64,436

Footnotes:

COL (7): EQUAL TO COL (6) / COL (5)

COL (8): FOR NON-DEMAND METERED CLASSES, FROM RELATIONSHIP OF SAMPLED ENERGY AND DEMAND VALUES, APPLIED TO POPULATION ENERGY USAGE

COL (9): EQUAL TO COLS (5) * (8) OR BILLING DEMAND

COL (10): FROM REPORT 2

COL (11): EQUAL TO COL (9) * (COL (10) / 100)

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 4 - ESTIMATED CLASS DEMAND DATA
CLASS - SC68 - Winter - 2023

LINE NO	SAMPLE STRATA	STRATIFICATION VARIABLE		HALF HOUR kW AT TIME OF CLASS PEAK UNADJ AT CUST	4 HOUR DEMANDS-kW					SYSTEM PEAK RESPBLTY
		Annual kWh			UNADJUSTED AT THE CUSTOMER	ADJUSTED AT THE CUSTOMER	UNADJUSTED AT SYSTEM INPUT	ADJUSTED AT SYSTEM INPUT		
		LOW (3)	HIGH (4)							
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)	
1	MultDw CV A	0	798,800	11,831	11,683	11,873	12,515	12,719	12,165	
2	Stratum B	798,801	1,215,000	12,360	12,305	12,505	13,182	13,396	12,918	
3	Stratum C	1,215,001	1,867,600	14,558	14,482	14,717	15,513	15,765	15,134	
4	Stratum D	1,867,601	3,656,000	13,072	12,945	13,155	13,867	14,092	13,582	
5	Stratum E	3,656,001	999,999,999	12,537	12,426	12,628	13,311	13,528	12,967	
6	68-MultDw CV			64,358	63,841	64,878	68,388	69,500	66,766	
7	SC68			64,358	63,841	64,878	68,388	69,500	66,766	

Footnotes:

COL (5): CLASS PEAK AT 8:30pm

COL (6): CLASS 4 HOUR PEAK FROM 6:30pm-10:00pm

COL (7): ADJUSTED SUM OF COMPONENT LOADS EQUALS SYSTEM LOADS

COL (8): EQUAL TO (COL (6) / EFFICIENCY FACTOR OF 93.350763896) * 100

COL (9): EQUAL TO (COL (7) / EFFICIENCY FACTOR OF 93.350763896) * 100

COL (10): SYSTEM PEAK RESPONSIBILITY FROM 4:30pm-8:00pm

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 2 - SAMPLE TEST CUSTOMER DATA
CLASS - SC68 TOD - Winter - 2023

LINE NO	SAMPLE STRATA	STRATIFICATION VARIABLE Annual kWh		NO OF TEST CUSTOMERS	STRAT VAR AVG PER TEST CUST	AVG NON-COIN kW PER CUST	AVG COIN kW PER CUST	COINCIDENCE FACTOR PERCENTAGE
		LOW (3)	HIGH (4)					
(1)	(2)			(5)	(6)	(7)	(8)	(9)
1	MultDw TOD	0	999,999,999	58	7,856,517	1,100.575	943.949	85.7687
2	68-MultDw TOD			58				
3	SC68 TOD			58				

Footnotes:

COL (9): EQUAL TO 100 * (COL (8) / COL (7))

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 3 - ESTIMATED CLASS DEMAND DATA
CLASS - SC68 TOD - Winter - 2023

LINE NO	SAMPLE STRATA	STRATIFICATION VARIABLE Annual kWh		EST AVG NO OF CUSTS	TOTAL ANNUAL kWh	AVG ANNUAL USE PER CUST	EST NON-COIN kW PER CUST	EST POPUL NON-COIN kW	COINCIDENCE FACTOR PERCENTAGE	EST POPUL COIN kW FOR INDIVIDUAL STRATA
(1)	(2)	LOW (3)	HIGH (4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)
1	MultDw TOD	0	999,999,999	57	464,250,850	8,144,752		60,258	85.7687	51,683
2	68-MultDw TOD			57	464,250,850			60,258		51,683
3	SC68 TOD			57	464,250,850			60,258		51,683

Footnotes:

COL (7): EQUAL TO COL (6) / COL (5)

COL (8): FOR NON-DEMAND METERED CLASSES, FROM RELATIONSHIP OF SAMPLED ENERGY AND DEMAND VALUES, APPLIED TO POPULATION ENERGY USAGE

COL (9): EQUAL TO COLS (5) * (8) OR BILLING DEMAND

COL (10): FROM REPORT 2

COL (11): EQUAL TO COL (9) * (COL (10) / 100)

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 4 - ESTIMATED CLASS DEMAND DATA
CLASS - SC68 TOD - Winter - 2023

LINE NO	SAMPLE STRATA	4 HOUR DEMANDS-kW							
		STRATIFICATION VARIABLE		HALF HOUR kW AT TIME OF CLASS PEAK UNADJ AT CUST	UNADJUSTED AT THE CUSTOMER	ADJUSTED AT THE CUSTOMER	UNADJUSTED AT SYSTEM INPUT	ADJUSTED AT SYSTEM INPUT	SYSTEM PEAK RESPBLTY
		Annual kWh							
		LOW	HIGH						
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)
1	MultDw TOD	0	999,999,999	51,683	51,228	52,060	54,906	55,799	53,471
2	68-MultDw TOD			51,683	51,228	52,060	54,906	55,799	53,471
3	SC68 TOD			51,683	51,228	52,060	54,906	55,799	53,471

Footnotes:

COL (5): CLASS PEAK AT 8:30pm

COL (6): CLASS 4 HOUR PEAK FROM 6:30pm-10:00pm

COL (7): ADJUSTED SUM OF COMPONENT LOADS EQUALS SYSTEM LOADS

COL (8): EQUAL TO (COL (6) / EFFICIENCY FACTOR OF 93.300000000) * 100

COL (9): EQUAL TO (COL (7) / EFFICIENCY FACTOR OF 93.300000000) * 100

COL (10): SYSTEM PEAK RESPONSIBILITY FROM 4:30pm-8:00pm

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 2 - SAMPLE TEST CUSTOMER DATA
CLASS - SC69 - Winter - 2023

LINE NO	SAMPLE STRATA	STRATIFICATION VARIABLE Annual kWh		NO OF TEST CUSTOMERS	STRAT VAR AVG PER TEST CUST	AVG NON-COIN kW PER CUST	AVG COIN kW PER CUST	COINCIDENCE FACTOR PERCENTAGE
		LOW (3)	HIGH (4)					
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)
1	GenLg CV A	0	206,120	613	71,089	21.345	11.791	55.2401
2	Stratum B	206,121	545,600	264	333,335	70.521	55.050	78.0619
3	Stratum C	545,601	1,254,800	160	804,480	158.182	128.434	81.1938
4	Stratum D	1,254,801	3,034,400	95	1,911,552	335.875	278.005	82.7704
5	Stratum E	3,034,401	999,999,999	36	4,681,339	712.892	575.617	80.7439
6	69-GenLg CV			1,168				
7	SC69			1,168				

Footnotes:

COL (9): EQUAL TO 100 * (COL (8) / COL (7))

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 3 - ESTIMATED CLASS DEMAND DATA
CLASS - SC69 - Winter - 2023

LINE NO	SAMPLE STRATA	STRATIFICATION VARIABLE Annual kWh		EST AVG NO OF CUSTS	TOTAL ANNUAL kWh	AVG ANNUAL USE PER CUST	EST NON-COIN kW PER CUST	EST POPUL NON-COIN kW	COINCIDENCE FACTOR PERCENTAGE	EST POPUL COIN kW FOR INDIVIDUAL STRATA
(1)	(2)	LOW (3)	HIGH (4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)
1	GenLg CV A	0	206,120	1,462	101,119,085	69,165		27,696	55.2401	15,299
2	Stratum B	206,121	545,600	363	120,107,099	330,874		25,679	78.0619	20,046
3	Stratum C	545,601	1,254,800	180	145,404,917	807,805		29,267	81.1938	23,763
4	Stratum D	1,254,801	3,034,400	98	187,346,012	1,911,694		34,197	82.7704	28,305
5	Stratum E	3,034,401	999,999,999	37	182,595,444	4,935,012		28,002	80.7439	22,610
6	69-GenLg CV			2,140	736,572,557			144,841		110,023
7	SC69			2,140	736,572,557			144,841		110,023

Footnotes:

COL (7): EQUAL TO COL (6) / COL (5)

COL (8): FOR NON-DEMAND METERED CLASSES, FROM RELATIONSHIP OF SAMPLED ENERGY AND DEMAND VALUES, APPLIED TO POPULATION ENERGY USAGE

COL (9): EQUAL TO COLS (5) * (8) OR BILLING DEMAND

COL (10): FROM REPORT 2

COL (11): EQUAL TO COL (9) * (COL (10) / 100)

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 4 - ESTIMATED CLASS DEMAND DATA
CLASS - SC69 - Winter - 2023

LINE NO	SAMPLE STRATA	STRATIFICATION VARIABLE		HALF HOUR kW AT TIME OF CLASS PEAK UNADJ AT CUST	4 HOUR DEMANDS-kW					SYSTEM PEAK RESPBLTY
		Annual kWh			UNADJUSTED AT THE CUSTOMER	ADJUSTED AT THE CUSTOMER	UNADJUSTED AT SYSTEM INPUT	ADJUSTED AT SYSTEM INPUT		
		LOW (3)	HIGH (4)							
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)	
1	GenLg CV A	0	206,120	15,299	15,165	14,990	16,237	16,050	15,813	
2	Stratum B	206,121	545,600	20,017	19,873	19,644	21,279	21,033	18,217	
3	Stratum C	545,601	1,254,800	23,738	23,644	23,371	25,315	25,023	20,791	
4	Stratum D	1,254,801	3,034,400	28,305	27,976	27,653	29,954	29,608	26,713	
5	Stratum E	3,034,401	999,999,999	22,470	22,482	22,223	24,072	23,794	23,882	
6	69-GenLg CV			109,829	109,140	107,881	116,857	115,508	105,416	
7	SC69			109,829	109,140	107,881	116,857	115,508	105,416	

Footnotes:

COL (5): CLASS PEAK AT 10:00am

COL (6): CLASS 4 HOUR PEAK FROM 9:00am-12:30pm

COL (7): ADJUSTED SUM OF COMPONENT LOADS EQUALS SYSTEM LOADS

COL (8): EQUAL TO (COL (6) / EFFICIENCY FACTOR OF 93.396698444) * 100

COL (9): EQUAL TO (COL (7) / EFFICIENCY FACTOR OF 93.396698444) * 100

COL (10): SYSTEM PEAK RESPONSIBILITY FROM 4:30pm-8:00pm

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 2 - SAMPLE TEST CUSTOMER DATA
CLASS - SC69 TOD - Winter - 2023

LINE NO	SAMPLE STRATA	STRATIFICATION VARIABLE Annual kWh		NO OF TEST CUSTOMERS	STRAT VAR AVG PER TEST CUST	AVG NON-COIN kW PER CUST	AVG COIN kW PER CUST	COINCIDENCE FACTOR PERCENTAGE
		LOW (3)	HIGH (4)					
(1)	(2)			(5)	(6)	(7)	(8)	(9)
1	GenLg TOD A	0	20,388,000	42	8,785,354	1,404.979	1,201.180	85.4945
2	Stratum B	20,388,001	999,999,999	8	49,679,181	7,220.361	6,198.392	85.8460
3	Stratum C	0	999,999,999	2	160,622,126	20,697.493	19,649.485	94.9365
4	69-GenLg TOD			52				
5	SC69 TOD			52				

Footnotes:

COL (9): EQUAL TO 100 * (COL (8) / COL (7))

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 3 - ESTIMATED CLASS DEMAND DATA
CLASS - SC69 TOD - Winter - 2023

LINE NO	SAMPLE STRATA	STRATIFICATION VARIABLE Annual kWh		EST AVG NO OF CUSTS	TOTAL ANNUAL kWh	AVG ANNUAL USE PER CUST	EST NON-COIN kW PER CUST	EST POPUL NON-COIN kW	COINCIDENCE FACTOR PERCENTAGE	EST POPUL COIN kW FOR INDIVIDUAL STRATA
(1)	(2)	LOW (3)	HIGH (4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)
1	GenLg TOD A	0	20,388,000	42	370,325,114	8,817,265		56,524	85.4945	48,325
2	Stratum B	20,388,001	999,999,999	11	546,839,836	49,712,712		74,052	85.8460	63,571
3	Stratum C	0	999,999,999	2	323,940,565	161,970,283		42,327	94.9365	40,184
4	69-GenLg TOD			55	1,241,105,515			172,903		152,080
5	SC69 TOD			55	1,241,105,515			172,903		152,080

Footnotes:

COL (7): EQUAL TO COL (6) / COL (5)

COL (8): FOR NON-DEMAND METERED CLASSES, FROM RELATIONSHIP OF SAMPLED ENERGY AND DEMAND VALUES, APPLIED TO POPULATION ENERGY USAGE

COL (9): EQUAL TO COLS (5) * (8) OR BILLING DEMAND

COL (10): FROM REPORT 2

COL (11): EQUAL TO COL (9) * (COL (10) / 100)

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 4 - ESTIMATED CLASS DEMAND DATA
CLASS - SC69 TOD - Winter - 2023

LINE NO	SAMPLE STRATA	STRATIFICATION VARIABLE		HALF HOUR kW AT TIME OF CLASS PEAK UNADJ AT CUST	4 HOUR DEMANDS-kW				
		Annual kWh			UNADJUSTED AT THE CUSTOMER	ADJUSTED AT THE CUSTOMER	UNADJUSTED AT SYSTEM INPUT	ADJUSTED AT SYSTEM INPUT	SYSTEM PEAK RESPBLTY
		LOW (3)	HIGH (4)						
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)
1	GenLg TOD A	0	20,388,000	47,180	47,729	47,736	50,592	50,600	49,405
2	Stratum B	20,388,001	999,999,999	62,836	63,302	63,312	67,100	67,110	64,913
3	Stratum C	0	999,999,999	40,054	38,937	38,937	41,273	41,273	42,232
4	69-GenLg TOD			150,070	149,968	149,985	158,965	158,983	156,550
5	SC69 TOD			150,070	149,968	149,985	158,965	158,983	156,550

Footnotes:

COL (5): CLASS PEAK AT 6:00pm

COL (6): CLASS 4 HOUR PEAK FROM 2:30pm-6:00pm

COL (7): ADJUSTED SUM OF COMPONENT LOADS EQUALS SYSTEM LOADS

COL (8): EQUAL TO (COL (6) / EFFICIENCY FACTOR OF 94.339932216) * 100

COL (9): EQUAL TO (COL (7) / EFFICIENCY FACTOR OF 94.339932216) * 100

COL (10): SYSTEM PEAK RESPONSIBILITY FROM 4:30pm-8:00pm

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 2 - SAMPLE TEST CUSTOMER DATA
CLASS - SC80 - Winter - 2023

LINE NO	SAMPLE STRATA	STRATIFICATION VARIABLE Annual kWh		NO OF TEST CUSTOMERS	STRAT VAR AVG PER TEST CUST	AVG NON-COIN kW PER CUST	AVG COIN kW PER CUST	COINCIDENCE FACTOR PERCENTAGE
		LOW (3)	HIGH (4)					
(1)	(2)			(5)	(6)	(7)	(8)	(9)
1	NYC SL	0	999,999,999	3	61,377,605	11,873.473	11,874.861	100.0117
2	80-NYC SL			3				
3	SC80			3				

Footnotes:

COL (9): EQUAL TO 100 * (COL (8) / COL (7))

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 3 - ESTIMATED CLASS DEMAND DATA
CLASS - SC80 - Winter - 2023

LINE NO	SAMPLE STRATA	STRATIFICATION VARIABLE Annual kWh		EST AVG NO OF CUSTS	TOTAL ANNUAL kWh	AVG ANNUAL USE PER CUST	EST NON-COIN kW PER CUST	EST POPUL NON-COIN kW	COINCIDENCE FACTOR PERCENTAGE	EST POPUL COIN kW FOR INDIVIDUAL STRATA
(1)	(2)	LOW (3)	HIGH (4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)
1	NYC SL	0	999,999,999	5	159,943,666	31,988,733		33,398	100.0117	33,402
2	80-NYC SL			5	159,943,666			33,398		33,402
3	SC80			5	159,943,666			33,398		33,402

Footnotes:

COL (7): EQUAL TO COL (6) / COL (5)

COL (8): FOR NON-DEMAND METERED CLASSES, FROM RELATIONSHIP OF SAMPLED ENERGY AND DEMAND VALUES, APPLIED TO POPULATION ENERGY USAGE

COL (9): EQUAL TO COLS (5) * (8) OR BILLING DEMAND

COL (10): FROM REPORT 2

COL (11): EQUAL TO COL (9) * (COL (10) / 100)

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 4 - ESTIMATED CLASS DEMAND DATA
CLASS - SC80 - Winter - 2023

LINE NO	SAMPLE STRATA	STRATIFICATION VARIABLE		HALF HOUR kW AT TIME OF CLASS PEAK UNADJ AT CUST	4 HOUR DEMANDS-kW					SYSTEM PEAK RESPBLTY
		Annual kWh			UNADJUSTED AT THE CUSTOMER	ADJUSTED AT THE CUSTOMER	UNADJUSTED AT SYSTEM INPUT	ADJUSTED AT SYSTEM INPUT		
		LOW	HIGH							
		(3)	(4)							
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)	
1	NYC SL	0	999,999,999	33,402	33,378	33,378	35,775	35,775	33,499	
2	80-NYC SL			33,402	33,378	33,378	35,775	35,775	33,499	
3	SC80			33,402	33,378	33,378	35,775	35,775	33,499	

Footnotes:

COL (5): CLASS PEAK AT 8:00pm

COL (6): CLASS 4 HOUR PEAK FROM 6:30pm-10:00pm

COL (7): ADJUSTED SUM OF COMPONENT LOADS EQUALS SYSTEM LOADS

COL (8): EQUAL TO (COL (6) / EFFICIENCY FACTOR OF 93.300000000) * 100

COL (9): EQUAL TO (COL (7) / EFFICIENCY FACTOR OF 93.300000000) * 100

COL (10): SYSTEM PEAK RESPONSIBILITY FROM 4:30pm-8:00pm

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 2 - SAMPLE TEST CUSTOMER DATA
CLASS - SC82 - Winter - 2023

LINE NO	SAMPLE STRATA	STRATIFICATION VARIABLE Annual kWh		NO OF TEST CUSTOMERS	STRAT VAR AVG PER TEST CUST	AVG NON-COIN kW PER CUST	AVG COIN kW PER CUST	COINCIDENCE FACTOR PERCENTAGE
		LOW (3)	HIGH (4)					
(1)	(2)			(5)	(6)	(7)	(8)	(9)
1	MultDwHt	0	999,999,999	2	2,399,696	474.720	473.952	99.8382
2	82-MultDwHt			2				
3	SC82			2				

Footnotes:

COL (9): EQUAL TO 100 * (COL (8) / COL (7))

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 3 - ESTIMATED CLASS DEMAND DATA
CLASS - SC82 - Winter - 2023

LINE NO	SAMPLE STRATA	STRATIFICATION VARIABLE Annual kWh		EST AVG NO OF CUSTS	TOTAL ANNUAL kWh	AVG ANNUAL USE PER CUST	EST NON-COIN kW PER CUST	EST POPUL NON-COIN kW	COINCIDENCE FACTOR PERCENTAGE	EST POPUL COIN kW FOR INDIVIDUAL STRATA
(1)	(2)	LOW (3)	HIGH (4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)
1	MultDwHt	0	999,999,999	3	6,419,842	2,139,947		1,417	99.8382	1,415
2	82-MultDwHt			3	6,419,842			1,417		1,415
3	SC82			3	6,419,842			1,417		1,415

Footnotes:

COL (7): EQUAL TO COL (6) / COL (5)

COL (8): FOR NON-DEMAND METERED CLASSES, FROM RELATIONSHIP OF SAMPLED ENERGY AND DEMAND VALUES, APPLIED TO POPULATION ENERGY USAGE

COL (9): EQUAL TO COLS (5) * (8) OR BILLING DEMAND

COL (10): FROM REPORT 2

COL (11): EQUAL TO COL (9) * (COL (10) / 100)

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 4 - ESTIMATED CLASS DEMAND DATA
CLASS - SC82 - Winter - 2023

LINE NO	SAMPLE STRATA	4 HOUR DEMANDS-kW							
		STRATIFICATION VARIABLE		HALF HOUR kW AT TIME OF CLASS PEAK UNADJ AT CUST	UNADJUSTED AT THE CUSTOMER	ADJUSTED AT THE CUSTOMER	UNADJUSTED AT SYSTEM INPUT	ADJUSTED AT SYSTEM INPUT	SYSTEM PEAK RESPBLTY
		Annual kWh							
		LOW (3)	HIGH (4)						
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)
1	MultDwHt	0	999,999,999	1,415	1,405	1,431	1,506	1,534	1,480
2	82-MultDwHt			1,415	1,405	1,431	1,506	1,534	1,480
3	SC82			1,415	1,405	1,431	1,506	1,534	1,480

Footnotes:

COL (5): CLASS PEAK AT 8:30pm

COL (6): CLASS 4 HOUR PEAK FROM 7:30pm-11:00pm

COL (7): ADJUSTED SUM OF COMPONENT LOADS EQUALS SYSTEM LOADS

COL (8): EQUAL TO (COL (6) / EFFICIENCY FACTOR OF 93.300000000) * 100

COL (9): EQUAL TO (COL (7) / EFFICIENCY FACTOR OF 93.300000000) * 100

COL (10): SYSTEM PEAK RESPONSIBILITY FROM 4:30pm-8:00pm

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 2 - SAMPLE TEST CUSTOMER DATA
CLASS - SC85 - Winter - 2023

LINE NO	SAMPLE STRATA	STRATIFICATION VARIABLE Annual kWh		NO OF TEST CUSTOMERS	STRAT VAR AVG PER TEST CUST	AVG NON-COIN kW PER CUST	AVG COIN kW PER CUST	COINCIDENCE FACTOR PERCENTAGE
		LOW (3)	HIGH (4)					
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)
1	Substn CIS A	0	57,744	145	22,086	7.160	2.861	39.9581
2	Stratum B	57,745	142,640	49	84,990	17.990	10.970	60.9783
3	Stratum C	142,641	999,999,999	13	386,724	66.292	53.608	80.8665
4	85-Substn CIS			207				
5	Substn TBIS	0	999,999,999	213	7,373,316	1,844.923	1,326.213	71.8845
6	85-Substn TBIS			213				
7	SC85			420				

Footnotes:

COL (9): EQUAL TO 100 * (COL (8) / COL (7))

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 3 - ESTIMATED CLASS DEMAND DATA
CLASS - SC85 - Winter - 2023

LINE NO	SAMPLE STRATA	STRATIFICATION VARIABLE Annual kWh		EST AVG NO OF CUSTS	TOTAL ANNUAL kWh	AVG ANNUAL USE PER CUST	EST NON-COIN kW PER CUST	EST POPUL NON-COIN kW	COINCIDENCE FACTOR PERCENTAGE	EST POPUL COIN kW FOR INDIVIDUAL STRATA
(1)	(2)	LOW (3)	HIGH (4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)
1	Substn CIS A	0	57,744	154	3,244,951	21,071		1,097	39.9581	438
2	Stratum B	57,745	142,640	49	4,164,525	84,990		941	60.9783	574
3	Stratum C	142,641	999,999,999	14	5,230,776	373,627		880	80.8665	712
4	85-Substn CIS			217	12,640,252			2,918		1,724
5	Substn TBIS	0	999,999,999	219	1,544,954,400	7,054,586		291,160	71.8845	209,299
6	85-Substn TBIS			219	1,544,954,400			291,160		209,299
7	SC85			436	1,557,594,652			294,078		211,023

Footnotes:

COL (7): EQUAL TO COL (6) / COL (5)

COL (8): FOR NON-DEMAND METERED CLASSES, FROM RELATIONSHIP OF SAMPLED ENERGY AND DEMAND VALUES, APPLIED TO POPULATION ENERGY USAGE

COL (9): EQUAL TO COLS (5) * (8) OR BILLING DEMAND

COL (10): FROM REPORT 2

COL (11): EQUAL TO COL (9) * (COL (10) / 100)

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 4 - ESTIMATED CLASS DEMAND DATA
CLASS - SC85 - Winter - 2023

LINE NO	SAMPLE STRATA	STRATIFICATION VARIABLE		HALF HOUR kW AT TIME OF CLASS PEAK UNADJ AT CUST	4 HOUR DEMANDS-kW				
		Annual kWh			UNADJUSTED AT THE CUSTOMER	ADJUSTED AT THE CUSTOMER	UNADJUSTED AT SYSTEM INPUT	ADJUSTED AT SYSTEM INPUT	SYSTEM PEAK RESPBLTY
		LOW	HIGH						
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)
1	Substn CIS A	0	57,744	388	373	375	394	397	396
2	Stratum B	57,745	142,640	553	527	530	557	561	558
3	Stratum C	142,641	999,999,999	665	668	673	707	712	712
4	85-Substn CIS			1,606	1,568	1,578	1,658	1,670	1,666
5	Substn TBIS	0	999,999,999	209,299	196,403	196,403	207,638	207,638	207,192
6	85-Substn TBIS			209,299	196,403	196,403	207,638	207,638	207,192
7	SC85			210,905	197,971	197,981	209,296	209,308	208,858

Footnotes:

COL (5): CLASS PEAK AT 8:30am

COL (6): CLASS 4 HOUR PEAK FROM 4:00pm-7:30pm

COL (7): ADJUSTED SUM OF COMPONENT LOADS EQUALS SYSTEM LOADS

COL (8): EQUAL TO (COL (6) / EFFICIENCY FACTOR OF 94.589304389) * 100

COL (9): EQUAL TO (COL (7) / EFFICIENCY FACTOR OF 94.589304389) * 100

COL (10): SYSTEM PEAK RESPONSIBILITY FROM 4:30pm-8:00pm

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 2 - SAMPLE TEST CUSTOMER DATA
CLASS - SC91 - Winter - 2023

LINE NO	SAMPLE STRATA	STRATIFICATION VARIABLE Annual kWh		NO OF TEST CUSTOMERS	STRAT VAR AVG PER TEST CUST	AVG NON-COIN kW PER CUST	AVG COIN kW PER CUST	COINCIDENCE FACTOR PERCENTAGE
		LOW (3)	HIGH (4)					
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)
1	NYCPB CV A	0	428,640	577	116,617	40.228	25.252	62.7722
2	Stratum B	428,641	886,800	287	617,942	136.068	110.970	81.5548
3	Stratum C	886,801	1,847,200	215	1,268,295	245.155	205.474	83.8139
4	Stratum D	1,847,201	6,145,600	108	2,868,918	463.775	400.256	86.3039
5	Stratum E	6,145,601	999,999,999	5	6,890,307	939.729	843.684	89.7795
6	91-NYCPB CV			1,192				
7	ElecHtSch A	0	999,999,999	13	527,410	155.030	122.878	79.2608
8	93-ElecHtSch			13				
9	PollCntl CV	0	999,999,999	1	201,594	68.112	26.698	39.1972
10	98-PollCntl CV			1				
11	SC91			1,206				

Footnotes:

COL (9): EQUAL TO 100 * (COL (8) / COL (7))

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 3 - ESTIMATED CLASS DEMAND DATA
CLASS - SC91 - Winter - 2023

LINE NO	SAMPLE STRATA	STRATIFICATION VARIABLE Annual kWh		EST AVG NO OF CUSTS	TOTAL ANNUAL kWh	AVG ANNUAL USE PER CUST	EST NON-COIN kW PER CUST	EST POPUL NON-COIN kW	COINCIDENCE FACTOR PERCENTAGE	EST POPUL COIN kW FOR INDIVIDUAL STRATA
(1)	(2)	LOW (3)	HIGH (4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)
1	NYCPB CV A	0	428,640	3,507	377,410,791	107,616		96,183	62.7722	60,376
2	Stratum B	428,641	886,800	744	456,073,802	613,002		102,389	81.5548	83,503
3	Stratum C	886,801	1,847,200	416	518,896,590	1,247,348		99,406	83.8139	83,316
4	Stratum D	1,847,201	6,145,600	165	461,284,484	2,795,664		75,303	86.3039	64,989
5	Stratum E	6,145,601	999,999,999	5	34,583,599	6,916,720		4,746	89.7795	4,261
6	91-NYCPB CV			4,837	1,848,249,266			378,027		296,445
7	ElecHtSch A	0	999,999,999	13	6,856,329	527,410		2,097	79.2608	1,662
8	93-ElecHtSch			13	6,856,329			2,097		1,662
9	PollCntl CV	0	999,999,999	1	201,594	201,594		68	39.1972	27
10	98-PollCntl CV			1	201,594			68		27
11	SC91			4,851	1,855,307,189			380,192		298,134

Footnotes:

COL (7): EQUAL TO COL (6) / COL (5)

COL (8): FOR NON-DEMAND METERED CLASSES, FROM RELATIONSHIP OF SAMPLED ENERGY AND DEMAND VALUES, APPLIED TO POPULATION ENERGY USAGE

COL (9): EQUAL TO COLS (5) * (8) OR BILLING DEMAND

COL (10): FROM REPORT 2

COL (11): EQUAL TO COL (9) * (COL (10) / 100)

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 4 - ESTIMATED CLASS DEMAND DATA
CLASS - SC91 - Winter - 2023

LINE NO	SAMPLE STRATA	STRATIFICATION VARIABLE		HALF HOUR kW AT TIME OF CLASS PEAK UNADJ AT CUST	4 HOUR DEMANDS-kW				
		Annual kWh			UNADJUSTED AT THE CUSTOMER	ADJUSTED AT THE CUSTOMER	UNADJUSTED AT SYSTEM INPUT	ADJUSTED AT SYSTEM INPUT	SYSTEM PEAK RESPBLTY
		LOW	HIGH						
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)
1	NYCPB CV A	0	428,640	59,341	58,189	57,515	62,353	61,632	49,688
2	Stratum B	428,641	886,800	83,427	82,532	81,582	88,438	87,420	62,719
3	Stratum C	886,801	1,847,200	83,316	82,881	81,925	88,812	87,788	67,386
4	Stratum D	1,847,201	6,145,600	64,825	64,624	63,877	69,249	68,449	62,066
5	Stratum E	6,145,601	999,999,999	4,199	4,217	4,217	4,519	4,519	4,339
6	91-NYCPB CV			295,108	292,443	289,116	313,371	309,808	246,198
7	ElecHtSch A	0	999,999,999	1,662	1,644	1,644	1,761	1,761	1,466
8	93-ElecHtSch			1,662	1,644	1,644	1,761	1,761	1,466
9	PollCntl CV	0	999,999,999	24	24	24	26	26	25
10	98-PollCntl CV			24	24	24	26	26	25
11	SC91			296,794	294,111	290,784	315,158	311,595	247,689

Footnotes:

COL (5): CLASS PEAK AT 10:00am

COL (6): CLASS 4 HOUR PEAK FROM 9:00am-12:30pm

COL (7): ADJUSTED SUM OF COMPONENT LOADS EQUALS SYSTEM LOADS

COL (8): EQUAL TO (COL (6) / EFFICIENCY FACTOR OF 93.321464488) * 100

COL (9): EQUAL TO (COL (7) / EFFICIENCY FACTOR OF 93.321464488) * 100

COL (10): SYSTEM PEAK RESPONSIBILITY FROM 4:30pm-8:00pm

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 2 - SAMPLE TEST CUSTOMER DATA
CLASS - SC91 TOD - Winter - 2023

LINE NO	SAMPLE STRATA	STRATIFICATION VARIABLE Annual kWh		NO OF TEST CUSTOMERS	STRAT VAR AVG PER TEST CUST	AVG NON-COIN kW PER CUST	AVG COIN kW PER CUST	COINCIDENCE FACTOR PERCENTAGE
		LOW (3)	HIGH (4)					
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)
1	NYCPB TOD	0	999,999,999	89	11,283,390	1,674.660	1,514.576	90.4408
2	91-NYCPB TOD			89				
3	PollCntl TOD	0	999,999,999	8	53,600,749	8,719.740	6,431.328	73.7560
4	98-PollCntl TOD			8				
5	SC91 TOD			97				

Footnotes:

COL (9): EQUAL TO 100 * (COL (8) / COL (7))

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 3 - ESTIMATED CLASS DEMAND DATA
CLASS - SC91 TOD - Winter - 2023

LINE NO	SAMPLE STRATA	STRATIFICATION VARIABLE Annual kWh		EST AVG NO OF CUSTS	TOTAL ANNUAL kWh	AVG ANNUAL USE PER CUST	EST NON-COIN kW PER CUST	EST POPUL NON-COIN kW	COINCIDENCE FACTOR PERCENTAGE	EST POPUL COIN kW FOR INDIVIDUAL STRATA
(1)	(2)	LOW (3)	HIGH (4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)
1	NYCPB TOD	0	999,999,999	94	1,067,080,538	11,351,921		148,638	90.4408	134,429
2	91-NYCPB TOD			94	1,067,080,538			148,638		134,429
3	PollCntl TOD	0	999,999,999	15	658,561,997	43,904,133		103,552	73.7560	76,376
4	98-PollCntl TOD			15	658,561,997			103,552		76,376
5	SC91 TOD			109	1,725,642,535			252,190		210,805

Footnotes:

COL (7): EQUAL TO COL (6) / COL (5)

COL (8): FOR NON-DEMAND METERED CLASSES, FROM RELATIONSHIP OF SAMPLED ENERGY AND DEMAND VALUES, APPLIED TO POPULATION ENERGY USAGE

COL (9): EQUAL TO COLS (5) * (8) OR BILLING DEMAND

COL (10): FROM REPORT 2

COL (11): EQUAL TO COL (9) * (COL (10) / 100)

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 4 - ESTIMATED CLASS DEMAND DATA
CLASS - SC91 TOD - Winter - 2023

LINE NO	SAMPLE STRATA	STRATIFICATION VARIABLE		HALF HOUR kW AT TIME OF CLASS PEAK UNADJ AT CUST	4 HOUR DEMANDS-kW				
		Annual kWh			UNADJUSTED AT THE CUSTOMER	ADJUSTED AT THE CUSTOMER	UNADJUSTED AT SYSTEM INPUT	ADJUSTED AT SYSTEM INPUT	SYSTEM PEAK RESPBLTY
		LOW (3)	HIGH (4)						
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)
1	NYCPB TOD	0	999,999,999	133,871	133,764	132,039	142,538	140,699	132,932
2	91-NYCPB TOD			133,871	133,764	132,039	142,538	140,699	132,932
3	PollCntl TOD	0	999,999,999	76,169	75,641	74,665	80,602	79,563	80,581
4	98-PollCntl TOD			76,169	75,641	74,665	80,602	79,563	80,581
5	SC91 TOD			210,040	209,405	206,704	223,140	220,262	213,513

Footnotes:

COL (5): CLASS PEAK AT 11:00am

COL (6): CLASS 4 HOUR PEAK FROM 10:00am-1:30pm

COL (7): ADJUSTED SUM OF COMPONENT LOADS EQUALS SYSTEM LOADS

COL (8): EQUAL TO (COL (6) / EFFICIENCY FACTOR OF 93.844547166) * 100

COL (9): EQUAL TO (COL (7) / EFFICIENCY FACTOR OF 93.844547166) * 100

COL (10): SYSTEM PEAK RESPONSIBILITY FROM 4:30pm-8:00pm

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 2 - SAMPLE TEST CUSTOMER DATA
CLASS - SC99 - Winter - 2023

LINE NO	SAMPLE STRATA	STRATIFICATION VARIABLE Annual kWh		NO OF TEST CUSTOMERS	STRAT VAR AVG PER TEST CUST	AVG NON-COIN kW PER CUST	AVG COIN kW PER CUST	COINCIDENCE FACTOR PERCENTAGE
		LOW (3)	HIGH (4)					
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)
1		0	999,999,999	151	412,826	71.742	58.834	82.0077
2	99-CON ED ACCT			151				
3	SC99			151				

Footnotes:

COL (9): EQUAL TO 100 * (COL (8) / COL (7))

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 3 - ESTIMATED CLASS DEMAND DATA
CLASS - SC99 - Winter - 2023

LINE NO	SAMPLE STRATA	STRATIFICATION VARIABLE Annual kWh		EST AVG NO OF CUSTS	TOTAL ANNUAL kWh	AVG ANNUAL USE PER CUST	EST NON-COIN kW PER CUST	EST POPUL NON-COIN kW	COINCIDENCE FACTOR PERCENTAGE	EST POPUL COIN kW FOR INDIVIDUAL STRATA
		LOW (3)	HIGH (4)							
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)
1		0	999,999,999	214	74,342,825	347,396		14,130	82.0077	11,588
2	99-CON ED ACCT			214	74,342,825			14,130		11,588
3	SC99			214	74,342,825			14,130		11,588

Footnotes:

COL (7): EQUAL TO COL (6) / COL (5)

COL (8): FOR NON-DEMAND METERED CLASSES, FROM RELATIONSHIP OF SAMPLED ENERGY AND DEMAND VALUES, APPLIED TO POPULATION ENERGY USAGE

COL (9): EQUAL TO COLS (5) * (8) OR BILLING DEMAND

COL (10): FROM REPORT 2

COL (11): EQUAL TO COL (9) * (COL (10) / 100)

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 4 - ESTIMATED CLASS DEMAND DATA
CLASS - SC99 - Winter - 2023

LINE NO	SAMPLE STRATA	STRATIFICATION VARIABLE		HALF HOUR kW AT TIME OF CLASS PEAK UNADJ AT CUST	4 HOUR DEMANDS-kW				
		Annual kWh			UNADJUSTED AT THE CUSTOMER	ADJUSTED AT THE CUSTOMER	UNADJUSTED AT SYSTEM INPUT	ADJUSTED AT SYSTEM INPUT	SYSTEM PEAK RESPBLTY
		LOW (3)	HIGH (4)						
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)
1		0	999,999,999	11,588	11,480	11,379	12,304	12,196	11,344
2	99-CON ED ACCT			11,588	11,480	11,379	12,304	12,196	11,344
3	SC99			11,588	11,480	11,379	12,304	12,196	11,344

Footnotes:

COL (5): CLASS PEAK AT 9:00am

COL (6): CLASS 4 HOUR PEAK FROM 7:30am-11:00am

COL (7): ADJUSTED SUM OF COMPONENT LOADS EQUALS SYSTEM LOADS

COL (8): EQUAL TO (COL (6) / EFFICIENCY FACTOR OF 93.300000000) * 100

COL (9): EQUAL TO (COL (7) / EFFICIENCY FACTOR OF 93.300000000) * 100

COL (10): SYSTEM PEAK RESPONSIBILITY FROM 4:30pm-8:00pm

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 5 - CLASS KWH DATA - SALES & DISTRIBUTED
YEAR - 2023

LINE NO	TYPE	CUSTOMER CLASS	DISTRIBUTION SYSTEM COMPONENT	kWh AT THE CUSTOMER	EFFICIENCY	kWh DISTRIBUTED
(1)	(2)	(3)	(4)	(5)	(6)	(7)
1	1-CONED	01-RESI-RELIG	Low	13,461,534,789	93.300000000	14,428,225,926
2	1-CONED	01-RESI-RELIG	High	0	94.600000000	0
3	1-CONED		Total	13,461,534,789	93.300000000	14,428,225,926
4	1-CONED	02-GENSM	Low	2,286,254,244	93.300000000	2,450,433,273
5	1-CONED	02-GENSM	High	0	94.600000000	0
6	1-CONED		Total	2,286,254,244	93.300000000	2,450,433,273
7	1-CONED	05-TRACT-CV	Low	652,826	93.300000000	699,706
8	1-CONED	05-TRACT-CV	High	0	94.600000000	0
9	1-CONED		Total	652,826	93.300000000	699,706
10	1-CONED	05-TRACT-TD	Low	13,134,713	93.300000000	14,077,935
11	1-CONED	05-TRACT-TD	High	83,872,971	94.600000000	88,660,646
12	1-CONED		Total	97,007,684	94.421864752	102,738,581
13	1-CONED	06-PUB-PRIV-STL	Low	7,288,356	93.300000000	7,811,743
14	1-CONED	06-PUB-PRIV-STL	High	0	94.600000000	0
15	1-CONED		Total	7,288,356	93.300000000	7,811,743

Footnotes:

COL (6): EQUAL TO COL (4) / (COL (5) / 100)

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 5 - CLASS KWH DATA - SALES & DISTRIBUTED
YEAR - 2023

LINE NO	TYPE	CUSTOMER CLASS	DISTRIBUTION SYSTEM COMPONENT	kWh AT THE CUSTOMER	EFFICIENCY	kWh DISTRIBUTED
(1)	(2)	(3)	(4)	(5)	(6)	(7)
16	1-CONED	08-MDWL-RED-CV	Low	1,489,550,203	93.300000000	1,596,516,831
17	1-CONED	08-MDWL-RED-CV	High	0	94.600000000	0
18	1-CONED		Total	1,489,550,203	93.300000000	1,596,516,831
19	1-CONED	08-MDWL-RED-TD	Low	127,807,785	93.300000000	136,985,836
20	1-CONED	08-MDWL-RED-TD	High	0	94.600000000	0
21	1-CONED		Total	127,807,785	93.300000000	136,985,836
22	1-CONED	09-GENLG-CV	Low	17,530,467,302	93.300000000	18,789,354,021
23	1-CONED	09-GENLG-CV	High	71,796,107	94.600000000	75,894,405
24	1-CONED		Total	17,602,263,409	93.305229864	18,865,248,426
25	1-CONED	09-GENLG-TD	Low	5,427,073,405	93.300000000	5,816,798,934
26	1-CONED	09-GENLG-TD	High	1,498,097,587	94.600000000	1,583,612,671
27	1-CONED		Total	6,925,170,992	93.578186750	7,400,411,605
28	1-CONED	12-MDWL-SPHT-CV	Low	130,307,957	93.300000000	139,665,549
29	1-CONED	12-MDWL-SPHT-CV	High	0	94.600000000	0
30	1-CONED		Total	130,307,957	93.300000000	139,665,549

Footnotes:

COL (6): EQUAL TO COL (4) / (COL (5) / 100)

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 5 - CLASS KWH DATA - SALES & DISTRIBUTED
YEAR - 2023

LINE NO	TYPE	CUSTOMER CLASS	DISTRIBUTION SYSTEM COMPONENT	kWh AT THE CUSTOMER	EFFICIENCY	kWh DISTRIBUTED
(1)	(2)	(3)	(4)	(5)	(6)	(7)
31	1-CONED	12-MDWL-SPHT-TD	Low	166,411,069	93.300000000	178,361,274
32	1-CONED	12-MDWL-SPHT-TD	High	0	94.600000000	0
33	1-CONED		Total	166,411,069	93.300000000	178,361,274
34	1-CONED	13-BLK-POWER-TD	Low	0	93.300000000	0
35	1-CONED	13-BLK-POWER-TD	High	16,515,100	94.600000000	17,457,822
36	1-CONED		Total	16,515,100	94.600000000	17,457,822
37	1-CONED	99-CON ED ACCT	Low	74,342,825	93.300000000	79,681,484
38	1-CONED	99-CON ED ACCT	High	0	94.600000000	0
39	1-CONED		Total	74,342,825	93.300000000	79,681,484
40	1-CONED			42,385,107,239		45,404,238,056
41	2-NYPA	62-GENSM-CV	Low	17,957,237	93.300000000	19,246,771
42	2-NYPA	62-GENSM-CV	High	0	94.600000000	0
43	2-NYPA		Total	17,957,237	93.300000000	19,246,771
44	2-NYPA	65-TRACTN	Low	296,066,563	93.300000000	317,327,506
45	2-NYPA	65-TRACTN	High	574,671,755	94.600000000	607,475,428
46	2-NYPA		Total	870,738,318	94.153931177	924,802,934
47	2-NYPA	66-WEST-STL	Low	29,967,952	93.300000000	32,119,991
48	2-NYPA	66-WEST-STL	High	0	94.600000000	0
49	2-NYPA		Total	29,967,952	93.300000000	32,119,991

Footnotes:

COL (6): EQUAL TO COL (4) / (COL (5) / 100)

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 5 - CLASS KWH DATA - SALES & DISTRIBUTED
YEAR - 2023

LINE NO	TYPE	CUSTOMER CLASS	DISTRIBUTION SYSTEM COMPONENT	kWh AT THE CUSTOMER	EFFICIENCY	kWh DISTRIBUTED
(1)	(2)	(3)	(4)	(5)	(6)	(7)
50	2-NYPA	68-MDWL-CV	Low	488,981,796	93.300000000	524,096,244
51	2-NYPA	68-MDWL-CV	High	20,147,069	94.600000000	21,297,113
52	2-NYPA		Total	509,128,865	93.350763896	545,393,357
53	2-NYPA	68-MDWL-TD	Low	464,250,850	93.300000000	497,589,335
54	2-NYPA	68-MDWL-TD	High	0	94.600000000	0
55	2-NYPA		Total	464,250,850	93.300000000	497,589,335
56	2-NYPA	69-GENLG-CV	Low	681,077,911	93.300000000	729,987,043
57	2-NYPA	69-GENLG-CV	High	55,494,646	94.600000000	58,662,416
58	2-NYPA		Total	736,572,557	93.396698444	788,649,459
59	2-NYPA	69-GENLG-TD	Low	245,548,933	93.300000000	263,182,136
60	2-NYPA	69-GENLG-TD	High	995,556,582	94.600000000	1,052,385,393
61	2-NYPA		Total	1,241,105,515	94.339932216	1,315,567,529
62	2-NYPA	80-NYC-STL	Low	159,943,666	93.300000000	171,429,438
63	2-NYPA	80-NYC-STL	High	0	94.600000000	0
64	2-NYPA		Total	159,943,666	93.300000000	171,429,438

Footnotes:

COL (6): EQUAL TO COL (4) / (COL (5) / 100)

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 5 - CLASS KWH DATA - SALES & DISTRIBUTED
YEAR - 2023

LINE NO	TYPE	CUSTOMER CLASS	DISTRIBUTION SYSTEM COMPONENT	kWh AT THE CUSTOMER	EFFICIENCY	kWh DISTRIBUTED
(1)	(2)	(3)	(4)	(5)	(6)	(7)
65	2-NYPA	82-MDWL-HT-CV	Low	6,419,842	93.300000000	6,880,860
66	2-NYPA	82-MDWL-HT-CV	High	0	94.600000000	0
67	2-NYPA		Total	6,419,842	93.300000000	6,880,860
68	2-NYPA	85-SUBST	Low	12,640,252	93.300000000	13,547,966
69	2-NYPA	85-SUBST	High	1,544,954,400	94.600000000	1,633,144,186
70	2-NYPA		Total	1,557,594,652	94.589304389	1,646,692,152
71	2-NYPA	91-NYCPB-CV	Low	1,824,254,281	93.300000000	1,955,256,464
72	2-NYPA	91-NYCPB-CV	High	31,052,908	94.600000000	32,825,484
73	2-NYPA		Total	1,855,307,189	93.321464488	1,988,081,948
74	2-NYPA	91-NYCPB-TD	Low	996,982,242	93.300000000	1,068,576,894
75	2-NYPA	91-NYCPB-TD	High	728,660,293	94.600000000	770,254,010
76	2-NYPA		Total	1,725,642,535	93.844547166	1,838,830,904
77	2-NYPA			9,174,629,178		9,775,284,678
78	Sales to Other Utilities		Interchg 60 Cyc	525,274,087	98.280000000	534,466,384
79	Sales to Other Utilities		Total	525,274,087		534,466,384
80	Grand Total			55,713,989,118		55,713,989,118
81	Other Losses					(811,729,734)
82	Other Losses		Total			(811,729,734)
83	Total System					54,902,259,384

Footnotes:

COL (6): EQUAL TO COL (4) / (COL (5) / 100)



CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 6 - CLASS DEMAND SUMMARY - 2023

LINE NO (1)	CUSTOMER CLASS (2)	SEASON (3)	NON-COIN kW (4)	HALF HOUR DEMAND AT TIME OF CLASS PEAK UNADJUSTED AT CUST-kW (5)	4 HOUR DEMANDS-kW		
					ADJUSTED AT THE CUSTOMER (6)	ADJUSTED AT SYSTEM INPUT (7)	SYSTEM PEAK RESPBLTY (8)
1	01-RESI-RELIG	Summer2023	9,552,675	4,301,973	3,943,227	4,226,395	3,914,073
2	01-RESI-RELIG	Winter2023	6,444,256	2,059,069	2,053,695	2,201,174	2,052,597
3	02-GENSM	Summer2023	1,057,077	474,963	433,823	464,978	463,053
4	02-GENSM	Winter2023	1,009,113	340,988	333,439	357,384	346,885
5	05-TRACT-CV	Summer2023	90	58	52	56	55
6	05-TRACT-CV	Winter2023	165	125	125	134	124
7	05-TRACT-TD	Summer2023	19,319	14,729	13,638	14,444	14,317
8	05-TRACT-TD	Winter2023	19,067	15,300	15,532	16,450	15,859
9	06-PUB-PRIV-STL	Summer2023	1,484	1,483	1,479	1,585	3
10	06-PUB-PRIV-STL	Winter2023	1,859	1,862	1,860	1,994	1,885

Footnotes:

COL (4) : FROM REPORT 3 COL (9)
COL (5) : FROM REPORT 4 COL (5)
COL (6) : FROM REPORT 4 COL (7)
COL (7) : FROM REPORT 4 COL (9)
COL (8) : FROM REPORT 4 COL (10)

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 6 - CLASS DEMAND SUMMARY - 2023

LINE NO	CUSTOMER CLASS	SEASON	NON-COIN kW	HALF HOUR DEMAND AT TIME OF CLASS PEAK UNADJUSTED AT CUST-kW	4 HOUR DEMANDS-kW		
					ADJUSTED AT THE CUSTOMER	ADJUSTED AT SYSTEM INPUT	SYSTEM PEAK RESPBLTY
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)
11	08-MDWL-RED-CV	Summer2023	386,484	371,601	344,559	369,303	360,625
12	08-MDWL-RED-CV	Winter2023	227,378	193,247	192,876	206,726	201,550
13	08-MDWL-RED-TD	Summer2023	29,997	29,722	27,597	29,579	28,682
14	08-MDWL-RED-TD	Winter2023	17,293	16,016	16,032	17,183	16,776
15	09-GENLG-CV	Summer2023	4,573,234	3,720,404	3,402,337	3,646,460	3,578,355
16	09-GENLG-CV	Winter2023	3,776,172	2,570,709	2,551,737	2,734,827	2,596,864
17	09-GENLG-TD	Summer2023	1,493,690	1,356,632	1,227,362	1,311,589	1,300,953
18	09-GENLG-TD	Winter2023	1,085,194	900,206	890,970	952,113	890,445
19	12-MDWL-SPHT-CV	Summer2023	21,414	19,033	17,746	19,020	18,410
20	12-MDWL-SPHT-CV	Winter2023	31,555	28,674	28,878	30,952	29,807

Footnotes:

COL (4) : FROM REPORT 3 COL (9)
COL (5) : FROM REPORT 4 COL (5)
COL (6) : FROM REPORT 4 COL (7)
COL (7) : FROM REPORT 4 COL (9)
COL (8) : FROM REPORT 4 COL (10)

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 6 - CLASS DEMAND SUMMARY - 2023

LINE NO	CUSTOMER CLASS	SEASON	NON-COIN kW	HALF HOUR DEMAND AT TIME OF CLASS PEAK UNADJUSTED AT CUST-kW	4 HOUR DEMANDS-kW		
					ADJUSTED AT THE CUSTOMER	ADJUSTED AT SYSTEM INPUT	SYSTEM PEAK RESPBLTY
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)
21	12-MDWL-SPHT-TD	Summer2023	25,978	25,950	23,771	25,478	24,598
22	12-MDWL-SPHT-TD	Winter2023	42,899	43,201	42,749	45,819	43,701
23	13-BLK-POWER-TD	Summer2023	8,748	133	45	47	45
24	13-BLK-POWER-TD	Winter2023	17,306	4,557	4,218	4,459	3,936
25	62-GENSM-CV	Summer2023	3,973	2,051	1,869	2,003	1,932
26	62-GENSM-CV	Winter2023	4,969	3,213	3,250	3,483	3,397
27	65-TRACTN	Summer2023	179,972	117,419	101,056	107,333	98,931
28	65-TRACTN	Winter2023	171,074	121,474	112,347	119,323	119,323
29	66-WEST-STL	Summer2023	6,638	6,637	6,632	7,109	754
30	66-WEST-STL	Winter2023	6,033	6,035	6,034	6,467	6,153

Footnotes:

COL (4) : FROM REPORT 3 COL (9)
COL (5) : FROM REPORT 4 COL (5)
COL (6) : FROM REPORT 4 COL (7)
COL (7) : FROM REPORT 4 COL (9)
COL (8) : FROM REPORT 4 COL (10)

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 6 - CLASS DEMAND SUMMARY - 2023

LINE NO	CUSTOMER CLASS	SEASON	NON-COIN kW	HALF HOUR DEMAND AT TIME OF CLASS PEAK UNADJUSTED AT CUST-kW	4 HOUR DEMANDS-kW			SYSTEM PEAK RESPBLTY
					ADJUSTED AT THE CUSTOMER	ADJUSTED AT SYSTEM INPUT		
(1)	(2)	(3)	(4)	(5)	(6)	(7)		(8)
31	68-MDWL-CV	Summer2023	113,575	111,992	103,455	110,825		105,883
32	68-MDWL-CV	Winter2023	74,159	64,358	64,878	69,500		66,766
33	68-MDWL-TD	Summer2023	103,686	106,887	98,712	105,800		100,763
34	68-MDWL-TD	Winter2023	60,258	51,683	52,060	55,799		53,471
35	69-GENLG-CV	Summer2023	174,265	145,681	131,917	141,244		132,856
36	69-GENLG-CV	Winter2023	144,841	109,829	107,881	115,508		105,416
37	69-GENLG-TD	Summer2023	225,073	203,247	189,172	200,523		199,540
38	69-GENLG-TD	Winter2023	172,903	150,070	149,985	158,983		156,550
39	80-NYC-STL	Summer2023	33,639	33,623	33,564	35,974		8,310
40	80-NYC-STL	Winter2023	33,398	33,402	33,378	35,775		33,499

Footnotes:

COL (4) : FROM REPORT 3 COL (9)
COL (5) : FROM REPORT 4 COL (5)
COL (6) : FROM REPORT 4 COL (7)
COL (7) : FROM REPORT 4 COL (9)
COL (8) : FROM REPORT 4 COL (10)

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 6 - CLASS DEMAND SUMMARY - 2023

LINE NO	CUSTOMER CLASS	SEASON	NON-COIN kW	HALF HOUR DEMAND AT TIME OF CLASS PEAK UNADJUSTED AT CUST-kW	4 HOUR DEMANDS-kW		
					ADJUSTED AT THE CUSTOMER	ADJUSTED AT SYSTEM INPUT	SYSTEM PEAK RESPBLTY
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)
41	82-MDWL-HT-CV	Summer2023	829	849	783	839	822
42	82-MDWL-HT-CV	Winter2023	1,417	1,415	1,431	1,534	1,480
43	85-SUBST	Summer2023	336,467	252,505	240,119	253,855	244,599
44	85-SUBST	Winter2023	294,078	210,905	197,981	209,308	208,858
45	91-NYCPB-CV	Summer2023	543,034	493,841	448,643	480,751	417,310
46	91-NYCPB-CV	Winter2023	380,192	296,794	290,784	311,595	247,689
47	91-NYCPB-TD	Summer2023	317,211	278,748	256,753	273,595	267,992
48	91-NYCPB-TD	Winter2023	252,190	210,040	206,704	220,262	213,513
49	99-CON ED ACCT	Summer2023	13,156	11,409	10,344	11,087	10,822
50	99-CON ED ACCT	Winter2023	14,130	11,588	11,379	12,196	11,344
51	Total System	Summer2023	19,221,708	12,081,570	11,058,655	11,839,872	11,293,683
52	Total System	Winter2023	14,281,899	7,444,760	7,370,203	7,888,948	7,427,888

Footnotes:

COL (4) : FROM REPORT 3 COL (9)
COL (5) : FROM REPORT 4 COL (5)
COL (6) : FROM REPORT 4 COL (7)
COL (7) : FROM REPORT 4 COL (9)
COL (8) : FROM REPORT 4 COL (10)

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 6A - LOW TENSION NON-COINCIDENT kW
BASED ON LOW TENSION KWH - 2023

LINE NO	CUSTOMER CLASS	SEASON	TOTAL kWh	LOW TENSION kWh	TOTAL NON-COIN kW	LOW TENSION kWh
(1)	(2)	(3)	(4)	(5)	(6)	(7)
1	01-RESI-RELIG	Summer2023	13,461,534,789	13,461,534,789	9,552,675	9,552,675
2	01-RESI-RELIG	Winter2023	13,461,534,789	13,461,534,789	6,444,256	6,444,256
3	02-GENSM	Summer2023	2,286,254,244	2,286,254,244	1,057,077	1,057,077
4	02-GENSM	Winter2023	2,286,254,244	2,286,254,244	1,009,113	1,009,113
5	05-TRACT-CV	Summer2023	652,826	652,826	90	90
6	05-TRACT-CV	Winter2023	652,826	652,826	165	165
7	05-TRACT-TD	Summer2023	97,007,684	13,134,713	19,319	2,616
8	05-TRACT-TD	Winter2023	97,007,684	13,134,713	19,067	2,582
9	06-PUB-PRIV-STL	Summer2023	7,288,356	7,288,356	1,484	1,484
10	06-PUB-PRIV-STL	Winter2023	7,288,356	7,288,356	1,859	1,859

Footnotes:

COL (7) = (COL (5) / COL(4)) * COL (6)

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 6A - LOW TENSION NON-COINCIDENT kW
BASED ON LOW TENSION KWH - 2023

LINE NO	CUSTOMER CLASS	SEASON	TOTAL kWh	LOW TENSION kWh	TOTAL NON-COIN kW	LOW TENSION kWh
(1)	(2)	(3)	(4)	(5)	(6)	(7)
11	08-MDWL-RED-CV	Summer2023	1,489,550,203	1,489,550,203	386,484	386,484
12	08-MDWL-RED-CV	Winter2023	1,489,550,203	1,489,550,203	227,378	227,378
13	08-MDWL-RED-TD	Summer2023	127,807,785	127,807,785	29,997	29,997
14	08-MDWL-RED-TD	Winter2023	127,807,785	127,807,785	17,293	17,293
15	09-GENLG-CV	Summer2023	17,602,263,409	17,530,467,302	4,573,234	4,554,581
16	09-GENLG-CV	Winter2023	17,602,263,409	17,530,467,302	3,776,172	3,760,770
17	09-GENLG-TD	Summer2023	6,925,170,992	5,427,073,405	1,493,690	1,170,565
18	09-GENLG-TD	Winter2023	6,925,170,992	5,427,073,405	1,085,194	850,438
19	12-MDWL-SPHT-CV	Summer2023	130,307,957	130,307,957	21,414	21,414
20	12-MDWL-SPHT-CV	Winter2023	130,307,957	130,307,957	31,555	31,555

Footnotes:

COL (7) = (COL (5) / COL(4)) * COL (6)

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 6A - LOW TENSION NON-COINCIDENT kW
BASED ON LOW TENSION KWH - 2023

LINE NO	CUSTOMER CLASS	SEASON	TOTAL kWh	LOW TENSION kWh	TOTAL NON-COIN kW	LOW TENSION kWh
(1)	(2)	(3)	(4)	(5)	(6)	(7)
21	12-MDWL-SPHT-TD	Summer2023	166,411,069	166,411,069	25,978	25,978
22	12-MDWL-SPHT-TD	Winter2023	166,411,069	166,411,069	42,899	42,899
23	13-BLK-POWER-TD	Summer2023	16,515,100	0	8,748	0
24	13-BLK-POWER-TD	Winter2023	16,515,100	0	17,306	0
25	62-GENSM-CV	Summer2023	17,957,237	17,957,237	3,973	3,973
26	62-GENSM-CV	Winter2023	17,957,237	17,957,237	4,969	4,969
27	65-TRACTN	Summer2023	870,738,318	296,066,563	179,972	61,194
28	65-TRACTN	Winter2023	870,738,318	296,066,563	171,074	58,168
29	66-WEST-STL	Summer2023	29,967,952	29,967,952	6,638	6,638
30	66-WEST-STL	Winter2023	29,967,952	29,967,952	6,033	6,033

Footnotes:

COL (7) = (COL (5) / COL(4)) * COL (6)

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 6A - LOW TENSION NON-COINCIDENT kW
BASED ON LOW TENSION KWH - 2023

LINE NO	CUSTOMER CLASS	SEASON	TOTAL kWh	LOW TENSION kWh	TOTAL NON-COIN kW	LOW TENSION kWh
(1)	(2)	(3)	(4)	(5)	(6)	(7)
31	68-MDWL-CV	Summer2023	509,128,865	488,981,796	113,575	109,081
32	68-MDWL-CV	Winter2023	509,128,865	488,981,796	74,159	71,224
33	68-MDWL-TD	Summer2023	464,250,850	464,250,850	103,686	103,686
34	68-MDWL-TD	Winter2023	464,250,850	464,250,850	60,258	60,258
35	69-GENLG-CV	Summer2023	736,572,557	681,077,911	174,265	161,136
36	69-GENLG-CV	Winter2023	736,572,557	681,077,911	144,841	133,928
37	69-GENLG-TD	Summer2023	1,241,105,515	245,548,933	225,073	44,530
38	69-GENLG-TD	Winter2023	1,241,105,515	245,548,933	172,903	34,208
39	80-NYC-STL	Summer2023	159,943,666	159,943,666	33,639	33,639
40	80-NYC-STL	Winter2023	159,943,666	159,943,666	33,398	33,398

Footnotes:

COL (7) = (COL (5) / COL(4)) * COL (6)

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 6A - LOW TENSION NON-COINCIDENT kW
BASED ON LOW TENSION KWH - 2023

LINE NO	CUSTOMER CLASS	SEASON	TOTAL kWh	LOW TENSION kWh	TOTAL NON-COIN kW	LOW TENSION kWh
(1)	(2)	(3)	(4)	(5)	(6)	(7)
41	82-MDWL-HT-CV	Summer2023	6,419,842	6,419,842	829	829
42	82-MDWL-HT-CV	Winter2023	6,419,842	6,419,842	1,417	1,417
43	85-SUBST	Summer2023	1,557,594,652	12,640,252	336,467	2,731
44	85-SUBST	Winter2023	1,557,594,652	12,640,252	294,078	2,387
45	91-NYCPB-CV	Summer2023	1,855,307,189	1,824,254,281	543,034	533,945
46	91-NYCPB-CV	Winter2023	1,855,307,189	1,824,254,281	380,192	373,829
47	91-NYCPB-TD	Summer2023	1,725,642,535	996,982,242	317,211	183,267
48	91-NYCPB-TD	Winter2023	1,725,642,535	996,982,242	252,190	145,702
49	99-CON ED ACCT	Summer2023	74,342,825	74,342,825	13,156	13,156
50	99-CON ED ACCT	Winter2023	74,342,825	74,342,825	14,130	14,130
51	Total System	Summer2023	51,559,736,417	45,938,916,999	19,221,708	18,060,766
52	Total System	Winter2023	51,559,736,417	45,938,916,999	14,281,899	13,327,959

Footnotes:

COL (7) = (COL (5) / COL(4)) * COL (6)

**CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 7 - ANALYSIS OF kWh FLOW BY DELIVERY SYSTEM
YEAR - 2023**

LINE NO	CUSTOMER CLASS	DELIVERY SYSTEM	kWh AT THE CUSTOMER	kWh LOW TENSION	kWh TRANSFORMER INPUT	kWh AT SYS INPUT
(1)	(2)	(3)	(4)	(5)	(6)	(7)
1	01-RESI-RELIG	Low	13,461,534,789	13,461,534,789	13,649,101,726	14,428,225,926
2	01-RESI-RELIG	High	0			0
3	01-RESI-RELIG	Total	13,461,534,789	13,461,534,789	13,649,101,726	14,428,225,926
4	02-GENSM	Low	2,286,254,244	2,286,254,244	2,318,109,877	2,450,433,273
5	02-GENSM	High	0			0
6	02-GENSM	Total	2,286,254,244	2,286,254,244	2,318,109,877	2,450,433,273
7	05-TRACT-CV	Low	652,826	652,826	661,922	699,706
8	05-TRACT-CV	High	0			0
9	05-TRACT-CV	Total	652,826	652,826	661,922	699,706
10	05-TRACT-TD	Low	13,134,713	13,134,713	13,317,726	14,077,935
11	05-TRACT-TD	High	83,872,971			88,660,646
12	05-TRACT-TD	Total	97,007,684	13,134,713	13,317,726	102,738,581
13	06-PUB-PRIV-STL	Low	7,288,356	7,288,356	7,389,909	7,811,743
14	06-PUB-PRIV-STL	High	0			0
15	06-PUB-PRIV-STL	Total	7,288,356	7,288,356	7,389,909	7,811,743

Footnotes:

COL (6): LOW TENSION: COL (4) / (LOW TENSION EFF / HIGH TENSION EFF)

COL (7): OVERALL SYSTEM EFF

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 7 - ANALYSIS OF kWh FLOW BY DELIVERY SYSTEM
YEAR - 2023

LINE NO	CUSTOMER CLASS	DELIVERY SYSTEM	kWh AT THE CUSTOMER	kWh LOW TENSION	kWh TRANSFORMER INPUT	kWh AT SYS INPUT
(1)	(2)	(3)	(4)	(5)	(6)	(7)
16	08-MDWL-RED-CV	Low	1,489,550,203	1,489,550,203	1,510,304,922	1,596,516,831
17	08-MDWL-RED-CV	High	0			0
18	08-MDWL-RED-CV	Total	1,489,550,203	1,489,550,203	1,510,304,922	1,596,516,831
19	08-MDWL-RED-TD	Low	127,807,785	127,807,785	129,588,601	136,985,836
20	08-MDWL-RED-TD	High	0			0
21	08-MDWL-RED-TD	Total	127,807,785	127,807,785	129,588,601	136,985,836
22	09-GENLG-CV	Low	17,530,467,302	17,530,467,302	17,774,728,904	18,789,354,021
23	09-GENLG-CV	High	71,796,107			75,894,405
24	09-GENLG-CV	Total	17,602,263,409	17,530,467,302	17,774,728,904	18,865,248,426
25	09-GENLG-TD	Low	5,427,073,405	5,427,073,405	5,502,691,791	5,816,798,934
26	09-GENLG-TD	High	1,498,097,587			1,583,612,671
27	09-GENLG-TD	Total	6,925,170,992	5,427,073,405	5,502,691,791	7,400,411,605
28	12-MDWL-SPHT-CV	Low	130,307,957	130,307,957	132,123,609	139,665,549
29	12-MDWL-SPHT-CV	High	0			0
30	12-MDWL-SPHT-CV	Total	130,307,957	130,307,957	132,123,609	139,665,549

Footnotes:

COL (6): LOW TENSION: COL (4) / (LOW TENSION EFF / HIGH TENSION EFF)

COL (7): OVERALL SYSTEM EFF

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 7 - ANALYSIS OF kWh FLOW BY DELIVERY SYSTEM
YEAR - 2023

LINE NO	CUSTOMER CLASS	DELIVERY SYSTEM	kWh AT THE CUSTOMER	kWh LOW TENSION	kWh TRANSFORMER INPUT	kWh AT SYS INPUT
(1)	(2)	(3)	(4)	(5)	(6)	(7)
31	12-MDWL-SPHT-TD	Low	166,411,069	166,411,069	168,729,766	178,361,274
32	12-MDWL-SPHT-TD	High	0			0
33	12-MDWL-SPHT-TD	Total	166,411,069	166,411,069	168,729,766	178,361,274
34	13-BLK-POWER-TD	Low	0	0	0	0
35	13-BLK-POWER-TD	High	16,515,100			17,457,822
36	13-BLK-POWER-TD	Total	16,515,100	0	0	17,457,822
37	99-CON ED ACCT	Low	74,342,825	74,342,825	75,378,684	79,681,484
38	99-CON ED ACCT	High	0			0
39	99-CON ED ACCT	Total	74,342,825	74,342,825	75,378,684	79,681,484
40	62-GENSM-CV	Low	17,957,237	17,957,237	18,207,445	19,246,771
41	62-GENSM-CV	High	0			0
42	62-GENSM-CV	Total	17,957,237	17,957,237	18,207,445	19,246,771
43	65-TRACTN	Low	296,066,563	296,066,563	300,191,821	317,327,506
44	65-TRACTN	High	574,671,755			607,475,428
45	65-TRACTN	Total	870,738,318	296,066,563	300,191,821	924,802,934
46	66-WEST-STL	Low	29,967,952	29,967,952	30,385,512	32,119,991
47	66-WEST-STL	High	0			0
48	66-WEST-STL	Total	29,967,952	29,967,952	30,385,512	32,119,991

Footnotes:

COL (6): LOW TENSION: COL (4) / (LOW TENSION EFF / HIGH TENSION EFF)

COL (7): OVERALL SYSTEM EFF

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 7 - ANALYSIS OF kWh FLOW BY DELIVERY SYSTEM
YEAR - 2023

LINE NO	CUSTOMER CLASS	DELIVERY SYSTEM	kWh AT THE CUSTOMER	kWh LOW TENSION	kWh TRANSFORMER INPUT	kWh AT SYS INPUT
(1)	(2)	(3)	(4)	(5)	(6)	(7)
49	68-MDWL-CV	Low	488,981,796	488,981,796	495,795,047	524,096,244
50	68-MDWL-CV	High	20,147,069			21,297,113
51	68-MDWL-CV	Total	509,128,865	488,981,796	495,795,047	545,393,357
52	68-MDWL-TD	Low	464,250,850	464,250,850	470,719,511	497,589,335
53	68-MDWL-TD	High	0			0
54	68-MDWL-TD	Total	464,250,850	464,250,850	470,719,511	497,589,335
55	69-GENLG-CV	Low	681,077,911	681,077,911	690,567,743	729,987,043
56	69-GENLG-CV	High	55,494,646			58,662,416
57	69-GENLG-CV	Total	736,572,557	681,077,911	690,567,743	788,649,459
58	69-GENLG-TD	Low	245,548,933	245,548,933	248,970,301	263,182,136
59	69-GENLG-TD	High	995,556,582			1,052,385,393
60	69-GENLG-TD	Total	1,241,105,515	245,548,933	248,970,301	1,315,567,529
61	80-NYC-STL	Low	159,943,666	159,943,666	162,172,249	171,429,438
62	80-NYC-STL	High	0			0
63	80-NYC-STL	Total	159,943,666	159,943,666	162,172,249	171,429,438

Footnotes:

COL (6): LOW TENSION: COL (4) / (LOW TENSION EFF / HIGH TENSION EFF)

COL (7): OVERALL SYSTEM EFF

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 7 - ANALYSIS OF kWh FLOW BY DELIVERY SYSTEM
YEAR - 2023

LINE NO	CUSTOMER CLASS	DELIVERY SYSTEM	kWh AT THE CUSTOMER	kWh LOW TENSION	kWh TRANSFORMER INPUT	kWh AT SYS INPUT
(1)	(2)	(3)	(4)	(5)	(6)	(7)
64	82-MDWL-HT-CV	Low	6,419,842	6,419,842	6,509,293	6,880,860
65	82-MDWL-HT-CV	High	0			0
66	82-MDWL-HT-CV	Total	6,419,842	6,419,842	6,509,293	6,880,860
67	85-SUBST	Low	12,640,252	12,640,252	12,816,376	13,547,966
68	85-SUBST	High	1,544,954,400			1,633,144,186
69	85-SUBST	Total	1,557,594,652	12,640,252	12,816,376	1,646,692,152
70	91-NYCPB-CV	Low	1,824,254,281	1,824,254,281	1,849,672,615	1,955,256,464
71	91-NYCPB-CV	High	31,052,908			32,825,484
72	91-NYCPB-CV	Total	1,855,307,189	1,824,254,281	1,849,672,615	1,988,081,948
73	91-NYCPB-TD	Low	996,982,242	996,982,242	1,010,873,742	1,068,576,894
74	91-NYCPB-TD	High	728,660,293			770,254,010
75	91-NYCPB-TD	Total	1,725,642,535	996,982,242	1,010,873,742	1,838,830,904
76	Sales to Other Utilities	Interchg 60 Cyc	1			1
77	Sales to Other Utilities	Total	1			1

Footnotes:

COL (6): LOW TENSION: COL (4) / (LOW TENSION EFF / HIGH TENSION EFF)

COL (7): OVERALL SYSTEM EFF

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 8 - ANALYSIS OF CLASS 4 HOUR NON-COINCIDENT PEAK DEMAND BY DELIVERY SYSTEM
Summer - 2023

LINE NO	CUSTOMER CLASS	DELIVERY POINT	kW AT THE CUSTOMER ADJUSTED	kW LOW TENSION	kW AT THE TRANS INPUT	kW AT SYS INPUT
(1)	(2)	(3)	(4)	(5)	(6)	(7)
1	01-RESI-RELIG	Total Class	3,943,227	3,943,227	3,998,170	4,226,395
2	02-GENSM	Total Class	433,823	433,823	439,868	464,976
3	05-TRACT-CV	Total Class	52	52	53	56
4	05-TRACT-TD	Total Class	13,638	1,847	1,872	14,444
5	06-PUB-PRIV-STL	Total Class	1,479	1,479	1,500	1,585
6	08-MDWL-RED-CV	Total Class	344,559	344,559	349,360	369,302
7	08-MDWL-RED-TD	Total Class	27,597	27,597	27,982	29,579
8	09-GENLG-CV	Total Class	3,402,337	3,388,460	3,435,673	3,646,459
9	09-GENLG-TD	Total Class	1,227,362	961,851	975,253	1,311,590
10	12-MDWL-SPHT-CV	Total Class	17,746	17,746	17,993	19,020
11	12-MDWL-SPHT-TD	Total Class	23,771	23,771	24,102	25,478
12	13-BLK-POWER-TD	Total Class	45	0	0	48
13	62-GENSM-CV	Total Class	1,869	1,869	1,895	2,003
14	65-TRACTN	Total Class	101,056	34,361	34,840	107,331
15	66-WEST-STL	Total Class	6,632	6,632	6,724	7,108
16	68-MDWL-CV	Total Class	103,455	99,361	100,746	110,824
17	68-MDWL-TD	Total Class	98,712	98,712	100,087	105,801
18	69-GENLG-CV	Total Class	131,917	121,978	123,678	141,244

Footnotes:

COL (4): FROM REPORT 4 COL (7)

COLS (5) - (7): BASED ON CORRESPONDING kWh RATIOS IN REPORT 7 * COL (4)

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 8 - ANALYSIS OF CLASS 4 HOUR NON-COINCIDENT PEAK DEMAND BY DELIVERY SYSTEM
Summer - 2023

LINE NO	CUSTOMER CLASS	DELIVERY POINT	kW AT THE CUSTOMER ADJUSTED	kW LOW TENSION	kW AT THE TRANS INPUT	kW AT SYS INPUT
(1)	(2)	(3)	(4)	(5)	(6)	(7)
19	69-GENLG-TD	Total Class	189,172	37,427	37,949	200,522
20	80-NYC-STL	Total Class	33,564	33,564	34,032	35,974
21	82-MDWL-HT-CV	Total Class	783	783	794	839
22	85-SUBST	Total Class	240,119	1,949	1,976	253,854
23	91-NYCPB-CV	Total Class	448,643	441,134	447,280	480,750
24	91-NYCPB-TD	Total Class	256,753	148,338	150,405	273,594
25	99-CON ED ACCT	Total Class	10,344	10,344	10,488	11,087

Footnotes:

COL (4): FROM REPORT 4 COL (7)

COLS (5) - (7): BASED ON CORRESPONDING kWh RATIOS IN REPORT 7 * COL (4)

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 8 - ANALYSIS OF CLASS 4 HOUR NON-COINCIDENT PEAK DEMAND BY DELIVERY SYSTEM
Winter - 2023

LINE NO	CUSTOMER CLASS	DELIVERY POINT	kW AT THE CUSTOMER ADJUSTED	kW LOW TENSION	kW AT THE TRANS INPUT	kW AT SYS INPUT
(1)	(2)	(3)	(4)	(5)	(6)	(7)
1	01-RESI-RELIG	Total Class	2,053,695	2,053,695	2,082,310	2,201,174
2	02-GENSM	Total Class	333,439	333,439	338,085	357,384
3	05-TRACT-CV	Total Class	125	125	127	134
4	05-TRACT-TD	Total Class	15,532	2,103	2,132	16,450
5	06-PUB-PRIV-STL	Total Class	1,860	1,860	1,886	1,994
6	08-MDWL-RED-CV	Total Class	192,876	192,876	195,563	206,727
7	08-MDWL-RED-TD	Total Class	16,032	16,032	16,255	17,183
8	09-GENLG-CV	Total Class	2,551,737	2,541,329	2,576,739	2,734,827
9	09-GENLG-TD	Total Class	890,970	698,230	707,958	952,113
10	12-MDWL-SPHT-CV	Total Class	28,878	28,878	29,280	30,952
11	12-MDWL-SPHT-TD	Total Class	42,749	42,749	43,345	45,819
12	13-BLK-POWER-TD	Total Class	4,218	0	0	4,459
13	62-GENSM-CV	Total Class	3,250	3,250	3,295	3,483
14	65-TRACTN	Total Class	112,347	38,200	38,732	119,323
15	66-WEST-STL	Total Class	6,034	6,034	6,118	6,467
16	68-MDWL-CV	Total Class	64,878	62,311	63,179	69,499
17	68-MDWL-TD	Total Class	52,060	52,060	52,785	55,798
18	69-GENLG-CV	Total Class	107,881	99,753	101,143	115,508

Footnotes:

COL (4): FROM REPORT 4 COL (7)

COLS (5) - (7): BASED ON CORRESPONDING kWh RATIOS IN REPORT 7 * COL (4)

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC - Electric
REPORT 8 - ANALYSIS OF CLASS 4 HOUR NON-COINCIDENT PEAK DEMAND BY DELIVERY SYSTEM
Winter - 2023

LINE NO	CUSTOMER CLASS	DELIVERY POINT	kW AT THE CUSTOMER ADJUSTED	kW LOW TENSION	kW AT THE TRANS INPUT	kW AT SYS INPUT
(1)	(2)	(3)	(4)	(5)	(6)	(7)
19	69-GENLG-TD	Total Class	149,985	29,674	30,088	158,984
20	80-NYC-STL	Total Class	33,378	33,378	33,843	35,775
21	82-MDWL-HT-CV	Total Class	1,431	1,431	1,451	1,534
22	85-SUBST	Total Class	197,981	1,607	1,629	209,306
23	91-NYCPB-CV	Total Class	290,784	285,917	289,901	311,594
24	91-NYCPB-TD	Total Class	206,704	119,422	121,086	220,262
25	99-CON ED ACCT	Total Class	11,379	11,379	11,538	12,196

Footnotes:

COL (4): FROM REPORT 4 COL (7)

COLS (5) - (7): BASED ON CORRESPONDING kWh RATIOS IN REPORT 7 * COL (4)

EXHIBIT ____ (DAC-2)

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC.

**EMBEDDED COST-OF-SERVICE STUDY AND UNBUNDLED COST
COMPONENTS**

YEAR 2023

Consolidated Edison Company of New York, Inc.

Index Listing for EXHIBIT ____ (DAC-2)

1. Exhibit ____ (DAC-2), Schedule 1– Embedded Cost-of-Service Study – Electric Department, Year 2023, Rates In Effect January 1, 2025
2. Exhibit ____ (DAC-2), Schedule 2 – Merchant Function
3. Exhibit ____ (DAC-2), Schedule 3 – Billing & Payment Processing

Exhibit ____ (DAC-2)
Schedule 1

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC.

EMBEDDED COST-OF-SERVICE STUDY - ELECTRIC DEPARTMENT
YEAR 2023
RATES IN EFFECT
JANUARY 1, 2025

EXPLANATION OF DATA SOURCES AND COSTING METHODS

TABLE OF CONTENTS

<u>SECTION</u>		<u>PAGE</u>
I	Summary	2
II	Description of Operating Functions - Tables 2, 3 and 5	3
III	Description of Allocation Factors - Table 7	7
IV	Description of Customer Classes	13
V	Rate of Return Statement - Table 1	14
VI	Rate Base - Table 2	15
VII	Operating Expenses - Table 3	21
VIII	Operating Revenues - Table 4	27
IX	State and Federal Income Taxes - Table 5	28
X	Customer Cost by Class - Table 6	29

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC.
EMBEDDED COST OF SERVICE STUDY
ELECTRIC DEPARTMENT
YEAR 2023

I - SUMMARY

The Embedded Cost of Service (ECOS) study allocates Consolidated Edison's Electric Department's costs among the respective electric service classes and New York Power Authority (NYPA) service classes based on an analysis of rate base (including book cost of plant) and operating expenses (including operation and maintenance) for the calendar year 2023. The ECOS study methodology is based on a two-step procedure. First, costs are functionalized and classified to **Operating Functions**, as shown in the ECOS study on **Tables 2** through **5**. Along with traditional functions, the study also includes fully unbundled competitive functions, i.e., the merchant function, printing and mailing a bill, and receipts processing. The costs within each function are then allocated to **Customer Classes** based on appropriate physical quantities, such as kW demand, or other appropriate bases of allocation, such as book cost of meters. The bases of cost allocation are shown in detail on **Table 7** as **Allocation Factors** and are further described below. The details of allocations by customer class are shown on **Tables 2** through **5**. The results of the cost allocation study are combined with class revenues to yield the rate of return statement by class shown on **Table 1**. The monthly average **Customer Costs by Class** are shown on **Table 6**. The costs allocated in the ECOS study reflect 2023 booked data. The revenues reflect current rates, i.e. rates effective January 1, 2025. This adjustment is needed to ensure that the study reflects current rate levels and shows the correct relationship among service classifications. These revenues comprise the annual sales revenues for Con Edison service classes (Retail Access customers are priced at full service rates) and total NYPA. They exclude all MAC/MSC, System Benefits Charge (SBC) revenues and represent merchant function, transmission, distribution, and customer revenue requirement. The majority of production costs (except for procurement and steam production) including fixed and appropriate allocated amounts for administrative and general ("A & G") expenses, common/general plant, O & M expenses including purchased power and fuel, depreciation expenses,

property taxes, and payroll and miscellaneous taxes, which are currently being collected in the MAC/MSC, have been assigned in the work papers but have been excluded from the ECOS transmission and distribution Exhibit ____ (DAC-2), Schedule 1. For purposes of unbundling, total revenues are used to allocate customer-care related expenses, i.e., credit & collection/theft, customer service related expenses, and information technology related expenses to competitive functions as determined by the Public Service Commission's Statement of Policy on Unbundling and Order Directing Tariff Filings, issued August 25, 2004, in Case 00-M-0504 ("Unbundling Policy Statement").

II - DESCRIPTION OF OPERATING FUNCTIONS - Tables 2, 3 and 5

The operating functions shown on **Table 2, Rate Base**, **Table 3, Operating Expenses**, and **Table 5, Income Taxes** (State and Federal) are described below. Where applicable, these functions include fixed costs including an allocation of common/general plant, associated operating expenses, A & G expenses, state income taxes ("SIT"), and federal income taxes ("FIT").

Lines 1 through 5, Production

Line 2, Steam Production

The Steam Production function includes the Electric Departments' fixed costs for East River Station.

Line 3, Merchant Function

The Merchant Function includes costs associated with commodity billing and analysis and commodity procurement and scheduling. Also included is a revenue-based allocation of credit & collection, theft, IT, and education & promotional advertising. This function is allocated to classes based on a hybrid allocator, which includes procurement costs being allocated 100% on annual sales, while the revenue-based adders of credit & collection, theft, IT, and education & promotional advertising are allocated 25% on annual sales (kWh) and 75% on number of customers.

Line 5, Total Production

The Total Production function, **Line 5** is the sum of the Steam Production and the Merchant Function functions (**Line 2** plus **Line 3**).

Line 7, Transmission

The Transmission function represents the fixed costs for interconnecting the transmission system to generating stations and other utilities.

Line 9, Substation

The Substation function represents the fixed costs associated with Land and Land Rights, Structures and Improvements, Station Equipment, and Storage and Battery Distribution Equipment.

High Tension System

Line 12, High Tension - Demand

Line 13, High Tension - Customer

The High Tension function includes the costs for primary feeders that provide the source of supply from substations to network and radial transformers and to high tension customers. These costs are further divided into a demand and customer component using a minimum system concept.

Low Tension Distribution System - Demand Component

Line 16, O.H. Transformers - Demand

Line 17, U.G. Transformers - Demand

Line 20, O.H. Lines Demand

Line 21, U.G. Lines Demand

The fixed costs for the above functions are subdivided to show separately the functions associated with the overhead (OH) and underground (UG) line transformers and the OH and UG lines. The demand component of these functions includes the portion of OH and UG transformers and the portion of the secondary system for OH and UG Lines above the minimum system requirements.

Low Tension Distribution System - Customer Component

Line 18, O.H. Transformers - Customer

Line 19, U.G. Transformers - Customer

Line 22, O.H. Lines Customer

Line 23, U.G. Lines Customer

The fixed costs for these functions are considered to be joint customer costs as distinguished from direct customer costs, since they represent the estimated costs of the minimum-size jointly-used network of line transformers and distribution lines needed to connect customers to the distribution system under the existing conditions of customer density and geographical dispersion. Expressed in another manner, the customer component is the cost of the secondary system theoretically needed to physically connect all of the existing service points.

Line 28, Service Costs - O.H.

Line 29, Service Costs - U.G.

These fixed costs represent overhead and underground service connections. The costs for these functions are considered to be direct customer costs since their service connections are attaching the customer to the distribution system.

Line 30, Metering

The Metering function includes the fixed costs for metering equipment on customers' premises, plus meters and meter devices carried in stock. Costs for this function are considered to be direct customer costs.

Line 31, Install. on Custr. Premises

The Installations on Customers' Premises function includes the fixed costs for equipment installed on customers' premises. These costs are considered to be direct customer costs.

Line 32, Services on Custr. Premises

The costs for services on customers' premises consist of O&M expenses for the services rendered principally for the inspection of new or altered customer installations, investigating and adjusting service complaints, and performing emergency repairs. These costs are considered to be direct customer costs.

Line 33, Street Lighting NYC

The Street Lighting NYC function includes the fixed costs for street lighting and signal systems for service to the City of New York.

Line 34, Street Lighting Other

The Street Lighting Other function includes the fixed costs for street lighting and signal systems including private street lighting, located in New York City and Westchester County.

Line 38, Custr. Acctg. & Collection

The Customer Accounting & Collection function consists of direct customer costs of customer records and collection expenses. The function was reduced for Receipts Processing and Printing & Mailing a Bill, as these costs were assigned directly to their respective functions. A portion of Credit and Collection/Theft related costs was allocated to competitive functions based on a revenue allocation. The remaining costs, which are direct customer costs, were assigned to customer classes based on the number of meters and total number of customers as applicable.

Line 39, Printing & Mailing a Bill

The Printing & Mailing a Bill function consists of the customer accounting expense of billing customers, as well as allocations for call center and service center operations and information technology, all based on a detailed study of those activities. Also included is a revenue based allocation of credit & collection, theft, uncollectibles, and education & promotional advertising. Printing & Mailing a Bill is a direct customer cost. This function is allocated to classes based on the number of bills.

Line 40, Receipts Processing

The Receipts Processing function consists of the customer accounting expense of accepting customer payments. It also includes allocations of call center and service center operations and information technology, all based on a detailed study of those activities. Also included is a revenue based allocation of credit & collection, theft, uncollectibles, and education & promotional advertising. Receipts Processing is a direct customer cost. This function is allocated to classes based on the number of bills.

Line 41, Customer Service

The Customer Service function consists of customer assistance expenses, informational and instructional expenses, miscellaneous customer service, and information expense. Educational customer advertising costs were allocated to competitive functions based on a revenue allocation. The remaining costs, which are direct customer costs, were allocated to the customer classes based on the number of customers.

Line 42, Uncollectibles

The Uncollectibles function includes the operation and maintenance expenses for uncollectibles accounts. Uncollectibles associated with commodity have been adjusted out of the study. A portion of uncollectibles was allocated on a revenue basis to competitive functions. The remaining expense, shown on Line 42, has been allocated to classes to reflect the comparative relationship between the uncollectible characteristics of residential classes (1.05) and non-residential classes (0.8).

Line 43, Revenue Items

The Revenue function is non-applicable for this study.

III - DESCRIPTION OF ALLOCATION FACTORS - Table 7

<u>Factor</u>	<u>Description and Source</u>
D03	<u>Transmission</u>
	The D03, Transmission, allocation factor, summer system peak responsibility demand, is based on the highest five-day, four-hour averages. This allocation factor includes all Con Edison service classes and total NYPA.
D04	<u>High Tension</u>
	The D04, High Tension, allocation factor is based on the Non-coincident maximum high tension demand at generating stations. This

allocation factor represents the highest summer or winter demand for all Con Edison and NYPA service classes.

D08

Low Tension - Demands

The D08, Low Tension - Demands, allocation factor is based on the average of non-coincident maximum demands and individual customer billing demands for summer and winter seasons. A special adjustment to this allocator is made for the Con Edison SC 1 service class to allow for the diversity of individual customer loads in multiple dwellings. No adjustments were made for NYPA, since they do not serve any direct residential customers. D08 was developed using a 75% weighting of the non-coincident demands and 25% of the billing demands for this class.

S01

Steam Production

The S01, Steam Production, allocation factor is a direct allocation to the Steam Department representing the year-end steam production function book costs of plant, including common and general plant.

S03

Services - Overhead

S03A

Services - Underground

The year-end book cost for the services allocation factors S03, Overhead Services, and S03A, Underground Services, were developed using the sample services study. The number of actual services installed for each class was estimated based on a sampling of customers from each class. The class samples were subdivided into energy usage strata levels and the number, size, and book cost of service wires were obtained for each sample customer.

S04

Metering

The S04, Metering, allocation factor is the year-end book cost of meters and meter installations and was based on a detailed study of customers' meters for each service classification including total NYPA.

S05

Install. on Customers' Premises

The S05, Installations on Customers' Premises, allocation factor is based on the direct book cost functionalization of installations on customers' premises by class.

S06

Services on Custr. Premises

The S06, Services on Customer Premises, allocation factor results from the sum of allocating 50% of the function's expense on the total number of meters and the other 50% on the total number of overhead and underground services.

S07

Custr. Acctg. & Collection

The S07, Customer Acctg. & Collection, allocation factor was developed by allocating the PSC accounts that comprise the total customer accounting expenses. The allocation factor consists of PSC Account 902, Meter Reading, allocated to the service classes based on the number of meters, PSC Account 903, Customer Records, allocated based on the number of customers, PSC Account 901, Supervision, and PSC Account 905, Miscellaneous, allocated based on the sum of allocations of PSC Account 902 and PSC Account 903.

S09

Uncollectibles

The S09, Uncollectibles, allocation factor is developed based on the uncollectible characteristics of residential and non-residential classes. The Uncollectibles function includes the operation and maintenance expenses for uncollectible accounts excluding uncollectibles associated with commodity, merchant function, and billing and receipts processing functions.

S10

Customer Service

The S10, Customer Service, allocation factor was developed by allocating the annual customer service expense on the number of customers by class.

S11

Printing & Mailing a Bill

The S11, Printing and Mailing a Bill, allocation factor was developed by allocating annual printing & mailing a bill expenses on the number of bills by class.

S12

Receipts Processing

The S12, Receipts Processing, allocation factor was developed by allocating annual receipts processing expenses on the number of bills by class.

S14

Street Lighting - City of New York

The S14, Street Lighting - City of New York, allocation factor is based on the year-end book cost of New York City's street lighting facilities directly assigned to NYPA.

S15 **Street Lighting - Oth. Book Cost**

The S15, Street Lighting - Oth. Book Cost, allocation factor was based on the average book cost of street lighting facilities, other than for NYC, allocated partly to SC 6, and partly to NYPA (Westchester Street Lighting) based on their respective individual customer maximum demands.

C01 **O.H. Lines - Customer Component**

C02 **U.G. Lines - Customer Component**

The C01, O.H. Lines - Customer Component, allocation factor consists of the number of overhead services. The C02, U.G. Lines - Customer Component, allocation factor consists of the number of underground services. No overhead and underground lines customer component costs were allocated to the street lighting classes or to those classes served at high tension.

C03 **Primary - Customer Component**

The C03, Primary - Customer Component, allocation factor represents the sum of customer-related primary overhead assets, allocated to service classes based on the number of overhead services, and customer-related primary underground assets, allocated to classes based on the number of underground services.

R01 **Revenues from Sales**

The R01, Revenues from Sales, allocation factor is based on the annual T&D revenues (2023 annual billing determinants priced out at January 1, 2025 T&D rates).

R02 **MFC Revenues**

The R02, MFC Revenues, allocation factor is based on the annual Merchant Function Charge revenues.

R03 **BPP Revenues**

The R03, BPP Revenues, allocation factor is based on the annual Billing and Payment Processing revenues received from customers.

R04 **Net Miscellaneous Revenues**

The R04, Net Miscellaneous Revenues, allocation factor is comprised of miscellaneous revenue items allocated to the revenue function. Where applicable, these items were reduced to exclude gross receipts taxes.

R06 **Other Revenues - Interdepartmental Rents**

The R06, Other Revenues, allocation factor is the miscellaneous revenue item PSC Account 455, Interdepartmental Rents, allocated to the Steam Department.

R08A **Revenue Adjustment**

The R08A, Revenue Adjustment, allocation factor is not applicable in this study.

R99 **Null Revenue Factor**

The R99, the Revenue function for this cost study is zero.

U01 **Unbundled Allocator**

The U01, the Unbundled Allocator, is used to allocate the unbundled merchant function. It is composed of procurement costs (allocated to service classes based on annual kWh sales); commodity-related credit

& collection/theft, information technology, and education & promotional advertising costs (all allocated to classes based on 25% full service sales/75% full service customers).

K01 **Annual kWh Sales**

K01, Annual kWh Sales, is the total annual kilowatt-hour sales for Con Edison service classes and total NYPA.

K02 **Annual kWh Sales - Con Ed Only**

K02, Annual kWh Sales - Con Ed only, is the total annual kilowatt-hour sales for Con Edison service classes.

K03 **Billing Demand - 1**

K03, Billing Demand - 1, is the annual billing kW for Con Edison service classes, and total NYPA.

K04 **Billing Demand - 2**

K04, Billing Demand - 2, is the annual billing kW for Con Edison service classes.

K05 **Number of Customers**

K05, Number of Customers, is the annual number of customers for Con Edison service classes and total NYPA.

IV - DESCRIPTION OF CUSTOMER CLASSES

The customer classes consist of: Total System, Total Con Ed, Total NYPA, S.C. No. 1 - Residential & Religious, S.C. No. 2 - General-Small, S.C. No. 5 and S.C. No. 5 TOD - Electric Traction Conventional and Time-of-Day, S.C. No. 6 - Street Lighting, S.C. No. 8 and S.C. No. 8 TOD - Multiple Dwellings-Redistribution Conventional and Time-of-Day, S.C. No. 9 and S.C. No. 9 TOD - General-Large-Conventional and Time-of-Day, S.C. No. 12 and S.C. No. 12 TOD - Multiple Dwellings Space Heating-

Redistribution-Conventional and Time-of-Day, S.C. No. 13 TOD - Bulk Power-Housing Developments, and Steam Department-Electric Facilities.

V - RATE OF RETURN STATEMENT - Table 1

The class allocations of the functional elements shown on **Table 2, Pages 33 through 36, Total Rate Base; Operating Expenses, Table 3, Pages 1 through 20; Operating Revenues, Table 4, Pages 1 through 4; and Income Taxes (State and Federal) Table 5, Pages 1 through 16**, were consolidated and tabulated in summary form on the **Rate of Return Statement, Table 1, Pages 1 through 4** detailed below;

Line 1, Total Operating Revenues

Total Operating Revenues are from **Table 4, Pages 1 through 4, Line 8**.

Line 4, Operation & Maintenance

Total Operation & Maintenance Expenses are from **Table 3, Pages 1 through 4, Line 50**.

Line 5, Depreciation & Amortization

Total Depreciation & Amortization are from **Table 3, Pages 5 through 8, Line 50**.

Line 6, Property Taxes

Total Property Taxes are from **Table 3, Pages 9 through 12, Line 50**.

Line 7, Payroll & Misc. Taxes

Total Payroll & Misc. Taxes are from **Table 3, Pages 13 through 16, Line 50**.

Line 8, State Income Tax

Total State Income Tax Computation is from **Table 5, Pages 5 through 8, Line 50**.

Line 9, Federal Income Tax

Total Federal Income Tax Computation is from **Table 5, Pages 13 through 16, Line 50**.

Line 11, Total Operating Expenses

Total Operating Expenses including Income Taxes (state and federal) is the sum of **Lines 4 through 9**.

Line 13, Utility Operating Income

Total Utility Operating Income (return) is Total Operating Revenues on **Line 1** less Total Operating Expenses on **Line 11**.

Line 15, Utility Rate Base

Total Utility Rate Base (Total Rate Base) is from **Table 2, Pages 33 through 36, Line 50**.

Line 17, Rate of Return (%)

The Rate of Return on Utility Rate Base (system rate of return) shown on **Line 17** is calculated by dividing Utility Operating Income on **Line 13** by Utility Rate Base on **Line 15**.

Line 19, Index

The Index (Relative Rate of Return), **Line 19**, is the ratio of the class rate of return to the system rate of return.

Line 21, Deviation

The Deviation is the extent (in percentage points) by which the actual rate of return for each customer class deviates from the total system rate of return.

Line 23 and 24, $\pm 10\%$ Tolerance Bands

A ± 10 tolerance band has been computed around the system rate of return and are shown on **Lines 23 and 24**, respectively.

Lines 26 and 27, Revenue Surplus and Deficiency

The Revenue Surplus or Deficiency for the return that falls outside the tolerance band are shown on **Lines 26 and 27**, respectively.

VI - RATE BASE - Table 2

The Rate Base is shown on **Table 2, Pages 1 through 36**. Total Rate Base shown on **Table 2, Pages 33 through 36** is the sum of book costs for **Plant in Service, Table 2, Pages 1 through 4**, for transmission and distribution plant, **Common/General Plant, Table 2, Pages 5 through 8** and **Plant Held for Future Use**,

Table 2, Pages 9 through 12 less the corresponding Reserve for Depreciation, Table 2, Pages 13 through 16 plus Non-Interest Bearing CWIP, Table 2, Pages 17 through 20 (resulting in Net Plant, Table 2, Pages 21 through 24) plus Rate Base Adjustments, Table 2, Pages 25 through 28 plus Working Capital, Table 2, Pages 29 through 32.

Plant in Service - Table 2, Pages 1 through 4

The total book costs for electric plant in service shown on **Table 2, Pages 1 through 4** are costs comprised of the production, transmission, and distribution plant in service book costs from the Company's accounting data organized by PSC Account shown functionalized on work paper **Summary of Plant In Service Book Costs**. The steam production plant was functionalized to the production and steam production functions. All other production plant was assigned directly to the production function. As stated above, since these embedded costs are recovered outside of delivery rates, they have been excluded from the ECOS study.

PSC Account 301 Organization PSC Account 302 Franchises and Consents and PSC Account 303

Miscellaneous Intangible Plants

The total costs for PSC Accounts 301, 302, and 303 were allocated across all functions based on total common/general plant.

Total Intangible Plant

Total Intangible Plant is equal to the sum of PSC Accounts 301 through 303.

Production Plant in Service Book Costs:

PSC Account 310, Land and Land Rights and PSC Account 310.1, Leasehold Steam Production

The total costs for PSC Accounts 310 and 310.1 were assigned to the Electric Production function.

PSC Accounts 311 through 316, Steam Production

The total costs for PSC Account 311, Structures and Improvements, and PSC Account 315, Accessory Electric Equipment, have an assignment made to the Steam Production function. The remaining balance of the Steam Production costs was assigned to the Electric Production function.

PSC Accounts 340 through 345, Other Production

These costs represent equipment related to gas turbines and were functionalized direct to the Electric Production function.

Total Production Plant

Total Production Plant is equal to the sum of PSC Accounts 310 through 316, and PSC Accounts 340 through 345.

PSC Accounts 350 through 358, Transmission

These costs were functionalized directly to the transmission function.

Total Transmission Plant

Total Transmission Plant is equal to the sum of PSC Accounts 350 through 358.

Distribution Plant in Service Book Costs:

PSC Account 360 Land and Land Rights

The cost is for land occupied by substations and distribution facilities at the generating stations and was functionalized to the substation function.

PSC Accounts 361 and 362, Structures & Improvement and Station Equipment

The costs represent the substation structures and equipment plant. These costs were functionalized to the substation function.

PSC Account 363, Storage and Battery Distribution

This cost represents storage and battery distribution equipment and was functionalized to the substation function.

PSC Account 364, Poles, Towers and Fixtures

The high tension portion of these costs was divided into a high tension demand and customer component using a minimum system methodology. The low tension plant was further subdivided into demand and customer components using a minimum system methodology. The results of the minimum system methodology for PSC Account 365, Overhead Conductors, were applied to this account.

PSC Account 365, Overhead Conductors

The high tension portion of these costs was divided into a high tension demand and customer component using a minimum system methodology. The total low-tension cost was further subdivided into demand and customer components using a minimum system methodology. The methodology employs the “Minimum Size” method to classify low tension distribution plant as either customer-related or demand-related. The minimum size is determined by calculating the weighted average unit cost using the embedded cost of installed wire sizes from 1 to 10.

PSC Account 366, Underground Conduit

The high tension portion of these costs was divided into a high tension demand and customer component using a minimum system methodology. The underground conduit low tension system is further subdivided into demand and customer components using a minimum system methodology. The results of the minimum size method for PSC Account 367, Underground Conductors, were applied to this account.

PSC Account 367, Underground Conductors

The costs for PSC Account 367 representing specific feeders and associated conduits and devices, were identified based on book costs from property records data. The costs for these assets are divided and assigned to high tension demand and customer component using a minimum system methodology. The underground conductors low tension system is further subdivided into demand and customer components using a minimum system methodology. The methodology employs the “Minimum Size” method to classify low tension distribution plant as either customer-related or demand-related. The minimum size is determined by calculating the weighted average unit cost using the embedded cost of installed wire sizes from 1 to 10.

PSC Account 368, Line Transformers

This represents the functionalized total book cost of the overhead and underground line transformers. These costs were further subdivided into demand and customer components using a minimum system methodology. The methodology employs the “Minimum Size” method to classify low tension distribution

plant as either customer-related or demand-related. The minimum size for the Overhead and Underground Transformers is determined by calculating the weighted average unit cost using the embedded cost of installed transformers up to and including 25 kVa. In addition, in the case of underground transformers, network protectors (including related equipment) were classified as entirely demand related. In the development of demand and customer components of overhead transformers, capacitors, and voltage regulators were classified as entirely demand related.

PSC Account 369, Services

The total cost of overhead and underground services is functionalized based on the breakdown of overhead and underground services book costs by company accounts.

PSC Account 370, Meters and Meter Installations

The total cost of meters and meter installations is functionalized directly to the metering function.

PSC Account 371, Installations on Customers' Premises

The cost for the installations on customer premises was obtained from book cost data and assigned directly to the function.

PSC Account 373, Street Lighting and Signal Systems

The costs for New York City street lighting and signal systems reflect the functionalization to NYC and to Other street lighting facilities.

Total Distribution Plant

Total distribution plant is the sum of PSC Accounts 360 through 373.

General Plant:

PSC Account 392, Transportation Equipment

The cost for Transportation Equipment was functionalized based on labor expenses.

PSC Account 397, Communication Equipment

The cost for Communication Equipment was functionalized based on labor expenses.

Total General Plant

Total General Plant is equal to PSC Accounts 392 and 397.

PSC Accounts 303, 389 through 399, Common Plant - Table 2, Pages 5 through 8

PSC Accounts 303, 389 through 399 represent the cost of common plant allocated to the Electric Department (83% of total common plant) and functionalized in part to Steam Production based on the apportionment used to develop Interdepartmental Rents charged to the Steam Department. The balance was functionalized to the remaining functions based on Labor. Distribution was functionalized based on the corresponding functionalization of distribution O&M expenses. PSC Accounts 303, 389 through 399 combined with Total Intangible Plant represent the functionalization of book cost of common plant.

Total Plant

Total Plant is the sum of Total Intangible Plant, Total Production Plant, Total Transmission Plant, Total Distribution Plant, and Total General Plant.

PSC Accounts 310, 350, 357, 360, and 366, Plant Held for Future Use - Table 2, Pages 9 through 12

PSC Accounts 310 through 366 represent the functionalization of book cost of Plant Held for Future Use.

Total Book Cost (Gross Plant)

Total Book Cost (Gross Plant) is the sum of Total Plant, Total Electric Common, and Total Plant Held for Future Use.

Reserve for Depreciation - Table 2, Pages 13 through 16

The **Reserve for Depreciation** is shown by function on **Table 2, Pages 13 through 16**.

Non-Interest Bearing CWIP (Construction Work In Progress) - Table 2, Pages 17 through 20

The year-end balance of Non-Interest Bearing Construction Work in Progress on which interest is not capitalized, is shown in total on **Line 50 of Table 2, Pages 17 through 20**. This amount was functionalized based on the book cost of plant shown on **Table 2, Pages 1 through 4**.

Net Plant - Table 2, Pages 21 through 24

Net Plant shown on **Table 2, Pages 21 through 24** by function by class is the sum of **Table 2, Pages 1 through 12, Book Cost of Plant (Plant in Service, Common/General Plant and Plant Held for Future Use)**, less **Table 2, Pages 13 through 16, Reserve for Depreciation**, plus **Table 2, Pages 17 through 20, Non-Interest Bearing CWIP**.

Rate Base Adjustments - Table 2, Pages 25 through 28

The year-end balance of Rate Base Adjustments is shown in total on **Line 50 of Table 2, Pages 25 through 28**.

Working Capital - Table 2, Pages 29 through 32

Working Capital appears on **Table 2, Pages 29 through 32** and is composed of the cost of materials and supplies on hand, prepayments of operating taxes, insurance, rents, and a cash allowance for operation and maintenance expenses representing a lag of revenue collection over payments for costs incurred. In addition, an adjustment for Excess Rate Base Capitalization has been added to the gross working capital functionalized on the subtotal rate base, resulting in the Total Working Capital shown on **Line 50 of Table 2, Pages 29 through 32**.

Total Rate Base - Table 2, Pages 33 through 36

The sum of **Net Plant, Pages 21 through 24, Rate Base Adjustments, Pages 25 through 28 and Working Capital, Pages 29 through 32** comprises the **Total Rate Base**, shown on **Table 2, Pages 33 through 36**.

VII - OPERATING EXPENSES - Table 3

Operating Expenses are shown on **Table 3, Pages 1 through 20. Table 3, Pages 17 through 20, Total Operating Expenses** represents the sum of expenses by function, by class of **Table 3, Pages 1 through 4, Operation & Maintenance Expenses and Total Other Expenses (Table 3, Pages 5 through 8, Depreciation & Amortization, Table 3, Pages 9 through 12, Property Taxes, and Table 3, Pages 13 through 16, Payroll & Misc. Taxes)**. The major types of operation and maintenance expenses are for Production, Transmission,

Distribution, Customer Accounting, and Customer Service including Miscellaneous Revenue Credits and Administrative and General Expenses.

Operation & Maintenance Expenses - Table 3, Pages 1 through 4

The total operation and maintenance expenses shown in **Table 3, Pages 1 through 4, Operation & Maintenance** are comprised of the merchant function, transmission, distribution, customer accounting, and customer service expenses as reflected in the Company's accounting data organized by PSC Account including allocations for miscellaneous revenue credits and administrative and general expenses shown functionalized on work paper, **Summary of Total Operating Expenses** described below:

Production Operation and Maintenance Expenses:

PSC Accounts 500 through 557, Production Expenses

The majority of the production expenses shown in **Total Production Expenses** have been functionalized to the production function. The production function has been excluded from the exhibit to only show transmission and distribution including customer costs. A portion of PSC Account 500, Operation Supervision and Engineering, has been functionalized to the merchant function.

PSC Accounts 560 through 573, Transmission & Maintenance Expenses

These costs represent transmission expenses, functionalized to the Transmission function based on the functionalization of transmission plant.

Distribution Operation and Maintenance Expenses:

PSC Account 580, Supervision and Engineering

The Supervision and Engineering expense related to Operation was reallocated to PSC Accounts 582 through 588.

PSC Account 582, Station Equipment

These costs were functionalized based on the method used to functionalize the related cost for PSC Accounts 360 through 363 previously described.

PSC Account 583, Overhead Lines

These costs were functionalized based on the functionalization of the book costs of PSC Account, 364 Poles, Towers and Fixtures, PSC Account 365, Overhead Conductors, and the overhead portion of PSC Account 368, Line Transformers.

PSC Account 584, Underground Lines, Underground Stray Voltage Mobile Testing

These underground lines operation expenses were functionalized based on the book costs of PSC Account 366, Underground Conduit, PSC Account 367, Underground Conductors, and the underground portion of PSC Account 368, Line Transformers. The portion of the Underground Lines account related to Stray Voltage Mobile Testing was functionalized based on the book cost of PSC Account 365, Overhead Conductors, PSC Account 367, Underground Conductors, and PSC Account 373, Street Lighting and Signal Systems.

PSC Account 585, Street Lighting and Signal Systems, Street Lighting Stray Voltage Manual Testing

Street Lighting and Signal Systems portion of these expenses was functionalized based on the book cost of PSC Account 373. The Street Lighting Stray Voltage Manual Testing expenses were functionalized based on the book costs of PSC Account 365, Overhead Conductors, 367 Underground Conductors and 373 Street Lighting and Signal Systems.

PSC Account 586, Meters

The costs were functionalized directly to the Metering function.

PSC Account 587, Customer Installations

The costs were functionalized directly to the Services on Customer Premises function.

PSC Account 588, Miscellaneous

The costs were functionalized based on the book costs of the total distribution plant. A portion of this account was functionalized to the merchant function.

Total Distribution Operation Expense

Total of PSC Accounts 580 through 588.

PSC Account 590, Supervision and Engineering

The Supervision and Engineering expense related to Maintenance was reallocated to PSC Accounts 591 through 598.

PSC Account 591, Structures

The costs were functionalized based on PSC Account 361, Structures and Improvements.

PSC Account 592, Station Equipment

The costs were functionalized based on PSC Account 362, Station Equipment.

PSC Account 593, Overhead Lines

The costs were functionalized based on PSC Account 364, Poles, Towers and Fixtures, PSC Account 365, Overhead Conductors and PSC Account 369, Overhead Services.

PSC Account 594, Underground Lines, Underground Lines - Stray Voltage Site Safety

The Underground Lines expenses were functionalized based on the book cost of PSC Accounts 366, Underground Conduit, PSC Account 367, Underground Conductors, and PSC Account 369, Underground Services. The Underground Lines - Stray Voltage Site Safety expenses were functionalized based on the book cost of PSC Account 365, Overhead Conductors, PSC Account 367, Underground Conductors, and PSC Account 373, Street Lighting and Signal System.

PSC Account 595, Line Transformers

The costs were functionalized based on book cost of PSC Account 368, Line Transformers and Devices.

PSC Account 596, Street Lighting and Signal Systems

The costs were functionalized based on the book costs of PSC Account 373, Street Lighting Overhead and and Signal Systems.

PSC Account 597, Meters

The costs were functionalized directly to the Metering function.

PSC Account 598, Miscellaneous Distribution Plant

The total cost of Miscellaneous Distribution Plant was functionalized based on book cost of total distribution plant.

Total Distribution Maintenance Expenses

Total of PSC Accounts 590 through 598.

Total Distribution Excluding Rents

Total of Distribution Operation Expenses and Distribution Maintenance Expenses, excluding PSC Account 589, Rents.

PSC Account 589, Rents

The costs were functionalized based on book costs of total distribution plant.

Total Distribution Expenses

Total Distribution Expenses is the sum of Total Distribution Expenses Excluding Rents and PSC Account 589.

PSC Accounts 901 through 905, Customer Accounting/Uncollectibles

The total annual expenses for customer accounting including uncollectibles are composed of PSC Accounts 901 through 905. The costs related to Receipts Processing, Printing & Mailing a Bill, and Uncollectibles (excluding a portion allocated to competitive functions) are assigned directly to their specific functions. The remaining costs were functionalized to the Customer Accounting & Collection function.

Total Customer Accounting Expenses

The total customer accounting expenses of PSC Accounts 901 through 905 is shown on Total Customer Accounting Expenses.

PSC Accounts 907 through 916, Total Customer Service Expenses (including Sales Expenses)

Customer Service expenses, excluding costs related to educational customer advertising that were allocated to competitive functions based on a revenue allocation, were functionalized directly to the Customer Service function. Customer Service expenses were adjusted to exclude SBC costs.

PSC Accounts 920 through 935, Administrative and General Expenses

Administrative and General Expenses consist of PSC Accounts 920 through 935. Labor was used as the basis of functionalization for PSC Accounts 920, 921, 922, 923, 926, 929, 931, and 935. PSC Accounts 924, 925, 928, 930.1 and 930.2 were functionalized based on production, transmission and distribution operation and maintenance expenses excluding fuel, purchased power and rents.

Unadjusted Total O & M

The Unadjusted O & M equals the sum of Total Production Expenses, Total Transmission Expenses, Total Distribution Expenses, Total Customer Accounting Expenses, Total Customer Service Expenses (including “Sales Expenses”), and Administrative and General Expenses.

Sub-Total Adj. Excluding Rents

The Sub-Total Adjusted O & M Excluding Rents equals Unadjusted Total O & M less PSC Account 589.

Miscellaneous Revenue Credits

The functionalized Miscellaneous Revenue Credits represent the adjusted sum of PSC Accounts 447, 451, 454, 455, 456 and 457.

Total Adjusted Operations and Maintenance Expenses

Total Adjusted O & M is the sum of Unadjusted O & M and Miscellaneous Revenue Credits.

Payroll & Misc. Taxes - Table 3, Pages 13 through 16

The Payroll & Miscellaneous Taxes shown on **Table 3, Pages 13 through 16** includes Federal and State Unemployment Insurance Taxes, Federal Social Security tax, and were functionalized on a labor basis. MTA Tax Surcharge was functionalized on the cost of net plant.

Property Taxes - Table 3, Pages 9 through 12

The Property Taxes shown on **Table 3, Pages 9 through 12** were functionalized based on total book cost of plant excluding meters, including common/general plant and future use plant. The property taxes were also adjusted to include the property tax Reconciliation Deferral included on the books of the Company in taxes other than FIT/SIT.

Depreciation & Amortization Expense - Table 3, Pages 5 through 8

The Depreciation & Amortization Expenses shown on **Table 3, Pages 5 through 8**, were identified with each plant PSC Account or group of accounts and functionalized in proportion to the corresponding depreciation reserve costs shown on **Table 2, Pages 13 through 16**.

Total Other Expenses

The Total Other Expenses is the sum of Payroll & Miscellaneous Taxes, Property Taxes, and Depreciation & Amortization Expense.

Total Expenses

The Grand Total tabulated on **Table 3, Pages 17 through 20 Total Expenses**, is the sum of Total Adjusted O & M and Total Other Expenses.

VIII - OPERATING REVENUES - Table 4

Operating Revenues are tabulated on **Table 4, Pages 1 through 4**. The **Total Operating Revenues** are shown on **Line 8** calculated by the sum of **Lines 1 through 6** as shown below:

Line 1, Revenue from Sales

Revenues from Sales are the annual T&D revenues.

Line 2, MFC Revenues

MFC Revenues are the annual Merchant Function Charge Revenues.

Line 3, BPP Revenues

The BPP Revenues are the annual Billing and Payment Processing Revenues.

Line 4, Net Miscellaneous Revenues

Net Miscellaneous Revenues are comprised of miscellaneous revenue items allocated to the revenue function. Where applicable, these items were reduced to exclude gross receipts taxes.

Line 5, Other Revs. - Interdepartmental Rents

Other Revs. - Interdepartmental Rents are the annual miscellaneous electric revenues, for interdepartmental rents from the steam department.

Line 6, Revenue Adjustment

The Revenue Adjustment is not applicable for this study.

Line 8, Total Operating Revenues

Total Operating Revenues are the sum of **Line 1** through **Line 6**.

IX - STATE AND FEDERAL INCOME TAXES - Table 5

State Income Taxes are shown on **Table 5, Pages 1** through **8**. **State Income Tax Computation** shown on **Table 5, Pages 5** through **8** was calculated at 6.50% of taxable income plus **SIT Adjustments, Table 5, Pages 1** through **4**. Federal Income Taxes are shown on **Table 5, Pages 9** through **16**. The **Federal Income Tax Computation** shown on **Table 5, Pages 13** through and **16** was calculated at 21% of taxable income (less SIT) plus **FIT Adjustments, Table 5, Pages 9** through **12**. SIT and FIT amounts by function are not the final amounts because they do not include the revenue functional amounts since they are not determined until subsequent calculations. Results are presented on a functional basis to maintain a consistent report format. The total state income tax by class is shown on **Line 50 of Table 5, Pages 5** through **8** and the total federal income tax by class is shown on **Line 50 of Table 5, Pages 13** through **16**.

State and Federal Income Tax Adjustments - Table 5, Pages 1 through 4 and Pages 9 through 12

In the Development of Total SIT Adjustments and Development of Total FIT Adjustments work papers, each individual deduction/addition tax adjustment line item is multiplied by 6.50% for SIT and 21% for FIT and is then functionalized based on cost causation. The functional results are shown on **Table 5, Pages 1** through **4 (State Income Tax Adjustments)** and **Table 5, Pages 9** through **12 (Federal Income Tax Adjustments)**.

X - CUSTOMER COST BY CLASS - Table 6

These are electric system costs considered to be customer related and are shown, by class, on **Table 6, Pages 1 through 4.**

Line 1, Number of Customers

The number of customers in each class from the allocation factor **K05.**

Line 3, Rate Base

The customer related rate base shown for each class from **Table 2, Pages 33 through 36, Line 47.**

Line 5, Total Customer Operating Exps.

The customer related operating expenses shown from **Table 3, Pages 17 through 20, Line 47.**

Line 6, Monthly Op. Exps Cost/Cust

The monthly amount for operating expenses per customer shown on **Line 6** is calculated starting with **Line 5** divided by **Line 1**, then the results are divided by 12.

Line 8, Return @ 10.71% (Customer)

The applied rate of return on rate base of 10.71% is the Total System Rate of Return developed in this study, shown on **Table 1, Page 1, Column 1, Line 17 as Rate of Return (%)**.

Line 9, S.I.T. & F.I.T. Percent on Return

The S.I.T. & F.I.T. Percent on Return, **Line 9** developed by dividing the sum of the Total Company State and Federal Income Taxes as shown on **Table 1, Page 1, Column 1, Lines 8 and 9**, respectively, by the Total System Utility Operating Income (return) shown on **Table 1, Column 1, Line 13.**

Line 10, Income Tax On Return

The Return of **Line 8** multiplied by the S.I.T. & F.I.T. Percent on Return **Line 9**, results in the Income Taxes on Return on a class-by-class basis.

Line 11, Total Return & F.I.T.

The Total Return & F.I.T. (including S.I.T.) shown on **Line 11** is the sum of **Line 8**, Return and **Line 10**, Income Tax on Return.

Line 12, Monthly Ret. F.I.T. Cost/Cust.

The monthly amount for Return and Income Taxes, (including State) per customer is calculated starting with **Line 11** divided by **Line 1**, and then the results are divided by 12.

Line 14, Monthly Customer Costs

The Monthly Customer Costs are the sum of **Line 6** and **Line 12**.

CON ED ELECTRIC 2023 ECOS

RATE OF RETURN

	TOTAL SYSTEM (1)	TOTAL CON ED (2)	TOTAL NYPA (3)	RESIDENTIAL & RELIGIOUS SC #1 (4)
RATE OF RETURN STATEMENT				
1 TOTAL OPERATING REVENUES	7,915,498,997	7,094,300,154	821,198,843	3,206,745,119
2				
3 OPERATING EXPENSES				
4 OPERATION & MAINTENANCE	1,471,509,588	1,346,987,892	124,521,695	767,543,876
5 DEPRECIATION & AMORTIZATION	1,354,572,091	1,199,274,429	155,297,662	546,942,861
6 PROPERTY TAXES	1,877,001,241	1,645,348,388	231,652,854	720,022,967
7 PAYROLL & MISC. TAXES	71,649,381	63,940,971	7,708,410	31,697,224
8 STATE INCOME TAX	61,508,297	56,478,121	5,030,176	10,523,151
9 FEDERAL INCOME TAX	217,653,094	198,088,516	19,564,578	38,959,977
10				
11 TOTAL OPERATING EXPENSES	5,053,893,693	4,510,118,318	543,775,375	2,115,690,055
12				
13 UTILITY OPERATING INCOME	2,861,605,305	2,584,181,837	277,423,468	1,091,055,064
14				
15 UTILITY RATE BASE	26,712,112,992	23,568,305,972	3,143,807,020	10,797,955,294
16				
17 RATE OF RETURN (%)	10.71%	10.96%	8.82%	10.10%
18				
19 INDEX	1.00	1.02	0.82	0.94
20				
21 DEVIATION	0.00	0.25	-1.89	-0.61
22				
23 TOLERANCE BAND +10%	11.78%			
24 TOLERANCE BAND -10%	9.64%			
25				
26 REVENUE SURPLUS	28,396,335	0	0	0
27 REVENUE DEFICIENCY	47,796,629	0	34,774,605	0
	=====	=====	=====	=====

CON ED ELECTRIC 2023 ECOS

RATE OF RETURN

	GENERAL SMALL SC #2 (5)	ELECTRIC TRACTION NTD-SC #5 (6)	ELECTRIC TRACTION TOD-SC #5 (7)	ST. LTG. & SIGNAL SC #6 (8)
RATE OF RETURN STATEMENT				
1 TOTAL OPERATING REVENUES	620,804,088	114,708	4,678,559	3,705,050
2				
3 OPERATING EXPENSES				
4 OPERATION & MAINTENANCE	123,053,261	18,123	843,997	799,990
5 DEPRECIATION & AMORTIZATION	103,563,034	25,233	908,366	741,655
6 PROPERTY TAXES	137,451,158	31,122	1,391,384	1,048,851
7 PAYROLL & MISC. TAXES	5,231,239	1,017	52,726	32,020
8 STATE INCOME TAX	4,519,517	82	16,383	(15,763)
9 FEDERAL INCOME TAX	17,075,222	1,343	56,571	(28,371)
10				
11 TOTAL OPERATING EXPENSES	390,893,431	76,920	3,269,427	2,578,381
12				
13 UTILITY OPERATING INCOME	229,910,657	37,788	1,409,131	1,126,668
14				
15 UTILITY RATE BASE	2,014,982,260	485,175	18,215,763	16,199,975
16				
17 RATE OF RETURN (%)	11.41%	7.79%	7.74%	6.95%
18				
19 INDEX	1.07	0.73	0.72	0.65
20				
21 DEVIATION	0.70	-2.92	-2.98	-3.76
22				
23 TOLERANCE BAND +10%				
24 TOLERANCE BAND -10%				
25				
26 REVENUE SURPLUS	0	0	0	0
27 REVENUE DEFICIENCY	0	12,171	469,964	589,251
	=====	=====	=====	=====

CON ED ELECTRIC 2023 ECOS

RATE OF RETURN

	MULTI-DW. REDISTRIB. NTD-SC #8 (9)	MULTI-DW. REDISTRIB. TOD-SC #8 (10)	GENERAL LARGE NTD-SC #9 (11)	GENERAL LARGE TOD-SC #9 (12)
RATE OF RETURN STATEMENT				
1 TOTAL OPERATING REVENUES	187,429,227	14,155,691	2,388,085,028	612,934,645
2				
3 OPERATING EXPENSES				
4 OPERATION & MAINTENANCE	26,835,649	2,038,756	334,110,893	86,829,539
5 DEPRECIATION & AMORTIZATION	31,823,246	2,414,353	393,341,572	101,472,343
6 PROPERTY TAXES	47,473,176	3,623,362	570,019,608	152,813,254
7 PAYROLL & MISC. TAXES	1,638,231	125,680	19,445,666	5,380,878
8 STATE INCOME TAX	2,183,404	161,889	31,168,365	7,911,969
9 FEDERAL INCOME TAX	7,504,806	553,953	107,347,380	26,384,598
10				
11 TOTAL OPERATING EXPENSES	117,458,511	8,917,993	1,455,433,483	380,792,582
12				
13 UTILITY OPERATING INCOME	69,970,716	5,237,698	932,651,545	232,142,062
14				
15 UTILITY RATE BASE	633,278,850	48,182,570	7,749,892,732	2,025,496,255
16				
17 RATE OF RETURN (%)	11.05%	10.87%	12.03%	11.46%
18				
19 INDEX	1.03	1.01	1.12	1.07
20				
21 DEVIATION	0.34	0.16	1.32	0.75
22				
23 TOLERANCE BAND +10%				
24 TOLERANCE BAND -10%				
25				
26 REVENUE SURPLUS	0	0	26,265,696	0
27 REVENUE DEFICIENCY	0	0	0	0
	=====	=====	=====	=====

CON ED ELECTRIC 2023 ECOS

RATE OF RETURN

	MULTI-DW. SPACE HTG. NTD-SC #12 (13)	MULTI-DW. SPACE HTG. TOD-SC #12 (14)	BULK POWER TOD-SC #13 (15)	STEAM DEPT. ELECTRIC FACILITIES (16)
RATE OF RETURN STATEMENT				
1 TOTAL OPERATING REVENUES	15,408,248	19,213,781	3,111,122	17,914,889
2				
3 OPERATING EXPENSES				
4 OPERATION & MAINTENANCE	2,123,329	2,644,040	151,792	(5,353)
5 DEPRECIATION & AMORTIZATION	2,559,553	3,174,910	168,417	12,138,889
6 PROPERTY TAXES	3,739,905	4,704,144	243,956	2,785,500
7 PAYROLL & MISC. TAXES	124,234	157,742	8,227	46,086
8 STATE INCOME TAX	209,091	271,608	152,881	(624,457)
9 FEDERAL INCOME TAX	702,781	889,306	459,943	(1,818,993)
10				
11 TOTAL OPERATING EXPENSES	9,458,893	11,841,751	1,185,217	12,521,673
12				
13 UTILITY OPERATING INCOME	5,949,355	7,372,031	1,925,905	5,393,216
14				
15 UTILITY RATE BASE	50,273,832	62,649,146	3,200,736	147,493,383
16				
17 RATE OF RETURN (%)	11.83%	11.77%	60.17%	3.66%
18				
19 INDEX	1.10	1.10	5.62	0.34
20				
21 DEVIATION	1.12	1.05	49.46	-7.06
22				
23 TOLERANCE BAND +10%				
24 TOLERANCE BAND -10%				
25				
26 REVENUE SURPLUS	33,937	0	2,096,703	0
27 REVENUE DEFICIENCY	0	0	0	11,950,638
	=====	=====	=====	=====

CON ED ELECTRIC 2023 ECOS

RATE BASE

			TOTAL SYSTEM (1)	TOTAL CON ED (2)	TOTAL NYPA (3)	RESIDENTIAL & RELIGIOUS SC #1 (4)
PLANT IN SERVICE						
1	PRODUCTION FUNCTION					
2	STEAM PRODUCTION	D S01	22,822,480	22,822,480	0	0
3	MERCHANT FUNCTION	E U01	0	0	0	0
4						
5	TOTAL PRODUCTION		22,822,480	22,822,480	0	0
6						
7	TRANSMISSION	D D03	6,040,165,608	5,194,493,461	845,672,147	2,095,359,424
8						
9	SUBSTATION	D D04	4,503,222,581	3,846,045,684	657,176,897	1,601,766,737
10						
11	HIGH TENSION SYSTEM					
12	HT - DEMAND	D D04	7,306,206,056	6,239,976,320	1,066,229,736	2,598,769,576
13	HT - CUSTOMER	C C03	602,881,101	583,128,936	19,752,165	326,396,188
14						
15	LOW TENSION SYSTEM					
16	O.H. TRANSFORMERS - DEMAND	D D08	445,021,199	405,229,780	39,791,419	186,732,741
17	U.G. TRANSFORMERS - DEMAND	D D08	2,727,752,535	2,483,851,470	243,901,065	1,144,576,278
18	O.H. TRANSFORMERS - CUSTOMER	C C01	184,092,547	183,721,368	371,179	171,466,421
19	U.G. TRANSFORMERS - CUSTOMER	C C02	736,868,877	708,943,944	27,924,933	350,953,334
20	O.H. LINES DEMAND	D D08	575,853,218	524,363,499	51,489,720	241,630,399
21	U.G. LINES DEMAND	D D08	4,040,718,716	3,679,419,227	361,299,489	1,695,502,333
22	O.H. LINES CUSTOMER	C C01	63,784,343	63,655,737	128,606	59,409,645
23	U.G. LINES CUSTOMER	C C02	3,595,263,408	3,459,014,621	136,248,788	1,712,339,492
24						
25	TOTAL LOW TENSION DEMAND		7,789,345,669	7,092,863,976	696,481,693	3,268,441,751
26	TOTAL LOW TENSION CUSTOMER		4,580,009,175	4,415,335,670	164,673,506	2,294,168,893
27						
28	SERVICE COSTS - O.H.	C S03	300,695,799	299,331,694	1,364,105	267,044,134
29	SERVICE COSTS - U.G.	C S03A	2,483,361,008	2,294,741,930	188,619,079	657,033,910
30	METERING	C S04	833,680,741	829,280,869	4,399,872	623,587,597
31	INSTALL. ON CUSTR. PREMISES	C S05	9,068,773	9,068,773	0	0
32	SERVICES ON CUSTR. PREMISES	C S06	0	0	0	0
33	STREET LIGHTING NYC	C S14	549,046,873	0	549,046,873	0
34	STREET LIGHTING OTHER	C S15	73,880,876	16,163,887	57,716,989	0
35						
36	TOTAL DISTRIBUTION PLANT		29,031,398,653	25,625,937,739	3,405,460,914	11,637,208,786
37						
38	CUSTR. ACCTG. & COLLECTION	C S07	0	0	0	0
39	PRINTING & MAILING A BILL	C S11	0	0	0	0
40	RECEIPTS PROCESSING	C S12	0	0	0	0
41	CUSTOMER SERVICE	C S10	0	0	0	0
42	UNCOLLECTIBLES	C S09	0	0	0	0
43	REVENUE ITEMS	R R99	0	0	0	0
44						
45	TOTAL DEMAND	D	25,661,762,395	22,396,201,921	3,265,560,473	9,564,337,488
46	TOTAL ENERGY	E	0	0	0	0
47	TOTAL CUSTOMER	C	9,432,624,346	8,447,051,759	985,572,588	4,168,230,722
48	TOTAL REVENUE	R	0	0	0	0
49						
50	TOTAL		35,094,386,741	30,843,253,680	4,251,133,061	13,732,568,210

CON ED ELECTRIC 2023 ECOS

RATE BASE

			GENERAL SMALL SC #2 (5)	ELECTRIC TRACTION NTD-SC #5 (6)	ELECTRIC TRACTION TOD-SC #5 (7)	ST. LTG. & SIGNAL SC #6 (8)
PLANT IN SERVICE						
1	PRODUCTION FUNCTION					
2	STEAM PRODUCTION	D S01	0	0	0	0
3	MERCHANT FUNCTION	E U01	0	0	0	0
4			-----	-----	-----	-----
5	TOTAL PRODUCTION		0	0	0	0
6						
7	TRANSMISSION	D D03	247,890,744	29,444	7,664,461	1,606
8						
9	SUBSTATION	D D04	176,222,595	50,785	6,234,406	755,709
10						
11	HIGH TENSION SYSTEM					
12	HT - DEMAND	D D04	285,910,493	82,395	10,114,947	1,226,091
13	HT - CUSTOMER	C C03	95,287,254	13,299	1,209	0
14						
15	LOW TENSION SYSTEM					
16	O.H. TRANSFORMERS - DEMAND	D D08	26,040,147	5,065	82,440	64,974
17	U.G. TRANSFORMERS - DEMAND	D D08	159,612,792	31,047	505,314	398,256
18	O.H. TRANSFORMERS - CUSTOMER	C C01	11,206,258	0	0	0
19	U.G. TRANSFORMERS - CUSTOMER	C C02	128,421,240	18,968	1,724	0
20	O.H. LINES DEMAND	D D08	33,695,703	6,554	106,676	84,075
21	U.G. LINES DEMAND	D D08	236,440,215	45,991	748,540	589,951
22	O.H. LINES CUSTOMER	C C01	3,882,742	0	0	0
23	U.G. LINES CUSTOMER	C C02	626,581,200	92,549	8,414	0
24			-----	-----	-----	-----
25	TOTAL LOW TENSION DEMAND		455,788,858	88,657	1,442,970	1,137,256
26	TOTAL LOW TENSION CUSTOMER		770,091,440	111,517	10,138	0
27						
28	SERVICE COSTS - O.H.	C S03	22,632,431	0	0	0
29	SERVICE COSTS - U.G.	C S03A	455,598,215	195,834	3,243	0
30	METERING	C S04	95,625,461	52,117	12,689	0
31	INSTALL. ON CUSTR. PREMISES	C S05	0	0	0	0
32	SERVICES ON CUSTR. PREMISES	C S06	0	0	0	0
33	STREET LIGHTING NYC	C S14	0	0	0	0
34	STREET LIGHTING OTHER	C S15	0	0	0	16,163,887
35			-----	-----	-----	-----
36	TOTAL DISTRIBUTION PLANT		2,357,156,747	594,604	17,819,601	19,282,943
37						
38	CUSTR. ACCTG. & COLLECTION	C S07	0	0	0	0
39	PRINTING & MAILING A BILL	C S11	0	0	0	0
40	RECEIPTS PROCESSING	C S12	0	0	0	0
41	CUSTOMER SERVICE	C S10	0	0	0	0
42	UNCOLLECTIBLES	C S09	0	0	0	0
43	REVENUE ITEMS	R R99	0	0	0	0
44			-----	-----	-----	-----
45	TOTAL DEMAND	D	1,165,812,690	251,281	25,456,784	3,120,662
46	TOTAL ENERGY	E	0	0	0	0
47	TOTAL CUSTOMER	C	1,439,234,801	372,767	27,279	16,163,887
48	TOTAL REVENUE	R	0	0	0	0
49			-----	-----	-----	-----
50	TOTAL		2,605,047,491	624,048	25,484,063	19,284,549
			=====	=====	=====	=====

CON ED ELECTRIC 2023 ECOS

RATE BASE

			MULTI-DW. REDISTRIB. NTD-SC #8 (9)	MULTI-DW. REDISTRIB. TOD-SC #8 (10)	GENERAL LARGE NTD-SC #9 (11)	GENERAL LARGE TOD-SC #9 (12)
PLANT IN SERVICE						
1	PRODUCTION FUNCTION					
2	STEAM PRODUCTION	D S01	0	0	0	0
3	MERCHANT FUNCTION	E U01	0	0	0	0
4			-----	-----	-----	-----
5	TOTAL PRODUCTION		0	0	0	0
6						
7	TRANSMISSION	D D03	193,056,949	15,354,619	1,915,636,185	696,452,041
8						
9	SUBSTATION	D D04	139,962,607	11,210,182	1,381,976,445	497,080,759
10						
11	HIGH TENSION SYSTEM					
12	HT - DEMAND	D D04	227,080,858	18,187,842	2,242,173,131	806,483,443
13	HT - CUSTOMER	C C03	5,387,222	259,931	147,954,357	7,121,014
14						
15	LOW TENSION SYSTEM					
16	O.H. TRANSFORMERS - DEMAND	D D08	12,768,457	1,005,940	138,733,637	37,244,903
17	U.G. TRANSFORMERS - DEMAND	D D08	78,264,118	6,165,899	850,366,297	228,292,221
18	O.H. TRANSFORMERS - CUSTOMER	C C01	0	0	1,048,447	242
19	U.G. TRANSFORMERS - CUSTOMER	C C02	7,683,926	370,746	210,330,239	10,156,716
20	O.H. LINES DEMAND	D D08	16,522,263	1,301,677	179,520,012	48,194,551
21	U.G. LINES DEMAND	D D08	115,935,476	9,133,770	1,259,678,423	338,177,543
22	O.H. LINES CUSTOMER	C C01	0	0	363,266	84
23	U.G. LINES CUSTOMER	C C02	37,490,712	1,808,910	1,026,224,118	49,555,722
24			-----	-----	-----	-----
25	TOTAL LOW TENSION DEMAND		223,490,314	17,607,287	2,428,298,369	651,909,217
26	TOTAL LOW TENSION CUSTOMER		45,174,639	2,179,656	1,237,966,069	59,712,763
27						
28	SERVICE COSTS - O.H.	C S03	0	0	9,642,318	12,810
29	SERVICE COSTS - U.G.	C S03A	34,944,077	1,534,341	1,064,842,779	75,720,609
30	METERING	C S04	2,007,243	79,756	105,050,566	2,484,305
31	INSTALL. ON CUSTR. PREMISES	C S05	0	0	7,249,582	1,819,191
32	SERVICES ON CUSTR. PREMISES	C S06	0	0	0	0
33	STREET LIGHTING NYC	C S14	0	0	0	0
34	STREET LIGHTING OTHER	C S15	0	0	0	0
35			-----	-----	-----	-----
36	TOTAL DISTRIBUTION PLANT		678,046,959	51,058,996	8,625,153,615	2,102,344,113
37						
38	CUSTR. ACCTG. & COLLECTION	C S07	0	0	0	0
39	PRINTING & MAILING A BILL	C S11	0	0	0	0
40	RECEIPTS PROCESSING	C S12	0	0	0	0
41	CUSTOMER SERVICE	C S10	0	0	0	0
42	UNCOLLECTIBLES	C S09	0	0	0	0
43	REVENUE ITEMS	R R99	0	0	0	0
44			-----	-----	-----	-----
45	TOTAL DEMAND	D	783,590,728	62,359,930	7,968,084,130	2,651,925,460
46	TOTAL ENERGY	E	0	0	0	0
47	TOTAL CUSTOMER	C	87,513,180	4,053,685	2,572,705,670	146,870,694
48	TOTAL REVENUE	R	0	0	0	0
49			-----	-----	-----	-----
50	TOTAL		871,103,908	66,413,614	10,540,789,800	2,798,796,154
			=====	=====	=====	=====

CON ED ELECTRIC 2023 ECOS

RATE BASE

			MULTI-DW. SPACE HTG. NTD-SC #12 (13)	MULTI-DW. SPACE HTG. TOD-SC #12 (14)	BULK POWER TOD-SC #13 (15)	STEAM DEPT. ELECTRIC FACILITIES (16)
PLANT IN SERVICE						
1	PRODUCTION FUNCTION					
2	STEAM PRODUCTION	D S01	0	0	0	22,822,480
3	MERCHANT FUNCTION	E U01	0	0	0	0
4						
5	TOTAL PRODUCTION		0	0	0	22,822,480
6						
7	TRANSMISSION	D D03	9,855,607	13,168,291	24,090	0
8						
9	SUBSTATION	D D04	11,730,537	17,365,000	1,689,922	0
10						
11	HIGH TENSION SYSTEM					
12	HT - DEMAND	D D04	19,032,087	28,173,662	2,741,796	0
13	HT - CUSTOMER	C C03	598,446	107,599	2,418	0
14						
15	LOW TENSION SYSTEM					
16	O.H. TRANSFORMERS - DEMAND	D D08	1,055,544	1,495,933	0	0
17	U.G. TRANSFORMERS - DEMAND	D D08	6,469,944	9,169,305	0	0
18	O.H. TRANSFORMERS - CUSTOMER	C C01	0	0	0	0
19	U.G. TRANSFORMERS - CUSTOMER	C C02	853,578	153,472	0	0
20	O.H. LINES DEMAND	D D08	1,365,864	1,935,723	0	0
21	U.G. LINES DEMAND	D D08	9,584,163	13,582,824	0	0
22	O.H. LINES CUSTOMER	C C01	0	0	0	0
23	U.G. LINES CUSTOMER	C C02	4,164,700	748,805	0	0
24						
25	TOTAL LOW TENSION DEMAND		18,475,514	26,183,784	0	0
26	TOTAL LOW TENSION CUSTOMER		5,018,278	902,276	0	0
27						
28	SERVICE COSTS - O.H.	C S03	0	0	0	0
29	SERVICE COSTS - U.G.	C S03A	4,057,110	706,535	105,276	0
30	METERING	C S04	311,646	64,103	5,386	0
31	INSTALL. ON CUSTR. PREMISES	C S05	0	0	0	0
32	SERVICES ON CUSTR. PREMISES	C S06	0	0	0	0
33	STREET LIGHTING NYC	C S14	0	0	0	0
34	STREET LIGHTING OTHER	C S15	0	0	0	0
35						
36	TOTAL DISTRIBUTION PLANT		59,223,617	73,502,961	4,544,797	0
37						
38	CUSTR. ACCTG. & COLLECTION	C S07	0	0	0	0
39	PRINTING & MAILING A BILL	C S11	0	0	0	0
40	RECEIPTS PROCESSING	C S12	0	0	0	0
41	CUSTOMER SERVICE	C S10	0	0	0	0
42	UNCOLLECTIBLES	C S09	0	0	0	0
43	REVENUE ITEMS	R R99	0	0	0	0
44						
45	TOTAL DEMAND	D	59,093,745	84,890,737	4,455,808	22,822,480
46	TOTAL ENERGY	E	0	0	0	0
47	TOTAL CUSTOMER	C	9,985,479	1,780,514	113,079	0
48	TOTAL REVENUE	R	0	0	0	0
49						
50	TOTAL		69,079,225	86,671,251	4,568,888	22,822,480
			=====	=====	=====	=====

CON ED ELECTRIC 2023 ECOS

RATE BASE

			TOTAL SYSTEM (1)	TOTAL CON ED (2)	TOTAL NYPA (3)	RESIDENTIAL & RELIGIOUS SC #1 (4)
COMMON/GENERAL PLANT						
1	PRODUCTION FUNCTION					
2	STEAM PRODUCTION	D S01	173,274,029	173,274,029	0	0
3	MERCHANT FUNCTION	E U01	68,413,427	68,413,427	0	50,859,516
4						
5	TOTAL PRODUCTION		241,687,455	241,687,455	0	50,859,516
6						
7	TRANSMISSION	D D03	953,465,063	819,972,226	133,492,838	330,761,131
8						
9	SUBSTATION	D D04	379,901,191	324,460,386	55,440,805	135,128,362
10						
11	HIGH TENSION SYSTEM					
12	HT - DEMAND	D D04	778,714,874	665,073,273	113,641,601	276,983,773
13	HT - CUSTOMER	C C03	58,361,134	56,449,051	1,912,083	31,596,366
14						
15	LOW TENSION SYSTEM					
16	O.H. TRANSFORMERS - DEMAND	D D08	14,101,063	12,840,221	1,260,842	5,916,865
17	U.G. TRANSFORMERS - DEMAND	D D08	68,095,535	62,006,796	6,088,739	28,573,169
18	O.H. TRANSFORMERS - CUSTOMER	C C01	5,833,207	5,821,445	11,761	5,433,132
19	U.G. TRANSFORMERS - CUSTOMER	C C02	18,395,173	17,698,056	697,117	8,761,189
20	O.H. LINES DEMAND	D D08	137,997,688	125,658,672	12,339,016	57,904,402
21	U.G. LINES DEMAND	D D08	317,875,421	289,452,699	28,422,723	133,381,845
22	O.H. LINES CUSTOMER	C C01	15,285,305	15,254,485	30,819	14,236,950
23	U.G. LINES CUSTOMER	C C02	282,832,325	272,113,900	10,718,425	134,706,392
24						
25	TOTAL LOW TENSION DEMAND		538,069,708	489,958,388	48,111,320	225,776,281
26	TOTAL LOW TENSION CUSTOMER		322,346,010	310,887,887	11,458,123	163,137,663
27						
28	SERVICE COSTS - O.H.	C S03	64,727,586	64,433,950	293,636	57,483,750
29	SERVICE COSTS - U.G.	C S03A	155,352,746	143,553,216	11,799,530	41,102,370
30	METERING	C S04	36,710,665	36,516,919	193,746	27,459,331
31	INSTALL. ON CUSTR. PREMISES	C S05	73,424	73,424	0	0
32	SERVICES ON CUSTR. PREMISES	C S06	85,625,635	84,829,151	796,484	66,362,679
33	STREET LIGHTING NYC	C S14	33,569,135	0	33,569,135	0
34	STREET LIGHTING OTHER	C S15	4,517,132	988,272	3,528,860	0
35						
36	TOTAL DISTRIBUTION PLANT		2,457,969,240	2,177,223,917	280,745,323	1,025,030,574
37						
38	CUSTR. ACCTG. & COLLECTION	C S07	350,910,604	349,829,695	1,080,909	276,354,611
39	PRINTING & MAILING A BILL	C S11	2,142,780	2,136,097	6,683	1,788,206
40	RECEIPTS PROCESSING	C S12	18,053,046	17,996,740	56,306	15,065,740
41	CUSTOMER SERVICE	C S10	74,221,024	73,989,534	231,490	61,939,388
42	UNCOLLECTIBLES	C S09	0	0	0	0
43	REVENUE ITEMS	R R99	0	0	0	0
44						
45	TOTAL DEMAND	D	2,823,424,865	2,472,738,301	350,686,564	968,649,547
46	TOTAL ENERGY	E	68,413,427	68,413,427	0	50,859,516
47	TOTAL CUSTOMER	C	1,206,610,921	1,141,683,936	64,926,985	742,290,103
48	TOTAL REVENUE	R	0	0	0	0
49						
50	TOTAL		4,098,449,213	3,682,835,664	415,613,549	1,761,799,166
			=====	=====	=====	=====

CON ED ELECTRIC 2023 ECOS

RATE BASE

			GENERAL SMALL SC #2 (5)	ELECTRIC TRACTION NTD-SC #5 (6)	ELECTRIC TRACTION TOD-SC #5 (7)	ST. LTG. & SIGNAL SC #6 (8)
COMMON/GENERAL PLANT						
1	PRODUCTION FUNCTION					
2	STEAM PRODUCTION	D S01	0	0	0	0
3	MERCHANT FUNCTION	E U01	7,269,151	190	0	55,032
4						
5	TOTAL PRODUCTION		7,269,151	190	0	55,032
6						
7	TRANSMISSION	D D03	39,130,577	4,648	1,209,867	254
8						
9	SUBSTATION	D D04	14,866,503	4,284	525,947	63,753
10						
11	HIGH TENSION SYSTEM					
12	HT - DEMAND	D D04	30,473,101	8,782	1,078,078	130,680
13	HT - CUSTOMER	C C03	9,224,161	1,287	117	0
14						
15	LOW TENSION SYSTEM					
16	O.H. TRANSFORMERS - DEMAND	D D08	825,115	160	2,612	2,059
17	U.G. TRANSFORMERS - DEMAND	D D08	3,984,569	775	12,615	9,942
18	O.H. TRANSFORMERS - CUSTOMER	C C01	355,085	0	0	0
19	U.G. TRANSFORMERS - CUSTOMER	C C02	3,205,904	474	43	0
20	O.H. LINES DEMAND	D D08	8,074,851	1,571	25,564	20,148
21	U.G. LINES DEMAND	D D08	18,600,288	3,618	58,886	46,410
22	O.H. LINES CUSTOMER	C C01	930,462	0	0	0
23	U.G. LINES CUSTOMER	C C02	49,291,915	7,281	662	0
24						
25	TOTAL LOW TENSION DEMAND		31,484,824	6,124	99,677	78,559
26	TOTAL LOW TENSION CUSTOMER		53,783,365	7,754	705	0
27						
28	SERVICE COSTS - O.H.	C S03	4,871,843	0	0	0
29	SERVICE COSTS - U.G.	C S03A	28,501,065	12,251	203	0
30	METERING	C S04	4,210,814	2,295	559	0
31	INSTALL. ON CUSTR. PREMISES	C S05	0	0	0	0
32	SERVICES ON CUSTR. PREMISES	C S06	9,416,758	2,012	488	0
33	STREET LIGHTING NYC	C S14	0	0	0	0
34	STREET LIGHTING OTHER	C S15	0	0	0	988,272
35						
36	TOTAL DISTRIBUTION PLANT		186,832,434	44,789	1,705,774	1,261,264
37						
38	CUSTR. ACCTG. & COLLECTION	C S07	40,275,564	3,397	2,472	256,800
39	PRINTING & MAILING A BILL	C S11	264,399	5	3	1,978
40	RECEIPTS PROCESSING	C S12	2,227,579	39	25	16,665
41	CUSTOMER SERVICE	C S10	9,158,189	162	101	68,514
42	UNCOLLECTIBLES	C S09	0	0	0	0
43	REVENUE ITEMS	R R99	0	0	0	0
44						
45	TOTAL DEMAND	D	115,955,005	23,838	2,913,569	273,246
46	TOTAL ENERGY	E	7,269,151	190	0	55,032
47	TOTAL CUSTOMER	C	161,933,737	29,202	4,672	1,332,229
48	TOTAL REVENUE	R	0	0	0	0
49						
50	TOTAL		285,157,893	53,230	2,918,241	1,660,507
			=====	=====	=====	=====

CON ED ELECTRIC 2023 ECOS

RATE BASE

			MULTI-DW. REDISTRIB. NTD-SC #8 (9)	MULTI-DW. REDISTRIB. TOD-SC #8 (10)	GENERAL LARGE NTD-SC #9 (11)	GENERAL LARGE TOD-SC #9 (12)
COMMON/GENERAL PLANT						
1	PRODUCTION FUNCTION					
2	STEAM PRODUCTION	D S01	0	0	0	0
3	MERCHANT FUNCTION	E U01	431,242	23,648	9,091,375	595,020
4						
5	TOTAL PRODUCTION		431,242	23,648	9,091,375	595,020
6						
7	TRANSMISSION	D D03	30,474,836	2,423,790	302,391,076	109,937,828
8						
9	SUBSTATION	D D04	11,807,536	945,714	116,586,397	41,934,763
10						
11	HIGH TENSION SYSTEM					
12	HT - DEMAND	D D04	24,202,882	1,938,509	238,976,776	85,957,150
13	HT - CUSTOMER	C C03	521,503	25,162	14,322,532	689,341
14						
15	LOW TENSION SYSTEM					
16	O.H. TRANSFORMERS - DEMAND	D D08	404,585	31,874	4,395,952	1,180,152
17	U.G. TRANSFORMERS - DEMAND	D D08	1,953,783	153,925	21,228,520	5,699,080
18	O.H. TRANSFORMERS - CUSTOMER	C C01	0	0	33,221	8
19	U.G. TRANSFORMERS - CUSTOMER	C C02	191,821	9,255	5,250,678	253,552
20	O.H. LINES DEMAND	D D08	3,959,401	311,934	43,020,245	11,549,361
21	U.G. LINES DEMAND	D D08	9,120,417	718,536	99,096,432	26,603,764
22	O.H. LINES CUSTOMER	C C01	0	0	87,053	20
23	U.G. LINES CUSTOMER	C C02	2,949,321	142,303	80,731,040	3,898,452
24						
25	TOTAL LOW TENSION DEMAND		15,438,186	1,216,270	167,741,149	45,032,358
26	TOTAL LOW TENSION CUSTOMER		3,141,142	151,559	86,101,992	4,152,031
27						
28	SERVICE COSTS - O.H.	C S03	0	0	2,075,599	2,758
29	SERVICE COSTS - U.G.	C S03A	2,186,013	95,984	66,613,855	4,736,889
30	METERING	C S04	88,388	3,512	4,625,843	109,395
31	INSTALL. ON CUSTR. PREMISES	C S05	0	0	58,695	14,729
32	SERVICES ON CUSTR. PREMISES	C S06	234,577	10,390	8,466,672	300,464
33	STREET LIGHTING NYC	C S14	0	0	0	0
34	STREET LIGHTING OTHER	C S15	0	0	0	0
35						
36	TOTAL DISTRIBUTION PLANT		57,620,226	4,387,100	705,569,512	182,929,878
37						
38	CUSTR. ACCTG. & COLLECTION	C S07	530,580	9,963	31,833,202	453,703
39	PRINTING & MAILING A BILL	C S11	1,074	12	79,749	403
40	RECEIPTS PROCESSING	C S12	9,047	104	671,886	3,397
41	CUSTOMER SERVICE	C S10	37,196	426	2,762,307	13,966
42	UNCOLLECTIBLES	C S09	0	0	0	0
43	REVENUE ITEMS	R R99	0	0	0	0
44						
45	TOTAL DEMAND	D	81,923,439	6,524,283	825,695,398	282,862,100
46	TOTAL ENERGY	E	431,242	23,648	9,091,375	595,020
47	TOTAL CUSTOMER	C	6,749,520	297,111	217,612,332	10,477,076
48	TOTAL REVENUE	R	0	0	0	0
49						
50	TOTAL		89,104,202	6,845,042	1,052,399,105	293,934,196
			=====	=====	=====	=====

CON ED ELECTRIC 2023 ECOS

RATE BASE

			MULTI-DW. SPACE HTG. NTD-SC #12 (13)	MULTI-DW. SPACE HTG. TOD-SC #12 (14)	BULK POWER TOD-SC #13 (15)	STEAM DEPT. ELECTRIC FACILITIES (16)
COMMON/GENERAL PLANT						
1	PRODUCTION FUNCTION					
2	STEAM PRODUCTION	D S01	0	0	0	173,274,029
3	MERCHANT FUNCTION	E U01	43,682	44,570	0	0
4			-----	-----	-----	-----
5	TOTAL PRODUCTION		43,682	44,570	0	173,274,029
6						
7	TRANSMISSION	D D03	1,555,748	2,078,669	3,803	0
8						
9	SUBSTATION	D D04	989,612	1,464,947	142,565	0
10						
11	HIGH TENSION SYSTEM					
12	HT - DEMAND	D D04	2,028,490	3,002,824	292,228	0
13	HT - CUSTOMER	C C03	57,932	10,416	234	0
14						
15	LOW TENSION SYSTEM					
16	O.H. TRANSFORMERS - DEMAND	D D08	33,446	47,401	0	0
17	U.G. TRANSFORMERS - DEMAND	D D08	161,515	228,902	0	0
18	O.H. TRANSFORMERS - CUSTOMER	C C01	0	0	0	0
19	U.G. TRANSFORMERS - CUSTOMER	C C02	21,309	3,831	0	0
20	O.H. LINES DEMAND	D D08	327,316	463,877	0	0
21	U.G. LINES DEMAND	D D08	753,967	1,068,534	0	0
22	O.H. LINES CUSTOMER	C C01	0	0	0	0
23	U.G. LINES CUSTOMER	C C02	327,629	58,907	0	0
24			-----	-----	-----	-----
25	TOTAL LOW TENSION DEMAND		1,276,245	1,808,714	0	0
26	TOTAL LOW TENSION CUSTOMER		348,937	62,738	0	0
27						
28	SERVICE COSTS - O.H.	C S03	0	0	0	0
29	SERVICE COSTS - U.G.	C S03A	253,802	44,199	6,586	0
30	METERING	C S04	13,723	2,823	237	0
31	INSTALL. ON CUSTR. PREMISES	C S05	0	0	0	0
32	SERVICES ON CUSTR. PREMISES	C S06	29,412	5,515	184	0
33	STREET LIGHTING NYC	C S14	0	0	0	0
34	STREET LIGHTING OTHER	C S15	0	0	0	0
35			-----	-----	-----	-----
36	TOTAL DISTRIBUTION PLANT		4,998,155	6,402,177	442,034	0
37						
38	CUSTR. ACCTG. & COLLECTION	C S07	95,423	13,208	773	0
39	PRINTING & MAILING A BILL	C S11	252	16	1	0
40	RECEIPTS PROCESSING	C S12	2,120	133	5	0
41	CUSTOMER SERVICE	C S10	8,716	547	20	0
42	UNCOLLECTIBLES	C S09	0	0	0	0
43	REVENUE ITEMS	R R99	0	0	0	0
44			-----	-----	-----	-----
45	TOTAL DEMAND	D	5,850,096	8,355,155	438,596	173,274,029
46	TOTAL ENERGY	E	43,682	44,570	0	0
47	TOTAL CUSTOMER	C	810,318	139,595	8,040	0
48	TOTAL REVENUE	R	0	0	0	0
49			-----	-----	-----	-----
50	TOTAL		6,704,096	8,539,320	446,636	173,274,029
			=====	=====	=====	=====

CON ED ELECTRIC 2023 ECOS

RATE BASE

			TOTAL SYSTEM (1)	TOTAL CON ED (2)	TOTAL NYPA (3)	RESIDENTIAL & RELIGIOUS SC #1 (4)
PLANT HELD FOR FUTURE USE						
1	PRODUCTION FUNCTION					
2	STEAM PRODUCTION	D S01	0	0	0	0
3	MERCHANT FUNCTION	E U01	0	0	0	0
4			-----	-----	-----	-----
5	TOTAL PRODUCTION		0	0	0	0
6						
7	TRANSMISSION	D D03	87,939,653	75,627,388	12,312,264	30,506,644
8						
9	SUBSTATION	D D04	12,214,604	10,432,068	1,782,536	4,344,655
10						
11	HIGH TENSION SYSTEM					
12	HT - DEMAND	D D04	3,892,481	3,324,433	568,048	1,384,530
13	HT - CUSTOMER	C C03	345,957	334,622	11,335	187,299
14						
15	LOW TENSION SYSTEM					
16	O.H. TRANSFORMERS - DEMAND	D D08	0	0	0	0
17	U.G. TRANSFORMERS - DEMAND	D D08	0	0	0	0
18	O.H. TRANSFORMERS - CUSTOMER	C C01	0	0	0	0
19	U.G. TRANSFORMERS - CUSTOMER	C C02	0	0	0	0
20	O.H. LINES DEMAND	D D08	0	0	0	0
21	U.G. LINES DEMAND	D D08	2,705,871	2,463,927	241,945	1,135,395
22	O.H. LINES CUSTOMER	C C01	0	0	0	0
23	U.G. LINES CUSTOMER	C C02	2,407,572	2,316,332	91,239	1,146,670
24			-----	-----	-----	-----
25	TOTAL LOW TENSION DEMAND		2,705,871	2,463,927	241,945	1,135,395
26	TOTAL LOW TENSION CUSTOMER		2,407,572	2,316,332	91,239	1,146,670
27						
28	SERVICE COSTS - O.H.	C S03	0	0	0	0
29	SERVICE COSTS - U.G.	C S03A	0	0	0	0
30	METERING	C S04	0	0	0	0
31	INSTALL. ON CUSTR. PREMISES	C S05	0	0	0	0
32	SERVICES ON CUSTR. PREMISES	C S06	0	0	0	0
33	STREET LIGHTING NYC	C S14	0	0	0	0
34	STREET LIGHTING OTHER	C S15	0	0	0	0
35			-----	-----	-----	-----
36	TOTAL DISTRIBUTION PLANT		21,566,485	18,871,382	2,695,103	8,198,548
37						
38	CUSTR. ACCTG. & COLLECTION	C S07	0	0	0	0
39	PRINTING & MAILING A BILL	C S11	(0)	(0)	(0)	(0)
40	RECEIPTS PROCESSING	C S12	0	0	0	0
41	CUSTOMER SERVICE	C S10	0	0	0	0
42	UNCOLLECTIBLES	C S09	0	0	0	0
43	REVENUE ITEMS	R R99	0	0	0	0
44			-----	-----	-----	-----
45	TOTAL DEMAND	D	106,752,609	91,847,816	14,904,793	37,371,223
46	TOTAL ENERGY	E	0	0	0	0
47	TOTAL CUSTOMER	C	2,753,529	2,650,955	102,574	1,333,969
48	TOTAL REVENUE	R	0	0	0	0
49			-----	-----	-----	-----
50	TOTAL		109,506,138	94,498,771	15,007,367	38,705,192
			=====	=====	=====	=====

CON ED ELECTRIC 2023 ECOS

RATE BASE

			GENERAL SMALL SC #2 (5)	ELECTRIC TRACTION NTD-SC #5 (6)	ELECTRIC TRACTION TOD-SC #5 (7)	ST. LTG. & SIGNAL SC #6 (8)
PLANT HELD FOR FUTURE USE						
1	PRODUCTION FUNCTION					
2	STEAM PRODUCTION	D S01	0	0	0	0
3	MERCHANT FUNCTION	E U01	0	0	0	0
4			-----	-----	-----	-----
5	TOTAL PRODUCTION		0	0	0	0
6						
7	TRANSMISSION	D D03	3,609,078	429	111,588	23
8						
9	SUBSTATION	D D04	477,989	138	16,910	2,050
10						
11	HIGH TENSION SYSTEM					
12	HT - DEMAND	D D04	152,323	44	5,389	653
13	HT - CUSTOMER	C C03	54,680	8	1	0
14						
15	LOW TENSION SYSTEM					
16	O.H. TRANSFORMERS - DEMAND	D D08	0	0	0	0
17	U.G. TRANSFORMERS - DEMAND	D D08	0	0	0	0
18	O.H. TRANSFORMERS - CUSTOMER	C C01	0	0	0	0
19	U.G. TRANSFORMERS - CUSTOMER	C C02	0	0	0	0
20	O.H. LINES DEMAND	D D08	0	0	0	0
21	U.G. LINES DEMAND	D D08	158,332	31	501	395
22	O.H. LINES CUSTOMER	C C01	0	0	0	0
23	U.G. LINES CUSTOMER	C C02	419,591	62	6	0
24			-----	-----	-----	-----
25	TOTAL LOW TENSION DEMAND		158,332	31	501	395
26	TOTAL LOW TENSION CUSTOMER		419,591	62	6	0
27						
28	SERVICE COSTS - O.H.	C S03	0	0	0	0
29	SERVICE COSTS - U.G.	C S03A	0	0	0	0
30	METERING	C S04	0	0	0	0
31	INSTALL. ON CUSTR. PREMISES	C S05	0	0	0	0
32	SERVICES ON CUSTR. PREMISES	C S06	0	0	0	0
33	STREET LIGHTING NYC	C S14	0	0	0	0
34	STREET LIGHTING OTHER	C S15	0	0	0	0
35			-----	-----	-----	-----
36	TOTAL DISTRIBUTION PLANT		1,262,914	282	22,807	3,098
37						
38	CUSTR. ACCTG. & COLLECTION	C S07	0	0	0	0
39	PRINTING & MAILING A BILL	C S11	(0)	(0)	(0)	(0)
40	RECEIPTS PROCESSING	C S12	0	0	0	0
41	CUSTOMER SERVICE	C S10	0	0	0	0
42	UNCOLLECTIBLES	C S09	0	0	0	0
43	REVENUE ITEMS	R R99	0	0	0	0
44			-----	-----	-----	-----
45	TOTAL DEMAND	D	4,397,721	641	134,388	3,121
46	TOTAL ENERGY	E	0	0	0	0
47	TOTAL CUSTOMER	C	474,270	70	6	(0)
48	TOTAL REVENUE	R	0	0	0	0
49			-----	-----	-----	-----
50	TOTAL		4,871,992	711	134,395	3,121
			=====	=====	=====	=====

CON ED ELECTRIC 2023 ECOS

RATE BASE

			MULTI-DW. REDISTRIB. NTD-SC #8 (9)	MULTI-DW. REDISTRIB. TOD-SC #8 (10)	GENERAL LARGE NTD-SC #9 (11)	GENERAL LARGE TOD-SC #9 (12)
PLANT HELD FOR FUTURE USE						
1	PRODUCTION FUNCTION					
2	STEAM PRODUCTION	D S01	0	0	0	0
3	MERCHANT FUNCTION	E U01	0	0	0	0
4			-----	-----	-----	-----
5	TOTAL PRODUCTION		0	0	0	0
6						
7	TRANSMISSION	D D03	2,810,744	223,550	27,890,027	10,139,747
8						
9	SUBSTATION	D D04	379,637	30,407	3,748,492	1,348,289
10						
11	HIGH TENSION SYSTEM					
12	HT - DEMAND	D D04	120,980	9,690	1,194,548	429,665
13	HT - CUSTOMER	C C03	3,091	149	84,902	4,086
14						
15	LOW TENSION SYSTEM					
16	O.H. TRANSFORMERS - DEMAND	D D08	0	0	0	0
17	U.G. TRANSFORMERS - DEMAND	D D08	0	0	0	0
18	O.H. TRANSFORMERS - CUSTOMER	C C01	0	0	0	0
19	U.G. TRANSFORMERS - CUSTOMER	C C02	0	0	0	0
20	O.H. LINES DEMAND	D D08	0	0	0	0
21	U.G. LINES DEMAND	D D08	77,636	6,116	843,545	226,461
22	O.H. LINES CUSTOMER	C C01	0	0	0	0
23	U.G. LINES CUSTOMER	C C02	25,106	1,211	687,212	33,185
24			-----	-----	-----	-----
25	TOTAL LOW TENSION DEMAND		77,636	6,116	843,545	226,461
26	TOTAL LOW TENSION CUSTOMER		25,106	1,211	687,212	33,185
27						
28	SERVICE COSTS - O.H.	C S03	0	0	0	0
29	SERVICE COSTS - U.G.	C S03A	0	0	0	0
30	METERING	C S04	0	0	0	0
31	INSTALL. ON CUSTR. PREMISES	C S05	0	0	0	0
32	SERVICES ON CUSTR. PREMISES	C S06	0	0	0	0
33	STREET LIGHTING NYC	C S14	0	0	0	0
34	STREET LIGHTING OTHER	C S15	0	0	0	0
35			-----	-----	-----	-----
36	TOTAL DISTRIBUTION PLANT		606,450	47,573	6,558,700	2,041,686
37						
38	CUSTR. ACCTG. & COLLECTION	C S07	0	0	0	0
39	PRINTING & MAILING A BILL	C S11	(0)	(0)	(0)	(0)
40	RECEIPTS PROCESSING	C S12	0	0	0	0
41	CUSTOMER SERVICE	C S10	0	0	0	0
42	UNCOLLECTIBLES	C S09	0	0	0	0
43	REVENUE ITEMS	R R99	0	0	0	0
44			-----	-----	-----	-----
45	TOTAL DEMAND	D	3,388,998	269,763	33,676,612	12,144,162
46	TOTAL ENERGY	E	0	0	0	0
47	TOTAL CUSTOMER	C	28,197	1,360	772,114	37,271
48	TOTAL REVENUE	R	0	0	0	0
49			-----	-----	-----	-----
50	TOTAL		3,417,195	271,124	34,448,726	12,181,433
			=====	=====	=====	=====

CON ED ELECTRIC 2023 ECOS

RATE BASE

			MULTI-DW. SPACE HTG. NTD-SC #12 (13)	MULTI-DW. SPACE HTG. TOD-SC #12 (14)	BULK POWER TOD-SC #13 (15)	STEAM DEPT. ELECTRIC FACILITIES (16)
PLANT HELD FOR FUTURE USE						
1	PRODUCTION FUNCTION					
2	STEAM PRODUCTION	D S01	0	0	0	0
3	MERCHANT FUNCTION	E U01	0	0	0	0
4			-----	-----	-----	-----
5	TOTAL PRODUCTION		0	0	0	0
6						
7	TRANSMISSION	D D03	143,489	191,719	351	0
8						
9	SUBSTATION	D D04	31,818	47,101	4,584	0
10						
11	HIGH TENSION SYSTEM					
12	HT - DEMAND	D D04	10,140	15,010	1,461	0
13	HT - CUSTOMER	C C03	343	62	1	0
14						
15	LOW TENSION SYSTEM					
16	O.H. TRANSFORMERS - DEMAND	D D08	0	0	0	0
17	U.G. TRANSFORMERS - DEMAND	D D08	0	0	0	0
18	O.H. TRANSFORMERS - CUSTOMER	C C01	0	0	0	0
19	U.G. TRANSFORMERS - CUSTOMER	C C02	0	0	0	0
20	O.H. LINES DEMAND	D D08	0	0	0	0
21	U.G. LINES DEMAND	D D08	6,418	9,096	0	0
22	O.H. LINES CUSTOMER	C C01	0	0	0	0
23	U.G. LINES CUSTOMER	C C02	2,789	501	0	0
24			-----	-----	-----	-----
25	TOTAL LOW TENSION DEMAND		6,418	9,096	0	0
26	TOTAL LOW TENSION CUSTOMER		2,789	501	0	0
27						
28	SERVICE COSTS - O.H.	C S03	0	0	0	0
29	SERVICE COSTS - U.G.	C S03A	0	0	0	0
30	METERING	C S04	0	0	0	0
31	INSTALL. ON CUSTR. PREMISES	C S05	0	0	0	0
32	SERVICES ON CUSTR. PREMISES	C S06	0	0	0	0
33	STREET LIGHTING NYC	C S14	0	0	0	0
34	STREET LIGHTING OTHER	C S15	0	0	0	0
35			-----	-----	-----	-----
36	TOTAL DISTRIBUTION PLANT		51,508	71,770	6,046	0
37						
38	CUSTR. ACCTG. & COLLECTION	C S07	0	0	0	0
39	PRINTING & MAILING A BILL	C S11	(0)	(0)	(0)	0
40	RECEIPTS PROCESSING	C S12	0	0	0	0
41	CUSTOMER SERVICE	C S10	0	0	0	0
42	UNCOLLECTIBLES	C S09	0	0	0	0
43	REVENUE ITEMS	R R99	0	0	0	0
44			-----	-----	-----	-----
45	TOTAL DEMAND	D	191,865	262,926	6,395	0
46	TOTAL ENERGY	E	0	0	0	0
47	TOTAL CUSTOMER	C	3,132	563	1	0
48	TOTAL REVENUE	R	0	0	0	0
49			-----	-----	-----	-----
50	TOTAL		194,997	263,489	6,397	0
			=====	=====	=====	=====

CON ED ELECTRIC 2023 ECOS

RATE BASE

			TOTAL SYSTEM (1)	TOTAL CON ED (2)	TOTAL NYPA (3)	RESIDENTIAL & RELIGIOUS SC #1 (4)
RESERVE FOR DEPRECIATION						
1	PRODUCTION FUNCTION					
2	STEAM PRODUCTION	D S01	59,461,643	59,461,643	0	0
3	MERCHANT FUNCTION	E U01	20,752,674	20,752,674	0	15,427,833
4						
5	TOTAL PRODUCTION		80,214,317	80,214,317	0	15,427,833
6						
7	TRANSMISSION	D D03	2,235,285,026	1,922,327,003	312,958,023	775,429,988
8						
9	SUBSTATION	D D04	1,799,063,986	1,536,517,939	262,546,047	639,915,260
10						
11	HIGH TENSION SYSTEM					
12	HT - DEMAND	D D04	2,118,535,846	1,809,367,736	309,168,110	753,549,306
13	HT - CUSTOMER	C C03	172,515,010	166,862,909	5,652,101	93,398,585
14						
15	LOW TENSION SYSTEM					
16	O.H. TRANSFORMERS - DEMAND	D D08	82,148,050	74,802,810	7,345,240	34,469,663
17	U.G. TRANSFORMERS - DEMAND	D D08	497,963,252	453,438,037	44,525,215	208,947,446
18	O.H. TRANSFORMERS - CUSTOMER	C C01	33,982,300	33,913,783	68,517	31,651,598
19	U.G. TRANSFORMERS - CUSTOMER	C C02	134,518,662	129,420,843	5,097,820	64,068,078
20	O.H. LINES DEMAND	D D08	209,396,113	190,673,031	18,723,082	87,863,477
21	U.G. LINES DEMAND	D D08	1,126,047,417	1,025,362,270	100,685,147	472,494,167
22	O.H. LINES CUSTOMER	C C01	23,193,746	23,146,982	46,765	21,602,986
23	U.G. LINES CUSTOMER	C C02	1,001,910,145	963,941,009	37,969,135	477,186,262
24						
25	TOTAL LOW TENSION DEMAND		1,915,554,831	1,744,276,148	171,278,684	803,774,752
26	TOTAL LOW TENSION CUSTOMER		1,193,604,853	1,150,422,616	43,182,237	594,508,925
27						
28	SERVICE COSTS - O.H.	C S03	95,587,240	95,153,609	433,631	84,889,818
29	SERVICE COSTS - U.G.	C S03A	674,396,235	623,173,720	51,222,515	178,428,023
30	METERING	C S04	(247,762,441)	(246,454,839)	(1,307,602)	(185,324,642)
31	INSTALL. ON CUSTR. PREMISES	C S05	3,064,824	3,064,824	0	0
32	SERVICES ON CUSTR. PREMISES	C S06	25,973,862	25,732,254	241,607	20,130,596
33	STREET LIGHTING NYC	C S14	84,561,164	0	84,561,164	0
34	STREET LIGHTING OTHER	C S15	11,378,724	2,489,473	8,889,252	0
35						
36	TOTAL DISTRIBUTION PLANT		7,846,474,133	6,910,606,388	935,867,745	2,983,270,622
37						
38	CUSTR. ACCTG. & COLLECTION	C S07	106,445,967	106,118,081	327,885	83,829,994
39	PRINTING & MAILING A BILL	C S11	649,995	647,968	2,027	542,438
40	RECEIPTS PROCESSING	C S12	5,476,249	5,459,169	17,080	4,570,073
41	CUSTOMER SERVICE	C S10	22,514,363	22,444,142	70,221	18,788,825
42	UNCOLLECTIBLES	C S09	0	0	0	0
43	REVENUE ITEMS	R R99	0	0	0	0
44						
45	TOTAL DEMAND	D	8,127,901,332	7,071,950,469	1,055,950,863	2,972,669,307
46	TOTAL ENERGY	E	20,752,674	20,752,674	0	15,427,833
47	TOTAL CUSTOMER	C	2,148,406,045	1,955,113,927	193,292,118	893,762,634
48	TOTAL REVENUE	R	0	0	0	0
49						
50	TOTAL		10,297,060,051	9,047,817,070	1,249,242,981	3,881,859,774
			=====	=====	=====	=====

CON ED ELECTRIC 2023 ECOS

RATE BASE

			GENERAL SMALL SC #2 (5)	ELECTRIC TRACTION NTD-SC #5 (6)	ELECTRIC TRACTION TOD-SC #5 (7)	ST. LTG. & SIGNAL SC #6 (8)
RESERVE FOR DEPRECIATION						
1	PRODUCTION FUNCTION					
2	STEAM PRODUCTION	D S01	0	0	0	0
3	MERCHANT FUNCTION	E U01	2,205,040	58	0	16,693
4						
5	TOTAL PRODUCTION		2,205,040	58	0	16,693
6						
7	TRANSMISSION	D D03	91,736,966	10,896	2,836,388	594
8						
9	SUBSTATION	D D04	70,401,966	20,289	2,490,682	301,910
10						
11	HIGH TENSION SYSTEM					
12	HT - DEMAND	D D04	82,903,716	23,892	2,932,969	355,522
13	HT - CUSTOMER	C C03	27,266,540	3,805	346	0
14						
15	LOW TENSION SYSTEM					
16	O.H. TRANSFORMERS - DEMAND	D D08	4,806,844	935	15,218	11,994
17	U.G. TRANSFORMERS - DEMAND	D D08	29,138,019	5,668	92,247	72,703
18	O.H. TRANSFORMERS - CUSTOMER	C C01	2,068,603	0	0	0
19	U.G. TRANSFORMERS - CUSTOMER	C C02	23,443,864	3,463	315	0
20	O.H. LINES DEMAND	D D08	12,252,687	2,383	38,790	30,572
21	U.G. LINES DEMAND	D D08	65,889,985	12,816	208,599	164,405
22	O.H. LINES CUSTOMER	C C01	1,411,872	0	0	0
23	U.G. LINES CUSTOMER	C C02	174,612,536	25,791	2,345	0
24						
25	TOTAL LOW TENSION DEMAND		112,087,534	21,803	354,855	279,674
26	TOTAL LOW TENSION CUSTOMER		201,536,875	29,254	2,659	0
27						
28	SERVICE COSTS - O.H.	C S03	7,194,552	0	0	0
29	SERVICE COSTS - U.G.	C S03A	123,724,952	53,182	881	0
30	METERING	C S04	(28,419,030)	(15,489)	(3,771)	0
31	INSTALL. ON CUSTR. PREMISES	C S05	0	0	0	0
32	SERVICES ON CUSTR. PREMISES	C S06	2,856,499	610	148	0
33	STREET LIGHTING NYC	C S14	0	0	0	0
34	STREET LIGHTING OTHER	C S15	0	0	0	2,489,473
35						
36	TOTAL DISTRIBUTION PLANT		599,553,604	137,346	5,778,769	3,426,579
37						
38	CUSTR. ACCTG. & COLLECTION	C S07	12,217,275	1,030	750	77,898
39	PRINTING & MAILING A BILL	C S11	80,203	1	1	600
40	RECEIPTS PROCESSING	C S12	675,719	12	7	5,055
41	CUSTOMER SERVICE	C S10	2,778,064	49	31	20,783
42	UNCOLLECTIBLES	C S09	0	0	0	0
43	REVENUE ITEMS	R R99	0	0	0	0
44						
45	TOTAL DEMAND	D	357,130,182	76,879	8,614,894	937,700
46	TOTAL ENERGY	E	2,205,040	58	0	16,693
47	TOTAL CUSTOMER	C	349,911,649	72,456	1,052	2,593,809
48	TOTAL REVENUE	R	0	0	0	0
49						
50	TOTAL		709,246,871	149,392	8,615,946	3,548,203
			=====	=====	=====	=====

CON ED ELECTRIC 2023 ECOS

RATE BASE

			MULTI-DW. REDISTRIB. NTD-SC #8 (9)	MULTI-DW. REDISTRIB. TOD-SC #8 (10)	GENERAL LARGE NTD-SC #9 (11)	GENERAL LARGE TOD-SC #9 (12)
RESERVE FOR DEPRECIATION						
1	PRODUCTION FUNCTION					
2	STEAM PRODUCTION	D S01	0	0	0	0
3	MERCHANT FUNCTION	E U01	130,814	7,173	2,757,797	180,495
4						
5	TOTAL PRODUCTION		130,814	7,173	2,757,797	180,495
6						
7	TRANSMISSION	D D03	71,444,615	5,682,286	708,919,781	257,736,115
8						
9	SUBSTATION	D D04	55,915,887	4,478,534	552,107,742	198,586,695
10						
11	HIGH TENSION SYSTEM					
12	HT - DEMAND	D D04	65,845,246	5,273,817	650,149,218	233,851,067
13	HT - CUSTOMER	C C03	1,541,559	74,380	42,337,282	2,037,685
14						
15	LOW TENSION SYSTEM					
16	O.H. TRANSFORMERS - DEMAND	D D08	2,356,975	185,690	25,609,337	6,875,169
17	U.G. TRANSFORMERS - DEMAND	D D08	14,287,460	1,125,612	155,238,117	41,675,751
18	O.H. TRANSFORMERS - CUSTOMER	C C01	0	0	193,537	45
19	U.G. TRANSFORMERS - CUSTOMER	C C02	1,402,735	67,681	38,396,713	1,854,153
20	O.H. LINES DEMAND	D D08	6,007,950	473,326	65,278,428	17,524,868
21	U.G. LINES DEMAND	D D08	32,308,322	2,545,354	351,040,925	94,241,637
22	O.H. LINES CUSTOMER	C C01	0	0	132,093	30
23	U.G. LINES CUSTOMER	C C02	10,447,725	504,098	285,983,039	13,809,942
24						
25	TOTAL LOW TENSION DEMAND		54,960,708	4,329,982	597,166,806	160,317,426
26	TOTAL LOW TENSION CUSTOMER		11,850,460	571,779	324,705,381	15,664,171
27						
28	SERVICE COSTS - O.H.	C S03	0	0	3,065,166	4,072
29	SERVICE COSTS - U.G.	C S03A	9,489,621	416,675	289,175,016	20,563,137
30	METERING	C S04	(596,535)	(23,703)	(31,220,086)	(738,313)
31	INSTALL. ON CUSTR. PREMISES	C S05	0	0	2,450,022	614,802
32	SERVICES ON CUSTR. PREMISES	C S06	71,157	3,152	2,568,298	91,144
33	STREET LIGHTING NYC	C S14	0	0	0	0
34	STREET LIGHTING OTHER	C S15	0	0	0	0
35						
36	TOTAL DISTRIBUTION PLANT		199,078,103	15,124,615	2,432,504,846	630,991,887
37						
38	CUSTR. ACCTG. & COLLECTION	C S07	160,947	3,022	9,656,351	137,627
39	PRINTING & MAILING A BILL	C S11	326	4	24,191	122
40	RECEIPTS PROCESSING	C S12	2,744	31	203,811	1,030
41	CUSTOMER SERVICE	C S10	11,283	129	837,924	4,237
42	UNCOLLECTIBLES	C S09	0	0	0	0
43	REVENUE ITEMS	R R99	0	0	0	0
44						
45	TOTAL DEMAND	D	248,166,456	19,764,619	2,508,343,546	850,491,304
46	TOTAL ENERGY	E	130,814	7,173	2,757,797	180,495
47	TOTAL CUSTOMER	C	22,531,563	1,045,469	643,803,358	38,379,715
48	TOTAL REVENUE	R	0	0	0	0
49						
50	TOTAL		270,828,833	20,817,261	3,154,904,701	889,051,513
			=====	=====	=====	=====

CON ED ELECTRIC 2023 ECOS

RATE BASE

			MULTI-DW. SPACE HTG. NTD-SC #12 (13)	MULTI-DW. SPACE HTG. TOD-SC #12 (14)	BULK POWER TOD-SC #13 (15)	STEAM DEPT. ELECTRIC FACILITIES (16)
RESERVE FOR DEPRECIATION						
1	PRODUCTION FUNCTION					
2	STEAM PRODUCTION	D S01	0	0	0	59,461,643
3	MERCHANT FUNCTION	E U01	13,251	13,520	0	0
4			-----	-----	-----	-----
5	TOTAL PRODUCTION		13,251	13,520	0	59,461,643
6						
7	TRANSMISSION	D D03	3,647,266	4,873,191	8,915	0
8						
9	SUBSTATION	D D04	4,686,419	6,937,420	675,134	0
10						
11	HIGH TENSION SYSTEM					
12	HT - DEMAND	D D04	5,518,618	8,169,344	795,022	0
13	HT - CUSTOMER	C C03	171,246	30,790	692	0
14						
15	LOW TENSION SYSTEM					
16	O.H. TRANSFORMERS - DEMAND	D D08	194,847	276,140	0	0
17	U.G. TRANSFORMERS - DEMAND	D D08	1,181,117	1,673,897	0	0
18	O.H. TRANSFORMERS - CUSTOMER	C C01	0	0	0	0
19	U.G. TRANSFORMERS - CUSTOMER	C C02	155,824	28,017	0	0
20	O.H. LINES DEMAND	D D08	496,666	703,882	0	0
21	U.G. LINES DEMAND	D D08	2,670,867	3,785,194	0	0
22	O.H. LINES CUSTOMER	C C01	0	0	0	0
23	U.G. LINES CUSTOMER	C C02	1,160,598	208,673	0	0
24			-----	-----	-----	-----
25	TOTAL LOW TENSION DEMAND		4,543,496	6,439,113	0	0
26	TOTAL LOW TENSION CUSTOMER		1,316,422	236,690	0	0
27						
28	SERVICE COSTS - O.H.	C S03	0	0	0	0
29	SERVICE COSTS - U.G.	C S03A	1,101,773	191,871	28,589	0
30	METERING	C S04	(92,618)	(19,051)	(1,601)	0
31	INSTALL. ON CUSTR. PREMISES	C S05	0	0	0	0
32	SERVICES ON CUSTR. PREMISES	C S06	8,922	1,673	56	0
33	STREET LIGHTING NYC	C S14	0	0	0	0
34	STREET LIGHTING OTHER	C S15	0	0	0	0
35			-----	-----	-----	-----
36	TOTAL DISTRIBUTION PLANT		17,254,277	21,987,850	1,497,892	0
37						
38	CUSTR. ACCTG. & COLLECTION	C S07	28,946	4,006	235	0
39	PRINTING & MAILING A BILL	C S11	76	5	0	0
40	RECEIPTS PROCESSING	C S12	643	40	1	0
41	CUSTOMER SERVICE	C S10	2,644	166	6	0
42	UNCOLLECTIBLES	C S09	0	0	0	0
43	REVENUE ITEMS	R R99	0	0	0	0
44			-----	-----	-----	-----
45	TOTAL DEMAND	D	18,395,799	26,419,068	1,479,071	59,461,643
46	TOTAL ENERGY	E	13,251	13,520	0	0
47	TOTAL CUSTOMER	C	2,538,054	446,190	27,979	0
48	TOTAL REVENUE	R	0	0	0	0
49			-----	-----	-----	-----
50	TOTAL		20,947,103	26,878,779	1,507,050	59,461,643
			=====	=====	=====	=====

CON ED ELECTRIC 2023 ECOS

RATE BASE

			TOTAL SYSTEM (1)	TOTAL CON ED (2)	TOTAL NYPA (3)	RESIDENTIAL & RELIGIOUS SC #1 (4)
NON-INTEREST BEARING CWIP						
1	PRODUCTION FUNCTION					
2	STEAM PRODUCTION	D S01	4,122,743	4,122,743	0	0
3	MERCHANT FUNCTION	E U01	1,438,327	1,438,327	0	1,069,273
4						
5	TOTAL PRODUCTION		5,561,071	5,561,071	0	1,069,273
6						
7	TRANSMISSION	D D03	148,883,302	128,038,432	20,844,869	51,648,258
8						
9	SUBSTATION	D D04	102,919,848	87,900,260	15,019,588	36,607,915
10						
11	HIGH TENSION SYSTEM					
12	HT - DEMAND	D D04	170,059,632	145,242,014	24,817,619	60,489,096
13	HT - CUSTOMER	C C03	13,909,264	13,453,556	455,709	7,530,392
14						
15	LOW TENSION SYSTEM					
16	O.H. TRANSFORMERS - DEMAND	D D08	9,652,610	8,789,525	863,085	4,050,275
17	U.G. TRANSFORMERS - DEMAND	D D08	58,780,055	53,524,256	5,255,799	24,664,355
18	O.H. TRANSFORMERS - CUSTOMER	C C01	3,993,009	3,984,958	8,051	3,719,145
19	U.G. TRANSFORMERS - CUSTOMER	C C02	15,878,711	15,276,959	601,751	7,562,657
20	O.H. LINES DEMAND	D D08	15,008,038	13,666,100	1,341,939	6,297,435
21	U.G. LINES DEMAND	D D08	91,692,197	83,493,571	8,198,627	38,474,426
22	O.H. LINES CUSTOMER	C C01	1,662,364	1,659,013	3,352	1,548,350
23	U.G. LINES CUSTOMER	C C02	81,583,903	78,492,138	3,091,765	38,856,496
24						
25	TOTAL LOW TENSION DEMAND		175,132,901	159,473,452	15,659,449	73,486,492
26	TOTAL LOW TENSION CUSTOMER		103,117,986	99,413,068	3,704,919	51,686,648
27						
28	SERVICE COSTS - O.H.	C S03	7,682,680	7,647,828	34,852	6,822,891
29	SERVICE COSTS - U.G.	C S03A	55,476,455	51,262,844	4,213,611	14,677,653
30	METERING	C S04	18,299,154	18,202,578	96,576	13,687,644
31	INSTALL. ON CUSTR. PREMISES	C S05	192,206	192,206	0	0
32	SERVICES ON CUSTR. PREMISES	C S06	1,800,198	1,783,452	16,745	1,395,212
33	STREET LIGHTING NYC	C S14	12,248,949	0	12,248,949	0
34	STREET LIGHTING OTHER	C S15	1,648,244	360,608	1,287,636	0
35						
36	TOTAL DISTRIBUTION PLANT		662,487,518	584,931,865	77,555,653	266,383,943
37						
38	CUSTR. ACCTG. & COLLECTION	C S07	7,377,563	7,354,838	22,725	5,810,094
39	PRINTING & MAILING A BILL	C S11	45,050	44,909	141	37,595
40	RECEIPTS PROCESSING	C S12	379,548	378,364	1,184	316,743
41	CUSTOMER SERVICE	C S10	1,560,427	1,555,560	4,867	1,302,217
42	UNCOLLECTIBLES	C S09	0	0	0	0
43	REVENUE ITEMS	R R99	0	0	0	0
44						
45	TOTAL DEMAND	D	601,118,426	524,776,902	76,341,524	222,231,760
46	TOTAL ENERGY	E	1,438,327	1,438,327	0	1,069,273
47	TOTAL CUSTOMER	C	223,737,724	201,649,810	22,087,914	103,267,090
48	TOTAL REVENUE	R	0	0	0	0
49						
50	TOTAL		826,294,477	727,865,039	98,429,438	326,568,123
			=====	=====	=====	=====

CON ED ELECTRIC 2023 ECOS

RATE BASE

			GENERAL SMALL SC #2 (5)	ELECTRIC TRACTION NTD-SC #5 (6)	ELECTRIC TRACTION TOD-SC #5 (7)	ST. LTG. & SIGNAL SC #6 (8)
NON-INTEREST BEARING CWIP						
1	PRODUCTION FUNCTION					
2	STEAM PRODUCTION	D S01	0	0	0	0
3	MERCHANT FUNCTION	E U01	152,827	4	0	1,157
4						
5	TOTAL PRODUCTION		152,827	4	0	1,157
6						
7	TRANSMISSION	D D03	6,110,229	726	188,920	40
8						
9	SUBSTATION	D D04	4,027,516	1,161	142,486	17,272
10						
11	HIGH TENSION SYSTEM					
12	HT - DEMAND	D D04	6,654,868	1,918	235,436	28,539
13	HT - CUSTOMER	C C03	2,198,403	307	28	0
14						
15	LOW TENSION SYSTEM					
16	O.H. TRANSFORMERS - DEMAND	D D08	564,817	110	1,788	1,409
17	U.G. TRANSFORMERS - DEMAND	D D08	3,439,479	669	10,889	8,582
18	O.H. TRANSFORMERS - CUSTOMER	C C01	243,066	0	0	0
19	U.G. TRANSFORMERS - CUSTOMER	C C02	2,767,336	409	37	0
20	O.H. LINES DEMAND	D D08	878,186	171	2,780	2,191
21	U.G. LINES DEMAND	D D08	5,365,314	1,044	16,986	13,387
22	O.H. LINES CUSTOMER	C C01	101,193	0	0	0
23	U.G. LINES CUSTOMER	C C02	14,218,413	2,100	191	0
24						
25	TOTAL LOW TENSION DEMAND		10,247,796	1,993	32,443	25,570
26	TOTAL LOW TENSION CUSTOMER		17,330,008	2,509	228	0
27						
28	SERVICE COSTS - O.H.	C S03	578,251	0	0	0
29	SERVICE COSTS - U.G.	C S03A	10,177,728	4,375	72	0
30	METERING	C S04	2,098,963	1,144	279	0
31	INSTALL. ON CUSTR. PREMISES	C S05	0	0	0	0
32	SERVICES ON CUSTR. PREMISES	C S06	197,978	42	10	0
33	STREET LIGHTING NYC	C S14	0	0	0	0
34	STREET LIGHTING OTHER	C S15	0	0	0	360,608
35						
36	TOTAL DISTRIBUTION PLANT		53,511,512	13,449	410,982	431,988
37						
38	CUSTR. ACCTG. & COLLECTION	C S07	846,756	71	52	5,399
39	PRINTING & MAILING A BILL	C S11	5,559	0	0	42
40	RECEIPTS PROCESSING	C S12	46,833	1	1	350
41	CUSTOMER SERVICE	C S10	192,542	3	2	1,440
42	UNCOLLECTIBLES	C S09	0	0	0	0
43	REVENUE ITEMS	R R99	0	0	0	0
44						
45	TOTAL DEMAND	D	27,040,408	5,798	599,285	71,419
46	TOTAL ENERGY	E	152,827	4	0	1,157
47	TOTAL CUSTOMER	C	33,673,021	8,452	672	367,839
48	TOTAL REVENUE	R	0	0	0	0
49						
50	TOTAL		60,866,257	14,254	599,957	440,416
			=====	=====	=====	=====

CON ED ELECTRIC 2023 ECOS

RATE BASE

			MULTI-DW. REDISTRIB. NTD-SC #8 (9)	MULTI-DW. REDISTRIB. TOD-SC #8 (10)	GENERAL LARGE NTD-SC #9 (11)	GENERAL LARGE TOD-SC #9 (12)
NON-INTEREST BEARING CWIP						
1	PRODUCTION FUNCTION					
2	STEAM PRODUCTION	D S01	0	0	0	0
3	MERCHANT FUNCTION	E U01	9,066	497	191,138	12,510
4			-----	-----	-----	-----
5	TOTAL PRODUCTION		9,066	497	191,138	12,510
6						
7	TRANSMISSION	D D03	4,758,637	378,474	47,218,281	17,166,761
8						
9	SUBSTATION	D D04	3,198,805	256,205	31,584,671	11,360,637
10						
11	HIGH TENSION SYSTEM					
12	HT - DEMAND	D D04	5,285,546	423,341	52,188,938	18,771,751
13	HT - CUSTOMER	C C03	124,290	5,997	3,413,503	164,291
14						
15	LOW TENSION SYSTEM					
16	O.H. TRANSFORMERS - DEMAND	D D08	276,951	21,819	3,009,164	807,850
17	U.G. TRANSFORMERS - DEMAND	D D08	1,686,505	132,868	18,324,455	4,919,445
18	O.H. TRANSFORMERS - CUSTOMER	C C01	0	0	22,741	5
19	U.G. TRANSFORMERS - CUSTOMER	C C02	165,580	7,989	4,532,384	218,866
20	O.H. LINES DEMAND	D D08	430,608	33,925	4,678,698	1,256,059
21	U.G. LINES DEMAND	D D08	2,630,814	207,264	28,584,688	7,673,942
22	O.H. LINES CUSTOMER	C C01	0	0	9,468	2
23	U.G. LINES CUSTOMER	C C02	850,741	41,048	23,287,131	1,124,521
24			-----	-----	-----	-----
25	TOTAL LOW TENSION DEMAND		5,024,877	395,876	54,597,004	14,657,297
26	TOTAL LOW TENSION CUSTOMER		1,016,321	49,037	27,851,724	1,343,394
27						
28	SERVICE COSTS - O.H.	C S03	0	0	246,358	327
29	SERVICE COSTS - U.G.	C S03A	780,625	34,276	23,787,803	1,691,543
30	METERING	C S04	44,059	1,751	2,305,842	54,530
31	INSTALL. ON CUSTR. PREMISES	C S05	0	0	153,650	38,556
32	SERVICES ON CUSTR. PREMISES	C S06	4,932	218	178,004	6,317
33	STREET LIGHTING NYC	C S14	0	0	0	0
34	STREET LIGHTING OTHER	C S15	0	0	0	0
35			-----	-----	-----	-----
36	TOTAL DISTRIBUTION PLANT		15,479,455	1,166,702	196,307,497	48,088,643
37						
38	CUSTR. ACCTG. & COLLECTION	C S07	11,155	209	669,263	9,539
39	PRINTING & MAILING A BILL	C S11	23	0	1,677	8
40	RECEIPTS PROCESSING	C S12	190	2	14,126	71
41	CUSTOMER SERVICE	C S10	782	9	58,075	294
42	UNCOLLECTIBLES	C S09	0	0	0	0
43	REVENUE ITEMS	R R99	0	0	0	0
44			-----	-----	-----	-----
45	TOTAL DEMAND	D	18,267,865	1,453,897	185,588,895	61,956,445
46	TOTAL ENERGY	E	9,066	497	191,138	12,510
47	TOTAL CUSTOMER	C	1,982,377	91,500	58,680,023	3,308,871
48	TOTAL REVENUE	R	0	0	0	0
49			-----	-----	-----	-----
50	TOTAL		20,259,308	1,545,894	244,460,056	65,277,826
			=====	=====	=====	=====

CON ED ELECTRIC 2023 ECOS

RATE BASE

			MULTI-DW. SPACE HTG. NTD-SC #12 (13)	MULTI-DW. SPACE HTG. TOD-SC #12 (14)	BULK POWER TOD-SC #13 (15)	STEAM DEPT. ELECTRIC FACILITIES (16)
NON-INTEREST BEARING CWIP						
1	PRODUCTION FUNCTION					
2	STEAM PRODUCTION	D S01	0	0	0	4,122,743
3	MERCHANT FUNCTION	E U01	918	937	0	0
4						
5	TOTAL PRODUCTION		918	937	0	4,122,743
6						
7	TRANSMISSION	D D03	242,930	324,584	594	0
8						
9	SUBSTATION	D D04	268,098	396,872	38,623	0
10						
11	HIGH TENSION SYSTEM					
12	HT - DEMAND	D D04	442,992	655,772	63,818	0
13	HT - CUSTOMER	C C03	13,807	2,482	56	0
14						
15	LOW TENSION SYSTEM					
16	O.H. TRANSFORMERS - DEMAND	D D08	22,895	32,447	0	0
17	U.G. TRANSFORMERS - DEMAND	D D08	139,420	197,588	0	0
18	O.H. TRANSFORMERS - CUSTOMER	C C01	0	0	0	0
19	U.G. TRANSFORMERS - CUSTOMER	C C02	18,394	3,307	0	0
20	O.H. LINES DEMAND	D D08	35,597	50,449	0	0
21	U.G. LINES DEMAND	D D08	217,484	308,222	0	0
22	O.H. LINES CUSTOMER	C C01	0	0	0	0
23	U.G. LINES CUSTOMER	C C02	94,506	16,992	0	0
24						
25	TOTAL LOW TENSION DEMAND		415,397	588,707	0	0
26	TOTAL LOW TENSION CUSTOMER		112,899	20,299	0	0
27						
28	SERVICE COSTS - O.H.	C S03	0	0	0	0
29	SERVICE COSTS - U.G.	C S03A	90,633	15,783	2,352	0
30	METERING	C S04	6,841	1,407	118	0
31	INSTALL. ON CUSTR. PREMISES	C S05	0	0	0	0
32	SERVICES ON CUSTR. PREMISES	C S06	618	116	4	0
33	STREET LIGHTING NYC	C S14	0	0	0	0
34	STREET LIGHTING OTHER	C S15	0	0	0	0
35						
36	TOTAL DISTRIBUTION PLANT		1,351,285	1,681,439	104,971	0
37						
38	CUSTR. ACCTG. & COLLECTION	C S07	2,006	278	16	0
39	PRINTING & MAILING A BILL	C S11	5	0	0	0
40	RECEIPTS PROCESSING	C S12	45	3	0	0
41	CUSTOMER SERVICE	C S10	183	12	0	0
42	UNCOLLECTIBLES	C S09	0	0	0	0
43	REVENUE ITEMS	R R99	0	0	0	0
44						
45	TOTAL DEMAND	D	1,369,416	1,965,934	103,035	4,122,743
46	TOTAL ENERGY	E	918	937	0	0
47	TOTAL CUSTOMER	C	227,037	40,380	2,546	0
48	TOTAL REVENUE	R	0	0	0	0
49						
50	TOTAL		1,597,372	2,007,252	105,581	4,122,743
			=====	=====	=====	=====

CON ED ELECTRIC 2023 ECOS

RATE BASE

		TOTAL SYSTEM (1)	TOTAL CON ED (2)	TOTAL NYPA (3)	RESIDENTIAL & RELIGIOUS SC #1 (4)
NET PLANT					
1	PRODUCTION FUNCTION				
2	STEAM PRODUCTION	D	140,757,609	140,757,609	0
3	MERCHANT FUNCTION	E	49,099,080	49,099,080	0
4					36,500,956
5	TOTAL PRODUCTION		189,856,689	189,856,689	0
6					36,500,956
7	TRANSMISSION	D	4,995,168,599	4,295,804,504	699,364,095
8					1,732,845,468
9	SUBSTATION	D	3,199,194,238	2,732,320,460	466,873,778
10					1,137,932,408
11	HIGH TENSION SYSTEM				
12	HT - DEMAND	D	6,140,337,198	5,244,248,303	896,088,895
13	HT - CUSTOMER	C	502,982,447	486,503,257	16,479,190
14					2,184,077,670
15	LOW TENSION SYSTEM				
16	O.H. TRANSFORMERS - DEMAND	D	386,626,822	352,056,717	34,570,106
17	U.G. TRANSFORMERS - DEMAND	D	2,356,664,874	2,145,944,486	210,720,388
18	O.H. TRANSFORMERS - CUSTOMER	C	159,936,463	159,613,989	322,474
19	U.G. TRANSFORMERS - CUSTOMER	C	636,624,099	612,498,117	24,125,982
20	O.H. LINES DEMAND	D	519,462,832	473,015,240	46,447,592
21	U.G. LINES DEMAND	D	3,326,944,790	3,029,467,153	297,477,637
22	O.H. LINES CUSTOMER	C	57,538,265	57,422,253	116,012
23	U.G. LINES CUSTOMER	C	2,960,177,063	2,847,995,982	112,181,081
24					1,409,862,787
25	TOTAL LOW TENSION DEMAND		6,589,699,318	6,000,483,595	589,215,723
26	TOTAL LOW TENSION CUSTOMER		3,814,275,890	3,677,530,341	136,745,549
27					2,765,065,166
28	SERVICE COSTS - O.H.	C	277,518,826	276,259,863	1,258,963
29	SERVICE COSTS - U.G.	C	2,019,793,974	1,866,384,270	153,409,705
30	METERING	C	1,136,453,001	1,130,455,204	5,997,796
31	INSTALL. ON CUSTR. PREMISES	C	6,269,579	6,269,579	0
32	SERVICES ON CUSTR. PREMISES	C	61,451,971	60,880,349	571,622
33	STREET LIGHTING NYC	C	510,303,793	0	510,303,793
34	STREET LIGHTING OTHER	C	68,667,527	15,023,294	53,644,233
35					0
36	TOTAL DISTRIBUTION PLANT		24,326,947,763	21,496,358,515	2,830,589,247
37					9,953,551,229
38	CUSTR. ACCTG. & COLLECTION	C	251,842,200	251,066,451	775,749
39	PRINTING & MAILING A BILL	C	1,537,834	1,533,038	4,796
40	RECEIPTS PROCESSING	C	12,956,345	12,915,935	40,410
41	CUSTOMER SERVICE	C	53,267,088	53,100,952	166,136
42	UNCOLLECTIBLES	C	0	0	0
43	REVENUE ITEMS	R	0	0	0
44					0
45	TOTAL DEMAND	D	21,065,156,962	18,413,614,471	2,651,542,491
46	TOTAL ENERGY	E	49,099,080	49,099,080	0
47	TOTAL CUSTOMER	C	8,717,320,476	7,837,922,533	879,397,943
48	TOTAL REVENUE	R	0	0	0
49					0
50	TOTAL		29,831,576,518	26,300,636,085	3,530,940,434
			=====	=====	=====
					11,977,780,916
					=====

CON ED ELECTRIC 2023 ECOS

RATE BASE

		GENERAL SMALL SC #2 (5)	ELECTRIC TRACTION NTD-SC #5 (6)	ELECTRIC TRACTION TOD-SC #5 (7)	ST. LTG. & SIGNAL SC #6 (8)
NET PLANT					
1	PRODUCTION FUNCTION				
2	STEAM PRODUCTION	D	0	0	0
3	MERCHANT FUNCTION	E	5,216,938	136	39,495
4					
5	TOTAL PRODUCTION		5,216,938	136	39,495
6					
7	TRANSMISSION	D	205,003,660	24,350	6,338,448
8					1,328
9	SUBSTATION	D	125,192,637	36,079	4,429,067
10					536,873
11	HIGH TENSION SYSTEM				
12	HT - DEMAND	D	240,287,069	69,247	8,500,880
13	HT - CUSTOMER	C	79,497,957	11,095	1,009
14					0
15	LOW TENSION SYSTEM				
16	O.H. TRANSFORMERS - DEMAND	D	22,623,235	4,401	71,622
17	U.G. TRANSFORMERS - DEMAND	D	137,898,822	26,823	436,570
18	O.H. TRANSFORMERS - CUSTOMER	C	9,735,806	0	0
19	U.G. TRANSFORMERS - CUSTOMER	C	110,950,617	16,388	1,490
20	O.H. LINES DEMAND	D	30,396,054	5,912	96,230
21	U.G. LINES DEMAND	D	194,674,165	37,867	616,314
22	O.H. LINES CUSTOMER	C	3,502,525	0	0
23	U.G. LINES CUSTOMER	C	515,898,583	76,201	6,927
24					0
25	TOTAL LOW TENSION DEMAND		385,592,276	75,003	1,220,736
26	TOTAL LOW TENSION CUSTOMER		640,087,530	92,588	8,417
27					962,106
28	SERVICE COSTS - O.H.	C	20,887,973	0	0
29	SERVICE COSTS - U.G.	C	370,552,057	159,278	2,638
30	METERING	C	130,354,268	71,045	17,298
31	INSTALL. ON CUSTR. PREMISES	C	0	0	0
32	SERVICES ON CUSTR. PREMISES	C	6,758,237	1,444	350
33	STREET LIGHTING NYC	C	0	0	0
34	STREET LIGHTING OTHER	C	0	0	0
35					15,023,294
36	TOTAL DISTRIBUTION PLANT		1,999,210,003	515,779	14,180,395
37					17,552,714
38	CUSTR. ACCTG. & COLLECTION	C	28,905,045	2,438	1,774
39	PRINTING & MAILING A BILL	C	189,755	3	2
40	RECEIPTS PROCESSING	C	1,598,693	28	18
41	CUSTOMER SERVICE	C	6,572,667	116	73
42	UNCOLLECTIBLES	C	0	0	0
43	REVENUE ITEMS	R	0	0	0
44					0
45	TOTAL DEMAND	D	956,075,642	204,679	20,489,132
46	TOTAL ENERGY	E	5,216,938	136	0
47	TOTAL CUSTOMER	C	1,285,404,181	338,036	31,578
48	TOTAL REVENUE	R	0	0	0
49					0
50	TOTAL		2,246,696,761	542,851	20,520,710
			=====	=====	=====
					17,840,389
					=====

CON ED ELECTRIC 2023 ECOS

RATE BASE

		MULTI-DW. REDISTRIB. NTD-SC #8 (9)	MULTI-DW. REDISTRIB. TOD-SC #8 (10)	GENERAL LARGE NTD-SC #9 (11)	GENERAL LARGE TOD-SC #9 (12)
NET PLANT					
1	PRODUCTION FUNCTION				
2	STEAM PRODUCTION	D	0	0	0
3	MERCHANT FUNCTION	E	309,495	16,972	6,524,715
4					
5	TOTAL PRODUCTION		309,495	16,972	6,524,715
6					
7	TRANSMISSION	D	159,656,551	12,698,147	1,584,215,788
8					
9	SUBSTATION	D	99,432,697	7,963,975	981,788,264
10					
11	HIGH TENSION SYSTEM				
12	HT - DEMAND	D	190,845,019	15,285,565	1,884,384,176
13	HT - CUSTOMER	C	4,494,548	216,860	123,438,012
14					
15	LOW TENSION SYSTEM				
16	O.H. TRANSFORMERS - DEMAND	D	11,093,018	873,944	120,529,416
17	U.G. TRANSFORMERS - DEMAND	D	67,616,947	5,327,081	734,681,155
18	O.H. TRANSFORMERS - CUSTOMER	C	0	0	910,873
19	U.G. TRANSFORMERS - CUSTOMER	C	6,638,593	320,309	181,716,589
20	O.H. LINES DEMAND	D	14,904,321	1,174,210	161,940,528
21	U.G. LINES DEMAND	D	95,456,020	7,520,333	1,037,162,163
22	O.H. LINES CUSTOMER	C	0	0	327,693
23	U.G. LINES CUSTOMER	C	30,868,155	1,489,375	844,946,461
24					
25	TOTAL LOW TENSION DEMAND		189,070,306	14,895,567	2,054,313,261
26	TOTAL LOW TENSION CUSTOMER		37,506,748	1,809,684	1,027,901,616
27					
28	SERVICE COSTS - O.H.	C	0	0	8,899,109
29	SERVICE COSTS - U.G.	C	28,421,094	1,247,927	866,069,420
30	METERING	C	2,736,224	108,722	143,202,337
31	INSTALL. ON CUSTR. PREMISES	C	0	0	5,011,904
32	SERVICES ON CUSTR. PREMISES	C	168,352	7,456	6,076,378
33	STREET LIGHTING NYC	C	0	0	0
34	STREET LIGHTING OTHER	C	0	0	0
35					
36	TOTAL DISTRIBUTION PLANT		552,674,988	41,535,755	7,101,084,478
37					
38	CUSTR. ACCTG. & COLLECTION	C	380,788	7,150	22,846,114
39	PRINTING & MAILING A BILL	C	771	9	57,234
40	RECEIPTS PROCESSING	C	6,493	74	482,200
41	CUSTOMER SERVICE	C	26,695	306	1,982,458
42	UNCOLLECTIBLES	C	0	0	0
43	REVENUE ITEMS	R	0	0	0
44					
45	TOTAL DEMAND	D	639,004,574	50,843,253	6,504,701,490
46	TOTAL ENERGY	E	309,495	16,972	6,524,715
47	TOTAL CUSTOMER	C	73,741,712	3,398,187	2,205,966,783
48	TOTAL REVENUE	R	0	0	0
49					
50	TOTAL		713,055,781	54,258,412	8,717,192,987
			=====	=====	=====

CON ED ELECTRIC 2023 ECOS

RATE BASE

		MULTI-DW. SPACE HTG. NTD-SC #12 (13)	MULTI-DW. SPACE HTG. TOD-SC #12 (14)	BULK POWER TOD-SC #13 (15)	STEAM DEPT. ELECTRIC FACILITIES (16)
NET PLANT					
1	PRODUCTION FUNCTION				
2	STEAM PRODUCTION	D	0	0	140,757,609
3	MERCHANT FUNCTION	E	31,350	31,987	0
4			-----	-----	-----
5	TOTAL PRODUCTION		31,350	31,987	0
6					140,757,609
7	TRANSMISSION	D	8,150,508	10,890,071	19,922
8					0
9	SUBSTATION	D	8,333,647	12,336,501	1,200,560
10					0
11	HIGH TENSION SYSTEM				
12	HT - DEMAND	D	15,995,091	23,677,923	2,304,281
13	HT - CUSTOMER	C	499,282	89,770	2,017
14					0
15	LOW TENSION SYSTEM				
16	O.H. TRANSFORMERS - DEMAND	D	917,038	1,299,641	0
17	U.G. TRANSFORMERS - DEMAND	D	5,589,763	7,921,898	0
18	O.H. TRANSFORMERS - CUSTOMER	C	0	0	0
19	U.G. TRANSFORMERS - CUSTOMER	C	737,456	132,593	0
20	O.H. LINES DEMAND	D	1,232,112	1,746,168	0
21	U.G. LINES DEMAND	D	7,891,165	11,183,482	0
22	O.H. LINES CUSTOMER	C	0	0	0
23	U.G. LINES CUSTOMER	C	3,429,025	616,532	0
24			-----	-----	-----
25	TOTAL LOW TENSION DEMAND		15,630,078	22,151,189	0
26	TOTAL LOW TENSION CUSTOMER		4,166,481	749,125	0
27					
28	SERVICE COSTS - O.H.	C	0	0	0
29	SERVICE COSTS - U.G.	C	3,299,772	574,647	85,624
30	METERING	C	424,828	87,384	7,341
31	INSTALL. ON CUSTR. PREMISES	C	0	0	0
32	SERVICES ON CUSTR. PREMISES	C	21,108	3,958	132
33	STREET LIGHTING NYC	C	0	0	0
34	STREET LIGHTING OTHER	C	0	0	0
35			-----	-----	-----
36	TOTAL DISTRIBUTION PLANT		48,370,288	59,670,496	3,599,956
37					0
38	CUSTR. ACCTG. & COLLECTION	C	68,484	9,479	555
39	PRINTING & MAILING A BILL	C	181	11	0
40	RECEIPTS PROCESSING	C	1,522	96	4
41	CUSTOMER SERVICE	C	6,256	393	15
42	UNCOLLECTIBLES	C	0	0	0
43	REVENUE ITEMS	R	0	0	0
44			-----	-----	-----
45	TOTAL DEMAND	D	48,109,324	69,055,683	3,524,764
46	TOTAL ENERGY	E	31,350	31,987	0
47	TOTAL CUSTOMER	C	8,487,913	1,514,862	95,688
48	TOTAL REVENUE	R	0	0	0
49			-----	-----	-----
50	TOTAL		56,628,588	70,602,533	3,620,452
			=====	=====	=====

CON ED ELECTRIC 2023 ECOS

RATE BASE

			TOTAL SYSTEM (1)	TOTAL CON ED (2)	TOTAL NYP&A (3)	RESIDENTIAL & RELIGIOUS SC #1 (4)
RATE BASE ADJUSTMENTS						
1	PRODUCTION FUNCTION					
2	STEAM PRODUCTION	D S01	(5,166,806)	(5,166,806)	0	0
3	MERCHANT FUNCTION	E U01	(887,136)	(887,136)	0	(659,509)
4						
5	TOTAL PRODUCTION		(6,053,942)	(6,053,942)	0	(659,509)
6						
7	TRANSMISSION	D D03	(894,728,165)	(769,458,969)	(125,269,196)	(310,385,048)
8						
9	SUBSTATION	D D04	(648,024,737)	(553,455,375)	(94,569,362)	(230,498,149)
10						
11	HIGH TENSION SYSTEM					
12	HT - DEMAND	D D04	(1,102,182,414)	(941,335,641)	(160,846,773)	(392,039,056)
13	HT - CUSTOMER	C C03	(90,942,238)	(87,962,701)	(2,979,536)	(49,235,578)
14						
15	LOW TENSION SYSTEM					
16	O.H. TRANSFORMERS - DEMAND	D D08	(64,520,248)	(58,751,192)	(5,769,056)	(27,072,964)
17	U.G. TRANSFORMERS - DEMAND	D D08	(395,238,370)	(359,898,265)	(35,340,104)	(165,843,659)
18	O.H. TRANSFORMERS - CUSTOMER	C C01	(26,690,182)	(26,636,367)	(53,814)	(24,859,616)
19	U.G. TRANSFORMERS - CUSTOMER	C C02	(106,768,796)	(102,722,606)	(4,046,190)	(50,851,469)
20	O.H. LINES DEMAND	D D08	(88,117,314)	(80,238,334)	(7,878,980)	(36,974,390)
21	U.G. LINES DEMAND	D D08	(614,328,441)	(559,398,472)	(54,929,969)	(257,774,762)
22	O.H. LINES CUSTOMER	C C01	(9,760,308)	(9,740,629)	(19,679)	(9,090,890)
23	U.G. LINES CUSTOMER	C C02	(546,603,889)	(525,889,379)	(20,714,509)	(260,334,590)
24						
25	TOTAL LOW TENSION DEMAND		(1,162,204,372)	(1,058,286,263)	(103,918,109)	(487,665,775)
26	TOTAL LOW TENSION CUSTOMER		(689,823,175)	(664,988,982)	(24,834,193)	(345,136,565)
27						
28	SERVICE COSTS - O.H.	C S03	(46,778,122)	(46,565,913)	(212,209)	(41,543,058)
29	SERVICE COSTS - U.G.	C S03A	(381,409,819)	(352,440,544)	(28,969,275)	(100,911,299)
30	METERING	C S04	(116,870,585)	(116,253,783)	(616,802)	(87,418,413)
31	INSTALL. ON CUSTR. PREMISES	C S05	(1,324,065)	(1,324,065)	0	0
32	SERVICES ON CUSTR. PREMISES	C S06	(1,110,331)	(1,100,003)	(10,328)	(860,543)
33	STREET LIGHTING NYC	C S14	(81,970,865)	0	(81,970,865)	0
34	STREET LIGHTING OTHER	C S15	(11,030,168)	(2,413,214)	(8,616,954)	0
35						
36	TOTAL DISTRIBUTION PLANT		(4,333,670,890)	(3,826,126,485)	(507,544,405)	(1,735,308,435)
37						
38	CUSTR. ACCTG. & COLLECTION	C S07	(4,550,355)	(4,536,338)	(14,016)	(3,583,566)
39	PRINTING & MAILING A BILL	C S11	(27,786)	(27,699)	(87)	(23,188)
40	RECEIPTS PROCESSING	C S12	(234,099)	(233,369)	(730)	(195,362)
41	CUSTOMER SERVICE	C S10	6,779,539	6,758,394	21,145	5,657,703
42	UNCOLLECTIBLES	C S09	0	0	0	0
43	REVENUE ITEMS	R R99	0	0	0	0
44						
45	TOTAL DEMAND	D	(3,812,306,493)	(3,327,703,055)	(484,603,439)	(1,420,588,027)
46	TOTAL ENERGY	E	(887,136)	(887,136)	0	(659,509)
47	TOTAL CUSTOMER	C	(1,419,292,068)	(1,271,088,217)	(148,203,851)	(623,249,869)
48	TOTAL REVENUE	R	0	0	0	0
49						
50	TOTAL		(5,232,485,697)	(4,599,678,408)	(632,807,289)	(2,044,497,406)
			=====	=====	=====	=====

CON ED ELECTRIC 2023 ECOS

RATE BASE

			GENERAL SMALL SC #2 (5)	ELECTRIC TRACTION NTD-SC #5 (6)	ELECTRIC TRACTION TOD-SC #5 (7)	ST. LTG. & SIGNAL SC #6 (8)
RATE BASE ADJUSTMENTS						
1	PRODUCTION FUNCTION					
2	STEAM PRODUCTION	D S01	0	0	0	0
3	MERCHANT FUNCTION	E U01	(94,261)	(2)	0	(714)
4						
5	TOTAL PRODUCTION		(94,261)	(2)	0	(714)
6						
7	TRANSMISSION	D D03	(36,719,992)	(4,361)	(1,135,335)	(238)
8						
9	SUBSTATION	D D04	(25,358,862)	(7,308)	(897,146)	(108,748)
10						
11	HIGH TENSION SYSTEM					
12	HT - DEMAND	D D04	(43,131,211)	(12,430)	(1,525,897)	(184,963)
13	HT - CUSTOMER	C C03	(14,373,707)	(2,006)	(182)	0
14						
15	LOW TENSION SYSTEM					
16	O.H. TRANSFORMERS - DEMAND	D D08	(3,775,363)	(734)	(11,952)	(9,420)
17	U.G. TRANSFORMERS - DEMAND	D D08	(23,127,134)	(4,499)	(73,218)	(57,705)
18	O.H. TRANSFORMERS - CUSTOMER	C C01	(1,624,710)	0	0	0
19	U.G. TRANSFORMERS - CUSTOMER	C C02	(18,607,627)	(2,748)	(250)	0
20	O.H. LINES DEMAND	D D08	(5,156,131)	(1,003)	(16,324)	(12,865)
21	U.G. LINES DEMAND	D D08	(35,947,058)	(6,992)	(113,804)	(89,693)
22	O.H. LINES CUSTOMER	C C01	(594,139)	0	0	0
23	U.G. LINES CUSTOMER	C C02	(95,261,927)	(14,071)	(1,279)	0
24						
25	TOTAL LOW TENSION DEMAND		(68,005,687)	(13,228)	(215,297)	(169,684)
26	TOTAL LOW TENSION CUSTOMER		(116,088,403)	(16,819)	(1,529)	0
27						
28	SERVICE COSTS - O.H.	C S03	(3,520,843)	0	0	0
29	SERVICE COSTS - U.G.	C S03A	(69,973,569)	(30,077)	(498)	0
30	METERING	C S04	(13,405,376)	(7,306)	(1,779)	0
31	INSTALL. ON CUSTR. PREMISES	C S05	0	0	0	0
32	SERVICES ON CUSTR. PREMISES	C S06	(122,110)	(26)	(6)	0
33	STREET LIGHTING NYC	C S14	0	0	0	0
34	STREET LIGHTING OTHER	C S15	0	0	0	(2,413,214)
35						
36	TOTAL DISTRIBUTION PLANT		(353,979,767)	(89,201)	(2,642,335)	(2,876,609)
37						
38	CUSTR. ACCTG. & COLLECTION	C S07	(522,264)	(44)	(32)	(3,330)
39	PRINTING & MAILING A BILL	C S11	(3,429)	(0)	(0)	(26)
40	RECEIPTS PROCESSING	C S12	(28,886)	(1)	(0)	(216)
41	CUSTOMER SERVICE	C S10	836,533	15	9	6,258
42	UNCOLLECTIBLES	C S09	0	0	0	0
43	REVENUE ITEMS	R R99	0	0	0	0
44						
45	TOTAL DEMAND	D	(173,215,752)	(37,327)	(3,773,675)	(463,633)
46	TOTAL ENERGY	E	(94,261)	(2)	0	(714)
47	TOTAL CUSTOMER	C	(217,202,053)	(56,265)	(4,018)	(2,410,528)
48	TOTAL REVENUE	R	0	0	0	0
49						
50	TOTAL		(390,512,066)	(93,594)	(3,777,693)	(2,874,874)
			=====	=====	=====	=====

CON ED ELECTRIC 2023 ECOS

RATE BASE

			MULTI-DW. REDISTRIB. NTD-SC #8 (9)	MULTI-DW. REDISTRIB. TOD-SC #8 (10)	GENERAL LARGE NTD-SC #9 (11)	GENERAL LARGE TOD-SC #9 (12)
RATE BASE ADJUSTMENTS						
1	PRODUCTION FUNCTION					
2	STEAM PRODUCTION	D S01	0	0	0	0
3	MERCHANT FUNCTION	E U01	(5,592)	(307)	(117,890)	(7,716)
4			-----	-----	-----	-----
5	TOTAL PRODUCTION		(5,592)	(307)	(117,890)	(7,716)
6						
7	TRANSMISSION	D D03	(28,597,476)	(2,274,476)	(283,762,691)	(103,165,260)
8						
9	SUBSTATION	D D04	(20,140,961)	(1,613,173)	(198,869,788)	(71,531,136)
10						
11	HIGH TENSION SYSTEM					
12	HT - DEMAND	D D04	(34,256,429)	(2,743,739)	(338,244,470)	(121,662,578)
13	HT - CUSTOMER	C C03	(812,641)	(39,210)	(22,318,332)	(1,074,177)
14						
15	LOW TENSION SYSTEM					
16	O.H. TRANSFORMERS - DEMAND	D D08	(1,851,202)	(145,844)	(20,113,938)	(5,399,856)
17	U.G. TRANSFORMERS - DEMAND	D D08	(11,340,099)	(893,409)	(123,214,032)	(33,078,457)
18	O.H. TRANSFORMERS - CUSTOMER	C C01	0	0	(152,006)	(35)
19	U.G. TRANSFORMERS - CUSTOMER	C C02	(1,113,364)	(53,719)	(30,475,851)	(1,471,660)
20	O.H. LINES DEMAND	D D08	(2,528,244)	(199,183)	(27,470,232)	(7,374,752)
21	U.G. LINES DEMAND	D D08	(17,626,186)	(1,388,648)	(191,514,514)	(51,414,636)
22	O.H. LINES CUSTOMER	C C01	0	0	(55,587)	(13)
23	U.G. LINES CUSTOMER	C C02	(5,699,880)	(275,017)	(156,021,418)	(7,534,177)
24			-----	-----	-----	-----
25	TOTAL LOW TENSION DEMAND		(33,345,730)	(2,627,084)	(362,312,715)	(97,267,701)
26	TOTAL LOW TENSION CUSTOMER		(6,813,244)	(328,736)	(186,704,862)	(9,005,885)
27						
28	SERVICE COSTS - O.H.	C S03	0	0	(1,500,019)	(1,993)
29	SERVICE COSTS - U.G.	C S03A	(5,366,926)	(235,654)	(163,545,087)	(11,629,636)
30	METERING	C S04	(281,388)	(11,181)	(14,726,646)	(348,265)
31	INSTALL. ON CUSTR. PREMISES	C S05	0	0	(1,058,458)	(265,607)
32	SERVICES ON CUSTR. PREMISES	C S06	(3,042)	(135)	(109,790)	(3,896)
33	STREET LIGHTING NYC	C S14	0	0	0	0
34	STREET LIGHTING OTHER	C S15	0	0	0	0
35			-----	-----	-----	-----
36	TOTAL DISTRIBUTION PLANT		(101,020,361)	(7,598,910)	(1,289,390,167)	(312,790,874)
37						
38	CUSTR. ACCTG. & COLLECTION	C S07	(6,880)	(129)	(412,790)	(5,883)
39	PRINTING & MAILING A BILL	C S11	(14)	(0)	(1,034)	(5)
40	RECEIPTS PROCESSING	C S12	(117)	(1)	(8,713)	(44)
41	CUSTOMER SERVICE	C S10	3,398	39	252,316	1,276
42	UNCOLLECTIBLES	C S09	0	0	0	0
43	REVENUE ITEMS	R R99	0	0	0	0
44			-----	-----	-----	-----
45	TOTAL DEMAND	D	(116,340,596)	(9,258,471)	(1,183,189,665)	(393,626,675)
46	TOTAL ENERGY	E	(5,592)	(307)	(117,890)	(7,716)
47	TOTAL CUSTOMER	C	(13,280,855)	(615,006)	(390,133,414)	(22,334,115)
48	TOTAL REVENUE	R	0	0	0	0
49			-----	-----	-----	-----
50	TOTAL		(129,627,043)	(9,873,784)	(1,573,440,969)	(415,968,507)
			=====	=====	=====	=====

CON ED ELECTRIC 2023 ECOS

RATE BASE

			MULTI-DW. SPACE HTG. NTD-SC #12 (13)	MULTI-DW. SPACE HTG. TOD-SC #12 (14)	BULK POWER TOD-SC #13 (15)	STEAM DEPT. ELECTRIC FACILITIES (16)
RATE BASE ADJUSTMENTS						
1	PRODUCTION FUNCTION					
2	STEAM PRODUCTION	D S01	0	0	0	(5,166,806)
3	MERCHANT FUNCTION	E U01	(566)	(578)	0	0
4						
5	TOTAL PRODUCTION		(566)	(578)	0	(5,166,806)
6						
7	TRANSMISSION	D D03	(1,459,909)	(1,950,615)	(3,568)	0
8						
9	SUBSTATION	D D04	(1,688,053)	(2,498,866)	(243,184)	0
10						
11	HIGH TENSION SYSTEM					
12	HT - DEMAND	D D04	(2,871,098)	(4,250,156)	(413,615)	0
13	HT - CUSTOMER	C C03	(90,273)	(16,231)	(365)	0
14						
15	LOW TENSION SYSTEM					
16	O.H. TRANSFORMERS - DEMAND	D D08	(153,035)	(216,884)	0	0
17	U.G. TRANSFORMERS - DEMAND	D D08	(937,464)	(1,328,589)	0	0
18	O.H. TRANSFORMERS - CUSTOMER	C C01	0	0	0	0
19	U.G. TRANSFORMERS - CUSTOMER	C C02	(123,679)	(22,237)	0	0
20	O.H. LINES DEMAND	D D08	(209,005)	(296,205)	0	0
21	U.G. LINES DEMAND	D D08	(1,457,123)	(2,065,057)	0	0
22	O.H. LINES CUSTOMER	C C01	0	0	0	0
23	U.G. LINES CUSTOMER	C C02	(633,178)	(113,844)	0	0
24						
25	TOTAL LOW TENSION DEMAND		(2,756,627)	(3,906,735)	0	0
26	TOTAL LOW TENSION CUSTOMER		(756,857)	(136,081)	0	0
27						
28	SERVICE COSTS - O.H.	C S03	0	0	0	0
29	SERVICE COSTS - U.G.	C S03A	(623,116)	(108,514)	(16,169)	0
30	METERING	C S04	(43,688)	(8,986)	(755)	0
31	INSTALL. ON CUSTR. PREMISES	C S05	0	0	0	0
32	SERVICES ON CUSTR. PREMISES	C S06	(381)	(72)	(2)	0
33	STREET LIGHTING NYC	C S14	0	0	0	0
34	STREET LIGHTING OTHER	C S15	0	0	0	0
35						
36	TOTAL DISTRIBUTION PLANT		(8,830,094)	(10,925,641)	(674,090)	0
37						
38	CUSTR. ACCTG. & COLLECTION	C S07	(1,237)	(171)	(10)	0
39	PRINTING & MAILING A BILL	C S11	(3)	(0)	(0)	0
40	RECEIPTS PROCESSING	C S12	(27)	(2)	(0)	0
41	CUSTOMER SERVICE	C S10	796	50	2	0
42	UNCOLLECTIBLES	C S09	0	0	0	0
43	REVENUE ITEMS	R R99	0	0	0	0
44						
45	TOTAL DEMAND	D	(8,775,687)	(12,606,372)	(660,368)	(5,166,806)
46	TOTAL ENERGY	E	(566)	(578)	0	0
47	TOTAL CUSTOMER	C	(1,514,788)	(270,007)	(17,299)	0
48	TOTAL REVENUE	R	0	0	0	0
49						
50	TOTAL		(10,291,041)	(12,876,958)	(677,667)	(5,166,806)
			=====	=====	=====	=====

CON ED ELECTRIC 2023 ECOS

RATE BASE

			TOTAL SYSTEM (1)	TOTAL CON ED (2)	TOTAL NYPA (3)	RESIDENTIAL & RELIGIOUS SC #1 (4)
WORKING CAPITAL						
1	PRODUCTION FUNCTION					
2	STEAM PRODUCTION	D S01	11,902,581	11,902,581	0	0
3	MERCHANT FUNCTION	E U01	9,113,330	9,113,330	0	6,774,980
4						
5	TOTAL PRODUCTION		21,015,911	21,015,911	0	6,774,980
6						
7	TRANSMISSION	D D03	369,354,808	317,642,140	51,712,667	128,130,771
8						
9	SUBSTATION	D D04	233,253,210	199,213,449	34,039,761	82,966,637
10						
11	HIGH TENSION SYSTEM					
12	HT - DEMAND	D D04	433,190,851	369,973,230	63,217,621	154,083,145
13	HT - CUSTOMER	C C03	35,184,948	34,032,186	1,152,763	19,048,919
14						
15	LOW TENSION SYSTEM					
16	O.H. TRANSFORMERS - DEMAND	D D08	22,570,221	20,552,113	2,018,109	9,470,558
17	U.G. TRANSFORMERS - DEMAND	D D08	136,368,398	124,175,064	12,193,334	57,220,745
18	O.H. TRANSFORMERS - CUSTOMER	C C01	9,336,655	9,317,830	18,825	8,696,294
19	U.G. TRANSFORMERS - CUSTOMER	C C02	36,838,249	35,442,200	1,396,050	17,545,193
20	O.H. LINES DEMAND	D D08	40,807,705	37,158,898	3,648,807	17,123,082
21	U.G. LINES DEMAND	D D08	228,882,876	208,417,391	20,465,484	96,040,204
22	O.H. LINES CUSTOMER	C C01	4,520,063	4,510,949	9,114	4,210,051
23	U.G. LINES CUSTOMER	C C02	203,650,461	195,932,771	7,717,690	96,993,930
24						
25	TOTAL LOW TENSION DEMAND		428,629,200	390,303,466	38,325,734	179,854,590
26	TOTAL LOW TENSION CUSTOMER		254,345,428	245,203,749	9,141,679	127,445,467
27						
28	SERVICE COSTS - O.H.	C S03	21,027,917	20,932,524	95,393	18,674,627
29	SERVICE COSTS - U.G.	C S03A	136,303,691	125,950,997	10,352,694	36,062,476
30	METERING	C S04	52,184,752	51,909,339	275,413	39,033,844
31	INSTALL. ON CUSTR. PREMISES	C S05	416,324	416,324	0	0
32	SERVICES ON CUSTR. PREMISES	C S06	9,224,937	9,139,127	85,810	7,149,629
33	STREET LIGHTING NYC	C S14	33,501,969	0	33,501,969	0
34	STREET LIGHTING OTHER	C S15	4,508,094	986,295	3,521,799	0
35						
36	TOTAL DISTRIBUTION PLANT		1,641,771,320	1,448,060,685	193,710,635	664,319,333
37						
38	CUSTR. ACCTG. & COLLECTION	C S07	43,623,425	43,489,052	134,373	34,355,002
39	PRINTING & MAILING A BILL	C S11	3,185,179	3,175,245	9,934	2,658,115
40	RECEIPTS PROCESSING	C S12	3,643,452	3,632,088	11,364	3,040,556
41	CUSTOMER SERVICE	C S10	30,428,076	30,333,173	94,903	25,393,026
42	UNCOLLECTIBLES	C S09	(0)	(0)	0	(0)
43	REVENUE ITEMS	R R99	0	0	0	0
44						
45	TOTAL DEMAND	D	1,476,330,650	1,289,034,866	187,295,783	545,035,143
46	TOTAL ENERGY	E	9,113,330	9,113,330	0	6,774,980
47	TOTAL CUSTOMER	C	627,578,191	569,200,098	58,378,092	312,861,661
48	TOTAL REVENUE	R	0	0	0	0
49						
50	TOTAL		2,113,022,171	1,867,348,295	245,673,876	864,671,784
			=====	=====	=====	=====

CON ED ELECTRIC 2023 ECOS

RATE BASE

			GENERAL SMALL SC #2 (5)	ELECTRIC TRACTION NTD-SC #5 (6)	ELECTRIC TRACTION TOD-SC #5 (7)	ST. LTG. & SIGNAL SC #6 (8)
WORKING CAPITAL						
1	PRODUCTION FUNCTION					
2	STEAM PRODUCTION	D S01	0	0	0	0
3	MERCHANT FUNCTION	E U01	968,321	25	0	7,331
4						
5	TOTAL PRODUCTION		968,321	25	0	7,331
6						
7	TRANSMISSION	D D03	15,158,465	1,800	468,680	98
8						
9	SUBSTATION	D D04	9,127,794	2,630	322,923	39,143
10						
11	HIGH TENSION SYSTEM					
12	HT - DEMAND	D D04	16,951,864	4,885	599,723	72,696
13	HT - CUSTOMER	C C03	5,561,092	776	71	0
14						
15	LOW TENSION SYSTEM					
16	O.H. TRANSFORMERS - DEMAND	D D08	1,320,683	257	4,181	3,295
17	U.G. TRANSFORMERS - DEMAND	D D08	7,979,514	1,552	25,262	19,910
18	O.H. TRANSFORMERS - CUSTOMER	C C01	568,350	0	0	0
19	U.G. TRANSFORMERS - CUSTOMER	C C02	6,420,157	948	86	0
20	O.H. LINES DEMAND	D D08	2,387,838	464	7,560	5,958
21	U.G. LINES DEMAND	D D08	13,392,943	2,605	42,400	33,417
22	O.H. LINES CUSTOMER	C C01	275,150	0	0	0
23	U.G. LINES CUSTOMER	C C02	35,492,128	5,242	477	0
24						
25	TOTAL LOW TENSION DEMAND		25,080,979	4,879	79,403	62,580
26	TOTAL LOW TENSION CUSTOMER		42,755,784	6,191	563	0
27						
28	SERVICE COSTS - O.H.	C S03	1,582,705	0	0	0
29	SERVICE COSTS - U.G.	C S03A	25,006,319	10,749	178	0
30	METERING	C S04	5,985,734	3,262	794	0
31	INSTALL. ON CUSTR. PREMISES	C S05	0	0	0	0
32	SERVICES ON CUSTR. PREMISES	C S06	1,014,521	217	53	0
33	STREET LIGHTING NYC	C S14	0	0	0	0
34	STREET LIGHTING OTHER	C S15	0	0	0	986,295
35						
36	TOTAL DISTRIBUTION PLANT		133,066,792	33,589	1,003,708	1,160,715
37						
38	CUSTR. ACCTG. & COLLECTION	C S07	5,006,854	422	307	31,924
39	PRINTING & MAILING A BILL	C S11	393,022	7	4	2,940
40	RECEIPTS PROCESSING	C S12	449,568	8	5	3,363
41	CUSTOMER SERVICE	C S10	3,754,544	66	42	28,089
42	UNCOLLECTIBLES	C S09	(0)	(0)	(0)	(0)
43	REVENUE ITEMS	R R99	0	0	0	0
44						
45	TOTAL DEMAND	D	66,319,101	14,195	1,470,730	174,518
46	TOTAL ENERGY	E	968,321	25	0	7,331
47	TOTAL CUSTOMER	C	91,510,143	21,698	2,016	1,052,611
48	TOTAL REVENUE	R	0	0	0	0
49						
50	TOTAL		158,797,565	35,918	1,472,746	1,234,460
			=====	=====	=====	=====

CON ED ELECTRIC 2023 ECOS

RATE BASE

			MULTI-DW. REDISTRIB. NTD-SC #8 (9)	MULTI-DW. REDISTRIB. TOD-SC #8 (10)	GENERAL LARGE NTD-SC #9 (11)	GENERAL LARGE TOD-SC #9 (12)
WORKING CAPITAL						
1	PRODUCTION FUNCTION					
2	STEAM PRODUCTION	D S01	0	0	0	0
3	MERCHANT FUNCTION	E U01	57,446	3,150	1,211,059	79,262
4			-----	-----	-----	-----
5	TOTAL PRODUCTION		57,446	3,150	1,211,059	79,262
6						
7	TRANSMISSION	D D03	11,805,390	938,932	117,140,734	42,587,890
8						
9	SUBSTATION	D D04	7,249,637	580,653	71,582,169	25,747,269
10						
11	HIGH TENSION SYSTEM					
12	HT - DEMAND	D D04	13,463,807	1,078,372	132,940,254	47,817,054
13	HT - CUSTOMER	C C03	314,405	15,170	8,634,814	415,592
14						
15	LOW TENSION SYSTEM					
16	O.H. TRANSFORMERS - DEMAND	D D08	647,580	51,018	7,036,179	1,888,957
17	U.G. TRANSFORMERS - DEMAND	D D08	3,912,654	308,251	42,512,320	11,413,002
18	O.H. TRANSFORMERS - CUSTOMER	C C01	0	0	53,174	12
19	U.G. TRANSFORMERS - CUSTOMER	C C02	384,142	18,535	10,515,029	507,764
20	O.H. LINES DEMAND	D D08	1,170,846	92,243	12,721,644	3,415,296
21	U.G. LINES DEMAND	D D08	6,567,061	517,374	71,353,351	19,155,763
22	O.H. LINES CUSTOMER	C C01	0	0	25,743	6
23	U.G. LINES CUSTOMER	C C02	2,123,628	102,464	58,129,542	2,807,039
24			-----	-----	-----	-----
25	TOTAL LOW TENSION DEMAND		12,298,141	968,887	133,623,494	35,873,017
26	TOTAL LOW TENSION CUSTOMER		2,507,770	120,999	68,723,488	3,314,822
27						
28	SERVICE COSTS - O.H.	C S03	0	0	674,296	896
29	SERVICE COSTS - U.G.	C S03A	1,917,968	84,215	58,445,792	4,156,060
30	METERING	C S04	125,645	4,992	6,575,704	155,507
31	INSTALL. ON CUSTR. PREMISES	C S05	0	0	332,809	83,514
32	SERVICES ON CUSTR. PREMISES	C S06	25,272	1,119	912,163	32,371
33	STREET LIGHTING NYC	C S14	0	0	0	0
34	STREET LIGHTING OTHER	C S15	0	0	0	0
35			-----	-----	-----	-----
36	TOTAL DISTRIBUTION PLANT		37,902,645	2,854,408	482,444,984	117,596,101
37						
38	CUSTR. ACCTG. & COLLECTION	C S07	65,959	1,239	3,957,342	56,402
39	PRINTING & MAILING A BILL	C S11	1,596	18	118,544	599
40	RECEIPTS PROCESSING	C S12	1,826	21	135,599	686
41	CUSTOMER SERVICE	C S10	15,249	175	1,132,451	5,726
42	UNCOLLECTIBLES	C S09	(0)	(0)	(0)	(0)
43	REVENUE ITEMS	R R99	0	0	0	0
44			-----	-----	-----	-----
45	TOTAL DEMAND	D	44,816,976	3,566,844	455,286,652	152,025,230
46	TOTAL ENERGY	E	57,446	3,150	1,211,059	79,262
47	TOTAL CUSTOMER	C	4,975,691	227,948	149,643,003	8,222,174
48	TOTAL REVENUE	R	0	0	0	0
49			-----	-----	-----	-----
50	TOTAL		49,850,112	3,797,942	606,140,714	160,326,666
			=====	=====	=====	=====

CON ED ELECTRIC 2023 ECOS

RATE BASE

			MULTI-DW. SPACE HTG. NTD-SC #12 (13)	MULTI-DW. SPACE HTG. TOD-SC #12 (14)	BULK POWER TOD-SC #13 (15)	STEAM DEPT. ELECTRIC FACILITIES (16)
WORKING CAPITAL						
1	PRODUCTION FUNCTION					
2	STEAM PRODUCTION	D S01	0	0	0	11,902,581
3	MERCHANT FUNCTION	E U01	5,819	5,937	0	0
4			-----	-----	-----	-----
5	TOTAL PRODUCTION		5,819	5,937	0	11,902,581
6						
7	TRANSMISSION	D D03	602,668	805,238	1,473	0
8						
9	SUBSTATION	D D04	607,606	899,454	87,533	0
10						
11	HIGH TENSION SYSTEM					
12	HT - DEMAND	D D04	1,128,428	1,670,439	162,563	0
13	HT - CUSTOMER	C C03	34,926	6,280	141	0
14						
15	LOW TENSION SYSTEM					
16	O.H. TRANSFORMERS - DEMAND	D D08	53,534	75,870	0	0
17	U.G. TRANSFORMERS - DEMAND	D D08	323,452	458,401	0	0
18	O.H. TRANSFORMERS - CUSTOMER	C C01	0	0	0	0
19	U.G. TRANSFORMERS - CUSTOMER	C C02	42,673	7,672	0	0
20	O.H. LINES DEMAND	D D08	96,792	137,175	0	0
21	U.G. LINES DEMAND	D D08	542,886	769,387	0	0
22	O.H. LINES CUSTOMER	C C01	0	0	0	0
23	U.G. LINES CUSTOMER	C C02	235,906	42,415	0	0
24			-----	-----	-----	-----
25	TOTAL LOW TENSION DEMAND		1,016,664	1,440,831	0	0
26	TOTAL LOW TENSION CUSTOMER		278,579	50,088	0	0
27						
28	SERVICE COSTS - O.H.	C S03	0	0	0	0
29	SERVICE COSTS - U.G.	C S03A	222,682	38,779	5,778	0
30	METERING	C S04	19,508	4,013	337	0
31	INSTALL. ON CUSTR. PREMISES	C S05	0	0	0	0
32	SERVICES ON CUSTR. PREMISES	C S06	3,169	594	20	0
33	STREET LIGHTING NYC	C S14	0	0	0	0
34	STREET LIGHTING OTHER	C S15	0	0	0	0
35			-----	-----	-----	-----
36	TOTAL DISTRIBUTION PLANT		3,311,560	4,110,478	256,372	0
37						
38	CUSTR. ACCTG. & COLLECTION	C S07	11,863	1,642	96	0
39	PRINTING & MAILING A BILL	C S11	374	23	1	0
40	RECEIPTS PROCESSING	C S12	428	27	1	0
41	CUSTOMER SERVICE	C S10	3,573	224	8	0
42	UNCOLLECTIBLES	C S09	(0)	(0)	(0)	0
43	REVENUE ITEMS	R R99	0	0	0	0
44			-----	-----	-----	-----
45	TOTAL DEMAND	D	3,355,366	4,815,963	251,569	11,902,581
46	TOTAL ENERGY	E	5,819	5,937	0	0
47	TOTAL CUSTOMER	C	575,101	101,670	6,383	0
48	TOTAL REVENUE	R	0	0	0	0
49			-----	-----	-----	-----
50	TOTAL		3,936,285	4,923,570	257,952	11,902,581
			=====	=====	=====	=====

CON ED ELECTRIC 2023 ECOS

RATE BASE

		TOTAL SYSTEM (1)	TOTAL CON ED (2)	TOTAL NYPA (3)	RESIDENTIAL & RELIGIOUS SC #1 (4)
TOTAL RATE BASE					
1	PRODUCTION FUNCTION				
2	STEAM PRODUCTION	D	147,493,383	147,493,383	0
3	MERCHANT FUNCTION	E	57,325,275	57,325,275	0
4					42,616,426
5	TOTAL PRODUCTION		204,818,658	204,818,658	0
6					42,616,426
7	TRANSMISSION	D	4,469,795,242	3,843,987,675	625,807,566
8					1,550,591,191
9	SUBSTATION	D	2,784,422,711	2,378,078,534	406,344,178
10					990,400,897
11	HIGH TENSION SYSTEM				
12	HT - DEMAND	D	5,471,345,635	4,672,885,892	798,459,743
13	HT - CUSTOMER	C	447,225,158	432,572,741	14,652,417
14					1,946,121,758
15	LOW TENSION SYSTEM				
16	O.H. TRANSFORMERS - DEMAND	D	344,676,796	313,857,637	30,819,158
17	U.G. TRANSFORMERS - DEMAND	D	2,097,794,902	1,910,221,284	187,573,617
18	O.H. TRANSFORMERS - CUSTOMER	C	142,582,936	142,295,452	287,484
19	U.G. TRANSFORMERS - CUSTOMER	C	566,693,552	545,217,710	21,475,842
20	O.H. LINES DEMAND	D	472,153,224	429,935,804	42,217,420
21	U.G. LINES DEMAND	D	2,941,499,225	2,678,486,072	263,013,152
22	O.H. LINES CUSTOMER	C	52,298,020	52,192,573	105,446
23	U.G. LINES CUSTOMER	C	2,617,223,635	2,518,039,374	99,184,262
24					1,246,522,127
25	TOTAL LOW TENSION DEMAND		5,856,124,147	5,332,500,798	523,623,348
26	TOTAL LOW TENSION CUSTOMER		3,378,798,144	3,257,745,109	121,053,035
27					2,457,253,981
28	SERVICE COSTS - O.H.	C	251,768,621	250,626,474	1,142,147
29	SERVICE COSTS - U.G.	C	1,774,687,846	1,639,894,723	134,793,123
30	METERING	C	1,071,767,168	1,066,110,761	5,656,408
31	INSTALL. ON CUSTR. PREMISES	C	5,361,838	5,361,838	0
32	SERVICES ON CUSTR. PREMISES	C	69,566,577	68,919,473	647,104
33	STREET LIGHTING NYC	C	461,834,896	0	461,834,896
34	STREET LIGHTING OTHER	C	62,145,453	13,596,375	48,549,078
35					0
36	TOTAL DISTRIBUTION PLANT		21,635,048,193	19,118,292,716	2,516,755,477
37					8,882,562,127
38	CUSTR. ACCTG. & COLLECTION	C	290,915,271	290,019,165	896,106
39	PRINTING & MAILING A BILL	C	4,695,227	4,680,583	14,644
40	RECEIPTS PROCESSING	C	16,365,698	16,314,655	51,043
41	CUSTOMER SERVICE	C	90,474,703	90,192,519	282,184
42	UNCOLLECTIBLES	C	(0)	(0)	0
43	REVENUE ITEMS	R	0	0	0
44					(0)
45	TOTAL DEMAND	D	18,729,181,118	16,374,946,282	2,354,234,836
46	TOTAL ENERGY	E	57,325,275	57,325,275	0
47	TOTAL CUSTOMER	C	7,925,606,599	7,136,034,415	789,572,184
48	TOTAL REVENUE	R	0	0	0
49					0
50	TOTAL		26,712,112,992	23,568,305,972	3,143,807,020
			=====	=====	=====
					10,797,955,294
					=====

CON ED ELECTRIC 2023 ECOS

RATE BASE

		GENERAL SMALL SC #2 (5)	ELECTRIC TRACTION NTD-SC #5 (6)	ELECTRIC TRACTION TOD-SC #5 (7)	ST. LTG. & SIGNAL SC #6 (8)
TOTAL RATE BASE					
1	PRODUCTION FUNCTION				
2	STEAM PRODUCTION	D	0	0	0
3	MERCHANT FUNCTION	E	6,090,998	159	46,112
4					
5	TOTAL PRODUCTION		6,090,998	159	46,112
6					
7	TRANSMISSION	D	183,442,134	21,789	5,671,794
8					1,188
9	SUBSTATION	D	108,961,568	31,401	3,854,844
10					467,268
11	HIGH TENSION SYSTEM				
12	HT - DEMAND	D	214,107,721	61,703	7,574,707
13	HT - CUSTOMER	C	70,685,342	9,865	897
14					918,174
15	LOW TENSION SYSTEM				0
16	O.H. TRANSFORMERS - DEMAND	D	20,168,555	3,923	63,851
17	U.G. TRANSFORMERS - DEMAND	D	122,751,202	23,877	388,615
18	O.H. TRANSFORMERS - CUSTOMER	C	8,679,445	0	0
19	U.G. TRANSFORMERS - CUSTOMER	C	98,763,146	14,588	1,326
20	O.H. LINES DEMAND	D	27,627,761	5,374	87,466
21	U.G. LINES DEMAND	D	172,120,051	33,480	544,910
22	O.H. LINES CUSTOMER	C	3,183,535	0	0
23	U.G. LINES CUSTOMER	C	456,128,784	67,372	6,125
24					0
25	TOTAL LOW TENSION DEMAND		342,667,568	66,653	1,084,842
26	TOTAL LOW TENSION CUSTOMER		566,754,911	81,960	7,451
27					855,003
28	SERVICE COSTS - O.H.	C	18,949,836	0	0
29	SERVICE COSTS - U.G.	C	325,584,807	139,949	2,318
30	METERING	C	122,934,626	67,001	16,313
31	INSTALL. ON CUSTR. PREMISES	C	0	0	0
32	SERVICES ON CUSTR. PREMISES	C	7,650,648	1,634	397
33	STREET LIGHTING NYC	C	0	0	0
34	STREET LIGHTING OTHER	C	0	0	0
35					13,596,375
36	TOTAL DISTRIBUTION PLANT		1,778,297,028	460,167	12,541,768
37					15,836,820
38	CUSTR. ACCTG. & COLLECTION	C	33,389,634	2,816	2,049
39	PRINTING & MAILING A BILL	C	579,348	10	6
40	RECEIPTS PROCESSING	C	2,019,376	36	22
41	CUSTOMER SERVICE	C	11,163,743	198	124
42	UNCOLLECTIBLES	C	(0)	(0)	(0)
43	REVENUE ITEMS	R	0	0	0
44					
45	TOTAL DEMAND	D	849,178,991	181,546	18,186,187
46	TOTAL ENERGY	E	6,090,998	159	0
47	TOTAL CUSTOMER	C	1,159,712,271	303,470	29,576
48	TOTAL REVENUE	R	0	0	0
49					
50	TOTAL		2,014,982,260	485,175	18,215,763
			=====	=====	=====

CON ED ELECTRIC 2023 ECOS

RATE BASE

		MULTI-DW. REDISTRIB. NTD-SC #8 (9)	MULTI-DW. REDISTRIB. TOD-SC #8 (10)	GENERAL LARGE NTD-SC #9 (11)	GENERAL LARGE TOD-SC #9 (12)
TOTAL RATE BASE					
1	PRODUCTION FUNCTION				
2	STEAM PRODUCTION	D	0	0	0
3	MERCHANT FUNCTION	E	361,349	19,815	7,617,884
4					
5	TOTAL PRODUCTION		361,349	19,815	7,617,884
6					
7	TRANSMISSION	D	142,864,466	11,362,603	1,417,593,831
8					
9	SUBSTATION	D	86,541,372	6,931,455	854,500,645
10					
11	HIGH TENSION SYSTEM				
12	HT - DEMAND	D	170,052,398	13,620,198	1,679,079,960
13	HT - CUSTOMER	C	3,996,312	192,820	109,754,495
14					
15	LOW TENSION SYSTEM				
16	O.H. TRANSFORMERS - DEMAND	D	9,889,396	779,118	107,451,657
17	U.G. TRANSFORMERS - DEMAND	D	60,189,503	4,741,923	653,979,443
18	O.H. TRANSFORMERS - CUSTOMER	C	0	0	812,041
19	U.G. TRANSFORMERS - CUSTOMER	C	5,909,371	285,124	161,755,767
20	O.H. LINES DEMAND	D	13,546,924	1,067,270	147,191,940
21	U.G. LINES DEMAND	D	84,396,895	6,649,059	917,001,000
22	O.H. LINES CUSTOMER	C	0	0	297,849
23	U.G. LINES CUSTOMER	C	27,291,903	1,316,822	747,054,586
24					
25	TOTAL LOW TENSION DEMAND		168,022,717	13,237,371	1,825,624,041
26	TOTAL LOW TENSION CUSTOMER		33,201,273	1,601,947	909,920,242
27					
28	SERVICE COSTS - O.H.	C	0	0	8,073,386
29	SERVICE COSTS - U.G.	C	24,972,136	1,096,489	760,970,125
30	METERING	C	2,580,480	102,533	135,051,395
31	INSTALL. ON CUSTR. PREMISES	C	0	0	4,286,256
32	SERVICES ON CUSTR. PREMISES	C	190,582	8,441	6,878,751
33	STREET LIGHTING NYC	C	0	0	0
34	STREET LIGHTING OTHER	C	0	0	0
35					
36	TOTAL DISTRIBUTION PLANT		489,557,272	36,791,253	6,294,139,294
37					
38	CUSTR. ACCTG. & COLLECTION	C	439,866	8,259	26,390,666
39	PRINTING & MAILING A BILL	C	2,353	27	174,744
40	RECEIPTS PROCESSING	C	8,202	94	609,087
41	CUSTOMER SERVICE	C	45,342	519	3,367,225
42	UNCOLLECTIBLES	C	(0)	(0)	(0)
43	REVENUE ITEMS	R	0	0	0
44					
45	TOTAL DEMAND	D	567,480,953	45,151,626	5,776,798,477
46	TOTAL ENERGY	E	361,349	19,815	7,617,884
47	TOTAL CUSTOMER	C	65,436,548	3,011,129	1,965,476,371
48	TOTAL REVENUE	R	0	0	0
49					
50	TOTAL		633,278,850	48,182,570	7,749,892,732
			=====	=====	=====

CON ED ELECTRIC 2023 ECOS

RATE BASE

		MULTI-DW. SPACE HTG. NTD-SC #12 (13)	MULTI-DW. SPACE HTG. TOD-SC #12 (14)	BULK POWER TOD-SC #13 (15)	STEAM DEPT. ELECTRIC FACILITIES (16)
TOTAL RATE BASE					
1	PRODUCTION FUNCTION				
2	STEAM PRODUCTION	D	0	0	147,493,383
3	MERCHANT FUNCTION	E	36,602	37,347	0
4			-----	-----	-----
5	TOTAL PRODUCTION		36,602	37,347	0
6					
7	TRANSMISSION	D	7,293,268	9,744,694	17,827
8					0
9	SUBSTATION	D	7,253,200	10,737,089	1,044,909
10					0
11	HIGH TENSION SYSTEM				
12	HT - DEMAND	D	14,252,421	21,098,206	2,053,229
13	HT - CUSTOMER	C	443,935	79,819	1,794
14					0
15	LOW TENSION SYSTEM				
16	O.H. TRANSFORMERS - DEMAND	D	817,537	1,158,627	0
17	U.G. TRANSFORMERS - DEMAND	D	4,975,750	7,051,710	0
18	O.H. TRANSFORMERS - CUSTOMER	C	0	0	0
19	U.G. TRANSFORMERS - CUSTOMER	C	656,449	118,028	0
20	O.H. LINES DEMAND	D	1,119,898	1,587,137	0
21	U.G. LINES DEMAND	D	6,976,929	9,887,811	0
22	O.H. LINES CUSTOMER	C	0	0	0
23	U.G. LINES CUSTOMER	C	3,031,753	545,103	0
24			-----	-----	-----
25	TOTAL LOW TENSION DEMAND		13,890,115	19,685,285	0
26	TOTAL LOW TENSION CUSTOMER		3,688,203	663,131	0
27					
28	SERVICE COSTS - O.H.	C	0	0	0
29	SERVICE COSTS - U.G.	C	2,899,338	504,912	75,233
30	METERING	C	400,647	82,410	6,924
31	INSTALL. ON CUSTR. PREMISES	C	0	0	0
32	SERVICES ON CUSTR. PREMISES	C	23,896	4,481	149
33	STREET LIGHTING NYC	C	0	0	0
34	STREET LIGHTING OTHER	C	0	0	0
35			-----	-----	-----
36	TOTAL DISTRIBUTION PLANT		42,851,754	52,855,334	3,182,238
37					0
38	CUSTR. ACCTG. & COLLECTION	C	79,109	10,949	641
39	PRINTING & MAILING A BILL	C	551	35	1
40	RECEIPTS PROCESSING	C	1,922	121	4
41	CUSTOMER SERVICE	C	10,625	667	25
42	UNCOLLECTIBLES	C	(0)	(0)	(0)
43	REVENUE ITEMS	R	0	0	0
44			-----	-----	-----
45	TOTAL DEMAND	D	42,689,004	61,265,274	3,115,965
46	TOTAL ENERGY	E	36,602	37,347	0
47	TOTAL CUSTOMER	C	7,548,226	1,346,525	84,771
48	TOTAL REVENUE	R	0	0	0
49			-----	-----	-----
50	TOTAL		50,273,832	62,649,146	3,200,736
			=====	=====	=====

CON ED ELECTRIC 2023 ECOS

OPERATING EXPENSES

			TOTAL SYSTEM (1)	TOTAL CON ED (2)	TOTAL NYPA (3)	RESIDENTIAL & RELIGIOUS SC #1 (4)
OPERATION & MAINTENANCE						
1	PRODUCTION FUNCTION					
2	STEAM PRODUCTION	D S01	(5,353)	(5,353)	0	0
3	MERCHANT FUNCTION	E U01	38,485,531	38,485,531	0	28,610,692
4						
5	TOTAL PRODUCTION		38,480,178	38,480,178	0	28,610,692
6						
7	TRANSMISSION	D D03	216,457,571	186,151,756	30,305,815	75,090,062
8						
9	SUBSTATION	D D04	127,495,712	108,889,651	18,606,062	45,349,389
10						
11	HIGH TENSION SYSTEM					
12	HT - DEMAND	D D04	252,461,362	215,618,463	36,842,899	89,798,851
13	HT - CUSTOMER	C C03	19,110,014	18,483,913	626,100	10,346,046
14						
15	LOW TENSION SYSTEM					
16	O.H. TRANSFORMERS - DEMAND	D D08	5,136,167	4,676,919	459,249	2,155,157
17	U.G. TRANSFORMERS - DEMAND	D D08	25,693,784	23,396,383	2,297,401	10,781,218
18	O.H. TRANSFORMERS - CUSTOMER	C C01	2,124,686	2,120,402	4,284	1,978,962
19	U.G. TRANSFORMERS - CUSTOMER	C C02	6,940,860	6,677,824	263,036	3,305,769
20	O.H. LINES DEMAND	D D08	40,580,840	36,952,318	3,628,522	17,027,889
21	U.G. LINES DEMAND	D D08	106,562,984	97,034,691	9,528,293	44,714,270
22	O.H. LINES CUSTOMER	C C01	4,494,934	4,485,871	9,063	4,186,646
23	U.G. LINES CUSTOMER	C C02	94,815,310	91,222,118	3,593,192	45,158,304
24						
25	TOTAL LOW TENSION DEMAND		177,973,775	162,060,311	15,913,465	74,678,534
26	TOTAL LOW TENSION CUSTOMER		108,375,790	104,506,215	3,869,575	54,629,681
27						
28	SERVICE COSTS - O.H.	C S03	20,895,990	20,801,196	94,795	18,557,464
29	SERVICE COSTS - U.G.	C S03A	52,862,468	48,847,397	4,015,071	13,986,059
30	METERING	C S04	8,954,565	8,907,306	47,259	6,697,955
31	INSTALL. ON CUSTR. PREMISES	C S05	38,417	38,417	0	0
32	SERVICES ON CUSTR. PREMISES	C S06	27,029,104	26,777,681	251,423	20,948,443
33	STREET LIGHTING NYC	C S14	11,515,144	0	11,515,144	0
34	STREET LIGHTING OTHER	C S15	1,549,501	339,005	1,210,497	0
35						
36	TOTAL DISTRIBUTION PLANT		808,261,842	715,269,555	92,992,288	334,992,422
37						
38	CUSTR. ACCTG. & COLLECTION	C S07	157,739,735	157,253,850	485,885	124,225,665
39	PRINTING & MAILING A BILL	C S11	23,354,725	23,281,884	72,842	19,490,130
40	RECEIPTS PROCESSING	C S12	19,138,824	19,079,132	59,692	15,971,850
41	CUSTOMER SERVICE	C S10	194,032,809	193,427,636	605,173	161,925,461
42	UNCOLLECTIBLES	C S09	14,043,903	14,043,903	0	7,237,594
43	REVENUE ITEMS	R R99	0	0	0	0
44						
45	TOTAL DEMAND	D	774,383,067	672,714,827	101,668,240	284,916,836
46	TOTAL ENERGY	E	38,485,531	38,485,531	0	28,610,692
47	TOTAL CUSTOMER	C	658,640,990	635,787,534	22,853,456	454,016,348
48	TOTAL REVENUE	R	0	0	0	0
49						
50	TOTAL		1,471,509,588	1,346,987,892	124,521,695	767,543,876
			=====	=====	=====	=====

CON ED ELECTRIC 2023 ECOS

OPERATING EXPENSES

			GENERAL SMALL SC #2 (5)	ELECTRIC TRACTION NTD-SC #5 (6)	ELECTRIC TRACTION TOD-SC #5 (7)	ST. LTG. & SIGNAL SC #6 (8)
OPERATION & MAINTENANCE						
1	PRODUCTION FUNCTION					
2	STEAM PRODUCTION	D S01	0	0	0	0
3	MERCHANT FUNCTION	E U01	4,089,214	107	0	30,958
4						
5	TOTAL PRODUCTION		4,089,214	107	0	30,958
6						
7	TRANSMISSION	D D03	8,883,503	1,055	274,666	58
8						
9	SUBSTATION	D D04	4,989,233	1,438	176,509	21,396
10						
11	HIGH TENSION SYSTEM					
12	HT - DEMAND	D D04	9,879,458	2,847	349,516	42,367
13	HT - CUSTOMER	C C03	3,020,398	422	38	0
14						
15	LOW TENSION SYSTEM					
16	O.H. TRANSFORMERS - DEMAND	D D08	300,540	58	951	750
17	U.G. TRANSFORMERS - DEMAND	D D08	1,503,456	292	4,760	3,751
18	O.H. TRANSFORMERS - CUSTOMER	C C01	129,336	0	0	0
19	U.G. TRANSFORMERS - CUSTOMER	C C02	1,209,651	179	16	0
20	O.H. LINES DEMAND	D D08	2,374,563	462	7,518	5,925
21	U.G. LINES DEMAND	D D08	6,235,469	1,213	19,741	15,558
22	O.H. LINES CUSTOMER	C C01	273,620	0	0	0
23	U.G. LINES CUSTOMER	C C02	16,524,378	2,441	222	0
24						
25	TOTAL LOW TENSION DEMAND		10,414,028	2,026	32,969	25,984
26	TOTAL LOW TENSION CUSTOMER		18,136,984	2,619	238	0
27						
28	SERVICE COSTS - O.H.	C S03	1,572,776	0	0	0
29	SERVICE COSTS - U.G.	C S03A	9,698,166	4,169	69	0
30	METERING	C S04	1,027,113	560	136	0
31	INSTALL. ON CUSTR. PREMISES	C S05	0	0	0	0
32	SERVICES ON CUSTR. PREMISES	C S06	2,972,551	635	154	0
33	STREET LIGHTING NYC	C S14	0	0	0	0
34	STREET LIGHTING OTHER	C S15	0	0	0	339,005
35						
36	TOTAL DISTRIBUTION PLANT		61,710,705	14,715	559,630	428,752
37						
38	CUSTR. ACCTG. & COLLECTION	C S07	18,104,488	1,527	1,111	115,435
39	PRINTING & MAILING A BILL	C S11	2,881,757	51	32	21,559
40	RECEIPTS PROCESSING	C S12	2,361,554	42	26	17,667
41	CUSTOMER SERVICE	C S10	23,941,857	424	265	179,114
42	UNCOLLECTIBLES	C S09	1,080,183	202	8,266	6,447
43	REVENUE ITEMS	R R99	0	0	0	0
44						
45	TOTAL DEMAND	D	34,166,221	7,366	833,661	89,805
46	TOTAL ENERGY	E	4,089,214	107	0	30,958
47	TOTAL CUSTOMER	C	84,797,826	10,650	10,336	679,228
48	TOTAL REVENUE	R	0	0	0	0
49						
50	TOTAL		123,053,261	18,123	843,997	799,990
			=====	=====	=====	=====

CON ED ELECTRIC 2023 ECOS

OPERATING EXPENSES

			MULTI-DW. REDISTRIB. NTD-SC #8 (9)	MULTI-DW. REDISTRIB. TOD-SC #8 (10)	GENERAL LARGE NTD-SC #9 (11)	GENERAL LARGE TOD-SC #9 (12)
OPERATION & MAINTENANCE						
1	PRODUCTION FUNCTION					
2	STEAM PRODUCTION	D S01	0	0	0	0
3	MERCHANT FUNCTION	E U01	242,593	13,303	5,114,294	334,725
4						
5	TOTAL PRODUCTION		242,593	13,303	5,114,294	334,725
6						
7	TRANSMISSION	D D03	6,918,459	550,254	68,649,435	24,958,309
8						
9	SUBSTATION	D D04	3,962,636	317,384	39,126,663	14,073,403
10						
11	HIGH TENSION SYSTEM					
12	HT - DEMAND	D D04	7,846,636	628,469	77,476,884	27,867,529
13	HT - CUSTOMER	C C03	170,763	8,239	4,689,830	225,721
14						
15	LOW TENSION SYSTEM					
16	O.H. TRANSFORMERS - DEMAND	D D08	147,366	11,610	1,601,180	429,858
17	U.G. TRANSFORMERS - DEMAND	D D08	737,201	58,079	8,009,938	2,150,375
18	O.H. TRANSFORMERS - CUSTOMER	C C01	0	0	12,101	3
19	U.G. TRANSFORMERS - CUSTOMER	C C02	72,378	3,492	1,981,184	95,670
20	O.H. LINES DEMAND	D D08	1,164,337	91,730	12,650,920	3,396,309
21	U.G. LINES DEMAND	D D08	3,057,483	240,878	33,220,598	8,918,514
22	O.H. LINES CUSTOMER	C C01	0	0	25,600	6
23	U.G. LINES CUSTOMER	C C02	988,716	47,705	27,063,874	1,306,898
24						
25	TOTAL LOW TENSION DEMAND		5,106,387	402,298	55,482,636	14,895,057
26	TOTAL LOW TENSION CUSTOMER		1,061,094	51,197	29,082,759	1,402,576
27						
28	SERVICE COSTS - O.H.	C S03	0	0	670,065	890
29	SERVICE COSTS - U.G.	C S03A	743,843	32,661	22,666,949	1,611,839
30	METERING	C S04	21,560	857	1,128,348	26,684
31	INSTALL. ON CUSTR. PREMISES	C S05	0	0	30,711	7,707
32	SERVICES ON CUSTR. PREMISES	C S06	74,048	3,280	2,672,641	94,846
33	STREET LIGHTING NYC	C S14	0	0	0	0
34	STREET LIGHTING OTHER	C S15	0	0	0	0
35						
36	TOTAL DISTRIBUTION PLANT		18,986,967	1,444,385	233,027,485	60,206,251
37						
38	CUSTR. ACCTG. & COLLECTION	C S07	238,504	4,478	14,309,516	203,946
39	PRINTING & MAILING A BILL	C S11	11,704	134	869,200	4,395
40	RECEIPTS PROCESSING	C S12	9,592	110	712,296	3,601
41	CUSTOMER SERVICE	C S10	97,241	1,113	7,221,379	36,512
42	UNCOLLECTIBLES	C S09	330,589	24,980	4,207,288	1,081,800
43	REVENUE ITEMS	R R99	0	0	0	0
44						
45	TOTAL DEMAND	D	23,834,119	1,898,405	240,735,618	81,794,297
46	TOTAL ENERGY	E	242,593	13,303	5,114,294	334,725
47	TOTAL CUSTOMER	C	2,758,937	127,049	88,260,982	4,700,518
48	TOTAL REVENUE	R	0	0	0	0
49						
50	TOTAL		26,835,649	2,038,756	334,110,893	86,829,539
			=====	=====	=====	=====

CON ED ELECTRIC 2023 ECOS

OPERATING EXPENSES

			MULTI-DW. SPACE HTG. NTD-SC #12 (13)	MULTI-DW. SPACE HTG. TOD-SC #12 (14)	BULK POWER TOD-SC #13 (15)	STEAM DEPT. ELECTRIC FACILITIES (16)
OPERATION & MAINTENANCE						
1	PRODUCTION FUNCTION					
2	STEAM PRODUCTION	D S01	0	0	0	(5,353)
3	MERCHANT FUNCTION	E U01	24,573	25,073	0	0
4			-----	-----	-----	-----
5	TOTAL PRODUCTION		24,573	25,073	0	(5,353)
6						
7	TRANSMISSION	D D03	353,189	471,904	863	0
8						
9	SUBSTATION	D D04	332,116	491,640	47,845	0
10						
11	HIGH TENSION SYSTEM					
12	HT - DEMAND	D D04	657,642	973,523	94,741	0
13	HT - CUSTOMER	C C03	18,969	3,411	77	0
14						
15	LOW TENSION SYSTEM					
16	O.H. TRANSFORMERS - DEMAND	D D08	12,182	17,265	0	0
17	U.G. TRANSFORMERS - DEMAND	D D08	60,943	86,369	0	0
18	O.H. TRANSFORMERS - CUSTOMER	C C01	0	0	0	0
19	U.G. TRANSFORMERS - CUSTOMER	C C02	8,040	1,446	0	0
20	O.H. LINES DEMAND	D D08	96,254	136,412	0	0
21	U.G. LINES DEMAND	D D08	252,756	358,210	0	0
22	O.H. LINES CUSTOMER	C C01	0	0	0	0
23	U.G. LINES CUSTOMER	C C02	109,833	19,748	0	0
24			-----	-----	-----	-----
25	TOTAL LOW TENSION DEMAND		422,135	598,257	0	0
26	TOTAL LOW TENSION CUSTOMER		117,873	21,193	0	0
27						
28	SERVICE COSTS - O.H.	C S03	0	0	0	0
29	SERVICE COSTS - U.G.	C S03A	86,362	15,040	2,241	0
30	METERING	C S04	3,347	689	58	0
31	INSTALL. ON CUSTR. PREMISES	C S05	0	0	0	0
32	SERVICES ON CUSTR. PREMISES	C S06	9,284	1,741	58	0
33	STREET LIGHTING NYC	C S14	0	0	0	0
34	STREET LIGHTING OTHER	C S15	0	0	0	0
35			-----	-----	-----	-----
36	TOTAL DISTRIBUTION PLANT		1,647,729	2,105,493	145,020	0
37						
38	CUSTR. ACCTG. & COLLECTION	C S07	42,894	5,937	348	0
39	PRINTING & MAILING A BILL	C S11	2,743	172	6	0
40	RECEIPTS PROCESSING	C S12	2,248	141	5	0
41	CUSTOMER SERVICE	C S10	22,787	1,431	53	0
42	UNCOLLECTIBLES	C S09	27,166	33,890	5,497	0
43	REVENUE ITEMS	R R99	0	0	0	0
44			-----	-----	-----	-----
45	TOTAL DEMAND	D	1,765,082	2,535,323	143,450	(5,353)
46	TOTAL ENERGY	E	24,573	25,073	0	0
47	TOTAL CUSTOMER	C	333,674	83,644	8,343	0
48	TOTAL REVENUE	R	0	0	0	0
49			-----	-----	-----	-----
50	TOTAL		2,123,329	2,644,040	151,792	(5,353)
			=====	=====	=====	=====

CON ED ELECTRIC 2023 ECOS

OPERATING EXPENSES

			TOTAL SYSTEM (1)	TOTAL CON ED (2)	TOTAL NYPA (3)	RESIDENTIAL & RELIGIOUS SC #1 (4)
DEPRECIATION & AMORTIZATION						
1	PRODUCTION FUNCTION					
2	STEAM PRODUCTION	D S01	12,138,889	12,138,889	0	0
3	MERCHANT FUNCTION	E U01	4,332,901	4,332,901	0	3,221,141
4						
5	TOTAL PRODUCTION		16,471,790	16,471,790	0	3,221,141
6						
7	TRANSMISSION	D D03	198,690,296	170,872,044	27,818,252	68,926,518
8						
9	SUBSTATION	D D04	137,611,130	117,528,877	20,082,253	48,947,376
10						
11	HIGH TENSION SYSTEM					
12	HT - DEMAND	D D04	295,719,459	252,563,698	43,155,761	105,185,472
13	HT - CUSTOMER	C C03	21,314,781	20,616,446	698,335	11,539,694
14						
15	LOW TENSION SYSTEM					
16	O.H. TRANSFORMERS - DEMAND	D D08	18,711,921	17,038,801	1,673,120	7,851,600
17	U.G. TRANSFORMERS - DEMAND	D D08	113,533,174	103,381,644	10,151,530	47,638,991
18	O.H. TRANSFORMERS - CUSTOMER	C C01	7,740,587	7,724,980	15,607	7,209,693
19	U.G. TRANSFORMERS - CUSTOMER	C C02	30,669,594	29,507,316	1,162,278	14,607,207
20	O.H. LINES DEMAND	D D08	26,122,574	23,786,833	2,335,741	10,961,140
21	U.G. LINES DEMAND	D D08	138,182,141	125,826,632	12,355,509	57,981,800
22	O.H. LINES CUSTOMER	C C01	2,893,465	2,887,631	5,834	2,695,015
23	U.G. LINES CUSTOMER	C C02	122,948,721	118,289,364	4,659,357	58,557,587
24						
25	TOTAL LOW TENSION DEMAND		296,549,811	270,033,910	26,515,900	124,433,531
26	TOTAL LOW TENSION CUSTOMER		164,252,366	158,409,291	5,843,075	83,069,502
27						
28	SERVICE COSTS - O.H.	C S03	16,000,606	15,928,020	72,587	14,209,936
29	SERVICE COSTS - U.G.	C S03A	108,127,286	99,914,679	8,212,607	28,607,719
30	METERING	C S04	42,922,824	42,696,293	226,531	32,105,984
31	INSTALL. ON CUSTR. PREMISES	C S05	149,193	149,193	0	0
32	SERVICES ON CUSTR. PREMISES	C S06	5,423,021	5,372,576	50,445	4,203,019
33	STREET LIGHTING NYC	C S14	20,391,236	0	20,391,236	0
34	STREET LIGHTING OTHER	C S15	2,743,887	600,316	2,143,571	0
35						
36	TOTAL DISTRIBUTION PLANT		1,111,205,601	983,813,300	127,392,301	452,302,233
37						
38	CUSTR. ACCTG. & COLLECTION	C S07	22,224,601	22,156,142	68,458	17,502,665
39	PRINTING & MAILING A BILL	C S11	135,711	135,288	423	113,254
40	RECEIPTS PROCESSING	C S12	1,143,373	1,139,807	3,566	954,175
41	CUSTOMER SERVICE	C S10	4,700,720	4,686,059	14,661	3,922,874
42	UNCOLLECTIBLES	C S09	0	0	0	0
43	REVENUE ITEMS	R R99	0	0	0	0
44						
45	TOTAL DEMAND	D	940,709,584	823,137,418	117,572,166	347,492,897
46	TOTAL ENERGY	E	4,332,901	4,332,901	0	3,221,141
47	TOTAL CUSTOMER	C	409,529,606	371,804,110	37,725,496	196,228,823
48	TOTAL REVENUE	R	0	0	0	0
49						
50	TOTAL		1,354,572,091	1,199,274,429	155,297,662	546,942,861
			=====	=====	=====	=====

CON ED ELECTRIC 2023 ECOS

OPERATING EXPENSES

			GENERAL SMALL SC #2 (5)	ELECTRIC TRACTION NTD-SC #5 (6)	ELECTRIC TRACTION TOD-SC #5 (7)	ST. LTG. & SIGNAL SC #6 (8)
DEPRECIATION & AMORTIZATION						
1	PRODUCTION FUNCTION					
2	STEAM PRODUCTION	D S01	0	0	0	0
3	MERCHANT FUNCTION	E U01	460,385	12	0	3,485
4			-----	-----	-----	-----
5	TOTAL PRODUCTION		460,385	12	0	3,485
6						
7	TRANSMISSION	D D03	8,154,327	969	252,121	53
8						
9	SUBSTATION	D D04	5,385,075	1,552	190,513	23,093
10						
11	HIGH TENSION SYSTEM					
12	HT - DEMAND	D D04	11,572,257	3,335	409,404	49,626
13	HT - CUSTOMER	C C03	3,368,868	470	43	0
14						
15	LOW TENSION SYSTEM					
16	O.H. TRANSFORMERS - DEMAND	D D08	1,094,917	213	3,466	2,732
17	U.G. TRANSFORMERS - DEMAND	D D08	6,643,325	1,292	21,032	16,576
18	O.H. TRANSFORMERS - CUSTOMER	C C01	471,192	0	0	0
19	U.G. TRANSFORMERS - CUSTOMER	C C02	5,345,086	789	72	0
20	O.H. LINES DEMAND	D D08	1,528,547	297	4,839	3,814
21	U.G. LINES DEMAND	D D08	8,085,645	1,573	25,598	20,175
22	O.H. LINES CUSTOMER	C C01	176,134	0	0	0
23	U.G. LINES CUSTOMER	C C02	21,427,458	3,165	288	0
24			-----	-----	-----	-----
25	TOTAL LOW TENSION DEMAND		17,352,433	3,375	54,936	43,297
26	TOTAL LOW TENSION CUSTOMER		27,419,870	3,954	359	0
27						
28	SERVICE COSTS - O.H.	C S03	1,204,316	0	0	0
29	SERVICE COSTS - U.G.	C S03A	19,837,067	8,527	141	0
30	METERING	C S04	4,923,365	2,683	653	0
31	INSTALL. ON CUSTR. PREMISES	C S05	0	0	0	0
32	SERVICES ON CUSTR. PREMISES	C S06	596,402	127	31	0
33	STREET LIGHTING NYC	C S14	0	0	0	0
34	STREET LIGHTING OTHER	C S15	0	0	0	600,316
35			-----	-----	-----	-----
36	TOTAL DISTRIBUTION PLANT		91,659,653	24,024	656,080	716,332
37						
38	CUSTR. ACCTG. & COLLECTION	C S07	2,550,816	215	157	16,264
39	PRINTING & MAILING A BILL	C S11	16,745	0	0	125
40	RECEIPTS PROCESSING	C S12	141,082	2	2	1,055
41	CUSTOMER SERVICE	C S10	580,025	10	6	4,339
42	UNCOLLECTIBLES	C S09	0	0	0	0
43	REVENUE ITEMS	R R99	0	0	0	0
44			-----	-----	-----	-----
45	TOTAL DEMAND	D	42,464,092	9,231	906,974	116,069
46	TOTAL ENERGY	E	460,385	12	0	3,485
47	TOTAL CUSTOMER	C	60,638,556	15,990	1,392	622,100
48	TOTAL REVENUE	R	0	0	0	0
49			-----	-----	-----	-----
50	TOTAL		103,563,034	25,233	908,366	741,655
			=====	=====	=====	=====

CON ED ELECTRIC 2023 ECOS

OPERATING EXPENSES

			MULTI-DW. REDISTRIB. NTD-SC #8 (9)	MULTI-DW. REDISTRIB. TOD-SC #8 (10)	GENERAL LARGE NTD-SC #9 (11)	GENERAL LARGE TOD-SC #9 (12)
DEPRECIATION & AMORTIZATION						
1	PRODUCTION FUNCTION					
2	STEAM PRODUCTION	D S01	0	0	0	0
3	MERCHANT FUNCTION	E U01	27,312	1,498	575,794	37,685
4			-----	-----	-----	-----
5	TOTAL PRODUCTION		27,312	1,498	575,794	37,685
6						
7	TRANSMISSION	D D03	6,350,578	505,088	63,014,550	22,909,680
8						
9	SUBSTATION	D D04	4,277,029	342,565	42,230,944	15,189,976
10						
11	HIGH TENSION SYSTEM					
12	HT - DEMAND	D D04	9,191,122	736,155	90,752,193	32,642,502
13	HT - CUSTOMER	C C03	190,465	9,190	5,230,907	251,763
14						
15	LOW TENSION SYSTEM					
16	O.H. TRANSFORMERS - DEMAND	D D08	536,879	42,297	5,833,369	1,566,046
17	U.G. TRANSFORMERS - DEMAND	D D08	3,257,471	256,634	35,393,528	9,501,866
18	O.H. TRANSFORMERS - CUSTOMER	C C01	0	0	44,084	10
19	U.G. TRANSFORMERS - CUSTOMER	C C02	319,817	15,431	8,754,262	422,738
20	O.H. LINES DEMAND	D D08	749,504	59,048	8,143,611	2,186,262
21	U.G. LINES DEMAND	D D08	3,964,694	312,351	43,077,748	11,564,798
22	O.H. LINES CUSTOMER	C C01	0	0	16,479	4
23	U.G. LINES CUSTOMER	C C02	1,282,086	61,860	35,094,214	1,694,678
24			-----	-----	-----	-----
25	TOTAL LOW TENSION DEMAND		8,508,547	670,331	92,448,256	24,818,972
26	TOTAL LOW TENSION CUSTOMER		1,601,902	77,291	43,909,039	2,117,429
27						
28	SERVICE COSTS - O.H.	C S03	0	0	513,086	682
29	SERVICE COSTS - U.G.	C S03A	1,521,490	66,806	46,364,004	3,296,929
30	METERING	C S04	103,345	4,106	5,408,626	127,907
31	INSTALL. ON CUSTR. PREMISES	C S05	0	0	119,265	29,928
32	SERVICES ON CUSTR. PREMISES	C S06	14,857	658	536,229	19,030
33	STREET LIGHTING NYC	C S14	0	0	0	0
34	STREET LIGHTING OTHER	C S15	0	0	0	0
35			-----	-----	-----	-----
36	TOTAL DISTRIBUTION PLANT		25,408,755	1,907,102	327,512,549	78,495,118
37						
38	CUSTR. ACCTG. & COLLECTION	C S07	33,604	631	2,016,127	28,735
39	PRINTING & MAILING A BILL	C S11	68	1	5,051	26
40	RECEIPTS PROCESSING	C S12	573	7	42,553	215
41	CUSTOMER SERVICE	C S10	2,356	27	174,948	885
42	UNCOLLECTIBLES	C S09	0	0	0	0
43	REVENUE ITEMS	R R99	0	0	0	0
44			-----	-----	-----	-----
45	TOTAL DEMAND	D	28,327,275	2,254,138	288,445,944	95,561,131
46	TOTAL ENERGY	E	27,312	1,498	575,794	37,685
47	TOTAL CUSTOMER	C	3,468,658	158,717	104,319,834	5,873,527
48	TOTAL REVENUE	R	0	0	0	0
49			-----	-----	-----	-----
50	TOTAL		31,823,246	2,414,353	393,341,572	101,472,343
			=====	=====	=====	=====

CON ED ELECTRIC 2023 ECOS

OPERATING EXPENSES

			MULTI-DW. SPACE HTG. NTD-SC #12 (13)	MULTI-DW. SPACE HTG. TOD-SC #12 (14)	BULK POWER TOD-SC #13 (15)	STEAM DEPT. ELECTRIC FACILITIES (16)
DEPRECIATION & AMORTIZATION						
1	PRODUCTION FUNCTION					
2	STEAM PRODUCTION	D S01	0	0	0	12,138,889
3	MERCHANT FUNCTION	E U01	2,767	2,823	0	0
4			-----	-----	-----	-----
5	TOTAL PRODUCTION		2,767	2,823	0	12,138,889
6						
7	TRANSMISSION	D D03	324,199	433,169	792	0
8						
9	SUBSTATION	D D04	358,466	530,646	51,641	0
10						
11	HIGH TENSION SYSTEM					
12	HT - DEMAND	D D04	770,326	1,140,332	110,974	0
13	HT - CUSTOMER	C C03	21,158	3,804	85	0
14						
15	LOW TENSION SYSTEM					
16	O.H. TRANSFORMERS - DEMAND	D D08	44,383	62,900	0	0
17	U.G. TRANSFORMERS - DEMAND	D D08	269,289	381,640	0	0
18	O.H. TRANSFORMERS - CUSTOMER	C C01	0	0	0	0
19	U.G. TRANSFORMERS - CUSTOMER	C C02	35,527	6,388	0	0
20	O.H. LINES DEMAND	D D08	61,960	87,811	0	0
21	U.G. LINES DEMAND	D D08	327,754	464,497	0	0
22	O.H. LINES CUSTOMER	C C01	0	0	0	0
23	U.G. LINES CUSTOMER	C C02	142,422	25,607	0	0
24			-----	-----	-----	-----
25	TOTAL LOW TENSION DEMAND		703,385	996,848	0	0
26	TOTAL LOW TENSION CUSTOMER		177,949	31,995	0	0
27						
28	SERVICE COSTS - O.H.	C S03	0	0	0	0
29	SERVICE COSTS - U.G.	C S03A	176,649	30,763	4,584	0
30	METERING	C S04	16,045	3,300	277	0
31	INSTALL. ON CUSTR. PREMISES	C S05	0	0	0	0
32	SERVICES ON CUSTR. PREMISES	C S06	1,863	349	12	0
33	STREET LIGHTING NYC	C S14	0	0	0	0
34	STREET LIGHTING OTHER	C S15	0	0	0	0
35			-----	-----	-----	-----
36	TOTAL DISTRIBUTION PLANT		2,225,842	2,738,038	167,574	0
37						
38	CUSTR. ACCTG. & COLLECTION	C S07	6,044	836	49	0
39	PRINTING & MAILING A BILL	C S11	16	1	0	0
40	RECEIPTS PROCESSING	C S12	134	8	0	0
41	CUSTOMER SERVICE	C S10	552	35	1	0
42	UNCOLLECTIBLES	C S09	0	0	0	0
43	REVENUE ITEMS	R R99	0	0	0	0
44			-----	-----	-----	-----
45	TOTAL DEMAND	D	2,156,376	3,100,995	163,408	12,138,889
46	TOTAL ENERGY	E	2,767	2,823	0	0
47	TOTAL CUSTOMER	C	400,411	71,092	5,009	0
48	TOTAL REVENUE	R	0	0	0	0
49			-----	-----	-----	-----
50	TOTAL		2,559,553	3,174,910	168,417	12,138,889
			=====	=====	=====	=====

CON ED ELECTRIC 2023 ECOS

OPERATING EXPENSES

			TOTAL SYSTEM (1)	TOTAL CON ED (2)	TOTAL NYPA (3)	RESIDENTIAL & RELIGIOUS SC #1 (4)
PROPERTY TAXES						
1	PRODUCTION FUNCTION					
2	STEAM PRODUCTION	D S01	2,785,500	2,785,500	0	0
3	MERCHANT FUNCTION	E U01	647,475	647,475	0	481,342
4						
5	TOTAL PRODUCTION		3,432,975	3,432,975	0	481,342
6						
7	TRANSMISSION	D D03	345,803,422	297,388,139	48,415,282	119,960,694
8						
9	SUBSTATION	D D04	230,771,641	197,094,027	33,677,614	82,083,959
10						
11	HIGH TENSION SYSTEM					
12	HT - DEMAND	D D04	400,022,947	341,645,677	58,377,270	142,285,539
13	HT - CUSTOMER	C C03	32,954,796	31,875,099	1,079,696	17,841,527
14						
15	LOW TENSION SYSTEM					
16	O.H. TRANSFORMERS - DEMAND	D D08	24,029,114	21,880,559	2,148,555	10,082,716
17	U.G. TRANSFORMERS - DEMAND	D D08	147,112,645	133,958,618	13,154,027	61,729,076
18	O.H. TRANSFORMERS - CUSTOMER	C C01	9,940,157	9,920,115	20,042	9,258,404
19	U.G. TRANSFORMERS - CUSTOMER	C C02	39,740,676	38,234,634	1,506,042	18,927,550
20	O.H. LINES DEMAND	D D08	32,226,787	29,345,240	2,881,547	13,522,493
21	U.G. LINES DEMAND	D D08	220,214,998	200,524,549	19,690,449	92,403,127
22	O.H. LINES CUSTOMER	C C01	3,569,598	3,562,401	7,197	3,324,774
23	U.G. LINES CUSTOMER	C C02	195,938,144	188,512,725	7,425,418	93,320,734
24						
25	TOTAL LOW TENSION DEMAND		423,583,543	385,708,965	37,874,578	177,737,412
26	TOTAL LOW TENSION CUSTOMER		249,188,575	240,229,875	8,958,700	124,831,463
27						
28	SERVICE COSTS - O.H.	C S03	16,758,618	16,682,593	76,025	14,883,117
29	SERVICE COSTS - U.G.	C S03A	134,815,722	124,576,044	10,239,678	35,668,798
30	METERING	C S04	347,435	345,601	1,834	259,879
31	INSTALL. ON CUSTR. PREMISES	C S05	487,648	487,648	0	0
32	SERVICES ON CUSTR. PREMISES	C S06	810,373	802,835	7,538	628,066
33	STREET LIGHTING NYC	C S14	29,799,078	0	29,799,078	0
34	STREET LIGHTING OTHER	C S15	4,009,825	877,282	3,132,543	0
35						
36	TOTAL DISTRIBUTION PLANT		1,523,550,202	1,340,325,647	183,224,555	596,219,759
37						
38	CUSTR. ACCTG. & COLLECTION	C S07	3,321,069	3,310,839	10,230	2,615,460
39	PRINTING & MAILING A BILL	C S11	20,280	20,216	63	16,924
40	RECEIPTS PROCESSING	C S12	170,857	170,324	533	142,584
41	CUSTOMER SERVICE	C S10	702,438	700,248	2,191	586,203
42	UNCOLLECTIBLES	C S09	0	0	0	0
43	REVENUE ITEMS	R R99	0	0	0	0
44						
45	TOTAL DEMAND	D	1,402,967,053	1,224,622,309	178,344,744	522,067,604
46	TOTAL ENERGY	E	647,475	647,475	0	481,342
47	TOTAL CUSTOMER	C	473,386,713	420,078,604	53,308,110	197,474,021
48	TOTAL REVENUE	R	0	0	0	0
49						
50	TOTAL		1,877,001,241	1,645,348,388	231,652,854	720,022,967
			=====	=====	=====	=====

CON ED ELECTRIC 2023 ECOS

OPERATING EXPENSES

			GENERAL SMALL SC #2 (5)	ELECTRIC TRACTION NTD-SC #5 (6)	ELECTRIC TRACTION TOD-SC #5 (7)	ST. LTG. & SIGNAL SC #6 (8)
PROPERTY TAXES						
1	PRODUCTION FUNCTION					
2	STEAM PRODUCTION	D S01	0	0	0	0
3	MERCHANT FUNCTION	E U01	68,796	2	0	521
4						
5	TOTAL PRODUCTION		68,796	2	0	521
6						
7	TRANSMISSION	D D03	14,191,907	1,686	438,795	92
8						
9	SUBSTATION	D D04	9,030,683	2,603	319,488	38,727
10						
11	HIGH TENSION SYSTEM					
12	HT - DEMAND	D D04	15,653,919	4,511	553,805	67,130
13	HT - CUSTOMER	C C03	5,208,609	727	66	0
14						
15	LOW TENSION SYSTEM					
16	O.H. TRANSFORMERS - DEMAND	D D08	1,406,049	273	4,451	3,508
17	U.G. TRANSFORMERS - DEMAND	D D08	8,608,208	1,674	27,252	21,479
18	O.H. TRANSFORMERS - CUSTOMER	C C01	605,087	0	0	0
19	U.G. TRANSFORMERS - CUSTOMER	C C02	6,925,991	1,023	93	0
20	O.H. LINES DEMAND	D D08	1,885,731	367	5,970	4,705
21	U.G. LINES DEMAND	D D08	12,885,748	2,506	40,795	32,152
22	O.H. LINES CUSTOMER	C C01	217,292	0	0	0
23	U.G. LINES CUSTOMER	C C02	34,148,028	5,044	459	0
24						
25	TOTAL LOW TENSION DEMAND		24,785,735	4,821	78,468	61,844
26	TOTAL LOW TENSION CUSTOMER		41,896,398	6,067	552	0
27						
28	SERVICE COSTS - O.H.	C S03	1,261,369	0	0	0
29	SERVICE COSTS - U.G.	C S03A	24,733,336	10,631	176	0
30	METERING	C S04	39,852	22	5	0
31	INSTALL. ON CUSTR. PREMISES	C S05	0	0	0	0
32	SERVICES ON CUSTR. PREMISES	C S06	89,122	19	5	0
33	STREET LIGHTING NYC	C S14	0	0	0	0
34	STREET LIGHTING OTHER	C S15	0	0	0	877,282
35						
36	TOTAL DISTRIBUTION PLANT		122,699,023	29,401	952,564	1,044,983
37						
38	CUSTR. ACCTG. & COLLECTION	C S07	381,174	32	23	2,430
39	PRINTING & MAILING A BILL	C S11	2,502	0	0	19
40	RECEIPTS PROCESSING	C S12	21,082	0	0	158
41	CUSTOMER SERVICE	C S10	86,674	2	1	648
42	UNCOLLECTIBLES	C S09	0	0	0	0
43	REVENUE ITEMS	R R99	0	0	0	0
44						
45	TOTAL DEMAND	D	63,662,244	13,621	1,390,556	167,793
46	TOTAL ENERGY	E	68,796	2	0	521
47	TOTAL CUSTOMER	C	73,720,118	17,500	828	880,537
48	TOTAL REVENUE	R	0	0	0	0
49						
50	TOTAL		137,451,158	31,122	1,391,384	1,048,851
			=====	=====	=====	=====

CON ED ELECTRIC 2023 ECOS

OPERATING EXPENSES

			MULTI-DW. REDISTRIB. NTD-SC #8 (9)	MULTI-DW. REDISTRIB. TOD-SC #8 (10)	GENERAL LARGE NTD-SC #9 (11)	GENERAL LARGE TOD-SC #9 (12)
PROPERTY TAXES						
1	PRODUCTION FUNCTION					
2	STEAM PRODUCTION	D S01	0	0	0	0
3	MERCHANT FUNCTION	E U01	4,081	224	86,042	5,631
4			-----	-----	-----	-----
5	TOTAL PRODUCTION		4,081	224	86,042	5,631
6						
7	TRANSMISSION	D D03	11,052,636	879,062	109,671,421	39,872,334
8						
9	SUBSTATION	D D04	7,172,508	574,476	70,820,610	25,473,345
10						
11	HIGH TENSION SYSTEM					
12	HT - DEMAND	D D04	12,432,931	995,805	122,761,485	44,155,870
13	HT - CUSTOMER	C C03	294,477	14,208	8,087,508	389,250
14						
15	LOW TENSION SYSTEM					
16	O.H. TRANSFORMERS - DEMAND	D D08	689,438	54,316	7,490,983	2,011,055
17	U.G. TRANSFORMERS - DEMAND	D D08	4,220,926	332,538	45,861,798	12,312,214
18	O.H. TRANSFORMERS - CUSTOMER	C C01	0	0	56,611	13
19	U.G. TRANSFORMERS - CUSTOMER	C C02	414,408	19,995	11,343,492	547,770
20	O.H. LINES DEMAND	D D08	924,644	72,846	10,046,576	2,697,138
21	U.G. LINES DEMAND	D D08	6,318,364	497,781	68,651,173	18,430,327
22	O.H. LINES CUSTOMER	C C01	0	0	20,330	5
23	U.G. LINES CUSTOMER	C C02	2,043,205	98,584	55,928,155	2,700,736
24			-----	-----	-----	-----
25	TOTAL LOW TENSION DEMAND		12,153,372	957,482	132,050,530	35,450,733
26	TOTAL LOW TENSION CUSTOMER		2,457,613	118,579	67,348,587	3,248,524
27						
28	SERVICE COSTS - O.H.	C S03	0	0	537,393	714
29	SERVICE COSTS - U.G.	C S03A	1,897,030	83,296	57,807,764	4,110,691
30	METERING	C S04	837	33	43,780	1,035
31	INSTALL. ON CUSTR. PREMISES	C S05	0	0	389,826	97,822
32	SERVICES ON CUSTR. PREMISES	C S06	2,220	98	80,130	2,844
33	STREET LIGHTING NYC	C S14	0	0	0	0
34	STREET LIGHTING OTHER	C S15	0	0	0	0
35			-----	-----	-----	-----
36	TOTAL DISTRIBUTION PLANT		36,410,989	2,743,977	459,927,614	112,930,827
37						
38	CUSTR. ACCTG. & COLLECTION	C S07	5,021	94	301,274	4,294
39	PRINTING & MAILING A BILL	C S11	10	0	755	4
40	RECEIPTS PROCESSING	C S12	86	1	6,359	32
41	CUSTOMER SERVICE	C S10	352	4	26,143	132
42	UNCOLLECTIBLES	C S09	0	0	0	0
43	REVENUE ITEMS	R R99	0	0	0	0
44			-----	-----	-----	-----
45	TOTAL DEMAND	D	42,811,448	3,406,824	435,304,047	144,952,282
46	TOTAL ENERGY	E	4,081	224	86,042	5,631
47	TOTAL CUSTOMER	C	4,657,647	216,314	134,629,519	7,855,341
48	TOTAL REVENUE	R	0	0	0	0
49			-----	-----	-----	-----
50	TOTAL		47,473,176	3,623,362	570,019,608	152,813,254
			=====	=====	=====	=====

CON ED ELECTRIC 2023 ECOS

OPERATING EXPENSES

			MULTI-DW. SPACE HTG. NTD-SC #12 (13)	MULTI-DW. SPACE HTG. TOD-SC #12 (14)	BULK POWER TOD-SC #13 (15)	STEAM DEPT. ELECTRIC FACILITIES (16)
PROPERTY TAXES						
1	PRODUCTION FUNCTION					
2	STEAM PRODUCTION	D S01	0	0	0	2,785,500
3	MERCHANT FUNCTION	E U01	413	422	0	0
4						
5	TOTAL PRODUCTION		413	422	0	2,785,500
6						
7	TRANSMISSION	D D03	564,240	753,893	1,379	0
8						
9	SUBSTATION	D D04	601,142	889,885	86,602	0
10						
11	HIGH TENSION SYSTEM					
12	HT - DEMAND	D D04	1,042,028	1,542,539	150,116	0
13	HT - CUSTOMER	C C03	32,712	5,882	132	0
14						
15	LOW TENSION SYSTEM					
16	O.H. TRANSFORMERS - DEMAND	D D08	56,995	80,774	0	0
17	U.G. TRANSFORMERS - DEMAND	D D08	348,936	494,517	0	0
18	O.H. TRANSFORMERS - CUSTOMER	C C01	0	0	0	0
19	U.G. TRANSFORMERS - CUSTOMER	C C02	46,035	8,277	0	0
20	O.H. LINES DEMAND	D D08	76,439	108,330	0	0
21	U.G. LINES DEMAND	D D08	522,327	740,250	0	0
22	O.H. LINES CUSTOMER	C C01	0	0	0	0
23	U.G. LINES CUSTOMER	C C02	226,972	40,809	0	0
24						
25	TOTAL LOW TENSION DEMAND		1,004,696	1,423,871	0	0
26	TOTAL LOW TENSION CUSTOMER		273,007	49,086	0	0
27						
28	SERVICE COSTS - O.H.	C S03	0	0	0	0
29	SERVICE COSTS - U.G.	C S03A	220,251	38,356	5,715	0
30	METERING	C S04	130	27	2	0
31	INSTALL. ON CUSTR. PREMISES	C S05	0	0	0	0
32	SERVICES ON CUSTR. PREMISES	C S06	278	52	2	0
33	STREET LIGHTING NYC	C S14	0	0	0	0
34	STREET LIGHTING OTHER	C S15	0	0	0	0
35						
36	TOTAL DISTRIBUTION PLANT		3,174,244	3,949,698	242,569	0
37						
38	CUSTR. ACCTG. & COLLECTION	C S07	903	125	7	0
39	PRINTING & MAILING A BILL	C S11	2	0	0	0
40	RECEIPTS PROCESSING	C S12	20	1	0	0
41	CUSTOMER SERVICE	C S10	82	5	0	0
42	UNCOLLECTIBLES	C S09	0	0	0	0
43	REVENUE ITEMS	R R99	0	0	0	0
44						
45	TOTAL DEMAND	D	3,212,106	4,610,188	238,097	2,785,500
46	TOTAL ENERGY	E	413	422	0	0
47	TOTAL CUSTOMER	C	527,386	93,534	5,859	0
48	TOTAL REVENUE	R	0	0	0	0
49						
50	TOTAL		3,739,905	4,704,144	243,956	2,785,500
			=====	=====	=====	=====

CON ED ELECTRIC 2023 ECOS

OPERATING EXPENSES

			TOTAL SYSTEM (1)	TOTAL CON ED (2)	TOTAL NYPA (3)	RESIDENTIAL & RELIGIOUS SC #1 (4)
PAYROLL & MISC. TAXES						
1	PRODUCTION FUNCTION					
2	STEAM PRODUCTION	D S01	46,086	46,086	0	0
3	MERCHANT FUNCTION	E U01	1,094,642	1,094,642	0	813,772
4						
5	TOTAL PRODUCTION		1,140,728	1,140,728	0	813,772
6						
7	TRANSMISSION	D D03	16,667,275	14,333,722	2,333,554	5,781,949
8						
9	SUBSTATION	D D04	7,036,771	6,009,861	1,026,910	2,502,933
10						
11	HIGH TENSION SYSTEM					
12	HT - DEMAND	D D04	14,287,214	12,202,212	2,085,002	5,081,868
13	HT - CUSTOMER	C C03	1,084,773	1,049,232	35,540	587,289
14						
15	LOW TENSION SYSTEM					
16	O.H. TRANSFORMERS - DEMAND	D D08	348,897	317,701	31,197	146,399
17	U.G. TRANSFORMERS - DEMAND	D D08	1,845,167	1,680,182	164,985	774,240
18	O.H. TRANSFORMERS - CUSTOMER	C C01	144,329	144,038	291	134,430
19	U.G. TRANSFORMERS - CUSTOMER	C C02	498,449	479,560	18,890	237,400
20	O.H. LINES DEMAND	D D08	2,345,672	2,135,934	209,737	984,254
21	U.G. LINES DEMAND	D D08	6,100,736	5,555,241	545,495	2,559,894
22	O.H. LINES CUSTOMER	C C01	259,818	259,294	524	241,998
23	U.G. LINES CUSTOMER	C C02	5,428,181	5,222,471	205,710	2,585,315
24						
25	TOTAL LOW TENSION DEMAND		10,640,472	9,689,058	951,414	4,464,786
26	TOTAL LOW TENSION CUSTOMER		6,330,778	6,105,363	225,415	3,199,143
27						
28	SERVICE COSTS - O.H.	C S03	1,111,322	1,106,280	5,042	986,951
29	SERVICE COSTS - U.G.	C S03A	3,110,515	2,874,262	236,253	822,963
30	METERING	C S04	950,853	945,835	5,018	711,232
31	INSTALL. ON CUSTR. PREMISES	C S05	3,210	3,210	0	0
32	SERVICES ON CUSTR. PREMISES	C S06	1,370,044	1,357,300	12,744	1,061,829
33	STREET LIGHTING NYC	C S14	696,314	0	696,314	0
34	STREET LIGHTING OTHER	C S15	93,697	20,499	73,198	0
35						
36	TOTAL DISTRIBUTION PLANT		46,715,962	41,363,112	5,352,850	19,418,995
37						
38	CUSTR. ACCTG. & COLLECTION	C S07	5,614,708	5,597,413	17,295	4,421,783
39	PRINTING & MAILING A BILL	C S11	34,285	34,178	107	28,612
40	RECEIPTS PROCESSING	C S12	288,856	287,955	901	241,058
41	CUSTOMER SERVICE	C S10	1,187,566	1,183,862	3,704	991,055
42	UNCOLLECTIBLES	C S09	0	0	0	0
43	REVENUE ITEMS	R R99	0	0	0	0
44						
45	TOTAL DEMAND	D	48,677,818	42,280,939	6,396,879	17,831,537
46	TOTAL ENERGY	E	1,094,642	1,094,642	0	813,772
47	TOTAL CUSTOMER	C	21,876,921	20,565,390	1,311,531	13,051,914
48	TOTAL REVENUE	R	0	0	0	0
49						
50	TOTAL		71,649,381	63,940,971	7,708,410	31,697,224
			=====	=====	=====	=====

CON ED ELECTRIC 2023 ECOS

OPERATING EXPENSES

			GENERAL SMALL SC #2 (5)	ELECTRIC TRACTION NTD-SC #5 (6)	ELECTRIC TRACTION TOD-SC #5 (7)	ST. LTG. & SIGNAL SC #6 (8)
PAYROLL & MISC. TAXES						
1	PRODUCTION FUNCTION					
2	STEAM PRODUCTION	D S01	0	0	0	0
3	MERCHANT FUNCTION	E U01	116,309	3	0	881
4						
5	TOTAL PRODUCTION		116,309	3	0	881
6						
7	TRANSMISSION	D D03	684,031	81	21,149	4
8						
9	SUBSTATION	D D04	275,367	79	9,742	1,181
10						
11	HIGH TENSION SYSTEM					
12	HT - DEMAND	D D04	559,095	161	19,780	2,398
13	HT - CUSTOMER	C C03	171,452	24	2	0
14						
15	LOW TENSION SYSTEM					
16	O.H. TRANSFORMERS - DEMAND	D D08	20,416	4	65	51
17	U.G. TRANSFORMERS - DEMAND	D D08	107,969	21	342	269
18	O.H. TRANSFORMERS - CUSTOMER	C C01	8,786	0	0	0
19	U.G. TRANSFORMERS - CUSTOMER	C C02	86,870	13	1	0
20	O.H. LINES DEMAND	D D08	137,256	27	435	342
21	U.G. LINES DEMAND	D D08	356,981	69	1,130	891
22	O.H. LINES CUSTOMER	C C01	15,816	0	0	0
23	U.G. LINES CUSTOMER	C C02	946,021	140	13	0
24						
25	TOTAL LOW TENSION DEMAND		622,621	121	1,971	1,554
26	TOTAL LOW TENSION CUSTOMER		1,057,493	153	14	0
27						
28	SERVICE COSTS - O.H.	C S03	83,646	0	0	0
29	SERVICE COSTS - U.G.	C S03A	570,656	245	4	0
30	METERING	C S04	109,065	59	14	0
31	INSTALL. ON CUSTR. PREMISES	C S05	0	0	0	0
32	SERVICES ON CUSTR. PREMISES	C S06	150,672	32	8	0
33	STREET LIGHTING NYC	C S14	0	0	0	0
34	STREET LIGHTING OTHER	C S15	0	0	0	20,499
35						
36	TOTAL DISTRIBUTION PLANT		3,600,066	875	31,535	25,631
37						
38	CUSTR. ACCTG. & COLLECTION	C S07	644,425	54	40	4,109
39	PRINTING & MAILING A BILL	C S11	4,230	0	0	32
40	RECEIPTS PROCESSING	C S12	35,642	1	0	267
41	CUSTOMER SERVICE	C S10	146,535	3	2	1,096
42	UNCOLLECTIBLES	C S09	0	0	0	0
43	REVENUE ITEMS	R R99	0	0	0	0
44						
45	TOTAL DEMAND	D	2,141,114	443	52,642	5,136
46	TOTAL ENERGY	E	116,309	3	0	881
47	TOTAL CUSTOMER	C	2,973,816	571	84	26,003
48	TOTAL REVENUE	R	0	0	0	0
49						
50	TOTAL		5,231,239	1,017	52,726	32,020
			=====	=====	=====	=====

CON ED ELECTRIC 2023 ECOS

OPERATING EXPENSES

			MULTI-DW. REDISTRIB. NTD-SC #8 (9)	MULTI-DW. REDISTRIB. TOD-SC #8 (10)	GENERAL LARGE NTD-SC #9 (11)	GENERAL LARGE TOD-SC #9 (12)
PAYROLL & MISC. TAXES						
1	PRODUCTION FUNCTION					
2	STEAM PRODUCTION	D S01	0	0	0	0
3	MERCHANT FUNCTION	E U01	6,900	378	145,466	9,521
4			-----	-----	-----	-----
5	TOTAL PRODUCTION		6,900	378	145,466	9,521
6						
7	TRANSMISSION	D D03	532,723	42,370	5,286,020	1,921,795
8						
9	SUBSTATION	D D04	218,707	17,517	2,159,487	776,742
10						
11	HIGH TENSION SYSTEM					
12	HT - DEMAND	D D04	444,054	35,566	4,384,547	1,577,070
13	HT - CUSTOMER	C C03	9,693	468	266,216	12,813
14						
15	LOW TENSION SYSTEM					
16	O.H. TRANSFORMERS - DEMAND	D D08	10,010	789	108,767	29,200
17	U.G. TRANSFORMERS - DEMAND	D D08	52,941	4,171	575,224	154,426
18	O.H. TRANSFORMERS - CUSTOMER	C C01	0	0	822	0
19	U.G. TRANSFORMERS - CUSTOMER	C C02	5,198	251	142,276	6,870
20	O.H. LINES DEMAND	D D08	67,302	5,302	731,254	196,315
21	U.G. LINES DEMAND	D D08	175,041	13,790	1,901,881	510,585
22	O.H. LINES CUSTOMER	C C01	0	0	1,480	0
23	U.G. LINES CUSTOMER	C C02	56,604	2,731	1,549,408	74,820
24			-----	-----	-----	-----
25	TOTAL LOW TENSION DEMAND		305,294	24,052	3,317,126	890,527
26	TOTAL LOW TENSION CUSTOMER		61,802	2,982	1,693,986	81,691
27						
28	SERVICE COSTS - O.H.	C S03	0	0	35,636	47
29	SERVICE COSTS - U.G.	C S03A	43,769	1,922	1,333,761	94,843
30	METERING	C S04	2,289	91	119,815	2,833
31	INSTALL. ON CUSTR. PREMISES	C S05	0	0	2,566	644
32	SERVICES ON CUSTR. PREMISES	C S06	3,753	166	135,470	4,808
33	STREET LIGHTING NYC	C S14	0	0	0	0
34	STREET LIGHTING OTHER	C S15	0	0	0	0
35			-----	-----	-----	-----
36	TOTAL DISTRIBUTION PLANT		1,089,362	82,764	13,448,612	3,442,019
37						
38	CUSTR. ACCTG. & COLLECTION	C S07	8,489	159	509,344	7,259
39	PRINTING & MAILING A BILL	C S11	17	0	1,276	6
40	RECEIPTS PROCESSING	C S12	145	2	10,750	54
41	CUSTOMER SERVICE	C S10	595	7	44,198	223
42	UNCOLLECTIBLES	C S09	0	0	0	0
43	REVENUE ITEMS	R R99	0	0	0	0
44			-----	-----	-----	-----
45	TOTAL DEMAND	D	1,500,778	119,505	15,147,181	5,166,134
46	TOTAL ENERGY	E	6,900	378	145,466	9,521
47	TOTAL CUSTOMER	C	130,553	5,797	4,153,020	205,223
48	TOTAL REVENUE	R	0	0	0	0
49			-----	-----	-----	-----
50	TOTAL		1,638,231	125,680	19,445,666	5,380,878
			=====	=====	=====	=====

CON ED ELECTRIC 2023 ECOS

OPERATING EXPENSES

			MULTI-DW. SPACE HTG. NTD-SC #12 (13)	MULTI-DW. SPACE HTG. TOD-SC #12 (14)	BULK POWER TOD-SC #13 (15)	STEAM DEPT. ELECTRIC FACILITIES (16)
PAYROLL & MISC. TAXES						
1	PRODUCTION FUNCTION					
2	STEAM PRODUCTION	D S01	0	0	0	46,086
3	MERCHANT FUNCTION	E U01	699	713	0	0
4						
5	TOTAL PRODUCTION		699	713	0	46,086
6						
7	TRANSMISSION	D D03	27,196	36,337	66	0
8						
9	SUBSTATION	D D04	18,330	27,135	2,641	0
10						
11	HIGH TENSION SYSTEM					
12	HT - DEMAND	D D04	37,217	55,093	5,362	0
13	HT - CUSTOMER	C C03	1,077	194	4	0
14						
15	LOW TENSION SYSTEM					
16	O.H. TRANSFORMERS - DEMAND	D D08	828	1,173	0	0
17	U.G. TRANSFORMERS - DEMAND	D D08	4,377	6,203	0	0
18	O.H. TRANSFORMERS - CUSTOMER	C C01	0	0	0	0
19	U.G. TRANSFORMERS - CUSTOMER	C C02	577	104	0	0
20	O.H. LINES DEMAND	D D08	5,564	7,885	0	0
21	U.G. LINES DEMAND	D D08	14,470	20,508	0	0
22	O.H. LINES CUSTOMER	C C01	0	0	0	0
23	U.G. LINES CUSTOMER	C C02	6,288	1,131	0	0
24						
25	TOTAL LOW TENSION DEMAND		25,238	35,768	0	0
26	TOTAL LOW TENSION CUSTOMER		6,865	1,234	0	0
27						
28	SERVICE COSTS - O.H.	C S03	0	0	0	0
29	SERVICE COSTS - U.G.	C S03A	5,082	885	132	0
30	METERING	C S04	355	73	6	0
31	INSTALL. ON CUSTR. PREMISES	C S05	0	0	0	0
32	SERVICES ON CUSTR. PREMISES	C S06	471	88	3	0
33	STREET LIGHTING NYC	C S14	0	0	0	0
34	STREET LIGHTING OTHER	C S15	0	0	0	0
35						
36	TOTAL DISTRIBUTION PLANT		94,635	120,470	8,148	0
37						
38	CUSTR. ACCTG. & COLLECTION	C S07	1,527	211	12	0
39	PRINTING & MAILING A BILL	C S11	4	0	0	0
40	RECEIPTS PROCESSING	C S12	34	2	0	0
41	CUSTOMER SERVICE	C S10	139	9	0	0
42	UNCOLLECTIBLES	C S09	0	0	0	0
43	REVENUE ITEMS	R R99	0	0	0	0
44						
45	TOTAL DEMAND	D	107,981	154,332	8,069	46,086
46	TOTAL ENERGY	E	699	713	0	0
47	TOTAL CUSTOMER	C	15,554	2,697	158	0
48	TOTAL REVENUE	R	0	0	0	0
49						
50	TOTAL		124,234	157,742	8,227	46,086
			=====	=====	=====	=====

CON ED ELECTRIC 2023 ECOS

OPERATING EXPENSES

		TOTAL SYSTEM (1)	TOTAL CON ED (2)	TOTAL NYPA (3)	RESIDENTIAL & RELIGIOUS SC #1 (4)
TOTAL OPERATING EXPENSES					
1	PRODUCTION FUNCTION				
2	STEAM PRODUCTION	D	14,965,122	14,965,122	0
3	MERCHANT FUNCTION	E	44,560,549	44,560,549	0
4					33,126,947
5	TOTAL PRODUCTION		59,525,671	59,525,671	0
6					33,126,947
7	TRANSMISSION	D	777,618,563	668,745,661	108,872,902
8					269,759,223
9	SUBSTATION	D	502,915,254	429,522,416	73,392,838
10					178,883,658
11	HIGH TENSION SYSTEM				
12	HT - DEMAND	D	962,490,982	822,030,051	140,460,931
13	HT - CUSTOMER	C	74,464,363	72,024,691	2,439,672
14					342,351,730
15	LOW TENSION SYSTEM				
16	O.H. TRANSFORMERS - DEMAND	D	48,226,100	43,913,979	4,312,120
17	U.G. TRANSFORMERS - DEMAND	D	288,184,769	262,416,826	25,767,943
18	O.H. TRANSFORMERS - CUSTOMER	C	19,949,759	19,909,535	40,224
19	U.G. TRANSFORMERS - CUSTOMER	C	77,849,579	74,899,334	2,950,246
20	O.H. LINES DEMAND	D	101,275,873	92,220,325	9,055,548
21	U.G. LINES DEMAND	D	471,060,860	428,941,113	42,119,747
22	O.H. LINES CUSTOMER	C	11,217,815	11,195,197	22,618
23	U.G. LINES CUSTOMER	C	419,130,355	403,246,678	15,883,677
24					199,621,941
25	TOTAL LOW TENSION DEMAND		908,747,601	827,492,244	81,255,358
26	TOTAL LOW TENSION CUSTOMER		528,147,509	509,250,744	18,896,765
27					381,314,263
28	SERVICE COSTS - O.H.	C	54,766,537	54,518,088	248,448
29	SERVICE COSTS - U.G.	C	298,915,992	276,212,382	22,703,610
30	METERING	C	53,175,678	52,895,035	280,642
31	INSTALL. ON CUSTR. PREMISES	C	678,469	678,469	0
32	SERVICES ON CUSTR. PREMISES	C	34,632,542	34,310,392	322,150
33	STREET LIGHTING NYC	C	62,401,771	0	62,401,771
34	STREET LIGHTING OTHER	C	8,396,911	1,837,102	6,559,808
35					0
36	TOTAL DISTRIBUTION PLANT		3,489,733,607	3,080,771,613	408,961,993
37					1,402,933,409
38	CUSTR. ACCTG. & COLLECTION	C	188,900,113	188,318,244	581,869
39	PRINTING & MAILING A BILL	C	23,545,001	23,471,566	73,435
40	RECEIPTS PROCESSING	C	20,741,910	20,677,217	64,692
41	CUSTOMER SERVICE	C	200,623,534	199,997,805	625,729
42	UNCOLLECTIBLES	C	14,043,903	14,043,903	0
43	REVENUE ITEMS	R	0	0	0
44					7,237,594
45	TOTAL DEMAND	D	3,166,737,523	2,762,755,494	403,982,029
46	TOTAL ENERGY	E	44,560,549	44,560,549	0
47	TOTAL CUSTOMER	C	1,563,434,230	1,448,235,638	115,198,592
48	TOTAL REVENUE	R	0	0	0
49					860,771,107
50	TOTAL		4,774,732,301	4,255,551,680	519,180,621
			=====	=====	=====
					2,066,206,927
					=====

CON ED ELECTRIC 2023 ECOS

OPERATING EXPENSES

		GENERAL SMALL SC #2 (5)	ELECTRIC TRACTION NTD-SC #5 (6)	ELECTRIC TRACTION TOD-SC #5 (7)	ST. LTG. & SIGNAL SC #6 (8)
TOTAL OPERATING EXPENSES					
1	PRODUCTION FUNCTION				
2	STEAM PRODUCTION	D	0	0	0
3	MERCHANT FUNCTION	E	4,734,704	124	35,845
4			-----	-----	-----
5	TOTAL PRODUCTION		4,734,704	124	35,845
6					
7	TRANSMISSION	D	31,913,768	3,791	986,732
8					207
9	SUBSTATION	D	19,680,358	5,672	696,252
10					84,397
11	HIGH TENSION SYSTEM				
12	HT - DEMAND	D	37,664,729	10,854	1,332,503
13	HT - CUSTOMER	C	11,769,327	1,643	149
14					0
15	LOW TENSION SYSTEM				
16	O.H. TRANSFORMERS - DEMAND	D	2,821,921	549	8,934
17	U.G. TRANSFORMERS - DEMAND	D	16,862,958	3,280	53,386
18	O.H. TRANSFORMERS - CUSTOMER	C	1,214,401	0	0
19	U.G. TRANSFORMERS - CUSTOMER	C	13,567,596	2,004	182
20	O.H. LINES DEMAND	D	5,926,097	1,153	18,761
21	U.G. LINES DEMAND	D	27,563,842	5,362	87,264
22	O.H. LINES CUSTOMER	C	682,862	0	0
23	U.G. LINES CUSTOMER	C	73,045,886	10,789	981
24			-----	-----	-----
25	TOTAL LOW TENSION DEMAND		53,174,817	10,343	168,345
26	TOTAL LOW TENSION CUSTOMER		88,510,745	12,793	1,163
27					0
28	SERVICE COSTS - O.H.	C	4,122,106	0	0
29	SERVICE COSTS - U.G.	C	54,839,225	23,572	390
30	METERING	C	6,099,396	3,324	809
31	INSTALL. ON CUSTR. PREMISES	C	0	0	0
32	SERVICES ON CUSTR. PREMISES	C	3,808,746	814	197
33	STREET LIGHTING NYC	C	0	0	0
34	STREET LIGHTING OTHER	C	0	0	0
35			-----	-----	-----
36	TOTAL DISTRIBUTION PLANT		279,669,447	69,015	2,199,810
37					2,215,698
38	CUSTR. ACCTG. & COLLECTION	C	21,680,903	1,829	1,331
39	PRINTING & MAILING A BILL	C	2,905,236	51	32
40	RECEIPTS PROCESSING	C	2,559,360	45	28
41	CUSTOMER SERVICE	C	24,755,091	438	274
42	UNCOLLECTIBLES	C	1,080,183	202	8,266
43	REVENUE ITEMS	R	0	0	0
44			-----	-----	-----
45	TOTAL DEMAND	D	142,433,672	30,660	3,183,833
46	TOTAL ENERGY	E	4,734,704	124	0
47	TOTAL CUSTOMER	C	222,130,316	44,711	12,640
48	TOTAL REVENUE	R	0	0	0
49			-----	-----	-----
50	TOTAL		369,298,692	75,495	3,196,473
			=====	=====	=====

CON ED ELECTRIC 2023 ECOS

OPERATING EXPENSES

		MULTI-DW. REDISTRIB. NTD-SC #8 (9)	MULTI-DW. REDISTRIB. TOD-SC #8 (10)	GENERAL LARGE NTD-SC #9 (11)	GENERAL LARGE TOD-SC #9 (12)
TOTAL OPERATING EXPENSES					
1	PRODUCTION FUNCTION				
2	STEAM PRODUCTION	D	0	0	0
3	MERCHANT FUNCTION	E	280,886	15,403	5,921,595
4					387,562
5	TOTAL PRODUCTION		280,886	15,403	5,921,595
6					387,562
7	TRANSMISSION	D	24,854,396	1,976,773	246,621,426
8					89,662,117
9	SUBSTATION	D	15,630,880	1,251,942	154,337,704
10					55,513,467
11	HIGH TENSION SYSTEM				
12	HT - DEMAND	D	29,914,743	2,395,995	295,375,110
13	HT - CUSTOMER	C	665,398	32,105	18,274,461
14					879,546
15	LOW TENSION SYSTEM				
16	O.H. TRANSFORMERS - DEMAND	D	1,383,693	109,012	15,034,300
17	U.G. TRANSFORMERS - DEMAND	D	8,268,539	651,422	89,840,487
18	O.H. TRANSFORMERS - CUSTOMER	C	0	0	113,618
19	U.G. TRANSFORMERS - CUSTOMER	C	811,800	39,169	22,221,214
20	O.H. LINES DEMAND	D	2,905,787	228,927	31,572,361
21	U.G. LINES DEMAND	D	13,515,582	1,064,801	146,851,400
22	O.H. LINES CUSTOMER	C	0	0	63,888
23	U.G. LINES CUSTOMER	C	4,370,610	210,880	119,635,651
24					5,777,131
25	TOTAL LOW TENSION DEMAND		26,073,600	2,054,162	283,298,548
26	TOTAL LOW TENSION CUSTOMER		5,182,411	250,049	142,034,371
27					6,850,220
28	SERVICE COSTS - O.H.	C	0	0	1,756,181
29	SERVICE COSTS - U.G.	C	4,206,132	184,685	128,172,478
30	METERING	C	128,030	5,087	6,700,569
31	INSTALL. ON CUSTR. PREMISES	C	0	0	542,368
32	SERVICES ON CUSTR. PREMISES	C	94,878	4,202	3,424,470
33	STREET LIGHTING NYC	C	0	0	0
34	STREET LIGHTING OTHER	C	0	0	0
35					0
36	TOTAL DISTRIBUTION PLANT		81,896,073	6,178,227	1,033,916,260
37					255,074,216
38	CUSTR. ACCTG. & COLLECTION	C	285,619	5,363	17,136,260
39	PRINTING & MAILING A BILL	C	11,800	135	876,282
40	RECEIPTS PROCESSING	C	10,395	119	771,958
41	CUSTOMER SERVICE	C	100,544	1,151	7,466,668
42	UNCOLLECTIBLES	C	330,589	24,980	4,207,288
43	REVENUE ITEMS	R	0	0	0
44					0
45	TOTAL DEMAND	D	96,473,619	7,678,872	979,632,789
46	TOTAL ENERGY	E	280,886	15,403	5,921,595
47	TOTAL CUSTOMER	C	11,015,796	507,876	331,363,354
48	TOTAL REVENUE	R	0	0	0
49					0
50	TOTAL		107,770,301	8,202,151	1,316,917,738
			=====	=====	=====

CON ED ELECTRIC 2023 ECOS

OPERATING EXPENSES

		MULTI-DW. SPACE HTG. NTD-SC #12 (13)	MULTI-DW. SPACE HTG. TOD-SC #12 (14)	BULK POWER TOD-SC #13 (15)	STEAM DEPT. ELECTRIC FACILITIES (16)
TOTAL OPERATING EXPENSES					
1	PRODUCTION FUNCTION				
2	STEAM PRODUCTION	D	0	0	14,965,122
3	MERCHANT FUNCTION	E	28,452	29,031	0
4			-----	-----	-----
5	TOTAL PRODUCTION		28,452	29,031	0
6					14,965,122
7	TRANSMISSION	D	1,268,823	1,695,302	3,101
8					0
9	SUBSTATION	D	1,310,054	1,939,305	188,729
10					0
11	HIGH TENSION SYSTEM				
12	HT - DEMAND	D	2,507,213	3,711,488	361,193
13	HT - CUSTOMER	C	73,917	13,290	299
14					0
15	LOW TENSION SYSTEM				
16	O.H. TRANSFORMERS - DEMAND	D	114,387	162,111	0
17	U.G. TRANSFORMERS - DEMAND	D	683,544	968,729	0
18	O.H. TRANSFORMERS - CUSTOMER	C	0	0	0
19	U.G. TRANSFORMERS - CUSTOMER	C	90,180	16,214	0
20	O.H. LINES DEMAND	D	240,216	340,438	0
21	U.G. LINES DEMAND	D	1,117,307	1,583,465	0
22	O.H. LINES CUSTOMER	C	0	0	0
23	U.G. LINES CUSTOMER	C	485,514	87,295	0
24			-----	-----	-----
25	TOTAL LOW TENSION DEMAND		2,155,454	3,054,743	0
26	TOTAL LOW TENSION CUSTOMER		575,694	103,509	0
27					
28	SERVICE COSTS - O.H.	C	0	0	0
29	SERVICE COSTS - U.G.	C	488,344	85,044	12,672
30	METERING	C	19,878	4,089	344
31	INSTALL. ON CUSTR. PREMISES	C	0	0	0
32	SERVICES ON CUSTR. PREMISES	C	11,896	2,231	74
33	STREET LIGHTING NYC	C	0	0	0
34	STREET LIGHTING OTHER	C	0	0	0
35			-----	-----	-----
36	TOTAL DISTRIBUTION PLANT		7,142,450	8,913,698	563,311
37					0
38	CUSTR. ACCTG. & COLLECTION	C	51,368	7,110	416
39	PRINTING & MAILING A BILL	C	2,765	174	6
40	RECEIPTS PROCESSING	C	2,436	153	6
41	CUSTOMER SERVICE	C	23,561	1,479	55
42	UNCOLLECTIBLES	C	27,166	33,890	5,497
43	REVENUE ITEMS	R	0	0	0
44			-----	-----	-----
45	TOTAL DEMAND	D	7,241,545	10,400,839	553,024
46	TOTAL ENERGY	E	28,452	29,031	0
47	TOTAL CUSTOMER	C	1,277,024	250,968	19,368
48	TOTAL REVENUE	R	0	0	0
49			-----	-----	-----
50	TOTAL		8,547,021	10,680,837	572,392
			=====	=====	=====

CON ED ELECTRIC 2023 ECOS

REVENUES

				TOTAL SYSTEM (1)	TOTAL CON ED (2)	TOTAL NYPA (3)	RESIDENTIAL & RELIGIOUS SC #1 (4)
OPERATING REVENUES							
1	REVENUES FROM SALES	R	R01	7,474,419,449	6,665,784,410	808,635,039	2,983,095,774
2	MFC REVENUES	R	R02	45,402,212	45,402,212	0	35,076,933
3	BPP REVENUES	R	R03	43,007,139	43,007,139	0	35,963,778
4	NET MISCELLANEOUS REVENUES	R	R04	334,755,308	322,191,504	12,563,804	152,608,634
5	OTHER REVS. - INTERDEPARTMENTAL RENTS	R	R06	17,914,889	17,914,889	0	0
6	REVENUE ADJUSTMENT	R	R08A	0	0	0	0
7				-----	-----	-----	-----
8	TOTAL OPERATING REVENUES			7,915,498,997	7,094,300,154	821,198,843	3,206,745,119
				=====	=====	=====	=====

CON ED ELECTRIC 2023 ECOS

REVENUES

				GENERAL SMALL SC #2 (5)	ELECTRIC TRACTION NTD-SC #5 (6)	ELECTRIC TRACTION TOD-SC #5 (7)	ST. LTG. & SIGNAL SC #6 (8)
OPERATING REVENUES							
1	REVENUES FROM SALES	R	R01	584,454,407	109,330	4,472,536	3,488,387
2	MFC REVENUES	R	R02	3,876,014	115	0	4,765
3	BPP REVENUES	R	R03	5,560,324	229	69	51,264
4	NET MISCELLANEOUS REVENUES	R	R04	26,913,343	5,034	205,953	160,634
5	OTHER REVS. - INTERDEPARTMENTAL RENTS	R	R06	0	0	0	0
6	REVENUE ADJUSTMENT	R	R08A	0	0	0	0
7				-----	-----	-----	-----
8	TOTAL OPERATING REVENUES			620,804,088	114,708	4,678,559	3,705,050
				=====	=====	=====	=====

CON ED ELECTRIC 2023 ECOS

REVENUES

			MULTI-DW. REDISTRIB. NTD-SC #8 (9)	MULTI-DW. REDISTRIB. TOD-SC #8 (10)	GENERAL LARGE NTD-SC #9 (11)	GENERAL LARGE TOD-SC #9 (12)
OPERATING REVENUES						
1	REVENUES FROM SALES	R R01	178,872,008	13,516,111	2,276,436,634	585,329,666
2	MFC REVENUES	R R02	305,691	17,069	5,474,097	586,327
3	BPP REVENUES	R R03	14,715	115	1,347,439	65,009
4	NET MISCELLANEOUS REVENUES	R R04	8,236,812	622,396	104,826,859	26,953,642
5	OTHER REVS. - INTERDEPARTMENTAL RENTS	R R06	0	0	0	0
6	REVENUE ADJUSTMENT	R R08A	0	0	0	0
7			-----	-----	-----	-----
8	TOTAL OPERATING REVENUES		187,429,227	14,155,691	2,388,085,028	612,934,645
			=====	=====	=====	=====

CON ED ELECTRIC 2023 ECOS

REVENUES

			MULTI-DW. SPACE HTG. NTD-SC #12 (13)	MULTI-DW. SPACE HTG. TOD-SC #12 (14)	BULK POWER TOD-SC #13 (15)	STEAM DEPT. ELECTRIC FACILITIES (16)
OPERATING REVENUES						
1	REVENUES FROM SALES	R R01	14,698,509	18,336,899	2,974,149	0
2	MFC REVENUES	R R02	29,036	32,165	0	0
3	BPP REVENUES	R R03	3,853	328	15	0
4	NET MISCELLANEOUS REVENUES	R R04	676,850	844,389	136,957	0
5	OTHER REVS. - INTERDEPARTMENTAL RENTS	R R06	0	0	0	17,914,889
6	REVENUE ADJUSTMENT	R R08A	0	0	0	0
7			-----	-----	-----	-----
8	TOTAL OPERATING REVENUES		15,408,248	19,213,781	3,111,122	17,914,889
			=====	=====	=====	=====

CON ED ELECTRIC 2023 ECOS

INCOME TAXES

			TOTAL SYSTEM (1)	TOTAL CON ED (2)	TOTAL NYPA (3)	RESIDENTIAL & RELIGIOUS SC #1 (4)
SIT ADJUSTMENTS						
1	PRODUCTION FUNCTION					
2	STEAM PRODUCTION	D S01	(816,192)	(816,192)	0	0
3	MERCHANT FUNCTION	E U01	(299,423)	(299,423)	0	(222,596)
4			-----	-----	-----	-----
5	TOTAL PRODUCTION		(1,115,615)	(1,115,615)	0	(222,596)
6						
7	TRANSMISSION	D D03	(24,774,664)	(21,306,011)	(3,468,654)	(8,594,438)
8						
9	SUBSTATION	D D04	(2,693,516)	(2,300,438)	(393,078)	(958,066)
10						
11	HIGH TENSION SYSTEM					
12	HT - DEMAND	D D04	(28,113,292)	(24,010,585)	(4,102,708)	(9,999,714)
13	HT - CUSTOMER	C C03	(2,289,632)	(2,214,617)	(75,015)	(1,239,593)
14						
15	LOW TENSION SYSTEM					
16	O.H. TRANSFORMERS - DEMAND	D D08	(1,600,314)	(1,457,223)	(143,092)	(671,498)
17	U.G. TRANSFORMERS - DEMAND	D D08	(9,732,510)	(8,862,281)	(870,229)	(4,083,802)
18	O.H. TRANSFORMERS - CUSTOMER	C C01	(662,004)	(660,669)	(1,335)	(616,600)
19	U.G. TRANSFORMERS - CUSTOMER	C C02	(2,629,118)	(2,529,483)	(99,635)	(1,252,187)
20	O.H. LINES DEMAND	D D08	(2,758,028)	(2,511,420)	(246,608)	(1,157,280)
21	U.G. LINES DEMAND	D D08	(16,376,965)	(14,912,624)	(1,464,341)	(6,871,842)
22	O.H. LINES CUSTOMER	C C01	(305,493)	(304,877)	(616)	(284,540)
23	U.G. LINES CUSTOMER	C C02	(14,571,542)	(14,019,328)	(552,214)	(6,940,083)
24			-----	-----	-----	-----
25	TOTAL LOW TENSION DEMAND		(30,467,817)	(27,743,548)	(2,724,270)	(12,784,423)
26	TOTAL LOW TENSION CUSTOMER		(18,168,157)	(17,514,357)	(653,800)	(9,093,411)
27						
28	SERVICE COSTS - O.H.	C S03	(1,385,415)	(1,379,130)	(6,285)	(1,230,369)
29	SERVICE COSTS - U.G.	C S03A	(9,670,555)	(8,936,046)	(734,509)	(2,558,582)
30	METERING	C S04	(3,907,707)	(3,887,084)	(20,623)	(2,922,939)
31	INSTALL. ON CUSTR. PREMISES	C S05	(31,155)	(31,155)	0	0
32	SERVICES ON CUSTR. PREMISES	C S06	(357,682)	(354,355)	(3,327)	(277,215)
33	STREET LIGHTING NYC	C S14	(2,140,501)	0	(2,140,501)	0
34	STREET LIGHTING OTHER	C S15	(288,030)	(63,016)	(225,014)	0
35			-----	-----	-----	-----
36	TOTAL DISTRIBUTION PLANT		(99,513,459)	(88,434,330)	(11,079,129)	(41,064,311)
37						
38	CUSTR. ACCTG. & COLLECTION	C S07	(13,937,028)	(13,894,097)	(42,930)	(10,975,906)
39	PRINTING & MAILING A BILL	C S11	(8,951)	(8,923)	(28)	(7,470)
40	RECEIPTS PROCESSING	C S12	(75,413)	(75,177)	(235)	(62,934)
41	CUSTOMER SERVICE	C S10	(3,216,408)	(3,206,377)	(10,032)	(2,684,177)
42	UNCOLLECTIBLES	C S09	0	0	0	0
43	REVENUE ITEMS	R R99	0	0	0	0
44			-----	-----	-----	-----
45	TOTAL DEMAND	D	(86,865,481)	(76,176,772)	(10,688,709)	(32,336,640)
46	TOTAL ENERGY	E	(299,423)	(299,423)	0	(222,596)
47	TOTAL CUSTOMER	C	(55,476,634)	(51,564,334)	(3,912,299)	(31,052,596)
48	TOTAL REVENUE	R	0	0	0	0
49			-----	-----	-----	-----
50	TOTAL		(142,641,538)	(128,040,530)	(14,601,008)	(63,611,831)
			=====	=====	=====	=====

CON ED ELECTRIC 2023 ECOS

INCOME TAXES

			GENERAL SMALL SC #2 (5)	ELECTRIC TRACTION NTD-SC #5 (6)	ELECTRIC TRACTION TOD-SC #5 (7)	ST. LTG. & SIGNAL SC #6 (8)
SIT ADJUSTMENTS						
1	PRODUCTION FUNCTION					
2	STEAM PRODUCTION	D S01	0	0	0	0
3	MERCHANT FUNCTION	E U01	(31,815)	(1)	0	(241)
4						
5	TOTAL PRODUCTION		(31,815)	(1)	0	(241)
6						
7	TRANSMISSION	D D03	(1,016,762)	(121)	(31,437)	(7)
8						
9	SUBSTATION	D D04	(105,404)	(30)	(3,729)	(452)
10						
11	HIGH TENSION SYSTEM					
12	HT - DEMAND	D D04	(1,100,145)	(317)	(38,921)	(4,718)
13	HT - CUSTOMER	C C03	(361,884)	(51)	(5)	0
14						
15	LOW TENSION SYSTEM					
16	O.H. TRANSFORMERS - DEMAND	D D08	(93,641)	(18)	(296)	(234)
17	U.G. TRANSFORMERS - DEMAND	D D08	(569,492)	(111)	(1,803)	(1,421)
18	O.H. TRANSFORMERS - CUSTOMER	C C01	(40,298)	0	0	0
19	U.G. TRANSFORMERS - CUSTOMER	C C02	(458,202)	(68)	(6)	0
20	O.H. LINES DEMAND	D D08	(161,384)	(31)	(511)	(403)
21	U.G. LINES DEMAND	D D08	(958,288)	(186)	(3,034)	(2,391)
22	O.H. LINES CUSTOMER	C C01	(18,596)	0	0	0
23	U.G. LINES CUSTOMER	C C02	(2,539,523)	(375)	(34)	0
24						
25	TOTAL LOW TENSION DEMAND		(1,782,806)	(347)	(5,644)	(4,448)
26	TOTAL LOW TENSION CUSTOMER		(3,056,619)	(443)	(40)	0
27						
28	SERVICE COSTS - O.H.	C S03	(104,276)	0	0	0
29	SERVICE COSTS - U.G.	C S03A	(1,774,163)	(763)	(13)	0
30	METERING	C S04	(448,225)	(244)	(59)	0
31	INSTALL. ON CUSTR. PREMISES	C S05	0	0	0	0
32	SERVICES ON CUSTR. PREMISES	C S06	(39,336)	(8)	(2)	0
33	STREET LIGHTING NYC	C S14	0	0	0	0
34	STREET LIGHTING OTHER	C S15	0	0	0	(63,016)
35						
36	TOTAL DISTRIBUTION PLANT		(8,772,858)	(2,203)	(48,413)	(72,634)
37						
38	CUSTR. ACCTG. & COLLECTION	C S07	(1,599,614)	(135)	(98)	(10,199)
39	PRINTING & MAILING A BILL	C S11	(1,104)	(0)	(0)	(8)
40	RECEIPTS PROCESSING	C S12	(9,305)	(0)	(0)	(70)
41	CUSTOMER SERVICE	C S10	(396,875)	(7)	(4)	(2,969)
42	UNCOLLECTIBLES	C S09	0	0	0	0
43	REVENUE ITEMS	R R99	0	0	0	0
44						
45	TOTAL DEMAND	D	(4,005,117)	(815)	(79,731)	(9,625)
46	TOTAL ENERGY	E	(31,815)	(1)	0	(241)
47	TOTAL CUSTOMER	C	(7,791,402)	(1,651)	(222)	(76,262)
48	TOTAL REVENUE	R	0	0	0	0
49						
50	TOTAL		(11,828,334)	(2,467)	(79,953)	(86,128)
			=====	=====	=====	=====

CON ED ELECTRIC 2023 ECOS

INCOME TAXES

			MULTI-DW. REDISTRIB. NTD-SC #8 (9)	MULTI-DW. REDISTRIB. TOD-SC #8 (10)	GENERAL LARGE NTD-SC #9 (11)	GENERAL LARGE TOD-SC #9 (12)
SIT ADJUSTMENTS						
1	PRODUCTION FUNCTION					
2	STEAM PRODUCTION	D S01	0	0	0	0
3	MERCHANT FUNCTION	E U01	(1,887)	(103)	(39,790)	(2,604)
4			-----	-----	-----	-----
5	TOTAL PRODUCTION		(1,887)	(103)	(39,790)	(2,604)
6						
7	TRANSMISSION	D D03	(791,853)	(62,979)	(7,857,275)	(2,856,605)
8						
9	SUBSTATION	D D04	(83,716)	(6,705)	(826,602)	(297,319)
10						
11	HIGH TENSION SYSTEM					
12	HT - DEMAND	D D04	(873,776)	(69,984)	(8,627,579)	(3,103,239)
13	HT - CUSTOMER	C C03	(20,460)	(987)	(561,904)	(27,044)
14						
15	LOW TENSION SYSTEM					
16	O.H. TRANSFORMERS - DEMAND	D D08	(45,916)	(3,617)	(498,892)	(133,934)
17	U.G. TRANSFORMERS - DEMAND	D D08	(279,243)	(22,000)	(3,034,072)	(814,537)
18	O.H. TRANSFORMERS - CUSTOMER	C C01	0	0	(3,770)	(1)
19	U.G. TRANSFORMERS - CUSTOMER	C C02	(27,416)	(1,323)	(750,450)	(36,239)
20	O.H. LINES DEMAND	D D08	(79,133)	(6,234)	(859,805)	(230,826)
21	U.G. LINES DEMAND	D D08	(469,885)	(37,019)	(5,105,455)	(1,370,628)
22	O.H. LINES CUSTOMER	C C01	0	0	(1,740)	(0)
23	U.G. LINES CUSTOMER	C C02	(151,949)	(7,331)	(4,159,269)	(200,849)
24			-----	-----	-----	-----
25	TOTAL LOW TENSION DEMAND		(874,176)	(68,870)	(9,498,224)	(2,549,925)
26	TOTAL LOW TENSION CUSTOMER		(179,365)	(8,654)	(4,915,229)	(237,089)
27						
28	SERVICE COSTS - O.H.	C S03	0	0	(44,426)	(59)
29	SERVICE COSTS - U.G.	C S03A	(136,077)	(5,975)	(4,146,647)	(294,867)
30	METERING	C S04	(9,409)	(374)	(492,403)	(11,645)
31	INSTALL. ON CUSTR. PREMISES	C S05	0	0	(24,905)	(6,250)
32	SERVICES ON CUSTR. PREMISES	C S06	(980)	(43)	(35,368)	(1,255)
33	STREET LIGHTING NYC	C S14	0	0	0	0
34	STREET LIGHTING OTHER	C S15	0	0	0	0
35			-----	-----	-----	-----
36	TOTAL DISTRIBUTION PLANT		(2,177,959)	(161,594)	(29,173,286)	(6,528,692)
37						
38	CUSTR. ACCTG. & COLLECTION	C S07	(21,073)	(396)	(1,264,311)	(18,020)
39	PRINTING & MAILING A BILL	C S11	(4)	(0)	(333)	(2)
40	RECEIPTS PROCESSING	C S12	(38)	(0)	(2,807)	(14)
41	CUSTOMER SERVICE	C S10	(1,612)	(18)	(119,706)	(605)
42	UNCOLLECTIBLES	C S09	0	0	0	0
43	REVENUE ITEMS	R R99	0	0	0	0
44			-----	-----	-----	-----
45	TOTAL DEMAND	D	(2,623,521)	(208,539)	(26,809,681)	(8,807,089)
46	TOTAL ENERGY	E	(1,887)	(103)	(39,790)	(2,604)
47	TOTAL CUSTOMER	C	(369,018)	(16,448)	(11,608,038)	(596,849)
48	TOTAL REVENUE	R	0	0	0	0
49			-----	-----	-----	-----
50	TOTAL		(2,994,426)	(225,091)	(38,457,509)	(9,406,542)
			=====	=====	=====	=====

CON ED ELECTRIC 2023 ECOS

INCOME TAXES

			MULTI-DW. SPACE HTG. NTD-SC #12 (13)	MULTI-DW. SPACE HTG. TOD-SC #12 (14)	BULK POWER TOD-SC #13 (15)	STEAM DEPT. ELECTRIC FACILITIES (16)
SIT ADJUSTMENTS						
1	PRODUCTION FUNCTION					
2	STEAM PRODUCTION	D S01	0	0	0	(816,192)
3	MERCHANT FUNCTION	E U01	(191)	(195)	0	0
4			-----	-----	-----	-----
5	TOTAL PRODUCTION		(191)	(195)	0	(816,192)
6						
7	TRANSMISSION	D D03	(40,424)	(54,012)	(99)	0
8						
9	SUBSTATION	D D04	(7,016)	(10,387)	(1,011)	0
10						
11	HIGH TENSION SYSTEM					
12	HT - DEMAND	D D04	(73,233)	(108,408)	(10,550)	0
13	HT - CUSTOMER	C C03	(2,273)	(409)	(9)	0
14						
15	LOW TENSION SYSTEM					
16	O.H. TRANSFORMERS - DEMAND	D D08	(3,796)	(5,379)	0	0
17	U.G. TRANSFORMERS - DEMAND	D D08	(23,084)	(32,716)	0	0
18	O.H. TRANSFORMERS - CUSTOMER	C C01	0	0	0	0
19	U.G. TRANSFORMERS - CUSTOMER	C C02	(3,046)	(548)	0	0
20	O.H. LINES DEMAND	D D08	(6,542)	(9,271)	0	0
21	U.G. LINES DEMAND	D D08	(38,844)	(55,051)	0	0
22	O.H. LINES CUSTOMER	C C01	0	0	0	0
23	U.G. LINES CUSTOMER	C C02	(16,879)	(3,035)	0	0
24			-----	-----	-----	-----
25	TOTAL LOW TENSION DEMAND		(72,266)	(102,417)	0	0
26	TOTAL LOW TENSION CUSTOMER		(19,925)	(3,582)	0	0
27						
28	SERVICE COSTS - O.H.	C S03	0	0	0	0
29	SERVICE COSTS - U.G.	C S03A	(15,799)	(2,751)	(410)	0
30	METERING	C S04	(1,461)	(300)	(25)	0
31	INSTALL. ON CUSTR. PREMISES	C S05	0	0	0	0
32	SERVICES ON CUSTR. PREMISES	C S06	(123)	(23)	(1)	0
33	STREET LIGHTING NYC	C S14	0	0	0	0
34	STREET LIGHTING OTHER	C S15	0	0	0	0
35			-----	-----	-----	-----
36	TOTAL DISTRIBUTION PLANT		(192,096)	(228,278)	(12,006)	0
37						
38	CUSTR. ACCTG. & COLLECTION	C S07	(3,790)	(525)	(31)	0
39	PRINTING & MAILING A BILL	C S11	(1)	(0)	(0)	0
40	RECEIPTS PROCESSING	C S12	(9)	(1)	(0)	0
41	CUSTOMER SERVICE	C S10	(378)	(24)	(1)	0
42	UNCOLLECTIBLES	C S09	0	0	0	0
43	REVENUE ITEMS	R R99	0	0	0	0
44			-----	-----	-----	-----
45	TOTAL DEMAND	D	(192,940)	(275,224)	(11,660)	(816,192)
46	TOTAL ENERGY	E	(191)	(195)	0	0
47	TOTAL CUSTOMER	C	(43,758)	(7,615)	(477)	0
48	TOTAL REVENUE	R	0	0	0	0
49			-----	-----	-----	-----
50	TOTAL		(236,889)	(283,034)	(12,136)	(816,192)
			=====	=====	=====	=====

CON ED ELECTRIC 2023 ECOS

INCOME TAXES

		TOTAL SYSTEM (1)	TOTAL CON ED (2)	TOTAL NYPA (3)	RESIDENTIAL & RELIGIOUS SC #1 (4)
STATE INCOME TAX COMPUTATION					
1	PRODUCTION FUNCTION				
2	STEAM PRODUCTION	D	(1,788,925)	(1,788,925)	0
3	MERCHANT FUNCTION	E	(3,195,859)	(3,195,859)	0
4					(2,375,847)
5	TOTAL PRODUCTION		(4,984,784)	(4,984,784)	0
6					(2,375,847)
7	TRANSMISSION	D	(75,319,871)	(64,774,479)	(10,545,392)
8					(26,128,787)
9	SUBSTATION	D	(35,383,007)	(30,219,395)	(5,163,612)
10					(12,585,504)
11	HIGH TENSION SYSTEM				
12	HT - DEMAND	D	(90,675,206)	(77,442,538)	(13,232,668)
13	HT - CUSTOMER	C	(7,129,815)	(6,896,222)	(233,594)
14					(3,860,039)
15	LOW TENSION SYSTEM				
16	O.H. TRANSFORMERS - DEMAND	D	(4,735,011)	(4,311,631)	(423,379)
17	U.G. TRANSFORMERS - DEMAND	D	(28,464,520)	(25,919,375)	(2,545,145)
18	O.H. TRANSFORMERS - CUSTOMER	C	(1,958,739)	(1,954,789)	(3,949)
19	U.G. TRANSFORMERS - CUSTOMER	C	(7,689,341)	(7,397,940)	(291,401)
20	O.H. LINES DEMAND	D	(9,340,960)	(8,505,741)	(835,219)
21	U.G. LINES DEMAND	D	(46,995,921)	(42,793,796)	(4,202,124)
22	O.H. LINES CUSTOMER	C	(1,034,651)	(1,032,565)	(2,086)
23	U.G. LINES CUSTOMER	C	(41,815,015)	(40,230,362)	(1,584,653)
24					(19,915,509)
25	TOTAL LOW TENSION DEMAND		(89,536,411)	(81,530,544)	(8,005,868)
26	TOTAL LOW TENSION CUSTOMER		(52,497,745)	(50,615,656)	(1,882,090)
27					(26,365,847)
28	SERVICE COSTS - O.H.	C	(4,945,239)	(4,922,805)	(22,434)
29	SERVICE COSTS - U.G.	C	(29,100,094)	(26,889,851)	(2,210,244)
30	METERING	C	(7,364,126)	(7,325,261)	(38,865)
31	INSTALL. ON CUSTR. PREMISES	C	(75,256)	(75,256)	0
32	SERVICES ON CUSTR. PREMISES	C	(2,608,797)	(2,584,531)	(24,267)
33	STREET LIGHTING NYC	C	(6,196,616)	0	(6,196,616)
34	STREET LIGHTING OTHER	C	(833,829)	(182,428)	(651,402)
35					0
36	TOTAL DISTRIBUTION PLANT		(326,346,144)	(288,684,485)	(37,661,659)
37					(132,254,982)
38	CUSTR. ACCTG. & COLLECTION	C	(26,215,535)	(26,134,783)	(80,752)
39	PRINTING & MAILING A BILL	C	(1,539,376)	(1,534,575)	(4,801)
40	RECEIPTS PROCESSING	C	(1,423,637)	(1,419,197)	(4,440)
41	CUSTOMER SERVICE	C	(16,256,938)	(16,206,234)	(50,704)
42	UNCOLLECTIBLES	C	(912,854)	(912,854)	0
43	REVENUE ITEMS	R	514,507,435	461,129,510	53,377,925
44					208,438,433
45	TOTAL DEMAND	D	(292,703,420)	(255,755,879)	(36,947,541)
46	TOTAL ENERGY	E	(3,195,859)	(3,195,859)	0
47	TOTAL CUSTOMER	C	(157,099,859)	(145,699,651)	(11,400,208)
48	TOTAL REVENUE	R	514,507,435	461,129,510	53,377,925
49					208,438,433
50	TOTAL		61,508,297	56,478,121	5,030,176
			=====	=====	=====
					10,523,151
					=====

CON ED ELECTRIC 2023 ECOS

INCOME TAXES

		GENERAL SMALL SC #2 (5)	ELECTRIC TRACTION NTD-SC #5 (6)	ELECTRIC TRACTION TOD-SC #5 (7)	ST. LTG. & SIGNAL SC #6 (8)
STATE INCOME TAX COMPUTATION					
1	PRODUCTION FUNCTION				
2	STEAM PRODUCTION	D	0	0	0
3	MERCHANT FUNCTION	E	(339,571)	(9)	(2,571)
4			-----	-----	-----
5	TOTAL PRODUCTION		(339,571)	(9)	(2,571)
6					
7	TRANSMISSION	D	(3,091,157)	(367)	(95,575)
8					(20)
9	SUBSTATION	D	(1,384,627)	(399)	(48,985)
10					(5,938)
11	HIGH TENSION SYSTEM				
12	HT - DEMAND	D	(3,548,352)	(1,023)	(125,534)
13	HT - CUSTOMER	C	(1,126,890)	(157)	(14)
14					0
15	LOW TENSION SYSTEM				
16	O.H. TRANSFORMERS - DEMAND	D	(277,066)	(54)	(877)
17	U.G. TRANSFORMERS - DEMAND	D	(1,665,584)	(324)	(5,273)
18	O.H. TRANSFORMERS - CUSTOMER	C	(119,234)	0	0
19	U.G. TRANSFORMERS - CUSTOMER	C	(1,340,096)	(198)	(18)
20	O.H. LINES DEMAND	D	(546,581)	(106)	(1,730)
21	U.G. LINES DEMAND	D	(2,749,938)	(535)	(8,706)
22	O.H. LINES CUSTOMER	C	(62,982)	0	0
23	U.G. LINES CUSTOMER	C	(7,287,506)	(1,076)	(98)
24			-----	-----	-----
25	TOTAL LOW TENSION DEMAND		(5,239,169)	(1,019)	(16,587)
26	TOTAL LOW TENSION CUSTOMER		(8,809,818)	(1,274)	(116)
27					0
28	SERVICE COSTS - O.H.	C	(372,213)	0	0
29	SERVICE COSTS - U.G.	C	(5,338,713)	(2,295)	(38)
30	METERING	C	(844,685)	(460)	(112)
31	INSTALL. ON CUSTR. PREMISES	C	0	0	0
32	SERVICES ON CUSTR. PREMISES	C	(286,905)	(61)	(15)
33	STREET LIGHTING NYC	C	0	0	0
34	STREET LIGHTING OTHER	C	0	0	0
35			-----	-----	-----
36	TOTAL DISTRIBUTION PLANT		(26,951,372)	(6,689)	(191,401)
37					(216,655)
38	CUSTR. ACCTG. & COLLECTION	C	(3,008,873)	(254)	(185)
39	PRINTING & MAILING A BILL	C	(189,945)	(3)	(2)
40	RECEIPTS PROCESSING	C	(175,664)	(3)	(2)
41	CUSTOMER SERVICE	C	(2,005,956)	(36)	(22)
42	UNCOLLECTIBLES	C	(70,212)	(13)	(537)
43	REVENUE ITEMS	R	40,352,266	7,456	304,106
44			-----	-----	-----
45	TOTAL DEMAND	D	(13,263,305)	(2,808)	(286,680)
46	TOTAL ENERGY	E	(339,571)	(9)	0
47	TOTAL CUSTOMER	C	(22,229,873)	(4,557)	(1,043)
48	TOTAL REVENUE	R	40,352,266	7,456	304,106
49			-----	-----	-----
50	TOTAL		4,519,517	82	16,383
			=====	=====	=====

CON ED ELECTRIC 2023 ECOS

INCOME TAXES

		MULTI-DW. REDISTRIB. NTD-SC #8 (9)	MULTI-DW. REDISTRIB. TOD-SC #8 (10)	GENERAL LARGE NTD-SC #9 (11)	GENERAL LARGE TOD-SC #9 (12)
STATE INCOME TAX COMPUTATION					
1	PRODUCTION FUNCTION				
2	STEAM PRODUCTION	D	0	0	0
3	MERCHANT FUNCTION	E	(20,145)	(424,694)	(27,796)
4			-----	-----	-----
5	TOTAL PRODUCTION		(20,145)	(424,694)	(27,796)
6					
7	TRANSMISSION	D	(2,407,388)	(23,887,668)	(8,684,642)
8					
9	SUBSTATION	D	(1,099,723)	(10,858,553)	(3,905,695)
10					
11	HIGH TENSION SYSTEM				
12	HT - DEMAND	D	(2,818,235)	(27,826,961)	(10,009,032)
13	HT - CUSTOMER	C	(63,711)	(1,749,743)	(84,215)
14					
15	LOW TENSION SYSTEM				
16	O.H. TRANSFORMERS - DEMAND	D	(135,856)	(1,476,121)	(396,285)
17	U.G. TRANSFORMERS - DEMAND	D	(816,698)	(8,873,704)	(2,382,265)
18	O.H. TRANSFORMERS - CUSTOMER	C	0	(11,155)	(3)
19	U.G. TRANSFORMERS - CUSTOMER	C	(80,183)	(2,194,829)	(105,987)
20	O.H. LINES DEMAND	D	(268,009)	(2,912,008)	(781,768)
21	U.G. LINES DEMAND	D	(1,348,397)	(14,650,796)	(3,933,203)
22	O.H. LINES CUSTOMER	C	0	(5,893)	(1)
23	U.G. LINES CUSTOMER	C	(436,039)	(11,935,586)	(576,362)
24			-----	-----	-----
25	TOTAL LOW TENSION DEMAND		(2,568,960)	(27,912,630)	(7,493,519)
26	TOTAL LOW TENSION CUSTOMER		(516,222)	(14,147,463)	(682,353)
27					
28	SERVICE COSTS - O.H.	C	0	(158,577)	(211)
29	SERVICE COSTS - U.G.	C	(409,476)	(12,477,858)	(887,296)
30	METERING	C	(17,731)	(927,940)	(21,945)
31	INSTALL. ON CUSTR. PREMISES	C	0	(60,159)	(15,096)
32	SERVICES ON CUSTR. PREMISES	C	(7,147)	(257,958)	(9,154)
33	STREET LIGHTING NYC	C	0	0	0
34	STREET LIGHTING OTHER	C	0	0	0
35			-----	-----	-----
36	TOTAL DISTRIBUTION PLANT		(7,501,204)	(96,377,843)	(23,108,516)
37					
38	CUSTR. ACCTG. & COLLECTION	C	(39,638)	(2,378,168)	(33,895)
39	PRINTING & MAILING A BILL	C	(771)	(57,291)	(290)
40	RECEIPTS PROCESSING	C	(713)	(52,984)	(268)
41	CUSTOMER SERVICE	C	(8,147)	(605,040)	(3,059)
42	UNCOLLECTIBLES	C	(21,488)	(273,474)	(70,317)
43	REVENUE ITEMS	R	12,182,900	155,225,527	39,840,752
44			-----	-----	-----
45	TOTAL DEMAND	D	(8,894,307)	(90,485,812)	(30,092,888)
46	TOTAL ENERGY	E	(20,145)	(424,694)	(27,796)
47	TOTAL CUSTOMER	C	(1,085,044)	(33,146,656)	(1,808,098)
48	TOTAL REVENUE	R	12,182,900	155,225,527	39,840,752
49			-----	-----	-----
50	TOTAL		2,183,404	31,168,365	7,911,969
			=====	=====	=====

CON ED ELECTRIC 2023 ECOS

INCOME TAXES

		MULTI-DW. SPACE HTG. NTD-SC #12 (13)	MULTI-DW. SPACE HTG. TOD-SC #12 (14)	BULK POWER TOD-SC #13 (15)	STEAM DEPT. ELECTRIC FACILITIES (16)
STATE INCOME TAX COMPUTATION					
1	PRODUCTION FUNCTION				
2	STEAM PRODUCTION	D	0	0	(1,788,925)
3	MERCHANT FUNCTION	E	(2,041)	0	0
4			-----	-----	-----
5	TOTAL PRODUCTION		(2,041)	0	(1,788,925)
6					
7	TRANSMISSION	D	(122,898)	(300)	0
8					
9	SUBSTATION	D	(92,170)	(13,278)	0
10					
11	HIGH TENSION SYSTEM				
12	HT - DEMAND	D	(236,202)	(34,028)	0
13	HT - CUSTOMER	C	(7,077)	(29)	0
14					
15	LOW TENSION SYSTEM				
16	O.H. TRANSFORMERS - DEMAND	D	(11,231)	0	0
17	U.G. TRANSFORMERS - DEMAND	D	(67,515)	0	0
18	O.H. TRANSFORMERS - CUSTOMER	C	0	0	0
19	U.G. TRANSFORMERS - CUSTOMER	C	(8,907)	0	0
20	O.H. LINES DEMAND	D	(22,156)	0	0
21	U.G. LINES DEMAND	D	(111,469)	0	0
22	O.H. LINES CUSTOMER	C	0	0	0
23	U.G. LINES CUSTOMER	C	(48,438)	0	0
24			-----	-----	-----
25	TOTAL LOW TENSION DEMAND		(212,371)	0	0
26	TOTAL LOW TENSION CUSTOMER		(57,345)	0	0
27					
28	SERVICE COSTS - O.H.	C	0	0	0
29	SERVICE COSTS - U.G.	C	(47,541)	(1,234)	0
30	METERING	C	(2,753)	(48)	0
31	INSTALL. ON CUSTR. PREMISES	C	0	0	0
32	SERVICES ON CUSTR. PREMISES	C	(896)	(6)	0
33	STREET LIGHTING NYC	C	0	0	0
34	STREET LIGHTING OTHER	C	0	0	0
35			-----	-----	-----
36	TOTAL DISTRIBUTION PLANT		(656,355)	(48,621)	0
37					
38	CUSTR. ACCTG. & COLLECTION	C	(7,129)	(58)	0
39	PRINTING & MAILING A BILL	C	(181)	(0)	0
40	RECEIPTS PROCESSING	C	(167)	(0)	0
41	CUSTOMER SERVICE	C	(1,909)	(4)	0
42	UNCOLLECTIBLES	C	(1,766)	(357)	0
43	REVENUE ITEMS	R	1,001,536	202,223	1,164,468
44			-----	-----	-----
45	TOTAL DEMAND	D	(663,640)	(47,606)	(1,788,925)
46	TOTAL ENERGY	E	(2,041)	0	0
47	TOTAL CUSTOMER	C	(126,764)	(1,736)	0
48	TOTAL REVENUE	R	1,001,536	202,223	1,164,468
49			-----	-----	-----
50	TOTAL		209,091	152,881	(624,457)
			=====	=====	=====

CON ED ELECTRIC 2023 ECOS

INCOME TAXES

			TOTAL SYSTEM (1)	TOTAL CON ED (2)	TOTAL NYP (3)	RESIDENTIAL & RELIGIOUS SC #1 (4)
FIT ADJUSTMENTS						
1	PRODUCTION FUNCTION					
2	STEAM PRODUCTION	D S01	(2,569,580)	(2,569,580)	0	0
3	MERCHANT FUNCTION	E U01	(1,191,356)	(1,191,356)	0	(885,671)
4						
5	TOTAL PRODUCTION		(3,760,935)	(3,760,935)	0	(885,671)
6						
7	TRANSMISSION	D D03	(70,896,616)	(60,970,515)	(9,926,101)	(24,594,341)
8						
9	SUBSTATION	D D04	(26,965,562)	(23,030,348)	(3,935,214)	(9,591,474)
10						
11	HIGH TENSION SYSTEM					
12	HT - DEMAND	D D04	(78,475,233)	(67,022,965)	(11,452,268)	(27,913,126)
13	HT - CUSTOMER	C C03	(6,358,788)	(6,150,455)	(208,333)	(3,442,609)
14						
15	LOW TENSION SYSTEM					
16	O.H. TRANSFORMERS - DEMAND	D D08	(4,314,634)	(3,928,842)	(385,792)	(1,810,438)
17	U.G. TRANSFORMERS - DEMAND	D D08	(26,138,995)	(23,801,786)	(2,337,209)	(10,968,031)
18	O.H. TRANSFORMERS - CUSTOMER	C C01	(1,784,841)	(1,781,242)	(3,599)	(1,662,426)
19	U.G. TRANSFORMERS - CUSTOMER	C C02	(7,061,129)	(6,793,535)	(267,594)	(3,363,050)
20	O.H. LINES DEMAND	D D08	(7,442,059)	(6,776,630)	(665,429)	(3,122,719)
21	U.G. LINES DEMAND	D D08	(40,500,305)	(36,878,984)	(3,621,321)	(16,994,096)
22	O.H. LINES CUSTOMER	C C01	(824,319)	(822,657)	(1,662)	(767,783)
23	U.G. LINES CUSTOMER	C C02	(36,035,487)	(34,669,859)	(1,365,628)	(17,162,856)
24						
25	TOTAL LOW TENSION DEMAND		(78,395,993)	(71,386,242)	(7,009,751)	(32,895,284)
26	TOTAL LOW TENSION CUSTOMER		(45,705,775)	(44,067,293)	(1,638,482)	(22,956,114)
27						
28	SERVICE COSTS - O.H.	C S03	(3,687,002)	(3,670,276)	(16,726)	(3,274,380)
29	SERVICE COSTS - U.G.	C S03A	(23,486,040)	(21,702,202)	(1,783,839)	(6,213,807)
30	METERING	C S04	(11,121,029)	(11,062,336)	(58,693)	(8,318,455)
31	INSTALL. ON CUSTR. PREMISES	C S05	(82,284)	(82,284)	0	0
32	SERVICES ON CUSTR. PREMISES	C S06	(1,435,930)	(1,422,573)	(13,357)	(1,112,893)
33	STREET LIGHTING NYC	C S14	(5,916,295)	0	(5,916,295)	0
34	STREET LIGHTING OTHER	C S15	(796,109)	(174,175)	(621,934)	0
35						
36	TOTAL DISTRIBUTION PLANT		(282,426,041)	(249,771,150)	(32,654,891)	(115,718,141)
37						
38	CUSTR. ACCTG. & COLLECTION	C S07	(60,942,640)	(60,754,918)	(187,722)	(47,994,501)
39	PRINTING & MAILING A BILL	C S11	(35,934)	(35,822)	(112)	(29,988)
40	RECEIPTS PROCESSING	C S12	(302,747)	(301,803)	(944)	(252,650)
41	CUSTOMER SERVICE	C S10	(10,626,257)	(10,593,114)	(33,142)	(8,867,890)
42	UNCOLLECTIBLES	C S09	0	0	0	0
43	REVENUE ITEMS	R R99	0	0	0	0
44						
45	TOTAL DEMAND	D	(257,302,984)	(224,979,650)	(32,323,334)	(94,994,224)
46	TOTAL ENERGY	E	(1,191,356)	(1,191,356)	0	(885,671)
47	TOTAL CUSTOMER	C	(170,496,830)	(160,017,252)	(10,479,578)	(102,463,287)
48	TOTAL REVENUE	R	0	0	0	0
49						
50	TOTAL		(428,991,170)	(386,188,258)	(42,802,912)	(198,343,182)
			=====	=====	=====	=====

CON ED ELECTRIC 2023 ECOS

INCOME TAXES

			GENERAL SMALL SC #2 (5)	ELECTRIC TRACTION NTD-SC #5 (6)	ELECTRIC TRACTION TOD-SC #5 (7)	ST. LTG. & SIGNAL SC #6 (8)
FIT ADJUSTMENTS						
1	PRODUCTION FUNCTION					
2	STEAM PRODUCTION	D S01	0	0	0	0
3	MERCHANT FUNCTION	E U01	(126,585)	(3)	0	(958)
4			-----	-----	-----	-----
5	TOTAL PRODUCTION		(126,585)	(3)	0	(958)
6						
7	TRANSMISSION	D D03	(2,909,625)	(346)	(89,962)	(19)
8						
9	SUBSTATION	D D04	(1,055,231)	(304)	(37,332)	(4,525)
10						
11	HIGH TENSION SYSTEM					
12	HT - DEMAND	D D04	(3,070,936)	(885)	(108,644)	(13,169)
13	HT - CUSTOMER	C C03	(1,005,026)	(140)	(13)	0
14						
15	LOW TENSION SYSTEM					
16	O.H. TRANSFORMERS - DEMAND	D D08	(252,468)	(49)	(799)	(630)
17	U.G. TRANSFORMERS - DEMAND	D D08	(1,529,508)	(298)	(4,842)	(3,816)
18	O.H. TRANSFORMERS - CUSTOMER	C C01	(108,649)	0	0	0
19	U.G. TRANSFORMERS - CUSTOMER	C C02	(1,230,611)	(182)	(17)	0
20	O.H. LINES DEMAND	D D08	(435,468)	(85)	(1,379)	(1,087)
21	U.G. LINES DEMAND	D D08	(2,369,851)	(461)	(7,503)	(5,913)
22	O.H. LINES CUSTOMER	C C01	(50,179)	0	0	0
23	U.G. LINES CUSTOMER	C C02	(6,280,252)	(928)	(84)	0
24			-----	-----	-----	-----
25	TOTAL LOW TENSION DEMAND		(4,587,294)	(892)	(14,523)	(11,446)
26	TOTAL LOW TENSION CUSTOMER		(7,669,690)	(1,109)	(101)	0
27						
28	SERVICE COSTS - O.H.	C S03	(277,509)	0	0	0
29	SERVICE COSTS - U.G.	C S03A	(4,308,757)	(1,852)	(31)	0
30	METERING	C S04	(1,275,612)	(695)	(169)	0
31	INSTALL. ON CUSTR. PREMISES	C S05	0	0	0	0
32	SERVICES ON CUSTR. PREMISES	C S06	(157,918)	(34)	(8)	0
33	STREET LIGHTING NYC	C S14	0	0	0	0
34	STREET LIGHTING OTHER	C S15	0	0	0	(174,175)
35			-----	-----	-----	-----
36	TOTAL DISTRIBUTION PLANT		(23,407,974)	(5,912)	(160,820)	(203,316)
37						
38	CUSTR. ACCTG. & COLLECTION	C S07	(6,994,657)	(590)	(429)	(44,598)
39	PRINTING & MAILING A BILL	C S11	(4,434)	(0)	(0)	(33)
40	RECEIPTS PROCESSING	C S12	(37,356)	(1)	(0)	(279)
41	CUSTOMER SERVICE	C S10	(1,311,182)	(23)	(15)	(9,809)
42	UNCOLLECTIBLES	C S09	0	0	0	0
43	REVENUE ITEMS	R R99	0	0	0	0
44			-----	-----	-----	-----
45	TOTAL DEMAND	D	(11,623,086)	(2,427)	(250,460)	(29,159)
46	TOTAL ENERGY	E	(126,585)	(3)	0	(958)
47	TOTAL CUSTOMER	C	(23,042,141)	(4,445)	(766)	(228,895)
48	TOTAL REVENUE	R	0	0	0	0
49			-----	-----	-----	-----
50	TOTAL		(34,791,813)	(6,875)	(251,226)	(259,013)
			=====	=====	=====	=====

CON ED ELECTRIC 2023 ECOS

INCOME TAXES

			MULTI-DW. REDISTRIB. NTD-SC #8 (9)	MULTI-DW. REDISTRIB. TOD-SC #8 (10)	GENERAL LARGE NTD-SC #9 (11)	GENERAL LARGE TOD-SC #9 (12)
FIT ADJUSTMENTS						
1	PRODUCTION FUNCTION					
2	STEAM PRODUCTION	D S01	0	0	0	0
3	MERCHANT FUNCTION	E U01	(7,510)	(412)	(158,318)	(10,362)
4			-----	-----	-----	-----
5	TOTAL PRODUCTION		(7,510)	(412)	(158,318)	(10,362)
6						
7	TRANSMISSION	D D03	(2,266,011)	(180,225)	(22,484,834)	(8,174,626)
8						
9	SUBSTATION	D D04	(838,104)	(67,127)	(8,275,356)	(2,976,549)
10						
11	HIGH TENSION SYSTEM					
12	HT - DEMAND	D D04	(2,439,053)	(195,354)	(24,082,959)	(8,662,358)
13	HT - CUSTOMER	C C03	(56,821)	(2,742)	(1,560,524)	(75,108)
14						
15	LOW TENSION SYSTEM					
16	O.H. TRANSFORMERS - DEMAND	D D08	(123,795)	(9,753)	(1,345,070)	(361,102)
17	U.G. TRANSFORMERS - DEMAND	D D08	(749,975)	(59,085)	(8,148,731)	(2,187,636)
18	O.H. TRANSFORMERS - CUSTOMER	C C01	0	0	(10,165)	(2)
19	U.G. TRANSFORMERS - CUSTOMER	C C02	(73,632)	(3,553)	(2,015,513)	(97,328)
20	O.H. LINES DEMAND	D D08	(213,526)	(16,822)	(2,320,033)	(622,844)
21	U.G. LINES DEMAND	D D08	(1,162,026)	(91,548)	(12,625,813)	(3,389,569)
22	O.H. LINES CUSTOMER	C C01	0	0	(4,695)	(1)
23	U.G. LINES CUSTOMER	C C02	(375,771)	(18,131)	(10,285,890)	(496,699)
24			-----	-----	-----	-----
25	TOTAL LOW TENSION DEMAND		(2,249,322)	(177,209)	(24,439,647)	(6,561,151)
26	TOTAL LOW TENSION CUSTOMER		(449,403)	(21,684)	(12,316,263)	(594,031)
27						
28	SERVICE COSTS - O.H.	C S03	0	0	(118,230)	(157)
29	SERVICE COSTS - U.G.	C S03A	(330,479)	(14,511)	(10,070,602)	(716,117)
30	METERING	C S04	(26,776)	(1,064)	(1,401,340)	(33,140)
31	INSTALL. ON CUSTR. PREMISES	C S05	0	0	(65,778)	(16,506)
32	SERVICES ON CUSTR. PREMISES	C S06	(3,934)	(174)	(141,985)	(5,039)
33	STREET LIGHTING NYC	C S14	0	0	0	0
34	STREET LIGHTING OTHER	C S15	0	0	0	0
35			-----	-----	-----	-----
36	TOTAL DISTRIBUTION PLANT		(6,393,892)	(479,864)	(82,472,685)	(19,640,155)
37						
38	CUSTR. ACCTG. & COLLECTION	C S07	(92,146)	(1,730)	(5,528,472)	(78,795)
39	PRINTING & MAILING A BILL	C S11	(18)	(0)	(1,337)	(7)
40	RECEIPTS PROCESSING	C S12	(152)	(2)	(11,267)	(57)
41	CUSTOMER SERVICE	C S10	(5,325)	(61)	(395,481)	(2,000)
42	UNCOLLECTIBLES	C S09	0	0	0	0
43	REVENUE ITEMS	R R99	0	0	0	0
44			-----	-----	-----	-----
45	TOTAL DEMAND	D	(7,792,491)	(619,915)	(79,282,797)	(26,374,684)
46	TOTAL ENERGY	E	(7,510)	(412)	(158,318)	(10,362)
47	TOTAL CUSTOMER	C	(965,053)	(41,967)	(31,611,280)	(1,520,955)
48	TOTAL REVENUE	R	0	0	0	0
49			-----	-----	-----	-----
50	TOTAL		(8,765,054)	(662,294)	(111,052,394)	(27,906,000)
			=====	=====	=====	=====

CON ED ELECTRIC 2023 ECOS

INCOME TAXES

			MULTI-DW. SPACE HTG. NTD-SC #12 (13)	MULTI-DW. SPACE HTG. TOD-SC #12 (14)	BULK POWER TOD-SC #13 (15)	STEAM DEPT. ELECTRIC FACILITIES (16)
FIT ADJUSTMENTS						
1	PRODUCTION FUNCTION					
2	STEAM PRODUCTION	D S01	0	0	0	(2,569,580)
3	MERCHANT FUNCTION	E U01	(761)	(776)	0	0
4			-----	-----	-----	-----
5	TOTAL PRODUCTION		(761)	(776)	0	(2,569,580)
6						
7	TRANSMISSION	D D03	(115,680)	(154,563)	(283)	0
8						
9	SUBSTATION	D D04	(70,243)	(103,983)	(10,119)	0
10						
11	HIGH TENSION SYSTEM					
12	HT - DEMAND	D D04	(204,422)	(302,610)	(29,449)	0
13	HT - CUSTOMER	C C03	(6,312)	(1,135)	(26)	0
14						
15	LOW TENSION SYSTEM					
16	O.H. TRANSFORMERS - DEMAND	D D08	(10,234)	(14,504)	0	0
17	U.G. TRANSFORMERS - DEMAND	D D08	(61,999)	(87,866)	0	0
18	O.H. TRANSFORMERS - CUSTOMER	C C01	0	0	0	0
19	U.G. TRANSFORMERS - CUSTOMER	C C02	(8,180)	(1,471)	0	0
20	O.H. LINES DEMAND	D D08	(17,652)	(25,016)	0	0
21	U.G. LINES DEMAND	D D08	(96,062)	(136,141)	0	0
22	O.H. LINES CUSTOMER	C C01	0	0	0	0
23	U.G. LINES CUSTOMER	C C02	(41,743)	(7,505)	0	0
24			-----	-----	-----	-----
25	TOTAL LOW TENSION DEMAND		(185,947)	(263,527)	0	0
26	TOTAL LOW TENSION CUSTOMER		(49,922)	(8,976)	0	0
27						
28	SERVICE COSTS - O.H.	C S03	0	0	0	0
29	SERVICE COSTS - U.G.	C S03A	(38,370)	(6,682)	(996)	0
30	METERING	C S04	(4,157)	(855)	(72)	0
31	INSTALL. ON CUSTR. PREMISES	C S05	0	0	0	0
32	SERVICES ON CUSTR. PREMISES	C S06	(493)	(92)	(3)	0
33	STREET LIGHTING NYC	C S14	0	0	0	0
34	STREET LIGHTING OTHER	C S15	0	0	0	0
35			-----	-----	-----	-----
36	TOTAL DISTRIBUTION PLANT		(559,867)	(687,861)	(40,665)	0
37						
38	CUSTR. ACCTG. & COLLECTION	C S07	(16,572)	(2,294)	(134)	0
39	PRINTING & MAILING A BILL	C S11	(4)	(0)	(0)	0
40	RECEIPTS PROCESSING	C S12	(36)	(2)	(0)	0
41	CUSTOMER SERVICE	C S10	(1,248)	(78)	(3)	0
42	UNCOLLECTIBLES	C S09	0	0	0	0
43	REVENUE ITEMS	R R99	0	0	0	0
44			-----	-----	-----	-----
45	TOTAL DEMAND	D	(576,292)	(824,683)	(39,851)	(2,569,580)
46	TOTAL ENERGY	E	(761)	(776)	0	0
47	TOTAL CUSTOMER	C	(117,114)	(20,115)	(1,233)	0
48	TOTAL REVENUE	R	0	0	0	0
49			-----	-----	-----	-----
50	TOTAL		(694,168)	(845,575)	(41,085)	(2,569,580)
			=====	=====	=====	=====

CON ED ELECTRIC 2023 ECOS

INCOME TAXES

		TOTAL SYSTEM (1)	TOTAL CON ED (2)	TOTAL NYPA (3)	RESIDENTIAL & RELIGIOUS SC #1 (4)
FEDERAL INCOME TAX COMPUTATION					
1	PRODUCTION FUNCTION				
2	STEAM PRODUCTION	D	(5,336,581)	0	0
3	MERCHANT FUNCTION	E	(9,877,940)	0	(7,343,402)
4					
5	TOTAL PRODUCTION		(15,214,522)	0	(7,343,402)
6					
7	TRANSMISSION	D	(218,379,342)	(30,574,878)	(75,756,733)
8					
9	SUBSTATION	D	(125,147,334)	(18,263,351)	(44,514,086)
10					
11	HIGH TENSION SYSTEM				
12	HT - DEMAND	D	(261,556,545)	(38,170,203)	(93,033,948)
13	HT - CUSTOMER	C	(20,499,043)	(671,609)	(11,098,058)
14					
15	LOW TENSION SYSTEM				
16	O.H. TRANSFORMERS - DEMAND	D	(13,447,762)	(1,202,427)	(5,642,737)
17	U.G. TRANSFORMERS - DEMAND	D	(80,680,247)	(7,213,997)	(33,853,766)
18	O.H. TRANSFORMERS - CUSTOMER	C	(5,562,955)	(11,216)	(5,181,415)
19	U.G. TRANSFORMERS - CUSTOMER	C	(21,794,779)	(825,951)	(10,380,341)
20	O.H. LINES DEMAND	D	(26,748,391)	(2,391,698)	(11,223,736)
21	U.G. LINES DEMAND	D	(129,553,943)	(11,584,022)	(54,361,372)
22	O.H. LINES CUSTOMER	C	(2,962,784)	(5,974)	(2,759,579)
23	U.G. LINES CUSTOMER	C	(115,271,708)	(4,368,423)	(54,901,206)
24					
25	TOTAL LOW TENSION DEMAND		(250,430,343)	(22,392,144)	(105,081,611)
26	TOTAL LOW TENSION CUSTOMER		(145,592,226)	(5,211,564)	(73,222,542)
27					
28	SERVICE COSTS - O.H.	C	(14,149,475)	(64,189)	(12,565,969)
29	SERVICE COSTS - U.G.	C	(80,147,379)	(6,087,445)	(21,204,950)
30	METERING	C	(20,741,455)	(109,466)	(15,514,469)
31	INSTALL. ON CUSTR. PREMISES	C	(208,959)	0	0
32	SERVICES ON CUSTR. PREMISES	C	(8,160,916)	(75,912)	(6,324,978)
33	STREET LIGHTING NYC	C	(17,719,378)	(17,719,378)	0
34	STREET LIGHTING OTHER	C	(2,384,356)	(1,862,699)	0
35					
36	TOTAL DISTRIBUTION PLANT		(946,737,408)	(110,627,961)	(382,560,610)
37					
38	CUSTR. ACCTG. & COLLECTION	C	(95,106,401)	(292,956)	(74,899,681)
39	PRINTING & MAILING A BILL	C	(4,657,115)	(14,525)	(3,886,485)
40	RECEIPTS PROCESSING	C	(4,359,584)	(13,597)	(3,638,187)
41	CUSTOMER SERVICE	C	(49,343,242)	(153,898)	(41,178,228)
42	UNCOLLECTIBLES	C	(2,757,520)	0	(1,421,102)
43	REVENUE ITEMS	R	1,554,208,228	161,242,393	629,644,404
44					
45	TOTAL DEMAND	D	(860,850,145)	(109,400,576)	(318,386,377)
46	TOTAL ENERGY	E	(9,877,940)	0	(7,343,402)
47	TOTAL CUSTOMER	C	(465,827,048)	(32,277,239)	(264,954,649)
48	TOTAL REVENUE	R	1,554,208,228	161,242,393	629,644,404
49					
50	TOTAL		217,653,094	19,564,578	38,959,977
			=====	=====	=====

CON ED ELECTRIC 2023 ECOS

INCOME TAXES

		GENERAL SMALL SC #2 (5)	ELECTRIC TRACTION NTD-SC #5 (6)	ELECTRIC TRACTION TOD-SC #5 (7)	ST. LTG. & SIGNAL SC #6 (8)
FEDERAL INCOME TAX COMPUTATION					
1	PRODUCTION FUNCTION				
2	STEAM PRODUCTION	D	0	0	0
3	MERCHANT FUNCTION	E	(1,049,564)	(27)	0
4					(7,946)
5	TOTAL PRODUCTION		(1,049,564)	(27)	0
6					(7,946)
7	TRANSMISSION	D	(8,962,373)	(1,065)	(277,105)
8					(58)
9	SUBSTATION	D	(4,897,335)	(1,411)	(173,258)
10					(21,002)
11	HIGH TENSION SYSTEM				
12	HT - DEMAND	D	(10,235,375)	(2,950)	(362,107)
13	HT - CUSTOMER	C	(3,239,938)	(452)	(41)
14					0
15	LOW TENSION SYSTEM				
16	O.H. TRANSFORMERS - DEMAND	D	(786,888)	(153)	(2,491)
17	U.G. TRANSFORMERS - DEMAND	D	(4,720,956)	(918)	(14,946)
18	O.H. TRANSFORMERS - CUSTOMER	C	(338,634)	0	0
19	U.G. TRANSFORMERS - CUSTOMER	C	(3,798,386)	(561)	(51)
20	O.H. LINES DEMAND	D	(1,565,166)	(304)	(4,955)
21	U.G. LINES DEMAND	D	(7,580,771)	(1,475)	(24,000)
22	O.H. LINES CUSTOMER	C	(180,353)	0	0
23	U.G. LINES CUSTOMER	C	(20,089,511)	(2,967)	(270)
24					0
25	TOTAL LOW TENSION DEMAND		(14,653,780)	(2,850)	(46,392)
26	TOTAL LOW TENSION CUSTOMER		(24,406,884)	(3,528)	(321)
27					0
28	SERVICE COSTS - O.H.	C	(1,064,987)	0	0
29	SERVICE COSTS - U.G.	C	(14,703,864)	(6,320)	(105)
30	METERING	C	(2,379,102)	(1,297)	(316)
31	INSTALL. ON CUSTR. PREMISES	C	0	0	0
32	SERVICES ON CUSTR. PREMISES	C	(897,504)	(192)	(47)
33	STREET LIGHTING NYC	C	0	0	0
34	STREET LIGHTING OTHER	C	0	0	0
35					(521,657)
36	TOTAL DISTRIBUTION PLANT		(76,478,769)	(19,001)	(582,586)
37					(623,115)
38	CUSTR. ACCTG. & COLLECTION	C	(10,915,783)	(921)	(670)
39	PRINTING & MAILING A BILL	C	(574,645)	(10)	(6)
40	RECEIPTS PROCESSING	C	(537,932)	(10)	(6)
41	CUSTOMER SERVICE	C	(6,088,500)	(108)	(67)
42	UNCOLLECTIBLES	C	(212,094)	(40)	(1,623)
43	REVENUE ITEMS	R	121,894,883	22,523	918,635
44					727,486
45	TOTAL DEMAND	D	(38,748,863)	(8,276)	(858,862)
46	TOTAL ENERGY	E	(1,049,564)	(27)	0
47	TOTAL CUSTOMER	C	(65,021,234)	(12,877)	(3,201)
48	TOTAL REVENUE	R	121,894,883	22,523	918,635
49					727,486
50	TOTAL		17,075,222	1,343	56,571
			=====	=====	=====

CON ED ELECTRIC 2023 ECOS

INCOME TAXES

		MULTI-DW. REDISTRIB. NTD-SC #8 (9)	MULTI-DW. REDISTRIB. TOD-SC #8 (10)	GENERAL LARGE NTD-SC #9 (11)	GENERAL LARGE TOD-SC #9 (12)
FEDERAL INCOME TAX COMPUTATION					
1	PRODUCTION FUNCTION				
2	STEAM PRODUCTION	D	0	0	0
3	MERCHANT FUNCTION	E	(62,265)	(1,312,667)	(85,913)
4			-----	-----	-----
5	TOTAL PRODUCTION		(62,265)	(1,312,667)	(85,913)
6					
7	TRANSMISSION	D	(6,979,883)	(69,258,924)	(25,179,895)
8					
9	SUBSTATION	D	(3,889,647)	(38,405,978)	(13,814,181)
10					
11	HIGH TENSION SYSTEM				
12	HT - DEMAND	D	(8,129,320)	(80,268,070)	(28,871,486)
13	HT - CUSTOMER	C	(183,175)	(5,030,715)	(242,127)
14					
15	LOW TENSION SYSTEM				
16	O.H. TRANSFORMERS - DEMAND	D	(385,840)	(4,192,288)	(1,125,476)
17	U.G. TRANSFORMERS - DEMAND	D	(2,314,861)	(25,151,755)	(6,752,325)
18	O.H. TRANSFORMERS - CUSTOMER	C	0	(31,682)	(7)
19	U.G. TRANSFORMERS - CUSTOMER	C	(227,272)	(6,221,054)	(300,411)
20	O.H. LINES DEMAND	D	(767,459)	(8,338,707)	(2,238,638)
21	U.G. LINES DEMAND	D	(3,717,135)	(40,387,940)	(10,842,683)
22	O.H. LINES CUSTOMER	C	0	(16,874)	(4)
23	U.G. LINES CUSTOMER	C	(1,202,031)	(32,902,904)	(1,588,861)
24			-----	-----	-----
25	TOTAL LOW TENSION DEMAND		(7,185,296)	(78,070,690)	(20,959,122)
26	TOTAL LOW TENSION CUSTOMER		(1,429,303)	(39,172,514)	(1,889,283)
27					
28	SERVICE COSTS - O.H.	C	0	(453,727)	(603)
29	SERVICE COSTS - U.G.	C	(1,127,777)	(34,366,472)	(2,443,788)
30	METERING	C	(49,939)	(2,613,592)	(61,808)
31	INSTALL. ON CUSTR. PREMISES	C	0	(167,042)	(41,917)
32	SERVICES ON CUSTR. PREMISES	C	(22,357)	(806,952)	(28,637)
33	STREET LIGHTING NYC	C	0	0	0
34	STREET LIGHTING OTHER	C	0	0	0
35			-----	-----	-----
36	TOTAL DISTRIBUTION PLANT		(22,016,814)	(279,355,752)	(68,352,952)
37					
38	CUSTR. ACCTG. & COLLECTION	C	(143,802)	(8,627,671)	(122,966)
39	PRINTING & MAILING A BILL	C	(2,334)	(173,325)	(876)
40	RECEIPTS PROCESSING	C	(2,185)	(162,252)	(820)
41	CUSTOMER SERVICE	C	(24,729)	(1,836,423)	(9,285)
42	UNCOLLECTIBLES	C	(64,911)	(826,101)	(212,411)
43	REVENUE ITEMS	R	36,801,729	468,900,495	120,349,717
44			-----	-----	-----
45	TOTAL DEMAND	D	(26,184,146)	(266,003,662)	(88,824,684)
46	TOTAL ENERGY	E	(62,265)	(1,312,667)	(85,913)
47	TOTAL CUSTOMER	C	(3,050,511)	(94,236,786)	(5,054,522)
48	TOTAL REVENUE	R	36,801,729	468,900,495	120,349,717
49			-----	-----	-----
50	TOTAL		7,504,806	107,347,380	26,384,598
			=====	=====	=====

CON ED ELECTRIC 2023 ECOS

INCOME TAXES

		MULTI-DW. SPACE HTG. NTD-SC #12 (13)	MULTI-DW. SPACE HTG. TOD-SC #12 (14)	BULK POWER TOD-SC #13 (15)	STEAM DEPT. ELECTRIC FACILITIES (16)
FEDERAL INCOME TAX COMPUTATION					
1	PRODUCTION FUNCTION				
2	STEAM PRODUCTION	D	0	0	(5,336,581)
3	MERCHANT FUNCTION	E	(6,307)	0	0
4			-----	-----	-----
5	TOTAL PRODUCTION		(6,307)	0	(5,336,581)
6					
7	TRANSMISSION	D	(356,325)	(871)	0
8					
9	SUBSTATION	D	(325,999)	(46,964)	0
10					
11	HIGH TENSION SYSTEM				
12	HT - DEMAND	D	(681,334)	(98,154)	0
13	HT - CUSTOMER	C	(20,348)	(82)	0
14					
15	LOW TENSION SYSTEM				
16	O.H. TRANSFORMERS - DEMAND	D	(31,897)	0	0
17	U.G. TRANSFORMERS - DEMAND	D	(191,365)	0	0
18	O.H. TRANSFORMERS - CUSTOMER	C	0	0	0
19	U.G. TRANSFORMERS - CUSTOMER	C	(25,247)	0	0
20	O.H. LINES DEMAND	D	(63,444)	0	0
21	U.G. LINES DEMAND	D	(307,288)	0	0
22	O.H. LINES CUSTOMER	C	0	0	0
23	U.G. LINES CUSTOMER	C	(133,529)	0	0
24			-----	-----	-----
25	TOTAL LOW TENSION DEMAND		(593,995)	0	0
26	TOTAL LOW TENSION CUSTOMER		(158,776)	0	0
27					
28	SERVICE COSTS - O.H.	C	0	0	0
29	SERVICE COSTS - U.G.	C	(130,938)	(3,398)	0
30	METERING	C	(7,754)	(134)	0
31	INSTALL. ON CUSTR. PREMISES	C	0	0	0
32	SERVICES ON CUSTR. PREMISES	C	(2,803)	(18)	0
33	STREET LIGHTING NYC	C	0	0	0
34	STREET LIGHTING OTHER	C	0	0	0
35			-----	-----	-----
36	TOTAL DISTRIBUTION PLANT		(1,921,946)	(148,750)	0
37					
38	CUSTR. ACCTG. & COLLECTION	C	(25,862)	(210)	0
39	PRINTING & MAILING A BILL	C	(547)	(1)	0
40	RECEIPTS PROCESSING	C	(512)	(1)	0
41	CUSTOMER SERVICE	C	(5,795)	(13)	0
42	UNCOLLECTIBLES	C	(5,334)	(1,079)	0
43	REVENUE ITEMS	R	3,025,410	610,869	3,517,588
44			-----	-----	-----
45	TOTAL DEMAND	D	(1,957,652)	(145,989)	(5,336,581)
46	TOTAL ENERGY	E	(6,307)	0	0
47	TOTAL CUSTOMER	C	(358,669)	(4,936)	0
48	TOTAL REVENUE	R	3,025,410	610,869	3,517,588
49			-----	-----	-----
50	TOTAL		702,781	459,943	(1,818,993)
			=====	=====	=====

CON ED ELECTRIC 2023 ECOS

CUSTOMER COSTS

	TOTAL SYSTEM (1)	TOTAL CON ED (2)	TOTAL NYP&A (3)	RESIDENTIAL & RELIGIOUS SC #1 (4)
CUSTOMER COST BY CLASS				
1 NUMBER OF CUSTOMERS	3,661,522	3,650,102	11,420	3,055,636
2				
3 RATE BASE	7,925,606,599	7,136,034,415	789,572,184	3,810,971,041
4				
5 TOTAL CUSTOMER OPERATING EXPS.	1,563,434,230	1,448,235,638	115,198,592	860,771,107
6 MONTHLY OP. EXPS. COST/CUST	35.58	33.06	840.62	23.47
7				
8 RETURN @ 10.71% (CUSTOMER)	849,051,436	764,466,440	84,584,995	408,260,288
9 S.I.T. & F.I.T. PERCENT ON RETURN	9.76%			
10 INCOME TAX ON RETURN	82,828,466	74,576,852	8,251,615	39,827,474
11 TOTAL RETURN & F.I.T.	931,879,902	839,043,292	92,836,610	448,087,762
12 MONTHLY RET. F.I.T. COST/CUST	21.21	19.16	677.44	12.22
13				
14 MONTHLY CUSTOMER COSTS	56.79	52.22	1,518.06	35.70
	=====	=====	=====	=====

CON ED ELECTRIC 2023 ECOS

CUSTOMER COSTS

	GENERAL SMALL SC #2 (5)	ELECTRIC TRACTION NTD-SC #5 (6)	ELECTRIC TRACTION TOD-SC #5 (7)	ST. LTG. & SIGNAL SC #6 (8)
CUSTOMER COST BY CLASS				
1 NUMBER OF CUSTOMERS	451,798	8	5	3,380
2				
3 RATE BASE	1,159,712,271	303,470	29,576	13,912,229
4				
5 TOTAL CUSTOMER OPERATING EXPS.	222,130,316	44,711	12,640	2,207,868
6 MONTHLY OP. EXPS. COST/CUST	40.97	465.74	210.67	54.43
7				
8 RETURN @ 10.71% (CUSTOMER)	124,237,225	32,510	3,168	1,490,384
9 S.I.T. & F.I.T. PERCENT ON RETURN				
10 INCOME TAX ON RETURN	12,119,853	3,171	309	145,393
11 TOTAL RETURN & F.I.T.	136,357,078	35,681	3,478	1,635,777
12 MONTHLY RET. F.I.T. COST/CUST	25.15	371.68	57.96	40.33
13				
14 MONTHLY CUSTOMER COSTS	66.12	837.43	268.63	94.76
	=====	=====	=====	=====

CON ED ELECTRIC 2023 ECOS

CUSTOMER COSTS

		MULTI-DW. REDISTRIB. NTD-SC #8 (9)	MULTI-DW. REDISTRIB. TOD-SC #8 (10)	GENERAL LARGE NTD-SC #9 (11)	GENERAL LARGE TOD-SC #9 (12)
CUSTOMER COST BY CLASS					
1	NUMBER OF CUSTOMERS	1,835	21	136,272	689
2					
3	RATE BASE	65,436,548	3,011,129	1,965,476,371	108,202,257
4					
5	TOTAL CUSTOMER OPERATING EXPS.	11,015,796	507,876	331,363,354	18,634,609
6	MONTHLY OP. EXPS. COST/CUST	500.26	2,015.38	202.64	2,253.82
7					
8	RETURN @ 10.71% (CUSTOMER)	7,010,062	322,575	210,556,822	11,591,451
9	S.I.T. & F.I.T. PERCENT ON RETURN				
10	INCOME TAX ON RETURN	683,860	31,469	20,540,686	1,130,794
11	TOTAL RETURN & F.I.T.	7,693,923	354,044	231,097,507	12,722,245
12	MONTHLY RET. F.I.T. COST/CUST	349.41	1,404.93	141.32	1,538.73
13					
14	MONTHLY CUSTOMER COSTS	849.67	3,420.32	343.96	3,792.56
		=====	=====	=====	=====

CON ED ELECTRIC 2023 ECOS

CUSTOMER COSTS

		MULTI-DW. SPACE HTG. NTD-SC #12 (13)	MULTI-DW. SPACE HTG. TOD-SC #12 (14)	BULK POWER TOD-SC #13 (15)	STEAM DEPT. ELECTRIC FACILITIES (16)
CUSTOMER COST BY CLASS					
1	NUMBER OF CUSTOMERS	430	27	1	0
2					
3	RATE BASE	7,548,226	1,346,525	84,771	0
4					
5	TOTAL CUSTOMER OPERATING EXPS.	1,277,024	250,968	19,368	0
6	MONTHLY OP. EXPS. COST/CUST	247.49	774.59	1,614.04	0.00
7					
8	RETURN @ 10.71% (CUSTOMER)	808,624	144,250	9,081	0
9	S.I.T. & F.I.T. PERCENT ON RETURN				
10	INCOME TAX ON RETURN	78,885	14,072	886	0
11	TOTAL RETURN & F.I.T.	887,508	158,322	9,967	0
12	MONTHLY RET. F.I.T. COST/CUST	172.00	488.65	830.61	0.00
13					
14	MONTHLY CUSTOMER COSTS	419.48	1,263.24	2,444.64	0.00
		=====	=====	=====	=====

CON ED ELECTRIC 2023 ECOS

ALLOCATION FACTORS

			TOTAL SYSTEM (1)	TOTAL CON ED (2)	TOTAL NYPA (3)	RESIDENTIAL & RELIGIOUS SC #1 (4)
ALLOCATION FACTORS						
1	TRANSMISSION		11,282,861	9,703,169	1,579,692	3,914,073
2	PERCENT	D03	100.000000%	85.999189%	14.000811%	34.690430%
3						
4	HIGH TENSION		11,882,128	10,148,112	1,734,016	4,226,395
5	PERCENT	D04	100.000000%	85.406520%	14.593480%	35.569344%
6						
7	LOW TENSION - DEMANDS		12,739,600	11,600,493	1,139,107	5,345,589
8	PERCENT	D08	100.000000%	91.058534%	8.941466%	41.960415%
9						
10	STEAM PRODUCTION		196,096,509	196,096,509	0	0
11	PERCENT	S01	100.000000%	100.000000%	0.000000%	0.000000%
12						
13	SERVICES - OVERHEAD		300,695,799	299,331,694	1,364,105	267,044,134
14	PERCENT	S03	100.000000%	99.546350%	0.453650%	88.808734%
15						
16	SERVICES - UNDERGROUND		2,483,361,008	2,294,741,930	188,619,079	657,033,910
17	PERCENT	S03A	100.000000%	92.404685%	7.595315%	26.457447%
18						
19	METERING		833,680,740	829,280,869	4,399,872	623,587,596
20	PERCENT	S04	100.000000%	99.472235%	0.527765%	74.799329%
21						
22	INSTALL. ON CUSTOMERS PREMISES		9,068,773	9,068,773	0	0
23	PERCENT	S05	100.000000%	100.000000%	0.000000%	0.000000%
24						
25	SERVICES ON CUSTR. PREMISES		27,029,104	26,777,681	251,423	20,948,443
26	PERCENT	S06	100.000000%	99.069806%	0.930194%	77.503283%
27						
28	CUSTR. ACCTG. AND COLLECTION		158,106,653	157,619,637	487,016	124,514,626
29	PERCENT	S07	100.000000%	99.691970%	0.308030%	78.753565%
30						
31	UNCOLLECTIBLES		14,043,902	14,043,902	0	7,237,594
32	PERCENT	S09	100.000000%	100.000000%	0.000000%	51.535492%
33						
34	CUSTOMER SERVICE		192,890,746	192,289,135	601,611	160,972,379
35	PERCENT	S10	100.000000%	99.688108%	0.311892%	83.452619%
36						
37	PRINTING & MAILING A BILL		23,243,651	23,171,156	72,495	19,397,436
38	PERCENT	S11	100.000000%	99.688108%	0.311892%	83.452619%
39						
40	RECEIPTS PROCESSING		18,830,288	18,771,558	58,730	15,714,368
41	PERCENT	S12	100.000000%	99.688108%	0.311892%	83.452619%
42						
43	STREET LIGHTING - CITY OF NEW YORK		552,625,702	0	552,625,702	0
44	PERCENT	S14	100.000000%	0.000000%	100.000000%	0.000000%
45						
46	STREET LIGHTING - OTH. BOOK COST		74,362,451	16,269,247	58,093,203	0
47	PERCENT	S15	100.000000%	21.878310%	78.121690%	0.000000%
48						
49	O.H. LINES - CUSTOMER COMPONENT		760,814	759,280	1,534	708,633
50	PERCENT	C01	100.000000%	99.798374%	0.201626%	93.141425%
51						
52	U.G. LINES - CUSTOMER COMPONENT		427,319	411,125	16,194	203,522
53	PERCENT	C02	100.000000%	96.210325%	3.789675%	47.627651%
54						
55	PRIMARY - CUSTOMER COMPONENT		602,883,519	583,131,275	19,752,244	326,397,497
56	PERCENT	C03	100.000000%	96.723705%	3.276295%	54.139396%
57						
58	REVENUES FROM SALES		7,474,419,449	6,665,784,410	808,635,039	2,983,095,774
59	PERCENT	R01	100.000000%	89.181300%	10.818700%	39.910735%
60						
61	MFC REVENUES		45,402,212	45,402,212	0	35,076,933
62	PERCENT	R02	100.000000%	100.000000%	0.000000%	77.258203%

CON ED ELECTRIC 2023 ECOS

ALLOCATION FACTORS

		TOTAL SYSTEM (1)	TOTAL CON ED (2)	TOTAL NYPA (3)	RESIDENTIAL & RELIGIOUS SC #1 (4)
63					
64	BPP REVENUES	43,007,139	43,007,139	0	35,963,778
65	PERCENT	R03 100.000000%	100.000000%	0.000000%	83.622808%
66					
67	NET MISCELLANEOUS REVENUES	334,755,308	322,191,504	12,563,804	152,608,634
68	PERCENT	R04 100.000000%	96.246869%	3.753131%	45.588115%
69					
70	OTHER REVENUES - INTERDEPARTMENTAL RENTS	17,914,889	17,914,889	0	0
71	PERCENT	R06 100.000000%	100.000000%	0.000000%	0.000000%
72					
73	REVENUE ADJUSTMENT	0	0	0	0
74	PERCENT	R08A 0.000000%	0.000000%	0.000000%	0.000000%
75					
76	NULL REVENUE FACTOR	0	0	0	0
77	PERCENT	R99 0.000000%	0.000000%	0.000000%	0.000000%
78					
79	UNBUNDLED ALLOCATOR	37,432,831	37,432,831	0	27,828,100
80	PERCENT	U01 100.000000%	100.000000%	0.000000%	74.341425%
81					
82	ANNUAL KWH SALES	51,485,393,593	42,310,764,415	9,174,629,179	13,461,534,789
83	PERCENT	K01 100.000000%	82.180132%	17.819868%	26.146318%
84					
85	ANNUAL KWH SALES - CON ED ONLY	42,310,764,415	42,310,764,415	0	13,461,534,789
86	PERCENT	K02 100.000000%	100.000000%	0.000000%	31.815863%
87					
88	BILLING DEMAND - 1	K03 187,769,148	166,352,057	21,417,091	85,579,445
89					
90	BILLING DEMAND - 2	K04 166,352,057	166,352,057	0	85,579,445
91					
92	NUMBER OF CUSTOMERS	K05 3,661,522	3,650,102	11,420	3,055,636

CON ED ELECTRIC 2023 ECOS

ALLOCATION FACTORS

			GENERAL SMALL SC #2 (5)	ELECTRIC TRACTION NTD-SC #5 (6)	ELECTRIC TRACTION TOD-SC #5 (7)	ST. LTG. & SIGNAL SC #6 (8)
ALLOCATION FACTORS						
1	TRANSMISSION		463,053	55	14,317	3
2	PERCENT	D03	4.104039%	0.000487%	0.126892%	0.000027%
3						
4	HIGH TENSION		464,978	134	16,450	1,994
5	PERCENT	D04	3.913255%	0.001128%	0.138443%	0.016782%
6						
7	LOW TENSION - DEMANDS		745,450	145	2,360	1,860
8	PERCENT	D08	5.851440%	0.001138%	0.018525%	0.014600%
9						
10	STEAM PRODUCTION		0	0	0	0
11	PERCENT	S01	0.000000%	0.000000%	0.000000%	0.000000%
12						
13	SERVICES - OVERHEAD		22,632,431	0	0	0
14	PERCENT	S03	7.526687%	0.000000%	0.000000%	0.000000%
15						
16	SERVICES - UNDERGROUND		455,598,215	195,834	3,243	0
17	PERCENT	S03A	18.346032%	0.007886%	0.000131%	0.000000%
18						
19	METERING		95,625,461	52,117	12,689	0
20	PERCENT	S04	11.470274%	0.006251%	0.001522%	0.000000%
21						
22	INSTALL. ON CUSTOMERS PREMISES		0	0	0	0
23	PERCENT	S05	0.000000%	0.000000%	0.000000%	0.000000%
24						
25	SERVICES ON CUSTR. PREMISES		2,972,551	635	154	0
26	PERCENT	S06	10.997592%	0.002349%	0.000570%	0.000000%
27						
28	CUSTR. ACCTG. AND COLLECTION		18,146,601	1,530	1,114	115,704
29	PERCENT	S07	11.477443%	0.000968%	0.000704%	0.073181%
30						
31	UNCOLLECTIBLES		1,080,183	202	8,266	6,447
32	PERCENT	S09	7.691473%	0.001438%	0.058858%	0.045906%
33						
34	CUSTOMER SERVICE		23,800,937	421	263	178,060
35	PERCENT	S10	12.339076%	0.000218%	0.000137%	0.092311%
36						
37	PRINTING & MAILING A BILL		2,868,052	51	32	21,457
38	PERCENT	S11	12.339076%	0.000218%	0.000137%	0.092311%
39						
40	RECEIPTS PROCESSING		2,323,484	41	26	17,382
41	PERCENT	S12	12.339076%	0.000218%	0.000137%	0.092311%
42						
43	STREET LIGHTING - CITY OF NEW YORK		0	0	0	0
44	PERCENT	S14	0.000000%	0.000000%	0.000000%	0.000000%
45						
46	STREET LIGHTING - OTH. BOOK COST		0	0	0	16,269,247
47	PERCENT	S15	0.000000%	0.000000%	0.000000%	21.878310%
48						
49	O.H. LINES - CUSTOMER COMPONENT		46,313	0	0	0
50	PERCENT	C01	6.087296%	0.000000%	0.000000%	0.000000%
51						
52	U.G. LINES - CUSTOMER COMPONENT		74,473	11	1	0
53	PERCENT	C02	17.427964%	0.002574%	0.000234%	0.000000%
54						
55	PRIMARY - CUSTOMER COMPONENT		95,287,636	13,299	1,209	0
56	PERCENT	C03	15.805314%	0.002206%	0.000201%	0.000000%
57						
58	REVENUES FROM SALES		584,454,407	109,330	4,472,536	3,488,387
59	PERCENT	R01	7.819395%	0.001463%	0.059838%	0.046671%
60						
61	MFC REVENUES		3,876,014	115	0	4,765
62	PERCENT	R02	8.537060%	0.000253%	0.000000%	0.010495%

CON ED ELECTRIC 2023 ECOS

ALLOCATION FACTORS

		GENERAL SMALL SC #2 (5)	ELECTRIC TRACTION NTD-SC #5 (6)	ELECTRIC TRACTION TOD-SC #5 (7)	ST. LTG. & SIGNAL SC #6 (8)
63					
64	BPP REVENUES	5,560,324	229	69	51,264
65	PERCENT	R03 12.928839%	0.000533%	0.000161%	0.119198%
66					
67	NET MISCELLANEOUS REVENUES	26,913,343	5,034	205,953	160,634
68	PERCENT	R04 8.039706%	0.001504%	0.061524%	0.047985%
69					
70	OTHER REVENUES - INTERDEPARTMENTAL RENTS	0	0	0	0
71	PERCENT	R06 0.000000%	0.000000%	0.000000%	0.000000%
72					
73	REVENUE ADJUSTMENT	0	0	0	0
74	PERCENT	R08A 0.000000%	0.000000%	0.000000%	0.000000%
75					
76	NULL REVENUE FACTOR	0	0	0	0
77	PERCENT	R99 0.000000%	0.000000%	0.000000%	0.000000%
78					
79	UNBUNDLED ALLOCATOR	3,977,361	104	0	30,111
80	PERCENT	U01 10.625328%	0.000278%	0.000000%	0.080440%
81					
82	ANNUAL KWH SALES	2,286,254,244	652,826	97,007,684	7,288,356
83	PERCENT	K01 4.440588%	0.001268%	0.188418%	0.014156%
84					
85	ANNUAL KWH SALES - CON ED ONLY	2,286,254,244	652,826	97,007,684	7,288,356
86	PERCENT	K02 5.403481%	0.001543%	0.229274%	0.017226%
87					
88	BILLING DEMAND - 1	K03 11,871,705	1,668	218,757	20,757
89					
90	BILLING DEMAND - 2	K04 11,871,705	1,668	218,757	20,757
91					
92	NUMBER OF CUSTOMERS	K05 451,798	8	5	3,380

CON ED ELECTRIC 2023 ECOS

ALLOCATION FACTORS

			MULTI-DW. REDISTRIB. NTD-SC #8 (9)	MULTI-DW. REDISTRIB. TOD-SC #8 (10)	GENERAL LARGE NTD-SC #9 (11)	GENERAL LARGE TOD-SC #9 (12)
ALLOCATION FACTORS						
1	TRANSMISSION		360,625	28,682	3,578,355	1,300,953
2	PERCENT	D03	3.196219%	0.254209%	31.714961%	11.530347%
3						
4	HIGH TENSION		369,303	29,579	3,646,460	1,311,589
5	PERCENT	D04	3.108054%	0.248937%	30.688611%	11.038334%
6						
7	LOW TENSION - DEMANDS		365,522	28,797	3,971,521	1,066,208
8	PERCENT	D08	2.869180%	0.226043%	31.174613%	8.369242%
9						
10	STEAM PRODUCTION		0	0	0	0
11	PERCENT	S01	0.000000%	0.000000%	0.000000%	0.000000%
12						
13	SERVICES - OVERHEAD		0	0	9,642,318	12,810
14	PERCENT	S03	0.000000%	0.000000%	3.206669%	0.004260%
15						
16	SERVICES - UNDERGROUND		34,944,077	1,534,341	1,064,842,779	75,720,609
17	PERCENT	S03A	1.407128%	0.061785%	42.879097%	3.049118%
18						
19	METERING		2,007,243	79,756	105,050,566	2,484,305
20	PERCENT	S04	0.240769%	0.009567%	12.600815%	0.297992%
21						
22	INSTALL. ON CUSTOMERS PREMISES		0	0	7,249,582	1,819,191
23	PERCENT	S05	0.000000%	0.000000%	79.940049%	20.059951%
24						
25	SERVICES ON CUSTR. PREMISES		74,048	3,280	2,672,641	94,846
26	PERCENT	S06	0.273957%	0.012134%	9.888011%	0.350905%
27						
28	CUSTR. ACCTG. AND COLLECTION		239,059	4,489	14,342,801	204,421
29	PERCENT	S07	0.151201%	0.002839%	9.071599%	0.129293%
30						
31	UNCOLLECTIBLES		330,589	24,980	4,207,288	1,081,800
32	PERCENT	S09	2.353968%	0.177871%	29.958113%	7.702987%
33						
34	CUSTOMER SERVICE		96,669	1,106	7,178,875	36,297
35	PERCENT	S10	0.050116%	0.000574%	3.721731%	0.018817%
36						
37	PRINTING & MAILING A BILL		11,649	133	865,066	4,374
38	PERCENT	S11	0.050116%	0.000574%	3.721731%	0.018817%
39						
40	RECEIPTS PROCESSING		9,437	108	700,813	3,543
41	PERCENT	S12	0.050116%	0.000574%	3.721731%	0.018817%
42						
43	STREET LIGHTING - CITY OF NEW YORK		0	0	0	0
44	PERCENT	S14	0.000000%	0.000000%	0.000000%	0.000000%
45						
46	STREET LIGHTING - OTH. BOOK COST		0	0	0	0
47	PERCENT	S15	0.000000%	0.000000%	0.000000%	0.000000%
48						
49	O.H. LINES - CUSTOMER COMPONENT		0	0	4,333	1
50	PERCENT	C01	0.000000%	0.000000%	0.569522%	0.000131%
51						
52	U.G. LINES - CUSTOMER COMPONENT		4,456	215	121,973	5,890
53	PERCENT	C02	1.042781%	0.050314%	28.543781%	1.378361%
54						
55	PRIMARY - CUSTOMER COMPONENT		5,387,243	259,932	147,954,950	7,121,043
56	PERCENT	C03	0.893579%	0.043115%	24.541217%	1.181164%
57						
58	REVENUES FROM SALES		178,872,008	13,516,111	2,276,436,634	585,329,666
59	PERCENT	R01	2.393122%	0.180832%	30.456367%	7.831105%
60						
61	MFC REVENUES		305,691	17,069	5,474,097	586,327
62	PERCENT	R02	0.673295%	0.037595%	12.056895%	1.291406%

CON ED ELECTRIC 2023 ECOS

ALLOCATION FACTORS

		MULTI-DW. REDISTRIB. NTD-SC #8 (9)	MULTI-DW. REDISTRIB. TOD-SC #8 (10)	GENERAL LARGE NTD-SC #9 (11)	GENERAL LARGE TOD-SC #9 (12)
63					
64	BPP REVENUES	14,715	115	1,347,439	65,009
65	PERCENT	R03 0.034216%	0.000268%	3.133058%	0.151160%
66					
67	NET MISCELLANEOUS REVENUES	8,236,812	622,396	104,826,859	26,953,642
68	PERCENT	R04 2.460547%	0.185926%	31.314473%	8.051745%
69					
70	OTHER REVENUES - INTERDEPARTMENTAL RENTS	0	0	0	0
71	PERCENT	R06 0.000000%	0.000000%	0.000000%	0.000000%
72					
73	REVENUE ADJUSTMENT	0	0	0	0
74	PERCENT	R08A 0.000000%	0.000000%	0.000000%	0.000000%
75					
76	NULL REVENUE FACTOR	0	0	0	0
77	PERCENT	R99 0.000000%	0.000000%	0.000000%	0.000000%
78					
79	UNBUNDLED ALLOCATOR	235,957	12,939	4,974,402	325,569
80	PERCENT	U01 0.630348%	0.034566%	13.288875%	0.869742%
81					
82	ANNUAL KWH SALES	1,489,550,203	127,807,785	17,602,263,409	6,925,170,992
83	PERCENT	K01 2.893151%	0.248241%	34.188849%	13.450749%
84					
85	ANNUAL KWH SALES - CON ED ONLY	1,489,550,203	127,807,785	17,602,263,409	6,925,170,992
86	PERCENT	K02 3.520499%	0.302069%	41.602329%	16.367397%
87					
88	BILLING DEMAND - 1	K03 3,344,291	261,713	49,129,573	15,106,893
89					
90	BILLING DEMAND - 2	K04 3,344,291	261,713	49,129,573	15,106,893
91					
92	NUMBER OF CUSTOMERS	K05 1,835	21	136,272	689

CON ED ELECTRIC 2023 ECOS

ALLOCATION FACTORS

			MULTI-DW. SPACE HTG. NTD-SC #12 (13)	MULTI-DW. SPACE HTG. TOD-SC #12 (14)	BULK POWER TOD-SC #13 (15)	STEAM DEPT. ELECTRIC FACILITIES (16)
ALLOCATION FACTORS						
1	TRANSMISSION		18,410	24,598	45	0
2	PERCENT	D03	0.163168%	0.218012%	0.000399%	0.000000%
3						
4	HIGH TENSION		30,952	45,819	4,459	0
5	PERCENT	D04	0.260492%	0.385613%	0.037527%	0.000000%
6						
7	LOW TENSION - DEMANDS		30,217	42,824	0	0
8	PERCENT	D08	0.237190%	0.336149%	0.000000%	0.000000%
9						
10	STEAM PRODUCTION		0	0	0	196,096,509
11	PERCENT	S01	0.000000%	0.000000%	0.000000%	100.000000%
12						
13	SERVICES - OVERHEAD		0	0	0	0
14	PERCENT	S03	0.000000%	0.000000%	0.000000%	0.000000%
15						
16	SERVICES - UNDERGROUND		4,057,110	706,535	105,276	0
17	PERCENT	S03A	0.163372%	0.028451%	0.004239%	0.000000%
18						
19	METERING		311,646	64,103	5,386	0
20	PERCENT	S04	0.037382%	0.007689%	0.000646%	0.000000%
21						
22	INSTALL. ON CUSTOMERS PREMISES		0	0	0	0
23	PERCENT	S05	0.000000%	0.000000%	0.000000%	0.000000%
24						
25	SERVICES ON CUSTR. PREMISES		9,284	1,741	58	0
26	PERCENT	S06	0.034349%	0.006441%	0.000215%	0.000000%
27						
28	CUSTR. ACCTG. AND COLLECTION		42,994	5,951	348	0
29	PERCENT	S07	0.027193%	0.003764%	0.000220%	0.000000%
30						
31	UNCOLLECTIBLES		27,166	33,890	5,497	0
32	PERCENT	S09	0.193436%	0.241315%	0.039142%	0.000000%
33						
34	CUSTOMER SERVICE		22,653	1,422	53	0
35	PERCENT	S10	0.011744%	0.000737%	0.000027%	0.000000%
36						
37	PRINTING & MAILING A BILL		2,730	171	6	0
38	PERCENT	S11	0.011744%	0.000737%	0.000027%	0.000000%
39						
40	RECEIPTS PROCESSING		2,211	139	5	0
41	PERCENT	S12	0.011744%	0.000737%	0.000027%	0.000000%
42						
43	STREET LIGHTING - CITY OF NEW YORK		0	0	0	0
44	PERCENT	S14	0.000000%	0.000000%	0.000000%	0.000000%
45						
46	STREET LIGHTING - OTH. BOOK COST		0	0	0	0
47	PERCENT	S15	0.000000%	0.000000%	0.000000%	0.000000%
48						
49	O.H. LINES - CUSTOMER COMPONENT		0	0	0	0
50	PERCENT	C01	0.000000%	0.000000%	0.000000%	0.000000%
51						
52	U.G. LINES - CUSTOMER COMPONENT		495	89	0	0
53	PERCENT	C02	0.115839%	0.020828%	0.000000%	0.000000%
54						
55	PRIMARY - CUSTOMER COMPONENT		598,448	107,600	2,418	0
56	PERCENT	C03	0.099264%	0.017848%	0.000401%	0.000000%
57						
58	REVENUES FROM SALES		14,698,509	18,336,899	2,974,149	0
59	PERCENT	R01	0.196651%	0.245329%	0.039791%	0.000000%
60						
61	MFC REVENUES		29,036	32,165	0	0
62	PERCENT	R02	0.063953%	0.070845%	0.000000%	0.000000%

CON ED ELECTRIC 2023 ECOS

ALLOCATION FACTORS

		MULTI-DW. SPACE HTG. NTD-SC #12 (13)	MULTI-DW. SPACE HTG. TOD-SC #12 (14)	BULK POWER TOD-SC #13 (15)	STEAM DEPT. ELECTRIC FACILITIES (16)
63					
64	BPP REVENUES	3,853	328	15	0
65	PERCENT	R03 0.008960%	0.000763%	0.000036%	0.000000%
66					
67	NET MISCELLANEOUS REVENUES	676,850	844,389	136,957	0
68	PERCENT	R04 0.202192%	0.252241%	0.040913%	0.000000%
69					
70	OTHER REVENUES - INTERDEPARTMENTAL RENTS	0	0	0	17,914,889
71	PERCENT	R06 0.000000%	0.000000%	0.000000%	100.000000%
72					
73	REVENUE ADJUSTMENT	0	0	0	0
74	PERCENT	R08A 0.000000%	0.000000%	0.000000%	0.000000%
75					
76	NULL REVENUE FACTOR	0	0	0	0
77	PERCENT	R99 0.000000%	0.000000%	0.000000%	0.000000%
78					
79	UNBUNDLED ALLOCATOR	23,901	24,387	0	0
80	PERCENT	U01 0.063850%	0.065149%	0.000000%	0.000000%
81					
82	ANNUAL KWH SALES	130,307,957	166,411,069	16,515,100	0
83	PERCENT	K01 0.253097%	0.323220%	0.032077%	0.000000%
84					
85	ANNUAL KWH SALES - CON ED ONLY	130,307,957	166,411,069	16,515,100	0
86	PERCENT	K02 0.307978%	0.393307%	0.039033%	0.000000%
87					
88	BILLING DEMAND - 1	K03 305,735	384,207	127,314	0
89					
90	BILLING DEMAND - 2	K04 305,735	384,207	127,314	0
91					
92	NUMBER OF CUSTOMERS	K05 430	27	1	0

Consolidated Edison Company of New York, Inc.
Embedded Cost-of-Service Study Results
For the Year 2023

<u>Service Classification</u>	<u>Rate of Return %</u>	<u>Initial Surplus/Deficiency*</u> <u>(\$000)</u>	<u>Adjustment**</u> <u>(\$000)</u>	<u>Adjusted Surplus/Deficiency*</u> <u>(\$000)</u>
TOTAL CECONY	10.96			
TOTAL NYPA	8.82	(34,775)	-	(34,775)
TOTAL SYSTEM	10.71			
<u>Individual CECONY Classes</u>				
SC 1 Residential	10.10	-		-
SC 2 General Small	11.41	-	1,520	1,520
SC 5 Traction	7.79	(12)		(12)
SC 5 TOD	7.74	(470)		(470)
SC 6 Street Lighting	6.95	(589)		(589)
SC 8 Apt. House	11.05	-	465	465
SC 8 TOD	10.87	-	35	35
SC 9 General Large	12.03	26,266	5,919	32,184
SC 9 TOD	11.46	-	1,522	1,522
SC 12 Apt. House Htg.	11.83	34	38	72
SC 12 TOD	11.77	-	48	48
Total Surplus		26,300		
Total Deficiency		(35,846)		
Grand Total		(9,546)	9,546	-
			9,546	-

* Deficiencies shown as negative

** Adjustments are based on Non-Competitive Delivery Revenues

Consolidated Edison Company of New York, Inc.
Merchant Function Charge Calculations
Supply Portion of the MFC for Full Service Customers
Based on 2023 Embedded Cost-of-Service Study

	Total Residential SC 1	General Small SC 2	Total Other Commercial	Total ConEd
1 Supply portion of the MFC	\$16,632,889	\$2,386,049	\$4,266,984	\$23,285,922
2				
3 Total ConEd T&D, MFC-Supply Related,				\$6,761,592,539
4 MFC and POR Credit & Collection, BPP Revenues				
5				
6				
7 Fixed Rate of Revenue Requirement	<u>0.24599%</u>	<u>0.03529%</u>	<u>0.06311%</u>	<u>0.34439%</u>
8 (as % of total revenues)				

Exhibit __ (DAC-2)
Schedule 2
Page 2 of 2

Consolidated Edison Company of New York, Inc.
Merchant Function Charge Calculations
Credit & Collection/Theft Portion of the MFC for Full Service and POR Customers
Based on 2023 Embedded Cost-of-Service Study

	Full Service Portion of Credit & Collection/Theft	Full Service % Breakdown
Residential SC 1	\$21,237,686	76.79374%
General Small SC 2	\$3,026,642	10.94409%
Total Other Commercial	<u>\$3,391,164</u>	12.26217%
Total Full Service	\$27,655,492	100.00000%
POR Portion of Credit & Collection/Theft	<u>\$11,764,568</u>	
Total Competitive Credit & Collection/Theft	\$39,420,060	
Total ConEd T&D, MFC-Supply Related, MFC and POR Credit & Collection, BPP Revenues	\$6,761,592,539	
Fixed Rate of Revenue Requirement (as % of total revenues)	<u>0.58300%</u>	

Consolidated Edison Company of New York, Inc.
Printing and Mailing a Bill
December 31, 2023

	<u>Electric Labor</u>	<u>Electric Non-Labor</u>	<u>Total Electric</u>
Direct Printing & Mailing a Bill Costs	\$422,398	\$6,811,896	\$7,234,294
Postage Costs	\$0	\$14,443,148	\$14,443,148
<u>Reallocation of IT Costs</u>			
Computer Maintenance	\$0	\$31,247	\$31,247
Application Services - Salary	\$46,292	\$0	\$46,292
Mainframe Software Licensing	\$0	\$1,305,685	\$1,305,685
Subtotal of Reallocation of IT Costs	<u>\$46,292</u>	<u>\$1,336,932</u>	<u>\$1,383,224</u>
Total Printing and Mailing a Bill Costs	\$468,690	\$22,591,976	\$23,060,666
Allocation of Credit & Collection/Theft	\$154,752	\$68,316	\$223,067
Allocation of Educ-Cust Advertising/Promo	\$1	\$7,453	\$7,454
Allocation of Uncollectibles	\$0	\$30,566	\$30,566
Subtotal Unbundled Customer Care Costs	<u>\$154,752</u>	<u>\$106,335</u>	<u>\$261,088</u>
Subtotal with Commission Ordered Costs	\$623,442	\$22,698,311	\$23,321,754
Total Overheads			\$845,983
Total Cost Printing and Mailing a Bill			\$24,167,736
Total 2023 Electric Mailings			25,682,220
Total Unit Cost for Printing and Mailing a Bill			\$0.94

Consolidated Edison Company of New York, Inc.
Receipts Processing
December 31, 2023

	<u>Electric Labor</u>	<u>Electric Non-Labor</u>	<u>Total Electric</u>
Direct Receipts Processing Costs	\$73,168	\$10,597,763	\$10,670,932
Allocation of Customer Care Costs	\$5,026,800	\$2,807,937	\$7,834,737
Allocation of Information Technology Costs	<u>\$27,418</u>	<u>\$116,800</u>	<u>\$144,218</u>
Total Receipts Processing Costs	\$5,127,386	\$13,522,500	\$18,649,886
Allocation of Credit & Collection/Theft	\$125,152	\$55,249	\$180,402
Allocation of Educ-Cust Advertising/Promo	\$1	\$6,028	\$6,028
Allocation of Uncollectibles	<u>\$0</u>	<u>\$24,720</u>	<u>\$24,720</u>
Subtotal Unbundled Customer Care Costs	\$125,153	\$85,997	\$211,150
Subtotal with Commission Ordered Costs	\$5,252,539	\$13,608,497	\$18,861,036
Total Overheads			\$3,763,897
Total Cost for Receipts Processing			\$22,624,933
Total 2023 Electric Mailings			25,682,220
Total Unit Cost for Receipts Processing			\$0.88

EXHIBIT ____ (DAC-3)

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC.

SEASONAL RATE STUDY

Consolidated Edison Company of New York, Inc.
Exhibit ____ (DAC-3)
Seasonal Rate Study
Cost-based Seasonal Ratios

	Total NYPA	SC1	SC2	SC5 Conventional	SC5 TOD	SC6	SC8 Conventional	SC8 TOD	SC9 Conventional	SC9 TOD	SC12 Conventional	SC12 TOD
Revenues ¹	821,198,843	3,206,745,119	620,804,088	114,708	4,678,559	3,705,050	187,429,227	14,155,691	2,388,085,028	612,934,645	15,408,248	19,213,781
Non-load	191,154,802	1,247,679,553	367,215,347	69,063	14,464	3,164,957	19,425,571	894,259	603,281,402	33,174,090	2,314,055	463,822
Load-carrying ²	166,488,412	439,382,247	55,223,845	5,491	1,425,317	286	42,309,835	3,337,628	438,737,513	155,507,475	2,237,432	2,980,677
Transmission	116,189,652	300,354,559	34,970,520	8,538	1,045,436	121,783	27,351,830	2,173,977	281,468,934	98,855,222	2,369,488	3,497,910
Substation	215,958,421	560,084,877	65,404,208	15,823	1,937,081	225,096	51,115,152	4,061,121	527,106,130	184,905,732	4,435,516	6,546,942
Primary - Demand	131,407,556	659,243,884	97,990,169	15,792	256,261	192,928	47,226,838	3,688,705	537,491,049	140,492,126	4,051,758	5,724,430
Secondary - Demand	630,044,040	1,959,065,567	253,588,741	45,645	4,664,095	540,093	168,003,655	13,261,432	1,784,803,625	579,760,555	13,094,194	18,749,959
Total Load-Carrying Costs												
System Summer peak ³	11,294	11,294	11,294	11,294	11,294	11,294	11,294	11,294	11,294	11,294	11,294	11,294
System Winter peak ⁴	7,428	7,428	7,428	7,428	7,428	7,428	7,428	7,428	7,428	7,428	7,428	7,428
System Summer / Winter Ratio	1.520	1.520	1.520	1.520	1.520	1.520	1.520	1.520	1.520	1.520	1.520	1.520
Class Summer peak ⁵	1,720	4,226	465	0.1	14	2	369	30	3,646	1,312	19	25
Class Winter peak ⁶	1,308	2,201	357	0.1	16	2	207	17	2,735	952	31	46
Class Summer / Winter Ratio	1.315	1.920	1.301	0.418	0.878	0.795	1.786	1.721	1.333	1.378	0.614	0.556
Load-carrying revenue												
Summer avg monthly												
Transmission	17,976,159	47,441,171	5,962,653	593	153,895	31	4,568,296	360,372	47,371,557	16,790,521	241,581	321,831
Substation	11,524,357	36,778,735	3,445,768	369	79,737	8,659	3,226,141	251,404	28,147,005	10,079,671	139,228	190,238
Primary - Demand	21,419,996	68,582,988	6,444,505	684	147,744	16,005	6,029,019	469,638	52,710,821	18,853,722	260,626	356,064
Secondary - Demand	13,033,756	80,725,114	9,655,314	682	19,545	13,718	5,570,393	426,571	53,749,317	14,325,134	238,077	311,330
Total Summer avg monthly	63,954,268	233,528,008	25,508,240	2,328	400,922	38,412	19,393,849	1,507,984	181,978,700	60,049,047	879,512	1,179,463
Winter avg monthly												
Transmission	11,822,972	31,202,195	3,921,654	390	101,217	20	3,004,581	237,018	31,156,410	11,043,174	158,888	211,669
Substation	8,761,528	19,154,952	2,648,431	883	90,811	10,893	1,805,908	146,045	21,110,114	7,317,068	226,572	342,120
Primary - Demand	16,284,805	35,719,115	4,953,273	1,636	168,263	20,135	3,374,885	272,821	39,532,856	13,686,356	424,127	640,336
Secondary - Demand	9,909,067	42,042,928	7,421,114	1,633	22,260	17,257	3,118,158	247,803	40,311,723	10,398,949	387,431	559,889
Total Winter avg monthly	46,778,371	128,119,192	18,944,473	4,542	382,551	48,306	11,303,532	903,687	132,111,103	42,445,546	1,197,018	1,754,013
Check	-	-	-	-	-	-	-	-	-	-	-	-
Non-Load Avg Monthly	15,929,567	103,973,296	30,601,279	5,755	1,205	263,746	1,618,798	74,522	50,273,450	2,764,507	192,838	38,652
Total Delivery												
Summer avg monthly	79,883,835	337,501,304	56,109,519	8,083	402,127	302,158	21,012,647	1,582,505	232,252,150	62,813,555	1,072,350	1,218,115
Winter avg monthly	62,707,938	232,092,488	49,545,752	10,297	383,756	312,052	12,922,330	978,209	182,384,553	45,210,053	1,389,856	1,792,665
Check	-	-	-	-	-	-	-	-	-	-	-	-
Summer Winter Ratio	1.2739	1.4542	1.1325	0.7850	1.0479	0.9683	1.6261	1.6178	1.2734	1.3894	0.7716	0.6795
Delivery Revenue												
Summer Winter Ratio	1.5669	1.4134	1.2221	1.0676	1.6170	0.8517	1.8510	3.0114	1.4366	2.4341	1.1858	1.1841

Notes:

- 1 From 2023 ECOS: including non-competitive & competitive delivery revenues and other operating revenues.
- 2 From 2023 ECOS: Demand related costs including overheads.
- 3 From 2023 Demand Analysis: 5day - 4hour average summer system peak (Report 6)
- 4 From 2023 Demand Analysis: 5day - 4hour average winter system peak (Report 6)
- 5 From 2023 Demand Analysis: 5day - 4hour average summer class peak
- 6 From 2023 Demand Analysis: 5day - 4hour average winter class peak

Consolidated Edison Company of New York, Inc.
Exhibit ____ (DAC-3)
Seasonal Rate Study
Delivery Revenue-based Seasonal Ratios

Non-Competitive Revenue		<u>NYPA</u>	<u>SC1</u>	<u>SC2</u>	<u>SC5</u>	<u>SC5</u>	<u>SC6</u>	<u>SC8</u>	<u>SC8</u>	<u>SC9</u>	<u>SC9</u>	<u>SC12</u>	<u>SC12</u>
(A)	*Non-Comp Rev Incl. CC				<u>CON</u>	<u>TOD</u>		<u>CON</u>	<u>TOD</u>	<u>CON</u>	<u>TOD</u>	<u>CON</u>	<u>TOD</u>
	Summer Winter Ratio	1.57	1.42	1.23	1.07	1.62	0.85	1.85	3.02	1.44	2.44	1.19	1.19
	- Summer Monthly	\$ 89,074,847	\$309,540,727	\$55,517,955	\$9,517	\$504,456	\$260,076	\$21,520,306	\$2,040,433	\$237,870,485	\$80,318,375	\$1,369,631	\$1,707,203
	- Winter Monthly	\$ 56,847,065	\$218,116,608	\$45,297,823	\$8,908	\$311,978	\$306,011	\$11,612,743	\$675,162	\$165,386,403	\$32,961,265	\$1,152,784	\$1,440,585
(B)	*Customer Charge												
	Summer Winter Ratio		1.00	1.01	1.00	1.00	1.00	1.01	1.00	1.00	1.01	1.00	1.00
	- Summer Monthly		\$61,957,889	\$15,016,050	\$397	\$2,530	\$158,555	\$108,007	\$10,625	\$9,814,333	\$352,693	\$13,881	\$13,661
	- Winter Monthly		\$61,772,813	\$14,898,890	\$396	\$2,527	\$158,983	\$107,375	\$10,612	\$9,766,708	\$349,163	\$13,888	\$13,644
(C=A-B)	*Non-Comp Rev Excl. CC												
	Summer Winter Ratio	1.57	1.58	1.33	1.07	1.62	0.69	1.86	3.05	1.47	2.45	1.19	1.19
	- Summer Monthly	\$89,074,847	\$247,582,837	\$40,501,905	\$9,120	\$501,926	\$101,521	\$21,412,299	\$2,029,807	\$228,056,152	\$79,965,682	\$1,355,749	\$1,693,542
	- Winter Monthly	\$56,847,065	\$156,343,795	\$30,398,934	\$8,512	\$309,451	\$147,027	\$11,505,368	\$664,550	\$155,619,695	\$32,612,102	\$1,138,896	\$1,426,941
Competitive Revenue		<u>NYPA</u>	<u>SC1</u>	<u>SC2</u>	<u>SC5</u>	<u>SC5</u>	<u>SC6</u>	<u>SC8</u>	<u>SC8</u>	<u>SC9</u>	<u>SC9</u>	<u>SC12</u>	<u>SC12</u>
(D)	**BPP & MFC				<u>CON</u>	<u>TOD</u>		<u>CON</u>	<u>TOD</u>	<u>CON</u>	<u>TOD</u>	<u>CON</u>	<u>TOD</u>
	Summer Winter Ratio		1.21	1.04	0.83	1.00	0.97	1.41	1.39	1.17	1.14	0.78	0.81
	- Summer Monthly		\$7,431,270	\$919,367	\$25	\$6	\$4,663	\$82,587	\$6,254	\$1,161,507	\$77,642	\$5,089	\$3,023
	- Winter Monthly		\$6,146,071	\$881,484	\$30	\$6	\$4,830	\$58,482	\$4,485	\$995,551	\$68,099	\$6,506	\$3,733
Total Bundled T&D Revenue		<u>NYPA</u>	<u>SC1</u>	<u>SC2</u>	<u>SC5</u>	<u>SC5</u>	<u>SC6</u>	<u>SC8</u>	<u>SC8</u>	<u>SC9</u>	<u>SC9</u>	<u>SC12</u>	<u>SC12</u>
(E=A+D)	Non-Comp & Comp				<u>CON</u>	<u>TOD</u>		<u>CON</u>	<u>TOD</u>	<u>CON</u>	<u>TOD</u>	<u>CON</u>	<u>TOD</u>
	Summer Winter Ratio	1.57	1.41	1.22	1.07	1.62	0.85	1.85	3.01	1.44	2.43	1.19	1.18
	- Summer Monthly	\$ 89,074,847	\$316,971,997	\$56,437,322	\$9,542	\$504,462	\$264,739	\$21,602,893	\$2,046,686	\$239,031,992	\$80,396,017	\$1,374,719	\$1,710,226
	- Winter Monthly	\$ 56,847,065	\$224,262,679	\$46,179,307	\$8,938	\$311,984	\$310,841	\$11,671,225	\$679,647	\$166,381,954	\$33,029,363	\$1,159,289	\$1,444,318

*Non-Competitive Revenue is calculated in the rate design model based on the 2023 historical year billing determinants priced out at the current 2025 rates.

**Competitive Revenue is based on the 2023 historical year billing determinants priced out at the current 2025 rates. MFC includes Supply-Related, C&C-Related, and POR.

EXHIBIT ____ (DAC-4)

CONSOLIDATED EDISON COMPANY OF NEW YORK, INC.

ALLOCATED COST OF SERVICE STUDY

Decision Tree Mapping

Higher Than Interconnection Voltage

FERC Accounts

TRANSMISSION PLANT IN SERVICE

	Question 1: Is the cost linked to a type of asset?	Question 2: Are all the costs attributable to customer demand?	Question 7: Does the cost apply to all cost categories?	Question 9: Is the cost a tax- related to either a specific asset or cost which varies with customer demand?	Question 8: Should the Customer Charge be set to a predetermined level and any difference in costs and revenues be re-allocated?	Result (Customer, Local, Shared, or Allocate b/w Shared & Local)	Exclude Local Costs from Buyback Rates? (if applicable)
(350) Land and Land Rights	Yes	Yes	N/A	N/A	N/A	Shared	N/A
(351) Energy Storage Equipment - Transmission	Yes	Yes	N/A	N/A	N/A	Shared	N/A
(352) Structures and Improvements	Yes	Yes	N/A	N/A	N/A	Shared	N/A
(353) Station Equipment	Yes	Yes	N/A	N/A	N/A	Shared	N/A
(354) Towers and Fixtures	Yes	Yes	N/A	N/A	N/A	Shared	N/A
(355) Poles and Fixtures	Yes	Yes	N/A	N/A	N/A	Shared	N/A
(356) Overhead Conductors and Devices	Yes	Yes	N/A	N/A	N/A	Shared	N/A
(357) Underground Conduit	Yes	Yes	N/A	N/A	N/A	Shared	N/A
(358) Underground Conductors and Devices	Yes	Yes	N/A	N/A	N/A	Shared	N/A
(359) Roads and Trails	Yes	Yes	N/A	N/A	N/A	Shared	N/A

TRANSMISSION EXPENSES

(560) Operation Supervision and Engineering	Yes	Yes	N/A	N/A	N/A	Shared	N/A
(561.1) Load Dispatch - Reliability	Yes	Yes	N/A	N/A	N/A	Shared	N/A
(561.2) Load Dispatch - Monitor and Operate Transmission System	Yes	Yes	N/A	N/A	N/A	Shared	N/A
(561.3) Load Dispatch - Transmission Service and Scheduling	Yes	Yes	N/A	N/A	N/A	Shared	N/A
(561.4) Scheduling, System Control and Dispatch Services	Yes	Yes	N/A	N/A	N/A	Shared	N/A
(561.5) Reliability, Planning and Standards Development	Yes	Yes	N/A	N/A	N/A	Shared	N/A
(561.8) Reliability, Planning and Standards Development Services	Yes	Yes	N/A	N/A	N/A	Shared	N/A
(562) Station Expenses	Yes	Yes	N/A	N/A	N/A	Shared	N/A
(562.1) Operation of Energy Storage Equipment	Yes	Yes	N/A	N/A	N/A	Shared	N/A
(563) Overhead Lines Expenses	Yes	Yes	N/A	N/A	N/A	Shared	N/A
(564) Underground Lines Expenses	Yes	Yes	N/A	N/A	N/A	Shared	N/A
(566) Miscellaneous Transmission Expenses	Yes	Yes	N/A	N/A	N/A	Shared	N/A
(567) Rents	Yes	Yes	N/A	N/A	N/A	Shared	N/A
(568) Maintenance Supervision and Engineering	Yes	Yes	N/A	N/A	N/A	Shared	N/A
(569) Maintenance of Structures	Yes	Yes	N/A	N/A	N/A	Shared	N/A
(570) Maintenance of Station Equipment	Yes	Yes	N/A	N/A	N/A	Shared	N/A
(571) Maintenance of Overhead Lines	Yes	Yes	N/A	N/A	N/A	Shared	N/A
(572) Maintenance of Underground Lines	Yes	Yes	N/A	N/A	N/A	Shared	N/A
(573) Maintenance of Miscellaneous Transmission Plant	Yes	Yes	N/A	N/A	N/A	Shared	N/A

The following discussion applies to all transmission plant FERC accounts 350 through 359 and associated transmission O&M expenses FERC Accounts 560 through 573:

Generally, the Company's customers are connected to the electrical system at voltages below the transmission level. Therefore, for these customers ACOS study evaluates transmission costs based on the decision tree framework applicable to higher than interconnection voltage level.

DT Q1: Yes

Transmission plant and O&M costs contained in these FERC Accounts are linked to Company's transmission assets.

DT Q2: Yes

Transmission costs are classified as entirely demand related in the Company's ECOS study.

Decision Tree Mapping

Interconnection Voltage

FERC Accounts

TRANSMISSION PLANT IN SERVICE

	Question 1: Is the cost linked to a type of asset?	Question 2: Are all the costs attributable to customer demand?	Question 3: Would a decrease in demand result in entirely unused assets?	Question 4: Does an increase in system coincident demand increase the costs?	Question 5: Does an increase in non- coincident peak demand increase the costs?	QUESTION 6: Could a kW of reverse power flow increase the costs?	Question 7: Does the cost apply to all cost categories?	Question 9: Is the cost a tax- related to either a specific asset or cost which varies with customer demand?	Question 8: Should the Customer Charge be set to a predetermined level and any difference in costs and revenues be re- allocated?	Result (Customer, Local, Shared, or Allocate b/w Shared & Local)	Exclude Local Costs from Buyback Rates? (if applicable)
(350) Land and Land Rights	Yes	Yes	No	Yes	Yes	Yes	N/A	N/A	N/A	Allocate	Include
(351) Energy Storage Equipment - Transmission	Yes	Yes	No	Yes	Yes	Yes	N/A	N/A	N/A	Allocate	Include
(352) Structures and Improvements	Yes	Yes	No	Yes	Yes	Yes	N/A	N/A	N/A	Allocate	Include
(353) Station Equipment	Yes	Yes	No	Yes	Yes	Yes	N/A	N/A	N/A	Allocate	Include
(354) Towers and Fixtures	Yes	Yes	No	Yes	Yes	Yes	N/A	N/A	N/A	Allocate	Include
(355) Poles and Fixtures	Yes	Yes	No	Yes	Yes	Yes	N/A	N/A	N/A	Allocate	Include
(356) Overhead Conductors and Devices	Yes	Yes	No	Yes	Yes	Yes	N/A	N/A	N/A	Allocate	Include
(357) Underground Conduit	Yes	Yes	No	Yes	Yes	Yes	N/A	N/A	N/A	Allocate	Include
(358) Underground Conductors and Devices	Yes	Yes	No	Yes	Yes	Yes	N/A	N/A	N/A	Allocate	Include
(359) Roads and Trails	Yes	Yes	No	Yes	Yes	Yes	N/A	N/A	N/A	Allocate	Include

TRANSMISSION EXPENSES

(560) Operation Supervision and Engineering	Yes	Yes	No	Yes	Yes	Yes	N/A	N/A	N/A	Allocate	Include
(561.1) Load Dispatch - Reliability	Yes	Yes	No	Yes	Yes	Yes	N/A	N/A	N/A	Allocate	Include
(561.2) Load Dispatch - Monitor and Operate Transmission System	Yes	Yes	No	Yes	Yes	Yes	N/A	N/A	N/A	Allocate	Include
(561.3) Load Dispatch - Transmission Service and Scheduling	Yes	Yes	No	Yes	Yes	Yes	N/A	N/A	N/A	Allocate	Include
(561.4) Scheduling, System Control and Dispatch Services	Yes	Yes	No	Yes	Yes	Yes	N/A	N/A	N/A	Allocate	Include
(561.5) Reliability, Planning and Standards Development	Yes	Yes	No	Yes	Yes	Yes	N/A	N/A	N/A	Allocate	Include
(561.8) Reliability, Planning and Standards Development Services	Yes	Yes	No	Yes	Yes	Yes	N/A	N/A	N/A	Allocate	Include
(562) Station Expenses	Yes	Yes	No	Yes	Yes	Yes	N/A	N/A	N/A	Allocate	Include
(562.1) Operation of Energy Storage Equipment	Yes	Yes	No	Yes	Yes	Yes	N/A	N/A	N/A	Allocate	Include
(563) Overhead Lines Expenses	Yes	Yes	No	Yes	Yes	Yes	N/A	N/A	N/A	Allocate	Include
(564) Underground Lines Expenses	Yes	Yes	No	Yes	Yes	Yes	N/A	N/A	N/A	Allocate	Include
(566) Miscellaneous Transmission Expenses	Yes	Yes	No	Yes	Yes	Yes	N/A	N/A	N/A	Allocate	Include
(567) Rents	Yes	Yes	No	Yes	Yes	Yes	N/A	N/A	N/A	Allocate	Include
(568) Maintenance Supervision and Engineering	Yes	Yes	No	Yes	Yes	Yes	N/A	N/A	N/A	Allocate	Include
(569) Maintenance of Structures	Yes	Yes	No	Yes	Yes	Yes	N/A	N/A	N/A	Allocate	Include
(570) Maintenance of Station Equipment	Yes	Yes	No	Yes	Yes	Yes	N/A	N/A	N/A	Allocate	Include
(571) Maintenance of Overhead Lines	Yes	Yes	No	Yes	Yes	Yes	N/A	N/A	N/A	Allocate	Include
(572) Maintenance of Underground Lines	Yes	Yes	No	Yes	Yes	Yes	N/A	N/A	N/A	Allocate	Include
(573) Maintenance of Miscellaneous Transmission Plant	Yes	Yes	No	Yes	Yes	Yes	N/A	N/A	N/A	Allocate	Include

The following discussion applies to all transmission plant FERC accounts 350 through 359 and associated transmission O&M expenses FERC Accounts 560 through 573:

DT Q1: Yes

Transmission plant and O&M costs contained in these FERC Accounts are linked to Company's transmission assets.

DT Q2: Yes

Transmission costs are classified as entirely demand related in the Company's ECOS study.

DT Q3: No

A decrease in demand would not result in entirely unused assets as this equipment serves all customers.

DT Q4: Yes

An increase in the system coincident demand would in all likelihood lead to an increase in transmission costs.

DT Q5: Yes

At the transmission customers' interconnection voltage level, an increase in non-coincident peak demand may lead to an increase in transmission costs.

DT Q6: Yes

Buyback customers should bear appropriate cost responsibility for using the Company's system related to their injections. To the extent a kW of reverse power flow requires the use of the Company's grid, the buyback customer should contribute to its costs.

Decision Tree Mapping

Higher Than Interconnection Voltage

FERC Accounts

SUBSTATION PLANT IN SERVICE

(360) Land and Land Rights	Yes	Yes	N/A	N/A	N/A	Shared	N/A
(361) Structures and Improvements	Yes	Yes	N/A	N/A	N/A	Shared	N/A
(362) Station Equipment	Yes	Yes	N/A	N/A	N/A	Shared	N/A
(363) Storage Battery Equipment - Distribution	Yes	Yes	N/A	N/A	N/A	Shared	N/A

SUBSTATION EXPENSES

(582) Station Expenses	Yes	Yes	N/A	N/A	N/A	Shared	N/A
(588) Miscellaneous Expenses	Yes	Yes	N/A	N/A	N/A	Shared	N/A
(589) Rents	Yes	Yes	N/A	N/A	N/A	Shared	N/A
(592) Maintenance of Station Equipment	Yes	Yes	N/A	N/A	N/A	Shared	N/A
(598) Maintenance of Miscellaneous Distribution Plant	Yes	Yes	N/A	N/A	N/A	Shared	N/A

The following discussion applies to distribution plant FERC accounts 360 through 363 and associated distribution O&M expenses FERC Accounts 582, 588, 589, 592, and 598:

Either entirely or partially these FERC Accounts constitute substation costs.

A majority of the Company's customers are connected to the electrical system at voltages below the substation level. Therefore, for these customers ACOS study evaluates these FERC Accounts based on the decision tree framework applicable to higher than interconnection voltage level.

DT Q1: Yes

Plant and O&M costs contained in these FERC Accounts are linked to Company's substation assets.

DT Q2: Yes

Substation costs are classified as entirely demand related in the Company's ECOS study.

Decision Tree Mapping

Interconnection Voltage

FERC Accounts

SUBSTATION PLANT IN SERVICE

	Question 1: Is the cost linked to a type of asset?	Question 2: Are all the costs attributable to customer demand?	Question 3: Would a decrease in demand result in entirely unused assets?	Question 4: Does an increase in system coincident demand increase the costs?	Question 5: Does an increase in non- coincident peak demand increase the costs?	QUESTION 6: Could a kW of reverse power flow increase the costs?	Question 7: Does the cost apply to all cost categories?	Question 9: Is the cost a tax- related to either a specific asset or cost which varies with customer demand?	Question 8: Should the Customer Charge be set to a predetermined level and any difference in costs and revenues be re- allocated?	Result (Customer, Local, Shared, or Allocate b/w Shared & Local)	Exclude Local Costs from Buyback Rates? (if applicable)
(360) Land and Land Rights	Yes	Yes	No	Yes	Yes	Yes	N/A	N/A	N/A	Allocate	Include
(361) Structures and Improvements	Yes	Yes	No	Yes	Yes	Yes	N/A	N/A	N/A	Allocate	Include
(362) Station Equipment	Yes	Yes	No	Yes	Yes	Yes	N/A	N/A	N/A	Allocate	Include
(363) Storage Battery Equipment - Distribution	Yes	Yes	No	Yes	Yes	Yes	N/A	N/A	N/A	Allocate	Include

SUBSTATION EXPENSES

(582) Station Expenses	Yes	Yes	No	Yes	Yes	Yes	N/A	N/A	N/A	Allocate	Include
(588) Miscellaneous Expenses	Yes	Yes	No	Yes	Yes	Yes	N/A	N/A	N/A	Allocate	Include
(589) Rents	Yes	Yes	No	Yes	Yes	Yes	N/A	N/A	N/A	Allocate	Include
(592) Maintenance of Station Equipment	Yes	Yes	No	Yes	Yes	Yes	N/A	N/A	N/A	Allocate	Include
(598) Maintenance of Miscellaneous Distribution Plant	Yes	Yes	No	Yes	Yes	Yes	N/A	N/A	N/A	Allocate	Include

The following discussion applies to distribution plant FERC accounts 360 through 363 and associated distribution O&M expenses FERC Accounts 582, 588, 589, 592, and 598:

Either entirely or partially these FERC Accounts constitute substation costs.

138kV customers may be connected to the Company's electrical system at the substation voltage level. Therefore, for these customers ACOS study evaluates these costs based on the decision tree framework applicable to their interconnection voltage level.

DT Q1: Yes

Plant and O&M costs contained in these FERC Accounts are linked to Company's substation assets.

DT Q2: Yes

Substation costs are classified as entirely demand related in the Company's ECOS study.

DT Q3: No

A decrease in demand would not result in entirely unused assets as this equipment serves customers at this interconnection voltage level, as well as primary and secondary connected customers.

DT Q4: Yes

The Company believes the appropriate answer to Question 4 is no. For the reasons discussed in the Company's July 14, 2022 filing and solely for the purposes of this filing, the Company has answered yes to Question 4. The Company reserves the right to change this determination in future standby rate filings if other aspects of the decision tree or ACOS process are changed.

DT Q5: Yes

At the substation customers' interconnection voltage level, an increase in non-coincident peak demand may lead to an increase in these costs. The Company believes that non-coincident peak demands are an important driver of substation costs at the customers' interconnection voltage levels. This is evident in the way substation costs are allocated to service classes in the Company's ECOS study, where class non-coincident demands are incorporated into the allocator.

DT Q6: Yes

Buyback customers should bear appropriate cost responsibility for using the Company's system related to their injections. To the extent a kW of reverse power flow requires the use of the Company's grid, the buyback customer should contribute to its costs.

Decision Tree Mapping

Higher Than Interconnection Voltage

FERC Accounts

PRIMARY DISTRIBUTION PLANT IN SERVICE

(364) Poles, Towers, and Fixtures	Yes	Yes	N/A	N/A	N/A	Shared	N/A
(365) Overhead Conductors and Devices	Yes	Yes	N/A	N/A	N/A	Shared	N/A
(366) Underground Conduit	Yes	Yes	N/A	N/A	N/A	Shared	N/A
(367) Underground Conductors and Devices	Yes	Yes	N/A	N/A	N/A	Shared	N/A

PRIMARY DISTRIBUTION EXPENSES

(583) Overhead Line Expenses	Yes	Yes	N/A	N/A	N/A	Shared	N/A
(584) Underground Line Expenses	Yes	Yes	N/A	N/A	N/A	Shared	N/A
(588) Miscellaneous Expenses	Yes	Yes	N/A	N/A	N/A	Shared	N/A
(589) Rents	Yes	Yes	N/A	N/A	N/A	Shared	N/A
(593) Maintenance of Overhead Lines	Yes	Yes	N/A	N/A	N/A	Shared	N/A
(594) Maintenance of Underground Lines	Yes	Yes	N/A	N/A	N/A	Shared	N/A
(598) Maintenance of Miscellaneous Distribution Plant	Yes	Yes	N/A	N/A	N/A	Shared	N/A

The following discussion applies to non-customer, primary portion of distribution plant FERC accounts 364 through 367 and associated portions of distribution O&M expenses FERC Accounts 583, 584, 588, 589, 593, 594, and 598:

For the Company's secondary service connected customers, the ACOS study evaluates these FERC Accounts based on the decision tree framework applicable to higher than interconnection voltage level.

DT Q1: Yes

Plant and O&M costs contained in these FERC Accounts are linked to Company's primary distribution assets.

DT Q2: Yes

Non-customer, primary costs are classified as entirely demand related in the Company's ECOS study.

Decision Tree Mapping

Interconnection Voltage

FERC Accounts

PRIMARY DISTRIBUTION PLANT IN SERVICE

	Question 1: Is the cost linked to a type of asset?	Question 2: Are all the costs attributable to customer demand?	Question 3: Would a decrease in demand result in entirely unused assets?	Question 4: Does an increase in system coincident demand increase the costs?	Question 5: Does an increase in non- coincident peak demand increase the costs?	QUESTION 6: Could a kW of reverse power flow increase the costs?	Question 7: Does the cost apply to all cost categories?	Question 9: Is the cost a tax- related to either a specific asset or cost which varies with customer demand?	Question 8: Should the Customer Charge be set to a predetermined level and any difference in costs and revenues be re- allocated?	Result (Customer, Local, Shared, or Allocate b/w Shared & Local)	Exclude Local Costs from Buyback Rates? (if applicable)
(364) Poles, Towers, and Fixtures	Yes	Yes	No	Yes	Yes	Yes	N/A	N/A	N/A	Allocate	Include
(365) Overhead Conductors and Devices	Yes	Yes	No	Yes	Yes	Yes	N/A	N/A	N/A	Allocate	Include
(366) Underground Conduit	Yes	Yes	No	Yes	Yes	Yes	N/A	N/A	N/A	Allocate	Include
(367) Underground Conductors and Devices	Yes	Yes	No	Yes	Yes	Yes	N/A	N/A	N/A	Allocate	Include

PRIMARY DISTRIBUTION EXPENSES

(583) Overhead Line Expenses	Yes	Yes	No	Yes	Yes	Yes	N/A	N/A	N/A	Allocate	Include
(584) Underground Line Expenses	Yes	Yes	No	Yes	Yes	Yes	N/A	N/A	N/A	Allocate	Include
(588) Miscellaneous Expenses	Yes	Yes	No	Yes	Yes	Yes	N/A	N/A	N/A	Allocate	Include
(589) Rents	Yes	Yes	No	Yes	Yes	Yes	N/A	N/A	N/A	Allocate	Include
(593) Maintenance of Overhead Lines	Yes	Yes	No	Yes	Yes	Yes	N/A	N/A	N/A	Allocate	Include
(594) Maintenance of Underground Lines	Yes	Yes	No	Yes	Yes	Yes	N/A	N/A	N/A	Allocate	Include
(598) Maintenance of Miscellaneous Distribution Plant	Yes	Yes	No	Yes	Yes	Yes	N/A	N/A	N/A	Allocate	Include

The following discussion applies to non-customer, primary portion of distribution plant FERC accounts 364 through 367 and associated portions of distribution O&M expenses FERC Accounts 583, 584, 588, 589, 593, 594, and 598:

For the Company's primary service connected customers, the ACOS study evaluates these costs based on the decision tree framework applicable to their interconnection voltage level.

DT Q1: Yes

Plant and O&M costs contained in these FERC Accounts are linked to Company's primary distribution assets.

DT Q2: Yes

Non-customer, primary distribution costs are classified as entirely demand related in the Company's ECOS study.

DT Q3: No

A decrease in demand would not result in entirely unused assets as this equipment serves customers at this interconnection voltage level, as well as secondary connected customers.

DT Q4: Yes

The Company believes the appropriate answer to Question 4 is no. For the reasons discussed in the Company's July 14, 2022 filing and solely for the purposes of this filing, the Company has answered yes to Question 4. The Company reserves the right to change this determination in future standby rate filings if other aspects of the decision tree or ACOS process are changed.

DT Q5: Yes

At the primary customers' interconnection voltage level, an increase in non-coincident peak demand may lead to an increase in these costs. The Company believes that non-coincident peak demands are an important driver of primary costs at the customers' interconnection voltage levels. This is evident in the way primary costs are allocated to service classes in the Company's ECOS study, where class non-coincident demands are incorporated into the allocator.

DT Q6: Yes

Buyback customers should bear appropriate cost responsibility for using the Company's system related to their injections. To the extent a kW of reverse power flow requires the use of the Company's grid, the buyback customer should contribute its costs.

Decision Tree Mapping

Interconnection Voltage

FERC Accounts

SECONDARY DISTRIBUTION PLANT IN SERVICE

	Question 1: Is the cost linked to a type of asset?	Question 2: Are all the costs attributable to customer demand?	Question 3: Would a decrease in demand result in entirely unused assets?	Question 4: Does an increase in system coincident demand increase the costs?	Question 5: Does an increase in non- coincident peak demand increase the costs?	QUESTION 6: Could a kW of reverse power flow increase the costs?	Question 7: Does the cost apply to all cost categories?	Question 9: Is the cost a tax- related to either a specific asset or cost which varies with customer demand?	Question 8: Should the Customer Charge be set to a predetermined level and any difference in costs and revenues be re-allocated?	Result (Customer, Local, Shared, or Allocate b/w Shared & Local)	Exclude Local Costs from Buyback Rates? (if applicable)
(364) Poles, Towers, and Fixtures	Yes	Yes	No	Yes	Yes	Yes	N/A	N/A	N/A	Allocate	Include
(365) Overhead Conductors and Devices	Yes	Yes	No	Yes	Yes	Yes	N/A	N/A	N/A	Allocate	Include
(366) Underground Conduit	Yes	Yes	No	Yes	Yes	Yes	N/A	N/A	N/A	Allocate	Include
(367) Underground Conductors and Devices	Yes	Yes	No	Yes	Yes	Yes	N/A	N/A	N/A	Allocate	Include
(368) Line Transformers	Yes	Yes	No	Yes	Yes	Yes	N/A	N/A	N/A	Allocate	Include

SECONDARY DISTRIBUTION EXPENSES

(583) Overhead Line Expenses	Yes	Yes	No	Yes	Yes	Yes	N/A	N/A	N/A	Allocate	Include
(584) Underground Line Expenses	Yes	Yes	No	Yes	Yes	Yes	N/A	N/A	N/A	Allocate	Include
(588) Miscellaneous Expenses	Yes	Yes	No	Yes	Yes	Yes	N/A	N/A	N/A	Allocate	Include
(589) Rents	Yes	Yes	No	Yes	Yes	Yes	N/A	N/A	N/A	Allocate	Include
(593) Maintenance of Overhead Lines	Yes	Yes	No	Yes	Yes	Yes	N/A	N/A	N/A	Allocate	Include
(594) Maintenance of Underground Lines	Yes	Yes	No	Yes	Yes	Yes	N/A	N/A	N/A	Allocate	Include
(595) Maintenance of Line Transformers	Yes	Yes	No	Yes	Yes	Yes	N/A	N/A	N/A	Allocate	Include
(598) Maintenance of Miscellaneous Distribution Plant	Yes	Yes	No	Yes	Yes	Yes	N/A	N/A	N/A	Allocate	Include

The following discussion applies to non-customer, secondary portion of distribution plant FERC accounts 364 through 367, non-customer portion of account 368, and associated portions of distribution O&M expenses FERC Accounts 583, 584, 588, 589, 593, 594, 595, and 598:

Secondary customers are connected to the Company's electrical system at the secondary voltage level. Therefore, for these customers ACOS study evaluates these costs based on the decision tree framework applicable to their interconnection voltage level.

DT Q1: Yes

Plant and O&M costs contained in these FERC Accounts are linked to Company's secondary distribution assets.

DT Q2: Yes

Non-customer, secondary distribution costs are classified as entirely demand related in the Company's ECOS study.

DT Q3: No

A decrease in demand would not result in entirely unused assets as this equipment serves all customers at this interconnection voltage level.

DT Q4: Yes

The Company believes the appropriate answer to Question 4 is no. For the reasons discussed in the Company's July 14, 2022 filing and solely for the purposes of this filing, the Company has answered yes to Question 4. The Company reserves the right to change this determination in future standby rate filings if other aspects of the decision tree or ACOS process are changed.

DT Q5: Yes

At the secondary distribution customers' interconnection voltage level, an increase in non-coincident peak demand may lead to an increase in these costs. The Company believes that non-coincident peak demands are an important driver of secondary distribution costs at the customers' interconnection voltage levels. This is evident in the way secondary distribution costs are allocated to service classes in the Company's ECOS study, where class non-coincident demands are incorporated into the allocator.

DT Q6: Yes

Buyback customers should bear appropriate cost responsibility for using the Company's system related to their injections. To the extent a kW of reverse power flow requires the use of the Company's grid, the buyback customer should contribute to its costs.

Interconnection Voltage											
	Question 1: Is the cost linked to a type of asset?	Question 2: Are all the costs attributable to customer demand?	Question 3: Would a decrease in demand result in entirely unused assets?	Question 4: Does an increase in system coincident demand increase the costs?	Question 5: Does an increase in non- coincident peak demand increase the costs?	QUESTION 6: Could a kW of reverse power flow increase the costs?	Question 7: Does the cost apply to all cost categories?	Question 9: Is the cost a tax- related to either a specific asset or cost which varies with customer demand?	Question 8: Should the Customer Charge be set to a predetermined level and any difference in costs and revenues be re-allocated?	Result (Customer, Local, Shared, or Allocate b/w Shared & Local)	Exclude Local Costs from Buyback Rates? (if applicable)
FERC Accounts											
CUSTOMER-RELATED PLANT IN SERVICE											
(364) Poles, Towers, and Fixtures	Yes	No	N/A	N/A	N/A	N/A	No	N/A	Yes ¹	Customer	N/A
(365) Overhead Conductors and Devices	Yes	No	N/A	N/A	N/A	N/A	No	N/A	Yes ¹	Customer	N/A
(366) Underground Conduit	Yes	No	N/A	N/A	N/A	N/A	No	N/A	Yes ¹	Customer	N/A
(367) Underground Conductors and Devices	Yes	No	N/A	N/A	N/A	N/A	No	N/A	Yes ¹	Customer	N/A
(368) Line Transformers	Yes	No	N/A	N/A	N/A	N/A	No	N/A	Yes ¹	Customer	N/A
(369) Services	Yes	No	N/A	N/A	N/A	N/A	No	N/A	Yes ¹	Customer	N/A
(370) Meters	Yes	No	N/A	N/A	N/A	N/A	No	N/A	Yes ¹	Customer	N/A
(371) Installations on Customer Premises	Yes	No	N/A	N/A	N/A	N/A	No	N/A	Yes ¹	Customer	N/A
CUSTOMER-RELATED DISTRIBUTION EXPENSES											
(583) Overhead Line Expenses	Yes	No	N/A	N/A	N/A	N/A	No	N/A	Yes ¹	Customer	N/A
(584) Underground Line Expenses	Yes	No	N/A	N/A	N/A	N/A	No	N/A	Yes ¹	Customer	N/A
(586) Meter Expenses	Yes	No	N/A	N/A	N/A	N/A	No	N/A	Yes ¹	Customer	N/A
(587) Customer Installations Expenses	Yes	No	N/A	N/A	N/A	N/A	No	N/A	Yes ¹	Customer	N/A
(588) Miscellaneous Expenses	Yes	No	N/A	N/A	N/A	N/A	No	N/A	Yes ¹	Customer	N/A
(589) Rents	Yes	No	N/A	N/A	N/A	N/A	No	N/A	Yes ¹	Customer	N/A
(593) Maintenance of Overhead Lines	Yes	No	N/A	N/A	N/A	N/A	No	N/A	Yes ¹	Customer	N/A
(594) Maintenance of Underground Lines	Yes	No	N/A	N/A	N/A	N/A	No	N/A	Yes ¹	Customer	N/A
(595) Maintenance of Line Transformers	Yes	No	N/A	N/A	N/A	N/A	No	N/A	Yes ¹	Customer	N/A
(597) Maintenance of Meters	Yes	No	N/A	N/A	N/A	N/A	No	N/A	Yes ¹	Customer	N/A
(598) Maintenance of Miscellaneous Distribution Plant	Yes	No	N/A	N/A	N/A	N/A	No	N/A	Yes ¹	Customer	N/A
CUSTOMER ACCOUNTS EXPENSES											
(901) Supervision	No	N/A	N/A	N/A	N/A	N/A	No	N/A	Yes ¹	Customer	N/A
(902) Meter Reading Expenses	No	N/A	N/A	N/A	N/A	N/A	No	N/A	Yes ¹	Customer	N/A
(903) Customer Records and Collection Expenses	No	N/A	N/A	N/A	N/A	N/A	No	N/A	Yes ¹	Customer	N/A
(904) Uncollectible Accounts	No	N/A	N/A	N/A	N/A	N/A	No	N/A	Yes ¹	Customer	N/A
(905) Miscellaneous Customer Accounts Expenses	No	N/A	N/A	N/A	N/A	N/A	No	N/A	Yes ¹	Customer	N/A
CUSTOMER SERVICE AND INFORMATIONAL EXPENSES											
(907) Supervision	No	N/A	N/A	N/A	N/A	N/A	No	N/A	Yes ¹	Customer	N/A
(908) Customer Assistance Expenses	No	N/A	N/A	N/A	N/A	N/A	No	N/A	Yes ¹	Customer	N/A
(909) Information and Instructional Expenses	No	N/A	N/A	N/A	N/A	N/A	No	N/A	Yes ¹	Customer	N/A
(910) Miscellaneous Customer Service and Information Expenses	No	N/A	N/A	N/A	N/A	N/A	No	N/A	Yes ¹	Customer	N/A
SALES EXPENSES											
(911) Supervision	No	N/A	N/A	N/A	N/A	N/A	No	N/A	Yes ¹	Customer	N/A
(912) Demonstrating and Selling Expenses	No	N/A	N/A	N/A	N/A	N/A	No	N/A	Yes ¹	Customer	N/A
(913) Advertising Expenses	No	N/A	N/A	N/A	N/A	N/A	No	N/A	Yes ¹	Customer	N/A
(916) Miscellaneous Sales Expenses	No	N/A	N/A	N/A	N/A	N/A	No	N/A	Yes ¹	Customer	N/A
ADMINISTRATIVE AND GENERAL EXPENSES											
FERC Accounts 920 - 935	No	N/A	N/A	N/A	N/A	N/A	No	N/A	Yes ¹	Customer	N/A

The following discussion applies to customer-related portions of distribution plant FERC accounts 364 through 368, entire FERC accounts 369, 370, 371 and associated portions of distribution O&M expenses FERC Accounts 583, 584, 588, 589, 593, 594, 595, and 598 and entire distribution FERC accounts 586, 587 and 597:

DT Q1: Yes

Plant and O&M costs contained in these FERC Accounts are linked to Company's distribution and customer-related assets.

DT Q2: No

Customer-related distribution costs are not attributable to customer demand in the Company's ECOS study.

DT Q7: No

Customer-related distribution costs do not apply to all cost categories. They are attributable to specific customer-related distribution functions in the Company's ECOS study.

In addition, FERC accounts related to Customer Accounts Expense, Customer Service and Informational Expenses, Sales Expenses, and Administrative and General Expenses are classified as customer-related for the following reasons:

DT Q1: No

These FERC Accounts are not linked to Company's assets.

DT Q7: No

Customer-related expenses do not apply to all cost categories in the Company's ECOS study. In addition, the Commission's 2022 Standby Order, Case 15-E-0751, found A&G costs to be allocated to the customer cost category.

NOTE 1:

The answer to Question 8 is evaluated in aggregate. To the extent total ACOS customer costs are higher than the otherwise applicable non-standby customer charges, resulting spillover (difference between ACOS customer costs and otherwise applicable customer charges) is classified as local and excluded from Buyback rates.

Decision Tree Mapping

Cost Categories	Interconnection Voltage									
	Question 1: Is the cost linked to a type of asset?	Question 2: Are all the costs attributable to customer demand?	Question 3: Would a decrease in demand result in entirely unused assets?	Question 4: Does an increase in system coincident demand increase the costs?	Question 5: Does an increase in non- coincident peak demand increase the costs?	QUESTION 6: Could a kW of reverse power flow increase the costs?	Question 7: Does the cost apply to all cost categories?	Question 9: Is the cost a tax- related to either a specific asset or cost which varies with customer demand?	Question 8: Should the Customer Charge be set to a predetermined level and any difference in costs and revenues be re-allocated?	Result (Customer, Local, Shared, or Allocate b/w Shared & Local) Exclude Local Costs from Buyback Rates? (if applicable)
GENERAL PLANT	No	N/A	N/A	N/A	N/A	N/A	Yes	Yes		Adder
COMMON PLANT	No	N/A	N/A	N/A	N/A	N/A	Yes	Yes		Adder
WORKING CAPITAL	No	N/A	N/A	N/A	N/A	N/A	Yes	Yes		Adder
PROPERTY TAXES	No	N/A	N/A	N/A	N/A	N/A	Yes	Yes		Adder
PAYROLL TAXES	No	N/A	N/A	N/A	N/A	N/A	Yes	Yes		Adder

The Commission's 2022 Standby Order has determined that general costs linked to both assets and customer demands should be functionalized to the various voltage levels and usage areas using the same method employed in ECOS studies. Once functionalized, these general costs are treated as adders to the associated asset costs within each function and thus be allocated to the shared, local and customer categories in the same manner as those assets.

Consolidated Edison Company of New York, Inc.
2023 ACOS - Local and Shared Cost Allocation Percentages

	SC01		SC02		SC05 CONV		SC05 TODL				SC08 CONV		SC08 TODL	
NCP	3,943,227		433,823		125		15,532				344,559		27,597	
CP	3,651,831		432,027		51		13,518				336,462		26,760	
Decision Tree: Question 4 - Yes	Local	Shared	Local	Shared	Local	Shared	LT - Local	LT - Shared	HT - Local	HT - Shared	Local	Shared	Local	Shared
Transmission Costs	0.0%	100.0%	0.0%	100.0%	0.0%	100.0%	0.0%	100.0%	0.0%	100.0%	0.0%	100.0%	0.0%	100.0%
Substation Costs	0.0%	100.0%	0.0%	100.0%	0.0%	100.0%	0.0%	100.0%	0.0%	100.0%	0.0%	100.0%	0.0%	100.0%
Primary Costs	0.0%	100.0%	0.0%	100.0%	0.0%	100.0%	0.0%	100.0%	13.0%	87.0%	0.0%	100.0%	0.0%	100.0%
Secondary Costs	7.4%	92.6%	0.4%	99.6%	59.1%	40.9%	13.0%	87.0%			2.3%	97.7%	3.0%	97.0%

	SC09 CONV				SC09 TODL				SC12 CONV		SC12 TODL		SC13 TODL	
NCP	3,402,337				1,227,362				28,878		42,749		4,218	
CP	3,338,791				1,217,409				17,177		22,950		43	
Decision Tree: Question 4 - Yes	LT - Local	LT - Shared	HT - Local	HT - Shared	LT - Local	LT - Shared	HT - Local	HT - Shared	Local	Shared	Local	Shared	HT - Local	HT - Shared
Transmission Costs	0.0%	100.0%	0.0%	100.0%	0.0%	100.0%	0.0%	100.0%	0.0%	100.0%	0.0%	100.0%	0.0%	100.0%
Substation Costs	0.0%	100.0%	0.0%	100.0%	0.0%	100.0%	0.0%	100.0%	0.0%	100.0%	0.0%	100.0%	0.0%	100.0%
Primary Costs	0.0%	100.0%	1.9%	98.1%	0.0%	100.0%	0.8%	99.2%	0.0%	100.0%	0.0%	100.0%	99.0%	1.0%
Secondary Costs	1.9%	98.1%			0.8%	99.2%			40.5%	59.5%	46.3%	53.7%		

	NYPA			
NCP	1,585,799			
CP	1,473,195			
Decision Tree: Question 4 - Yes	LT - Local	LT - Shared	HT - Local	HT - Shared
Transmission Costs	0.0%	100.0%	0.0%	100.0%
Substation Costs	0.0%	100.0%	0.0%	100.0%
Primary Costs	0.0%	100.0%	7.1%	92.9%
Secondary Costs	7.1%	92.9%		

Consolidated Edison Company of New York, Inc.
2023 ACOS - Buyback Rates Local Cost Allocation Percentages

	SC01	SC02	SC05 CONV	SC05 TODL		SC08 CONV	SC08 TODL
Decision Tree: Question 6 - Yes	Local	Local	Local	LT - Local	HT - Local	Local	Local
Transmission Costs							
Substation Costs							
Primary Costs					13.0%		
Secondary Costs	7.4%	0.4%	59.1%	13.0%		2.3%	3.0%

	SC09 CONV		SC09 TODL		SC12 CONV	SC12 TODL	SC13 TODL
Decision Tree: Question 6 - Yes	LT - Local	HT - Local	LT - Local	HT - Local	Local	Local	HT - Local
Transmission Costs							
Substation Costs							
Primary Costs		1.9%		0.8%			99.0%
Secondary Costs	1.9%		0.8%		40.5%	46.3%	

	NYPA	
Decision Tree: Question 6 - Yes	LT - Local	HT - Local
Transmission Costs		
Substation Costs		
Primary Costs		7.1%
Secondary Costs	7.1%	

Consolidated Edison Company of New York, Inc.
2023 ACOS Customer Costs - Low Tension

	TOTAL NYP (1)	RESIDENTIAL & RELIGIOUS SC #1 (2)	GENERAL SMALL SC #2 (3)	ELECTRIC TRACTION NTD-SC #5 (4)	ELECTRIC TRACTION TOD-SC #5 (5)	MULTI-DW. REDISTRIB. NTD-SC #8 (6)	MULTI-DW. REDISTRIB. TOD-SC #8 (7)	GENERAL LARGE NTD-SC #9 (8)	GENERAL LARGE TOD-SC #9 (9)	MULTI-DW. SPACE HTG. NTD-SC #12 (10)	MULTI-DW. SPACE HTG. TOD-SC #12 (11)
CUSTOMER COST BY CLASS											
1 NUMBER OF CUSTOMERS	11,420	3,055,636	451,798	8	5	1,835	21	136,272	689	430	27
2											
3 RATE BASE	279,122,523	3,793,395,147	1,157,113,547	303,424	29,547	65,425,993	3,011,008	1,964,692,540	108,198,294	7,545,752	1,346,370
4											
5 TOTAL CUSTOMER OPERATING EXPS.	70,758,862	893,243,983	225,001,955	46,356	216,051	16,770,981	967,605	388,084,454	38,494,451	1,693,255	854,261
6 MONTHLY OP. EXPS. COST/CUST	516.34	24.36	41.50	482.87	3,600.84	761.62	3,839.70	237.32	4,655.84	328.15	2,636.61
7											
8 RETURN @ 10.71% (CUSTOMER)	29,901,734	406,377,424	123,958,830	32,505	3,165	7,008,931	322,562	210,472,852	11,591,027	808,359	144,233
9 INCOME TAX ON RETURN	2,917,037	39,643,792	12,092,695	3,171	309	683,750	31,467	20,532,494	1,130,752	78,859	14,071
10 TOTAL RETURN & S.I.T. & F.I.T.	32,818,771	446,021,217	136,051,524	35,676	3,474	7,692,682	354,029	231,005,346	12,721,779	887,217	158,304
11 MONTHLY RET. S.I.T. & F.I.T. COST/CUST	239.48	12.16	25.09	371.63	57.90	349.35	1,404.88	141.26	1,538.68	171.94	488.59
12											
13 MONTHLY CUSTOMER COSTS	755.82	36.52	66.60	854.50	3,658.75	1,110.97	5,244.58	378.59	6,194.51	500.09	3,125.20
	=====	=====	=====	=====	=====	=====	=====	=====	=====	=====	=====

Note Customer Costs Exclude:
- BPP

Consolidated Edison Company of New York, Inc.
2023 ACOS Customer Costs - High Tension

	TOTAL NYP (1)	RESIDENTIAL & RELIGIOUS SC #1 (2)	GENERAL SMALL SC #2 (3)	ELECTRIC TRACTION NTD-SC #5 (4)	ELECTRIC TRACTION TOD-SC #5 (5)	MULTI-DW. REDISTRIB. NTD-SC #8 (6)	MULTI-DW. REDISTRIB. TOD-SC #8 (7)	GENERAL LARGE NTD-SC #9 (8)	GENERAL LARGE TOD-SC #9 (9)	MULTI-DW. SPACE HTG. NTD-SC #12 (10)	MULTI-DW. SPACE HTG. TOD-SC #12 (11)	BULK POWER TOD-SC #13 (12)
CUSTOMER COST BY CLASS												
1 NUMBER OF CUSTOMERS	11,420	3,055,636	451,798	8	5	1,835	21	136,272	689	430	27	1
2												
3 RATE BASE	158,069,488	2,095,455,297	590,358,636	221,464	22,097	32,224,720	1,409,061	1,054,772,298	64,312,154	3,857,550	683,239	84,766
4												
5 TOTAL CUSTOMER OPERATING EXPS.	51,862,097	627,514,194	136,491,210	33,563	214,888	11,588,571	717,556	246,050,083	31,644,231	1,117,561	750,752	52,479
6 MONTHLY OP. EXPS. COST/CUST	378.44	17.11	25.18	349.61	3,581.46	526.27	2,847.44	150.47	3,827.31	216.58	2,317.14	4,373.25
7												
8 RETURN @ 10.71% (CUSTOMER)	16,933,609	224,481,156	63,243,720	23,725	2,367	3,452,158	150,949	112,995,254	6,889,608	413,250	73,194	9,081
9 INCOME TAX ON RETURN	1,651,943	21,899,062	6,169,686	2,314	231	336,772	14,726	11,023,153	672,110	40,314	7,140	886
10 TOTAL RETURN & S.I.T. & F.I.T.	18,585,553	246,380,217	69,413,406	26,039	2,598	3,788,930	165,675	124,018,407	7,561,718	453,564	80,334	9,967
11 MONTHLY RET. S.I.T. & F.I.T.	135.62	6.72	12.80	271.24	43.30	172.07	657.44	75.84	914.58	87.90	247.94	830.55
12												
13 MONTHLY CUSTOMER COSTS	514.07	23.83	37.98	620.85	3,624.76	698.34	3,504.88	226.31	4,741.89	304.48	2,565.08	5,203.80
	=====	=====	=====	=====	=====	=====	=====	=====	=====	=====	=====	=====

Note Customer Costs Exclude:

- BPP
- Low Tension Minimum Grid

Consolidated Edison Company of New York, Inc.
2023 ACOS Customer Costs - 138kV

	TOTAL NYPA (1)	RESIDENTIAL & RELIGIOUS SC #1 (2)	GENERAL SMALL SC #2 (3)	ELECTRIC TRACTION NTD-SC #5 (4)	ELECTRIC TRACTION TOD-SC #5 (5)	MULTI-DW. REDISTRIB. NTD-SC #8 (6)	MULTI-DW. REDISTRIB. TOD-SC #8 (7)	GENERAL LARGE NTD-SC #9 (8)	GENERAL LARGE TOD-SC #9 (9)	MULTI-DW. SPACE HTG. NTD-SC #12 (10)	MULTI-DW. SPACE HTG. TOD-SC #12 (11)	BULK POWER TOD-SC #13 (12)
CUSTOMER COST BY CLASS												
1 NUMBER OF CUSTOMERS	11,420	3,055,636	451,798	8	5	1,835	21	136,272	689	430	27	1
2												
3 RATE BASE	6,834,697	1,106,284,301	167,488,003	70,015	18,486	3,065,689	111,311	164,809,286	3,586,943	490,381	94,027	7,589
4												
5 TOTAL CUSTOMER OPERATING EXPS.	26,148,217	432,635,274	61,951,808	7,534	214,151	6,622,162	496,564	93,880,125	21,390,422	543,404	650,188	39,434
6 MONTHLY OP. EXPS. COST/CUST	190.81	11.80	11.43	78.48	3,569.18	300.73	1,970.49	57.41	2,587.13	105.31	2,006.75	3,286.18
7												
8 RETURN @ 10.71% (CUSTOMER)	732,185	118,513,613	17,942,592	7,501	1,980	328,420	11,925	17,655,628	384,261	52,533	10,073	813
9 INCOME TAX ON RETURN	71,428	11,561,491	1,750,374	732	193	32,039	1,163	1,722,379	37,486	5,125	983	79
10 TOTAL RETURN & S.I.T. & F.I.T.	803,613	130,075,105	19,692,966	8,232	2,174	360,459	13,088	19,378,007	421,747	57,658	11,056	892
11 MONTHLY RET. S.I.T. & F.I.T.	5.86	3.55	3.63	85.75	36.23	16.37	51.94	11.85	51.01	11.17	34.12	74.36
12												
13 MONTHLY CUSTOMER COSTS	196.67	15.35	15.06	164.23	3,605.40	317.10	2,022.43	69.26	2,638.14	116.48	2,040.87	3,360.54
	=====	=====	=====	=====	=====	=====	=====	=====	=====	=====	=====	=====

Note Customer Costs Exclude:

- BPP
- High Tension and Low Tension Minimum Grid
- Services
- Installation on Customer Premises
- Services on Customer Premises