

EXHIBIT ____ (DAC -1)

ORANGE AND ROCKLAND UTILITIES, INC.

ELECTRIC CLASS DEMAND STUDY

YEAR 2019

ORANGE AND ROCKLAND UTILITIES, INC.

Electric Class Demand Estimates
Analyzed by Customer Service Classification
Year 2019

Basis for Calculations

The class demand estimates presented in this exhibit are based upon studies of sample AMI test customers' interval data. These profile data have been extrapolated to the appropriate 2019 class populations obtained from billing records.

Sample test data are used to estimate class demands for Orange and Rockland Service Classification Nos. 1, 2 (except 2-802, Not Metered), 3, 19, 20, and 21. Profile data for selected summer and winter peak days were used to calculate demands for Orange and Rockland Service Classification Nos. 9, 22, and West Point, and for customers eligible for mandatory day-ahead hourly pricing. Calculations for Orange and Rockland Service Classification No. 2-802 (Not Metered), 4, 5, 6, and 16 used day-lighting schedules for street lighting and 24-hour demand estimates for traffic signals.

Sample Test Data

For the sampled classes, the test customers were selected by statistically sampling the class populations. Orange and Rockland test customers were arranged and stratified according to system peak month ranges. Test customer daily load profiles were collected for a complete annual period. Class test data were arranged according to the five summer and winter system peak days, with Saturdays, Sundays, and holidays excluded. Load characteristics were calculated for each stratum.

Application of Test Results

The load test summer and winter coincidence factors and load characteristics have been applied to the individual customers' non-coincident summer and winter (billing) demands for the year 2019 in the corresponding classes after each class' customers were arranged and stratified in the same manner as the test customers. Summation of the stratum load curves, extrapolated to class proportions for each class, produced summer and winter daily load profiles for that class at the customers' meters.

Development of Total System Service Area Distribution Curves

Peak-day curves were prepared from 2019 integrated hourly system demands. The total system service area distribution curves were developed by averaging the system demand data for five selected summer weekdays and five selected winter weekdays. These data

include the kilowatt input (including losses) to our entire transmission and distribution system, as metered at the system input level.

In selecting the five specific summer and winter peak days to be averaged those with the highest one-hour net load were chosen. The data for all five days were averaged to rule out the effect of any unusual system conditions that might have occurred for short periods during any one of the selected days.

Class Loads at the System Input Level

Employing the class load curves at the customers' meters and the distribution efficiencies (losses), class load curves for the summer and winter were developed as they appeared at the system input level. The sum of the class load curves at the system input level was determined for the fully sampled sub-classes of Orange and Rockland Service Classifications Nos. 2, 3, 4, 5, 6, 9, 16, 20, 21, 22, and West Point.

This sum was subtracted from the curve representing the (summer or winter) total system service area distribution curve and the resultant curve was then compared to the sum of the class load curves at the system input level for the remaining sub-classes of Orange and Rockland Service Classification Nos. 1, 2, 3, 9, 19, 20, 21, and 22.

For sampled classes, a percentage adjustment factor was applied to the class demands for every half-hour. The sum of the 'adjusted classes' and the 'fully sampled' classes exactly equaled the total system service area distribution curve.

Four-Hour Class Non-Coincident Peak Demands and System Summer Peak Responsibility Demands

After developing the class load profile curves for the summer and winter as described above, the numerical half-hour demand values from the curves were examined. Four-hour class non-coincident peak demands for the summer and winter and four-hour system summer peak responsibility demands (for summer half-hours ending 4:00 PM to 7:30 PM) were calculated from these values. The four-hour figures were obtained by averaging eight consecutive half-hour demands. The four-hour demand figures are shown in the Class Demand Summary report.

Description of Reports

Report 2 - Sample Test Customer Data

These reports show a summary of load research data by stratum for each service classification for the summer and winter periods.

Report 3 - Estimated Class Demand Data

This report shows a summary of class population data by stratum for each service classification for the summer and winter periods.

Report 4 - Estimated Class Demand Data

This report shows a summary of class demand responsibilities by stratum for each service classification for the summer and winter periods. Demands at the customer and at the system input level are shown.

Class Demand Summary Report

This report shows a summary of the class demand responsibilities for the summer and winter periods.

Index for Individual Class Demand Reports 2, 3, and 4
For Each Service Classification and Grouping

		<u>Page No.</u>
S.C. No 1-301	Residential	1 to 3
S.C. No 2-102	Commercial & Industrial General Service - Secondary	4 to 6
S.C. No 2-202	Small Commercial & Industrial General Service - Primary	7 to 9
S.C. No 2-402	Commercial & Industrial Separately Metered Space Heating >= 10 kW	10 to 12
S.C. No 2-802	Small Commercial & Industrial General Service - Secondary - Not Metered or No Demand Meter	13 to 15
S.C. No 3-203	Commercial & Industrial Primary >= 100 kW	16 to 18
S.C. No 4-104	Municipal Street Lighting	19 to 21
S.C. No 5-105	Traffic Lights	22 to 24
S.C. No 6-136	Municipal Owned Lights	25 to 27
S.C. No 9-110	Commercial Primary, Substation, and Transmission TOU Standard	28 to 30
S.C. No 11-111	West Point	31 to 33
S.C. No 16-212	Private Overhead Lighting Dusk to Dawn	34 to 36
S.C. No 16-412	Energy Only Lighting Metered and Unmetered	37 to 39
S.C. No 19-318	Voluntary Residential TOU	40 to 42
S.C. No 20-120	Voluntary Commercial & Industrial Secondary TOU	43 to 45
S.C. No 21-121	Voluntary Commercial & Industrial Primary TOU	46 to 48
S.C. No 22-211	Industrial Primary, Substation, and Transmission TOU Standard	49 to 51
Orange & Rockland	Orange and Rockland Company Use	52 to 54

Index for Summary Report

	<u>Page No.</u>
Class Demand Summary	R-1 to R-4

Orange & Rockland Utilities, Inc - Electric
Report 2 - Sample Test Customer Data
Class - SC1 - Summer - 2019

Line No	Sample Strata	Stratification Variable pk mo kWh		No of Test Customers	Strat Var Avg Per Test Cust	Avg Non-Coin kW Per Cust	Avg Coin kW Per Cust	Coincidence Factor Percentage
(1)	(2)	Low (3)	High (4)	(5)	(6)	(7)	(8)	(9)
1	1201 08	0	999,999,999	247	1,406	6.875	4.130	60.0727
2	1501 07	0	999,999,999	617	794	6.335	1.850	29.2028
3	1801 06	0	999,999,999	256	1,076	7.091	2.698	38.0482
4	01-ResiSpecProv			1,120				
5	1301 01	0	600	2,480	325	2.808	1.050	37.3932
6	1301 02	601	1,200	550	806	4.837	2.332	48.2117
7	1301 03	1,201	2,000	314	1,572	6.979	4.269	61.1692
8	1301 04	2,001	3,800	502	2,773	10.431	6.742	64.6343
9	1301 05	3,801	999,999,999	374	6,106	20.517	13.057	63.6399
10	01-Residential			4,220				
11	SC1			5,340				

Footnotes:

Col (9): Equal to 100 * (Col (8) / Col (7))

Orange & Rockland Utilities, Inc - Electric
Report 3 - Estimated Class Demand Data
Class - SC1 - Summer - 2019

Line No	Sample Strata	Stratification Variable pk mo kWh		Est Avg No of Custs	Total Annual kWh	Avg Annual Use Per Cust	Est Non-Coin kW Per Cust	Est Popul Non-Coin kW	Coincidence Factor Percentage	Est Popul Coin kW for Individual Strata
(1)	(2)	Low (3)	High (4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)
1	1201 08	0	999,999,999	1,707	16,432,883	9,627	4.399	7,509	60.0727	4,511
2	1501 07	0	999,999,999	2,227	28,662,880	12,871	6.645	14,798	29.2028	4,321
3	1801 06	0	999,999,999	2,187	19,582,866	8,954	5.490	12,007	38.0482	4,568
4	01-ResiSpecProv			6,121	64,678,629			34,314		13,400
5	1301 01	0	600	86,220	311,367,673	3,611	2.541	219,085	37.3932	81,923
6	1301 02	601	1,200	64,375	483,621,742	7,513	4.884	314,408	48.2117	151,581
7	1301 03	1,201	2,000	33,065	371,042,975	11,222	6.500	214,923	61.1692	131,467
8	1301 04	2,001	3,800	12,737	216,946,029	17,033	9.165	116,735	64.6343	75,451
9	1301 05	3,801	999,999,999	1,819	86,008,072	47,283	20.839	37,906	63.6399	24,123
10	01-Residential			198,216	1,468,986,491			903,057		464,545
11	SC1			204,337	1,533,665,120			937,371		477,945

Footnotes:

Col (7): Equal to Col (6) / Col (5)

Col (8): For non-demand metered classes, from relationship of sampled energy and demand values, applied to population energy usage

Col (9): Equal to Cols (5) * (8) or Billing Demand

Col (10): From Report 2

Col (11): Equal to Col (9) * (Col (10) / 100)

Orange & Rockland Utilities, Inc - Electric
Report 4 - Estimated Class Demand Data
Class - SC1 - Summer - 2019

Line No	Sample Strata		Stratification Variable pk mo kWh		Half Hour kW at Time of Class Peak Unadj at Cust	4 Hour Demands-kW				
						Unadjusted at the Customer	Adjusted at the Customer	Unadjusted at System Input	Adjusted at System Input	System Peak Respblty
			Low (3)	High (4)						
(1)	(2)		(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)
1	1201	08	0	999,999,999	4,410	4,330	4,110	4,716	4,477	4,505
2	1501	07	0	999,999,999	4,321	4,167	3,960	4,539	4,314	4,099
3	1801	06	0	999,999,999	4,508	4,377	4,157	4,768	4,529	4,435
4	01-ResiSpecProv				13,239	12,874	12,227	14,023	13,320	13,039
5	1301	01	0	600	81,923	78,168	74,296	85,151	80,932	76,722
6	1301	02	601	1,200	151,014	147,154	139,769	160,298	152,254	148,861
7	1301	03	1,201	2,000	131,333	128,110	121,649	139,553	132,515	132,128
8	1301	04	2,001	3,800	73,662	72,886	69,198	79,396	75,379	75,848
9	1301	05	3,801	999,999,999	23,759	23,386	22,203	25,475	24,186	24,407
10	01-Residential				461,691	449,704	427,115	489,873	465,266	457,966
11	SC1				474,930	462,578	439,342	503,896	478,586	471,005

Footnotes:

Col (5): Class Peak at 7:00pm

Col (6): Class 4 hour peak from 5:00pm-8:30pm

Col (7): Adjusted sum of component loads equals system loads

Col (8): Equal to (Col (6) / Efficiency Factor of 91.800000000) * 100

Col (9): Equal to (Col (7) / Efficiency Factor of 91.800000000) * 100

Col (10): System Peak Responsibility from 4:00pm-7:30pm

Orange & Rockland Utilities, Inc - Electric
Report 2 - Sample Test Customer Data
Class - SC2 - Summer - 2019

Line No	Sample Strata	Stratification Variable pk mo kW (2102,2302,2602) max ann kW (2322,2612)		No of Test Customers	Strat Var Avg Per Test Cust	Avg Non-Coin kW Per Cust	Avg Coin kW Per Cust	Coincidence Factor Percentage
		Low (3)	High (4)					
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)
1	2102 09	0	6	222	2	2.377	1.184	49.8107
2	2102 10	7	16	145	10	9.582	6.304	65.7900
3	2102 11	17	35	131	22	21.442	15.899	74.1489
4	2102 12	36	80	59	52	134.420	116.811	86.9000
5	2102 13	81	999,999,999	47	125	120.003	96.053	80.0422
6	02-GenSmallSec			604				
7	2302 13	0	999,999,999	24	151	151.179	123.807	81.8943
8	2322 99	200	999,999,999	52	391	396.564	342.353	86.3298
9	02-LgCom			76				
10	2602 13	0	999,999,999	2	131	117.778	89.645	76.1135
11	2612 11	200	999,999,999	1	276	247.860	213.612	86.1825
12	02-LgInd			3				
13	SC2			683				

Footnotes:

Col (9): Equal to 100 * (Col (8) / Col (7))

Orange & Rockland Utilities, Inc - Electric
Report 3 - Estimated Class Demand Data
Class - SC2 - Summer - 2019

Line No	Sample Strata	Stratification Variable pk mo kW (2102,2302,2602) max ann kW (2322,2612)		Est Avg No of Custs	Total Annual kWh	Avg Annual Use Per Cust	Est Non- Coin kW Per Cust	Est Popul Non- Coin kW	Coincidence Factor Percentage	Est Popul Coin kW for Individual Strata
(1)	(2)	Low (3)	High (4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)
1	2102 09	0	6	13,570	89,919,530	6,626		31,071	49.8107	15,477
2	2102 10	7	16	6,764	148,710,028	21,986		68,420	65.7900	45,014
3	2102 11	17	35	2,856	171,097,364	59,908		66,666	74.1489	49,432
4	2102 12	36	80	991	147,157,627	148,494		51,133	86.9000	44,435
5	2102 13	81	999,999,999	365	137,582,433	376,938		45,319	80.0422	36,274
6	02-GenSmallSec			24,546	694,466,982			262,609		190,632
7	2302 13	0	999,999,999	94	44,751,651	476,081		12,318	81.8943	10,088
8	2322 99	200	999,999,999	59	100,502,730	1,703,436		23,261	86.3298	20,081
9	02-LgCom			153	145,254,381			35,579		30,169
10	2602 13	0	999,999,999	4	1,383,354	345,839		431	76.1135	328
11	2612 11	200	999,999,999	1	977,462	977,462		281	86.1825	242
12	02-LgInd			5	2,360,816			712		570
13	SC2			24,704	842,082,179			298,900		221,371

Footnotes:

Col (7): Equal to Col (6) / Col (5)

Col (8): For non-demand metered classes, from relationship of sampled energy and demand values, applied to population energy usage

Col (9): Equal to Cols (5) * (8) or Billing Demand

Col (10): From Report 2

Col (11): Equal to Col (9) * (Col (10) / 100)

Orange & Rockland Utilities, Inc - Electric
Report 4 - Estimated Class Demand Data
Class - SC2 - Summer - 2019

Line No	Sample Strata	4 Hour Demands-kW							
		Stratification Variable pk mo kW (2102,2302,2602) max ann kW (2322,2612)		Half Hour kW at Time of Class Peak Unadj at Cust	Unadjusted at the Customer	Adjusted at the Customer	Unadjusted at System Input	Adjusted at System Input	System Peak Respblty
		Low	High						
		(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)
1	2102 09	0	6	15,418	15,237	13,733	16,598	14,960	13,731
2	2102 10	7	16	45,014	43,782	39,457	47,693	42,981	38,043
3	2102 11	17	35	49,432	48,495	43,714	52,827	47,618	45,994
4	2102 12	36	80	43,702	43,463	39,185	47,345	42,685	39,737
5	2102 13	81	999,999,999	35,860	34,633	31,202	37,727	33,989	31,138
6	02-GenSmallSec			189,426	185,610	167,291	202,190	182,233	168,643
7	2302 13	0	999,999,999	9,983	9,895	8,920	10,779	9,717	9,594
8	2322 99	200	999,999,999	19,803	19,638	19,638	21,392	21,392	20,172
9	02-LgCom			29,786	29,533	28,558	32,171	31,109	29,766
10	2602 13	0	999,999,999	309	306	276	333	300	310
11	2612 11	200	999,999,999	191	191	191	208	208	186
12	02-LgInd			500	497	467	541	508	496
13	SC2			219,712	215,640	196,316	234,902	213,850	198,905

Footnotes:

Col (5): Class Peak at 3:00pm

Col (6): Class 4 hour peak from 1:30pm-5:00pm

Col (7): Adjusted sum of component loads equals system loads

Col (8): Equal to (Col (6) / Efficiency Factor of 91.800000000) * 100

Col (9): Equal to (Col (7) / Efficiency Factor of 91.800000000) * 100

Col (10): System Peak Responsibility from 4:00pm-7:30pm

Orange & Rockland Utilities, Inc - Electric
 Report 2 - Sample Test Customer Data
 Class - SC2_SM_Pri - Summer - 2019

Line No	Sample Strata	Stratification Variable		No of Test Customers	Strat Var Avg Per Test Cust	Avg Non-Coin kW Per Cust	Avg Coin kW Per Cust	Coincidence Factor Percentage
		pk mo kW (2202) max ann kW(2712)						
(1)	(2)	Low (3)	High (4)	(5)	(6)	(7)	(8)	(9)
1	2202 09	0	6	6	1	11.038	9.948	90.1250
2	2202 10	7	16	9	11	10.944	7.586	69.3165
3	2202 11	17	35	9	25	26.171	21.273	81.2846
4	2202 12	36	80	28	60	57.191	43.744	76.4876
5	2202 13	81	999,999,999	18	117	114.478	87.512	76.4444
6	2712 99	200	999,999,999	5	479	472.500	414.183	87.6578
7	02-GenSmall			75				
8	SC2_SM_Pri			75				

Footnotes:

Col (9): Equal to 100 * (Col (8) / Col (7))

Orange & Rockland Utilities, Inc - Electric
 Report 3 - Estimated Class Demand Data
 Class - SC2_SM_Pri - Summer - 2019

Line No	Sample Strata	Stratification Variable pk mo kW (2202) max ann kW(2712)		Est Avg No of Custs	Total Annual kWh	Avg Annual Use Per Cust	Est Non-Coin kW Per Cust	Est Popul Non-Coin kW	Coincidence Factor Percentage	Est Popul Coin kW for Individual Strata
(1)	(2)	Low (3)	High (4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)
1	2202 09	0	6	22	886,127	40,279		97	90.1250	87
2	2202 10	7	16	24	1,031,989	43,000		289	69.3165	200
3	2202 11	17	35	27	2,947,321	109,160		697	81.2846	567
4	2202 12	36	80	56	12,611,773	225,210		3,194	76.4876	2,443
5	2202 13	81	999,999,999	51	18,840,037	369,412		5,895	76.4444	4,506
6	2712 99	200	999,999,999	7	14,004,602	2,000,657		2,642	87.6578	2,316
7	02-GenSmall			187	50,321,849			12,814		10,119
8	SC2_SM_Pri			187	50,321,849			12,814		10,119

Footnotes:

Col (7): Equal to Col (6) / Col (5)

Col (8): For non-demand metered classes, from relationship of sampled energy and demand values, applied to population energy usage

Col (9): Equal to Cols (5) * (8) or Billing Demand

Col (10): From Report 2

Col (11): Equal to Col (9) * (Col (10) / 100)

Orange & Rockland Utilities, Inc - Electric
 Report 4 - Estimated Class Demand Data
 Class - SC2_SM_Pri - Summer - 2019

Line No	Sample Strata	4 Hour Demands-kW							
		Stratification Variable		Half Hour kW at Time of Class Peak Unadj at Cust	Unadjusted at the Customer	Adjusted at the Customer	Unadjusted at System Input	Adjusted at System Input	System Peak Respbilty
		pk mo kW (2202)	max ann kW (2712)						
(1)	(2)	Low (3)	High (4)	(5)	(6)	(7)	(8)	(9)	(10)
1	2202 09	0	6	83	84	75	90	81	77
2	2202 10	7	16	200	197	178	212	191	185
3	2202 11	17	35	563	535	482	574	517	442
4	2202 12	36	80	2,403	2,401	2,164	2,576	2,322	2,226
5	2202 13	81	999,999,999	4,471	4,440	4,002	4,764	4,294	4,280
6	2712 99	200	999,999,999	2,256	2,251	2,029	2,415	2,177	2,082
7	02-GenSmall			9,976	9,908	8,930	10,631	9,582	9,292
8	SC2_SM_Pri			9,976	9,908	8,930	10,631	9,582	9,292

Footnotes:

Col (5): Class Peak at 3:30pm

Col (6): Class 4 hour peak from 1:30pm-5:00pm

Col (7): Adjusted sum of component loads equals system loads

Col (8): Equal to (Col (6) / Efficiency Factor of 93.200000000) * 100

Col (9): Equal to (Col (7) / Efficiency Factor of 93.200000000) * 100

Col (10): System Peak Responsibility from 4:00pm-7:30pm

Orange & Rockland Utilities, Inc - Electric
 Report 2 - Sample Test Customer Data
 Class - SC2_SMSH - Summer - 2019

Line No	Sample Strata	Stratification Variable pk mo kWh		No of Test Customers	Strat Var Avg Per Test Cust	Avg Non-Coin kW Per Cust	Avg Coin kW Per Cust	Coincidence Factor Percentage
(1)	(2)	Low (3)	High (4)	(5)	(6)	(7)	(8)	(9)
1	2402 14	0	4,000	93	1,090	5.715	3.918	68.5564
2	2402 15	4,001	20,000	13	8,584	26.851	22.566	84.0416
3	2402 16	20,001	100,000	5	41,768	117.605	106.362	90.4400
4	02-CI SepMtrSpHt10kW			111				
5	SC2_SMSH			111				

Footnotes:

Col (9): Equal to 100 * (Col (8) / Col (7))

Orange & Rockland Utilities, Inc - Electric
 Report 3 - Estimated Class Demand Data
 Class - SC2_SMSH - Summer - 2019

Line No	Sample Strata	Stratification Variable pk mo kWh		Est Avg No of Custs	Total Annual kWh	Avg Annual Use Per Cust	Est Non-Coin kW Per Cust	Est Popul Non-Coin kW	Coincidence Factor Percentage	Est Popul Coin kW for Individual Strata
		Low (3)	High (4)							
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)
1	2402 14	0	4,000	287	4,866,840	16,958	5.038	1,446	68.5564	991
2	2402 15	4,001	20,000	46	4,259,920	92,607	25.682	1,181	84.0416	993
3	2402 16	20,001	100,000	16	8,466,169	529,136	95.355	1,526	90.4400	1,380
4	02-CI SepMtrSpHt10kW			349	17,592,929			4,153		3,364
5	SC2 SMSH			349	17,592,929			4,153		3,364

Footnotes:

Col (7): Equal to Col (6) / Col (5)

Col (8): For non-demand metered classes, from relationship of sampled energy and demand values, applied to population energy usage

Col (9): Equal to Cols (5) * (8) or Billing Demand

Col (10): From Report 2

Col (11): Equal to Col (9) * (Col (10) / 100)

Orange & Rockland Utilities, Inc - Electric
 Report 4 - Estimated Class Demand Data
 Class - SC2_SMSH - Summer - 2019

Line No	Sample Strata	4 Hour Demands-kW							
		Stratification Variable pk mo kWh		Half Hour kW at Time of Class Peak Unadj at Cust	Unadjusted at the Customer	Adjusted at the Customer	Unadjusted at System Input	Adjusted at System Input	System Peak Respblty
		Low (3)	High (4)						
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)
1	2402 14	0	4,000	990	935	856	1,019	933	843
2	2402 15	4,001	20,000	993	958	878	1,044	956	934
3	2402 16	20,001	100,000	1,380	1,340	1,228	1,459	1,337	1,335
4	02-CI SepMtrSpHt10kW			3,363	3,233	2,962	3,522	3,226	3,112
5	SC2_SMSH			3,363	3,233	2,962	3,522	3,226	3,112

Footnotes:

Col (5): Class Peak at 3:00pm

Col (6): Class 4 hour peak from 2:30pm-6:00pm

Col (7): Adjusted sum of component loads equals system loads

Col (8): Equal to (Col (6) / Efficiency Factor of 91.800000000) * 100

Col (9): Equal to (Col (7) / Efficiency Factor of 91.800000000) * 100

Col (10): System Peak Responsibility from 4:00pm-7:30pm

Orange & Rockland Utilities, Inc - Electric
 Report 2 - Sample Test Customer Data
 Class - SC2_SNMT - Summer - 2019

Line No	Sample Strata		Stratification Variable		No of Test Customers	Strat Var Avg Per Test Cust	Avg Non-Coin kW Per Cust	Avg Coin kW Per Cust	Coincidence Factor Percentage
			Low pk mo kWh	High pk mo kWh					
(1)	(2)		(3)	(4)	(5)	(6)	(7)	(8)	(9)
1	2802	25	0	999,999,999	1	967,313	0.583	0.583	100.0000
2	2902	18	0	150	344	68	0.382	0.146	38.2199
3	2902	19	151	500	183	283	1.645	0.472	28.6930
4	2902	20	501	999,999,999	36	617	2.236	1.063	47.5403
5	02-GenSmall				564				
6	SC2_SNMT				564				

Footnotes:

Col (9): Equal to 100 * (Col (8) / Col (7))

Orange & Rockland Utilities, Inc - Electric
 Report 3 - Estimated Class Demand Data
 Class - SC2_SNMT - Summer - 2019

Line No	Sample Strata		Stratification Variable pk mo kWh		Est Avg No of Custs	Total Annual kWh	Avg Annual Use Per Cust	Est Non-Coin kW Per Cust	Est Popul Non-Coin kW	Coincidence Factor Percentage	Est Popul Coin kW for Individual Strata
(1)	(2)		Low (3)	High (4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)
1	2802	25	0	999,999,999	2,253	11,723,912	5,204	0.584	1,316	100.0000	1,316
2	2902	18	0	150	1,671	1,400,962	838	0.278	465	38.2199	178
3	2902	19	151	500	599	1,880,831	3,140	1.674	1,003	28.6930	288
4	2902	20	501	999,999,999	90	504,008	5,600	2.335	210	47.5403	100
5	02-GenSmall				4,613	15,509,713			2,994		1,882
6	SC2_SNMT				4,613	15,509,713			2,994		1,882

Footnotes:

Col (7): Equal to Col (6) / Col (5)

Col (8): For non-demand metered classes, from relationship of sampled energy and demand values, applied to population energy usage

Col (9): Equal to Cols (5) * (8) or Billing Demand

Col (10): From Report 2

Col (11): Equal to Col (9) * (Col (10) / 100)

Orange & Rockland Utilities, Inc - Electric
 Report 4 - Estimated Class Demand Data
 Class - SC2_SNMT - Summer - 2019

Line No	Sample Strata		Stratification Variable pk mo kWh		Half Hour kW at Time of Class Peak Unadj at Cust	4 Hour Demands-kW				
						Unadjusted at the Customer	Adjusted at the Customer	Unadjusted at System Input	Adjusted at System Input	System Peak Respbilty
			Low (3)	High (4)		(6)	(7)	(8)	(9)	(10)
1	2802	25	0	999,999,999	1,316	1,316	1,296	1,429	1,407	1,340
2	2902	18	0	150	171	173	170	188	185	76
3	2902	19	151	500	280	274	269	297	292	237
4	2902	20	501	999,999,999	77	78	77	84	83	94
5	02-GenSmall				1,844	1,841	1,812	1,998	1,967	1,747
6	SC2_SNMT				1,844	1,841	1,812	1,998	1,967	1,747

Footnotes:

Col (5): Class Peak at 10:30pm

Col (6): Class 4 hour peak from 9:00pm-12:30am

Col (7): Adjusted sum of component loads equals system loads

Col (8): Equal to (Col (6) / Efficiency Factor of 92.100000000) * 100

Col (9): Equal to (Col (7) / Efficiency Factor of 92.100000000) * 100

Col (10): System Peak Responsibility from 4:00pm-7:30pm

Orange & Rockland Utilities, Inc - Electric
 Report 2 - Sample Test Customer Data
 Class -SC3 - Summer - 2019

Line No	Sample Strata	Stratification Variable pk mo kW (3203,3503,3423) max ann kW (3253,3553,3753)		No of Test Customers	Strat Var Avg Per Test Cust	Avg Non-Coin kW Per Cust	Avg Coin kW Per Cust	Coincidence Factor Percentage
		Low (3)	High (4)					
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)
1	3203 21	0	999,999,999	16	144	140.717	97.388	69.2084
2	3253 99	200	999,999,999	14	399	387.879	339.021	87.4038
3	03-GenSmall			30				
4	3503 22	0	999,999,999	30	173	171.079	137.361	80.2910
5	3553 99	200	999,999,999	119	409	417.501	352.068	84.3275
6	03-LgComm			149				
7	3423 23	0	999,999,999	5	192	185.767	150.062	80.7797
8	3753 99	200	999,999,999	15	428	415.439	327.895	78.9274
9	03-LgIndPri			20				
10	SC3			199				

Footnotes:

Col (9): Equal to 100 * (Col (8) / Col (7))

Orange & Rockland Utilities, Inc - Electric
Report 3 - Estimated Class Demand Data
Class - SC3 - Summer - 2019

Line No	Sample Strata		Stratification Variable		Est Avg No of Custs	Total Annual kWh	Avg Annual Use Per Cust	Est Non- Coin kW Per Cust	Est Popul Non- Coin kW	Coincidence Factor Percentage	Est Popul Coin kW for Individual Strata
			pk mo kW (3203,3503,3423) max ann kW (3253,3553,3753)								
(1)	(2)		Low (3)	High (4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)
1	3203 21		0	999,999,999	37	20,554,355	555,523		5,474	69.2084	3,788
2	3253 99		200	999,999,999	14	25,908,371	1,850,598		5,919	87.4038	5,173
3	03-GenSmall				51	46,462,726			11,393		8,961
4	3503 22		0	999,999,999	63	46,461,916	737,491		11,812	80.2910	9,484
5	3553 99		200	999,999,999	120	228,027,238	1,900,227		52,617	84.3275	44,371
6	03-LgComm				183	274,489,154			64,429		53,855
7	3423 23		0	999,999,999	10	7,101,149	710,115		2,062	80.7797	1,666
8	3753 99		200	999,999,999	15	29,377,250	1,958,483		6,859	78.9274	5,414
9	03-LgIndPri				25	36,478,399			8,921		7,080
10	SC3				259	357,430,279			84,743		69,896

Footnotes:

Col (7): Equal to Col (6) / Col (5)

Col (8): For non-demand metered classes, from relationship of sampled energy and demand values, applied to population energy usage

Col (9): Equal to Cols (5) * (8) or Billing Demand

Col (10): From Report 2

Col (11): Equal to Col (9) * (Col (10) / 100)

Orange & Rockland Utilities, Inc - Electric
Report 4 - Estimated Class Demand Data
Class - SC3 - Summer - 2019

Line No	Sample Strata	4 Hour Demands-kW							
		Stratification Variable pk mo kW (3203,3503,3423) max ann kW (3253,3553,3753)		Half Hour kW at Time of Class Peak Unadj at Cust	Unadjusted at the Customer	Adjusted at the Customer	Unadjusted at System Input	Adjusted at System Input	System Peak Respblty
		Low (3)	High (4)						
		(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)
1	3203 21	0	999,999,999	3,589	3,600	3,135	3,863	3,363	3,534
2	3253 99	200	999,999,999	5,173	5,078	5,078	5,449	5,449	4,863
3	03-GenSmall			8,762	8,678	8,213	9,312	8,812	8,397
4	3503 22	0	999,999,999	9,469	9,439	8,218	10,128	8,817	8,721
5	3553 99	200	999,999,999	44,371	43,638	43,638	46,822	46,822	42,614
6	03-LgComm			53,840	53,077	51,856	56,950	55,639	51,335
7	3423 23	0	999,999,999	1,618	1,595	1,389	1,711	1,490	1,292
8	3753 99	200	999,999,999	5,374	5,292	5,292	5,678	5,678	4,934
9	03-LgIndPri			6,992	6,887	6,681	7,389	7,168	6,226
10	SC3			69,594	68,642	66,750	73,651	71,619	65,958

Footnotes:

Col (5): Class Peak at 1:30pm

Col (6): Class 4 hour peak from 11:30am-3:00pm

Col (7): Adjusted sum of component loads equals system loads

Col (8): Equal to (Col (6) / Efficiency Factor of 93.200000000) * 100

Col (9): Equal to (Col (7) / Efficiency Factor of 93.200000000) * 100

Col (10): System Peak Responsibility from 4:00pm-7:30pm

Orange & Rockland Utilities, Inc - Electric
 Report 2 - Sample Test Customer Data
 Class - SC4 - Summer - 2019

Line No	Sample Strata	Stratification Variable pk mo kWh		No of Test Customers	Strat Var Avg Per Test Cust	Avg Non-Coin kW Per Cust	Avg Coin kW Per Cust	Coincidence Factor Percentage
		Low (3)	High (4)					
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)
1	4104 24	0	999,999,999	1	173,495	40.396	40.396	100.0000
2	04-MunStreetLights			1				
3	SC4			1				

Footnotes:

Col (9): Equal to 100 * (Col (8) / Col (7))

Orange & Rockland Utilities, Inc - Electric
 Report 3 - Estimated Class Demand Data
 Class - SC4 - Summer - 2019

Line No	Sample Strata	Stratification Variable		Est Avg No of Custs	Total Annual kWh	Avg Annual Use Per Cust	Est Non-Coin kW Per Cust	Est Popul Non- Coin kW	Coincidence Factor Percentage	Est Popul Coin kW for Individual Strata
		Low pk mo kWh	High pk mo kWh							
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)
1	4104 24	0	999,999,999	70	11,732,153	167,602	40.704	2,849	100.0000	2,849
2	04-MunStreetLights			70	11,732,153			2,849		2,849
3	SC4			70	11,732,153			2,849		2,849

Footnotes:

Col (7): Equal to Col (6) / Col (5)

Col (8): For non-demand metered classes, from relationship of sampled energy and demand values, applied to population energy usage

Col (9): Equal to Cols (5) * (8) or Billing Demand

Col (10): From Report 2

Col (11): Equal to Col (9) * (Col (10) / 100)

Orange & Rockland Utilities, Inc - Electric
Report 4 - Estimated Class Demand Data
Class - SC4 - Summer - 2019

Line No	Sample Strata	Stratification Variable pk mo kWh		Half Hour kW at Time of Class Peak Unadj at Cust	4 Hour Demands-kW				
					Unadjusted at the Customer	Adjusted at the Customer	Unadjusted at System Input	Adjusted at System Input	System Peak Respblty
(1)	(2)	Low (3)	High (4)	(5)	(6)	(7)	(8)	(9)	(10)
1	4104 24	0	999,999,999	2,849	2,849	2,849	3,090	3,090	68
2	04-MunStreetLights			2,849	2,849	2,849	3,090	3,090	68
3	SC4			2,849	2,849	2,849	3,090	3,090	68

Footnotes:

Col (5): Class Peak at 12:30am

Col (6): Class 4 hour peak from 12:30am-4:00am

Col (7): Adjusted sum of component loads equals system loads

Col (8): Equal to (Col (6) / Efficiency Factor of 92.200000000) * 100

Col (9): Equal to (Col (7) / Efficiency Factor of 92.200000000) * 100

Col (10): System Peak Responsibility from 4:00pm-7:30pm

Orange & Rockland Utilities, Inc - Electric
 Report 2 - Sample Test Customer Data
 Class - SC5 - Summer - 2019

Line No	Sample Strata	Stratification Variable		No of Test Customers	Strat Var Avg Per Test Cust	Avg Non-Coin kW Per Cust	Avg Coin kW Per Cust	Coincidence Factor Percentage
		pk	mo kWh					
(1)	(2)	Low (3)	High (4)	(5)	(6)	(7)	(8)	(9)
1	5105 26	0	999,999,999	6	836	0.271	0.267	98.5240
2	05-TrafficLights			6				
3	SC5			6				

Footnotes:

Col (9): Equal to 100 * (Col (8) / Col (7))

Orange & Rockland Utilities, Inc - Electric
 Report 3 - Estimated Class Demand Data
 Class - SC5 - Summer - 2019

Line No	Sample Strata	Stratification Variable pk mo kWh		Est Avg No of Custs	Total Annual kWh	Avg Annual Use Per Cust	Est Non-Coin kW Per Cust	Est Popul Non-Coin kW	Coincidence Factor Percentage	Est Popul Coin kW for Individual Strata
(1)	(2)	Low (3)	High (4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)
1	5105 26	0	999,999,999	502	2,249,389	4,481	0.593	298	98.5240	294
2	05-TrafficLights			502	2,249,389			298		294
3	SC5			502	2,249,389			298		294

Footnotes:

Col (7): Equal to Col (6) / Col (5)

Col (8): For non-demand metered classes, from relationship of sampled energy and demand values, applied to population energy usage

Col (9): Equal to Cols (5) * (8) or Billing Demand

Col (10): From Report 2

Col (11): Equal to Col (9) * (Col (10) / 100)

Orange & Rockland Utilities, Inc - Electric
 Report 4 - Estimated Class Demand Data
 Class - SC5 - Summer - 2019

Line No	Sample Strata	Stratification Variable pk mo kWh		Half Hour kW at Time of Class Peak Unadj at Cust	4 Hour Demands-kW				
					Unadjusted at the Customer	Adjusted at the Customer	Unadjusted at System Input	Adjusted at System Input	System Peak Respblty
		Low (3)	High (4)						
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)
1	5105 26	0	999,999,999	294	293	293	318	318	317
2	05-TrafficLights			294	293	293	318	318	317
3	SC5			294	293	293	318	318	317

Footnotes:

Col (5): Class Peak at 8:00pm

Col (6): Class 4 hour peak from 7:00pm-10:30pm

Col (7): Adjusted sum of component loads equals system loads

Col (8): Equal to (Col (6) / Efficiency Factor of 92.200000000) * 100

Col (9): Equal to (Col (7) / Efficiency Factor of 92.200000000) * 100

Col (10): System Peak Responsibility from 4:00pm-7:30pm

Orange & Rockland Utilities, Inc - Electric
 Report 2 - Sample Test Customer Data
 Class - SC6 - Summer - 2019

Line No	Sample Strata	Stratification Variable pk mo kWh		No of Test Customers	Strat Var Avg Per Test Cust	Avg Non-Coin kW Per Cust	Avg Coin kW Per Cust	Coincidence Factor Percentage
		Low (3)	High (4)					
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)
1	6136 26	0	999,999,999	3	138,212	37.066	37.057	99.9757
2	06-MunOwnLights			3				
3	SC6			3				

Footnotes:

Col (9): Equal to 100 * (Col (8) / Col (7))

Orange & Rockland Utilities, Inc - Electric
 Report 3 - Estimated Class Demand Data
 Class - SC6 - Summer - 2019

Line No	Sample Strata	Stratification Variable		Est Avg No of Custs	Total Annual kWh	Avg Annual Use Per Cust	Est Non- Coin kW Per Cust	Est Popul Non- Coin kW	Coincidence Factor Percentage	Est Popul Coin kW for Individual Strata
(1)	(2)	Low (3)	High (4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)
1	6136 26	0	999,999,999	7	3,065,945	437,992	109.945	770	99.9757	770
2	06-MunOwnLights			7	3,065,945			770		770
3	SC6			7	3,065,945			770		770

Footnotes:

Col (7): Equal to Col (6) / Col (5)

Col (8): For non-demand metered classes, from relationship of sampled energy and demand values, applied to population energy usage

Col (9): Equal to Cols (5) * (8) or Billing Demand

Col (10): From Report 2

Col (11): Equal to Col (9) * (Col (10) / 100)

Orange & Rockland Utilities, Inc - Electric
 Report 4 - Estimated Class Demand Data
 Class - SC6 - Summer - 2019

Line No	Sample Strata	4 Hour Demands-kW							
		Stratification Variable		Half Hour kW at Time of Class Peak Unadj at Cust	Unadjusted at the Customer	Adjusted at the Customer	Unadjusted at System Input	Adjusted at System Input	System Peak Respbilty
		Low pk mo kWh	High						
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)
1	6136 26	0	999,999,999	770	770	770	835	835	18
2	06-MunOwnLights			770	770	770	835	835	18
3	SC6			770	770	770	835	835	18

Footnotes:

Col (5): Class Peak at 3:00am

Col (6): Class 4 hour peak from 12:30am-4:00am

Col (7): Adjusted sum of component loads equals system loads

Col (8): Equal to (Col (6) / Efficiency Factor of 92.200000000) * 100

Co (9): Equal to (Col (7) / Efficiency Factor of 92.200000000) * 100

Col (10): System Peak Responsibility from 4:00pm-7:30pm

Orange & Rockland Utilities, Inc - Electric
 Report 2 - Sample Test Customer Data
 Class - SC9 - Summer - 2019

Line No	Sample Strata	Stratification Variable		No of Test Customers	Strat Var Avg Per Test Cust	Avg Non-Coin kW Per Cust	Avg Coin kW Per Cust	Coincidence Factor Percentage
		Low (3)	High (4)					
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)
1	9110 90	0	999,999,999	36	1,192	1,180.925	976.239	82.6673
2	09-CommPri			36				
3	9838 90	0	999,999,999	1	2,195	2,148.840	2,060.448	95.8865
4	09-CommSub			1				
5	9848 90	0	999,999,999	1	1,352	1,355.550	1,255.800	92.6414
6	09-CommTrans			1				
7	SC9			38				

Footnotes:

Col (9): Equal to 100 * (Col (8) / Col (7))

Orange & Rockland Utilities, Inc - Electric
Report 3 - Estimated Class Demand Data
Class - SC9 - Summer - 2019

Line No	Sample Strata	Stratification Variable pk mo kW		Est Avg No of Custs	Total Annual kWh	Avg Annual Use Per Cust	Est Non- Coin kW Per Cust	Est Popul Non- Coin kW	Coincidence Factor Percentage	Est Popul Coin kW for Individual Strata
(1)	(2)	Low (3)	High (4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)
1	9110 90	0	999,999,999	42	262,412,790	6,247,924		49,021	82.6673	40,524
2	09-CommPri			42	262,412,790			49,021		40,524
3	9838 90	0	999,999,999	8	182,111,796	22,763,975		26,548	95.8865	25,456
4	09-CommSub			8	182,111,796			26,548		25,456
5	9848 90	0	999,999,999	1	10,121,397	10,121,397		1,319	92.6414	1,222
6	09-CommTrans			1	10,121,397			1,319		1,222
7	SC9			51	454,645,983			76,888		67,202

Footnotes:

Col (7): Equal to Col (6) / Col (5)

Col (8): For non-demand metered classes, from relationship of sampled energy and demand values, applied to population energy usage

Col (9): Equal to Cols (5) * (8) or Billing Demand

Col (10): From Report 2

Col (11): Equal to Col (9) * (Col (10) / 100)

Orange & Rockland Utilities, Inc - Electric
 Report 4 - Estimated Class Demand Data
 Class - SC9 - Summer - 2019

Line No	Sample Strata	4 Hour Demands-kW							
		Stratification Variable		Half Hour kW at Time of Class Peak Unadj at Cust	Unadjusted at the Customer	Adjusted at the Customer	Unadjusted at System Input	Adjusted at System Input	System Peak Respbilty
		Low pk mo kW	High pk mo kW						
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)
1	9110 90	0	999,999,999	40,325	39,707	35,481	41,973	37,506	37,988
2	09-CommPri			40,325	39,707	35,481	41,973	37,506	37,988
3	9838 90	0	999,999,999	25,456	24,110	21,539	25,486	22,769	20,002
4	09-CommSub			25,456	24,110	21,539	25,486	22,769	20,002
5	9848 90	0	999,999,999	1,138	1,136	1,136	1,201	1,201	1,116
6	09-CommTrans			1,138	1,136	1,136	1,201	1,201	1,116
7	SC9			66,919	64,953	58,156	68,660	61,476	59,106

Footnotes:

Col (5): Class Peak at 2:00pm

Col (6): Class 4 hour peak from 1:00pm-4:30pm

Col (7): Adjusted sum of component loads equals system loads

Col (8): Equal to (Col (6) / Efficiency Factor of 94.600000000) * 100

Col (9): Equal to (Col (7) / Efficiency Factor of 94.600000000) * 100

Col (10): System Peak Responsibility from 4:00pm-7:30pm

Orange & Rockland Utilities, Inc - Electric
 Report 2 - Sample Test Customer Data
 Class - SC11 - Summer - 2019

Line No	Sample Strata	Stratification Variable pk mo kWh		No of Test Customers	Strat Var Avg Per Test Cust	Avg Non- Coin kW Per Cust	Avg Coin kW Per Cust	Coincidence Factor Percentage
		Low (3)	High (4)					
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)
1	11111 111	0	999,999,999	1	17,613	17,926.080	15,066.240	84.0465
2	11-WEST_POINT			1				
3	SC11			1				

Footnotes:

Col (9): Equal to 100 * (Col (8) / Col (7))

Orange & Rockland Utilities, Inc - Electric
 Report 3 - Estimated Class Demand Data
 Class - SC11 - Summer - 2019

Line No	Sample Strata	Stratification Variable pk mo kWh		Est Avg No of Custs	Total Annual kWh	Avg Annual Use Per Cust	Est Non-Coin kW Per Cust	Est Popul Non-Coin kW	Coincidence Factor Percentage	Est Popul Coin kW for Individual Strata
(1)	(2)	Low (3)	High (4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)
1	11111 111	0	999,999,999	1	97,560,556	97,560,556		18,967	84.0465	15,941
2	11-WEST_POINT			1	97,560,556			18,967		15,941
3	SC11			1	97,560,556			18,967		15,941

Footnotes:

Col (7): Equal to Col (6) / Col (5)

Col (8): For non-demand metered classes, from relationship of sampled energy and demand values, applied to population energy usage

Col (9): Equal to Cols (5) * (8) or Billing Demand

Col (10): From Report 2

Col (11): Equal to Col (9) * (Col (10) / 100)

Orange & Rockland Utilities, Inc - Electric
 Report 4 - Estimated Class Demand Data
 Class - SC11 - Summer - 2019

Line No	Sample Strata	4 Hour Demands-kW							
		Stratification Variable		Half Hour kW at Time of Class Peak Unadj at Cust	Unadjusted at the Customer	Adjusted at the Customer	Unadjusted at System Input	Adjusted at System Input	System Peak Respblty
		Low pk mo kWh	High pk mo kWh						
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)
1	11111 111	0	999,999,999	15,941	15,752	15,752	16,902	16,902	16,217
2	11-WEST_POINT			15,941	15,752	15,752	16,902	16,902	16,217
3	SC11			15,941	15,752	15,752	16,902	16,902	16,217

Footnotes:

Col (5): Class Peak at 2:30pm

Col (6): Class 4 hour peak from 1:00pm-4:30pm

Col (7): Adjusted sum of component loads equals system loads

Col (8): Equal to (Col (6) / Efficiency Factor of 93.200000000) * 100

Col (9): Equal to (Col (7) / Efficiency Factor of 93.200000000) * 100

Col (10): System Peak Responsibility from 4:00pm-7:30pm

Orange & Rockland Utilities, Inc - Electric
 Report 2 - Sample Test Customer Data
 Class - SC16_PriD2d - Summer - 2019

Line No	Sample Strata	Stratification Variable pk mo kWh		No of Test Customers	Strat Var Avg Per Test Cust	Avg Non-Coin kW Per Cust	Avg Coin kW Per Cust	Coincidence Factor Percentage
(1)	(2)	Low (3)	High (4)	(5)	(6)	(7)	(8)	(9)
1	16212 24	0	999,999,999		1	4,326	0.974	100.0000
2	16-PriOverD2D				1			
3	SC16_PriD2d				1			

Footnotes:

Col (9): Equal to 100 * (Col (8) / Col (7))

Orange & Rockland Utilities, Inc - Electric
 Report 3 - Estimated Class Demand Data
 Class - SC16_PriD2d - Summer - 2019

Line No	Sample Strata	Stratification Variable pk mo kWh		Est Avg No of Custs	Total Annual kWh	Avg Annual Use Per Cust	Est Non- Coin kW Per Cust	Est Popul Non-Coin kW	Coincidence Factor Percentage	Est Popul Coin kW for Individual Strata
(1)	(2)	Low (3)	High (4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)
1	16212 24	0	999,999,999	2,312	9,762,617	4,223	0.975	2,254	100.0000	2,254
2	16-PriOverD2D			2,312	9,762,617			2,254		2,254
3	SC16_PriD2d			2,312	9,762,617			2,254		2,254

Footnotes:

Col (7): Equal to Col (6) / Col (5)

Col (8): For non-demand metered classes, from relationship of sampled energy and demand values, applied to population energy usage

Col (9): Equal to Cols (5) * (8) or Billing Demand

Col (10): From Report 2

Col (11): Equal to Col (9) * (Col (10) / 100)

Orange & Rockland Utilities, Inc - Electric
 Report 4 - Estimated Class Demand Data
 Class - SC16_PriD2d - Summer - 2019

Line No	Sample Strata	Stratification Variable pk mo kWh		Half Hour kW at Time of Class Peak Unadj at Cust	4 Hour Demands-kW				
					Unadjusted at the Customer	Adjusted at the Customer	Unadjusted at System Input	Adjusted at System Input	System Peak Respblty
(1)	(2)	Low (3)	High (4)	(5)	(6)	(7)	(8)	(9)	(10)
1	16212 24	0	999,999,999	2,254	2,254	2,254	2,445	2,445	54
2	16-PriOverD2D			2,254	2,254	2,254	2,445	2,445	54
3	SC16_PriD2d			2,254	2,254	2,254	2,445	2,445	54

Footnotes:

Col (5): Class Peak at 12:30am

Col (6): Class 4 hour peak from 12:30am-4:00am

Col (7): Adjusted sum of component loads equals system loads

Col (8): Equal to (Col (6) / Efficiency Factor of 92.200000000) * 100

Col (9): Equal to (Col (7) / Efficiency Factor of 92.200000000) * 100

Col (10): System Peak Responsibility from 4:00pm-7:30pm

Orange & Rockland Utilities, Inc - Electric
 Report 2 - Sample Test Customer Data
 Class - SC16_Enoly - Summer - 2019

Line No	Sample Strata	Stratification Variable pk mo kWh		No of Test Customers	Strat Var Avg Per Test Cust	Avg Non- Coin kW Per Cust	Avg Coin kW Per Cust	Coincidence Factor Percentage
		Low (3)	High (4)					
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)
1	16412 24	0	999,999,999	41	1,278	10.724	4.977	46.4099
2	16512 24	0	999,999,999	1	7,408	0.830	0.830	100.0000
3	16-EngyOnlyLght			42				
4	SC16_Enoly			42				

Footnotes:

Col (9): Equal to 100 * (Col (8) / Col (7))

Orange & Rockland Utilities, Inc - Electric
 Report 3 - Estimated Class Demand Data
 Class - SC16_Enoly - Summer - 2019

Line No	Sample Strata	Stratification Variable pk mo kWh		Est Avg No of Custs	Total Annual kWh	Avg Annual Use Per Cust	Est Non-Coin kW Per Cust	Est Popul Non-Coin kW	Coincidence Factor Percentage	Est Popul Coin kW for Individual Strata
(1)	(2)	Low (3)	High (4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)
1	16412 24	0	999,999,999	353	2,355,096	6,672	5.968	2,107	46.4099	978
2	16512 24	0	999,999,999	78	577,789	7,408	0.834	65	100.0000	65
3	16-EngyOnlyLght			431	2,932,885			2,172		1,043
4	SC16_Enoly			431	2,932,885			2,172		1,043

Footnotes:

Col (7): Equal to Col (6) / Col (5)

Col (8): For non-demand metered classes, from relationship of sampled energy and demand values, applied to population energy usage

Col (9): Equal to Cols (5) * (8) or Billing Demand

Col (10): From Report 2

Col (11): Equal to Col (9) * (Col (10) / 100)

Orange & Rockland Utilities, Inc - Electric
 Report 4 - Estimated Class Demand Data
 Class - SC16_Enoly - Summer - 2019

Line No	Sample Strata	4 Hour Demands-kW							
		Stratification Variable		Half Hour kW at Time of Class Peak Unadj at Cust	Unadjusted at the Customer	Adjusted at the Customer	Unadjusted at System Input	Adjusted at System Input	System Peak Respbilty
		Low (3)	High (4)						
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)
1	16412 24	0	999,999,999	978	787	766	854	831	298
2	16512 24	0	999,999,999	65	65	65	70	70	70
3	16-EngyOnlyLght			1,043	852	831	924	901	368
4	SC16_Enoly			1,043	852	831	924	901	368

Footnotes:

Col (5): Class Peak at 9:00pm

Col (6): Class 4 hour peak from 7:30pm-11:00pm

Col (7): Adjusted sum of component loads equals system loads

Col (8): Equal to (Col (6) / Efficiency Factor of 92.200000000) * 100

Col (9): Equal to (Col (7) / Efficiency Factor of 92.200000000) * 100

Col (10): System Peak Responsibility from 4:00pm-7:30pm

Orange & Rockland Utilities, Inc - Electric
 Report 2 - Sample Test Customer Data
 Class - SC19 - Summer - 2019

Line No	Sample Strata	Stratification Variable pk mo kWh		No of Test Customers	Strat Var Avg Per Test Cust	Avg Non-Coin kW Per Cust	Avg Coin kW Per Cust	Coincidence Factor Percentage
(1)	(2)	Low (3)	High (4)	(5)	(6)	(7)	(8)	(9)
1	19318 01	0	600	70	369	5.286	2.346	44.3814
2	19318 02	601	1,200	109	888	6.759	3.364	49.7707
3	19318 03	1,201	2,000	114	1,582	8.336	4.660	55.9021
4	19318 04	2,001	3,800	214	2,785	11.180	7.194	64.3470
5	19318 05	3,801	999,999,999	86	5,738	19.296	12.079	62.5985
6	19-VolResidential			593				
7	SC19			593				

Footnotes:

Col (9): Equal to 100 * (Col (8) / Col (7))

Orange & Rockland Utilities, Inc - Electric
Report 3 - Estimated Class Demand Data
Class - SC19 - Summer - 2019

Line No	Sample Strata	Stratification Variable pk mo kWh		Est Avg No of Custs	Total Annual kWh	Avg Annual Use Per Cust	Est Non-Coin kW Per Cust	Est Popul Non-Coin kW	Coincidence Factor Percentage	Est Popul Coin kW for Individual Strata
(1)	(2)	Low (3)	High (4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)
1	19318 01	0	600	321	1,979,082	6,165	3.897	1,251	44.3814	555
2	19318 02	601	1,200	577	5,751,479	9,968	6.505	3,753	49.7707	1,868
3	19318 03	1,201	2,000	901	12,081,746	13,409	8.000	7,208	55.9021	4,029
4	19318 04	2,001	3,800	1,109	22,412,674	20,210	10.167	11,275	64.3470	7,255
5	19318 05	3,801	999,999,999	413	26,795,212	64,879	25.236	10,422	62.5985	6,524
6	19-VolResidential			3,321	69,020,193			33,909		20,231
7	SC19			3,321	69,020,193			33,909		20,231

Footnotes:

Col (7): Equal to Col (6) / Col (5)

Col (8): For non-demand metered classes, from relationship of sampled energy and demand values, applied to population energy usage

Col (9): Equal to Cols (5) * (8) or Billing Demand

Col (10): From Report 2

Col (11): Equal to Col (9) * (Col (10) / 100)

Orange & Rockland Utilities, Inc - Electric
 Report 4 - Estimated Class Demand Data
 Class - SC19 - Summer - 2019

Line No	Sample Strata		Stratification Variable pk mo kWh		Half Hour kW at Time of Class Peak Unadj at Cust	4 Hour Demands-kW				
						Unadjusted at the Customer	Adjusted at the Customer	Unadjusted at System Input	Adjusted at System Input	System Peak Respblty
(1)	(2)		Low (3)	High (4)	(5)	(6)	(7)	(8)	(9)	(10)
1	19318	01	0	600	555	502	474	546	516	492
2	19318	02	601	1,200	1,868	1,788	1,689	1,948	1,840	1,804
3	19318	03	1,201	2,000	4,025	3,938	3,717	4,290	4,049	4,017
4	19318	04	2,001	3,800	6,966	7,037	6,639	7,666	7,232	7,245
5	19318	05	3,801	999,999,999	6,465	6,409	6,048	6,982	6,588	6,586
6	19-VolResidential				19,879	19,674	18,567	21,432	20,225	20,144
7	SC19				19,879	19,674	18,567	21,432	20,225	20,144

Footnotes:

Col (5): Class Peak at 7:00pm

Col (6): Class 4 hour peak from 4:30pm-8:00pm

Col (7): Adjusted sum of component loads equals system loads

Col (8): Equal to (Col (6) / Efficiency Factor of 91.800000000) * 100

Col (9): Equal to (Col (7) / Efficiency Factor of 91.800000000) * 100

Col (10): System Peak Responsibility from 4:00pm-7:30pm

Orange & Rockland Utilities, Inc - Electric
 Report 2 - Sample Test Customer Data
 Class - SC20 - Summer - 2019

Line No	Sample Strata		Stratification Variable		No of Test Customers	Strat Var Avg Per Test Cust	Avg Non-Coin kW Per Cust	Avg Coin kW Per Cust	Coincidence Factor Percentage
			pk mo kW (20120)	max ann kW (20130)					
(1)	(2)		Low (3)	High (4)	(5)	(6)	(7)	(8)	(9)
1	20120	11	0	35	17	11	24.299	22.034	90.6786
2	20120	12	36	80	10	50	48.717	36.694	75.3207
3	20120	13	81	999,999,999	11	121	120.430	102.410	85.0370
4	20130	99	200	999,999,999	2	491	506.060	446.040	88.1397
5	20-VolComm2				40				
6	SC20				40				

Footnotes:

Col (9): Equal to 100 * (Col (8) / Col (7))

Orange & Rockland Utilities, Inc - Electric
 Report 3 - Estimated Class Demand Data
 Class - SC20 - Summer - 2019

Line No	Sample Strata	Stratification Variable pk mo kW (20120) max ann kW (20130)		Est Avg No of Custs	Total Annual kWh	Avg Annual Use Per Cust	Est Non-Coin kW Per Cust	Est Popul Non-Coin kW	Coincidence Factor Percentage	Est Popul Coin kW for Individual Strata
(1)	(2)	Low (3)	High (4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)
1	20120 11	0	35	348	21,017,648	60,396		4,054	90.6786	3,676
2	20120 12	36	80	144	24,514,628	170,240		6,218	75.3207	4,683
3	20120 13	81	999,999,999	59	27,303,176	462,766		6,477	85.0370	5,508
4	20130 99	200	999,999,999	4	5,410,525	1,352,631		1,059	88.1397	933
5	20-VolComm2			555	78,245,977			17,808		14,800
6	SC20			555	78,245,977			17,808		14,800

Footnotes:

Col (7): Equal to Col (6) / Col (5)

Col (8): For non-demand metered classes, from relationship of sampled energy and demand values, applied to population energy usage

Col (9): Equal to Cols (5) * (8) or Billing Demand

Col (10): From Report 2

Col (11): Equal to Col (9) * (Col (10) / 100)

Orange & Rockland Utilities, Inc - Electric
Report 4 - Estimated Class Demand Data
Class - SC20 - Summer - 2019

Line No	Sample Strata	4 Hour Demands-kW								
		Stratification Variable		Half Hour kW at Time of Class Peak Unadj at Cust	Unadjusted at the Customer	Adjusted at the Customer	Unadjusted at System Input	Adjusted at System Input	System Peak Respbilty	
		pk mo kW (20120)	max ann kW (20130)							
		Low (3)	High (4)							
		(1)	(2)							(3)
1	20120 11	0	35	3,370	3,242	2,993	3,532	3,260	3,188	
2	20120 12	36	80	4,477	4,526	4,179	4,930	4,552	4,528	
3	20120 13	81	999,999,999	5,476	5,474	5,056	5,963	5,507	5,530	
4	20130 99	200	999,999,999	686	723	667	788	727	689	
5	20-VolComm2			14,009	13,965	12,895	15,213	14,046	13,935	
6	SC20			14,009	13,965	12,895	15,213	14,046	13,935	

Footnotes:

Col (5): Class Peak at 5:30pm

Col (6): Class 4 hour peak from 3:00pm-6:30pm

Col (7): Adjusted sum of component loads equals system loads

Col (8): Equal to (Col (6) / Efficiency Factor of 91.800000000) * 100

Col (9): Equal to (Col (7) / Efficiency Factor of 91.800000000) * 100

Col (10): System Peak Responsibility from 4:00pm-7:30pm

Orange & Rockland Utilities, Inc - Electric
Report 2 - Sample Test Customer Data
Class - SC21 - Summer - 2019

Line No	Sample Strata	Stratification Variable pk mo kW (21121,21221) max ann kW (21131)		No of Test Customers	Strat Var Avg Per Test Cust	Avg Non-Coin kW Per Cust	Avg Coin kW Per Cust	Coincidence Factor Percentage
		Low (3)	High (4)					
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)
1	21121 21	0	999,999,999	3	150	150.106	139.549	92.9670
2	21131 99	200	999,999,999	14	456	477.244	399.058	83.6172
3	21-VolCommPriTOU			17				
4	SC21			17				

Footnotes:

Col (9): Equal to 100 * (Col (8) / Col (7))

Orange & Rockland Utilities, Inc - Electric
 Report 3 - Estimated Class Demand Data
 Class - SC21 - Summer - 2019

Line No	Sample Strata	Stratification Variable pk mo kW (21121,21221) max ann kW (21131)		Est Avg No of Custs	Total Annual kWh	Avg Annual Use Per Cust	Est Non-Coin kW Per Cust	Est Popul Non- Coin kW	Coincidence Factor Percentage	Est Popul Coin kW for Individual Strata
(1)	(2)	Low (3)	High (4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)
1	21121 21	0	999,999,999	10	5,202,440	520,244		1,247	92.9670	1,159
2	21131 99	200	999,999,999	15	32,067,140	2,137,809		6,914	83.6172	5,781
3	21-VolCommPriTOU			25	37,269,580			8,161		6,940
4	SC21			25	37,269,580			8,161		6,940

Footnotes:

Col (7): Equal to Col (6) / Col (5)

Col (8): For non-demand metered classes, from relationship of sampled energy and demand values, applied to population energy usage

Col (9): Equal to Cols (5) * (8) or Billing Demand

Col (10): From Report 2

Col (11): Equal to Col (9) * (Col (10) / 100)

Orange & Rockland Utilities, Inc - Electric
 Report 4 - Estimated Class Demand Data
 Class - SC21 - Summer - 2019

Line No	Sample Strata	4 Hour Demands-kW							
		Stratification Variable pk mo kW (21121,21221) max ann kW (21131)		Half Hour kW at Time of Class Peak Unadj at Cust	Unadjusted at the Customer	Adjusted at the Customer	Unadjusted at System Input	Adjusted at System Input	System Peak Respblty
		Low	High						
		(3)	(4)						
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)
1	21121 21	0	999,999,999	1,159	1,124	1,030	1,206	1,105	1,101
2	21131 99	200	999,999,999	5,751	5,739	5,739	6,158	6,158	6,102
3	21-VolCommPriTOU			6,910	6,863	6,769	7,364	7,263	7,203
4	SC21			6,910	6,863	6,769	7,364	7,263	7,203

Footnotes:

Col (5): Class Peak at 4:00pm

Col (6): Class 4 hour peak from 2:30pm-6:00pm

Col (7): Adjusted sum of component loads equals system loads

Col (8): Equal to (Col (6) / Efficiency Factor of 93.200000000) * 100

Col (9): Equal to (Col (7) / Efficiency Factor of 93.200000000) * 100

Col (10): System Peak Responsibility from 4:00pm-7:30pm

Orange & Rockland Utilities, Inc - Electric
 Report 2 - Sample Test Customer Data
 Class - SC22 - Summer - 2019

Line No	Sample Strata		Stratification Variable		No of Test Customers	Strat Var Avg Per Test Cust	Avg Non-Coin kW Per Cust	Avg Coin kW Per Cust	Coincidence Factor Percentage
			Low pk mo kW	High pk mo kW					
(1)	(2)		(3)	(4)	(5)	(6)	(7)	(8)	(9)
1	22211	22	0	999,999,999	21	1,493	1,475.875	1,166.243	79.0204
2	22868	22	0	999,999,999	2	2,612	2,557.607	2,010.391	78.6044
3	22961	22	0	999,999,999	5	17,298	2,190.831	1,549.928	70.7461
4	22-Industrial				28				
5	SC22				28				

Footnotes:

Col (9): Equal to 100 * (Col (8) / Col (7))

Orange & Rockland Utilities, Inc - Electric
 Report 3 - Estimated Class Demand Data
 Class - SC22 - Summer - 2019

Line No	Sample Strata	Stratification Variable pk mo kW		Est Avg No of Custs	Total Annual kWh	Avg Annual Use Per Cust	Est Non-Coin kW Per Cust	Est Popul Non-Coin kW	Coincidence Factor Percentage	Est Popul Coin kW for Individual Strata
(1)	(2)	Low (3)	High (4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)
1	22211 22	0	999,999,999	31	240,365,993	7,753,742		44,797	79.0204	35,399
2	22868 22	0	999,999,999	3	19,460,264	6,486,755		5,274	78.6044	4,146
3	22961 22	0	999,999,999	5	49,634,878	9,926,976		15,840	70.7461	11,206
4	22-Industrial			39	309,461,135			65,911		50,751
5	SC22			39	309,461,135			65,911		50,751

Footnotes:

Col (7): Equal to Col (6) / Col (5)

Col (8): For non-demand metered classes, from relationship of sampled energy and demand values, applied to population energy usage

Col (9): Equal to Cols (5) * (8) or Billing Demand

Col (10): From Report 2

Col (11): Equal to Col (9) * (Col (10) / 100)

Orange & Rockland Utilities, Inc - Electric
 Report 4 - Estimated Class Demand Data
 Class - SC22 - Summer - 2019

Line No	Sample Strata		Stratification Variable pk mo kW		Half Hour kW at Time of Class Peak Unadj at Cust	4 Hour Demands-kW				
						Unadjusted at the Customer	Adjusted at the Customer	Unadjusted at System Input	Adjusted at System Input	System Peak Respblty
			Low (3)	High (4)		(6)	(7)	(8)	(9)	(10)
1	22211	22	0	999,999,999	34,598	34,276	30,152	36,271	31,907	34,136
2	22868	22	0	999,999,999	3,723	3,728	3,276	3,945	3,467	1,922
3	22961	22	0	999,999,999	10,993	10,724	10,724	11,348	11,348	8,550
4	22-Industrial				49,314	48,728	44,152	51,564	46,722	44,608
5	SC22				49,314	48,728	44,152	51,564	46,722	44,608

Footnotes:

Col (5): Class Peak at 8:00am

Col (6): Class 4 hour peak from 7:00am-10:30am

Col (7): Adjusted sum of component loads equals system loads

Col (8): Equal to (Col(6) / Efficiency Factor of 94.500000000) * 100

Col (9): Equal to (Col(7) / Efficiency Factor of 94.500000000) * 100

Col (10): System Peak Responsibility from 4:00pm-7:30pm

Orange & Rockland Utilities, Inc - Electric
 Report 2 - Sample Test Customer Data
 Class - SC99 - Summer - 2019

Line No	Sample Strata	Stratification Variable pk mo kWh		No of Test Customers	Strat Var Avg Per Test Cust	Avg Non-Coin kW Per Cust	Avg Coin kW Per Cust	Coincidence Factor Percentage
		Low (3)	High (4)					
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)
1	99999 99	0	999,999,999	29	-	38.006	34.736	91.3961
2	99-Company Use			29				
3	SC99			29				

Footnotes:

Col (9): Equal to $100 * (\text{Col (8)} / \text{Col (7)})$

Orange & Rockland Utilities, Inc - Electric
 Report 3 - Estimated Class Demand Data
 Class - SC99 - Summer - 2019

Line No	Sample Strata	Stratification Variable pk mo kWh		Est Avg No of Custs	Total Annual kWh	Avg Annual Use Per Cust	Est Non-Coin kW Per Cust	Est Popul Non- Coin kW	Coincidence Factor Percentage	Est Popul Coin kW for Individual Strata
(1)	(2)	Low (3)	High (4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)
1	99999 99	0	999,999,999	190	14,622,737	76,962	11.531	2,191	91.3961	2,002
2	99-Company Use			190	14,622,737			2,191		2,002
3	SC99			190	14,622,737			2,191		2,002

Footnotes:

Col (7): Equal to Col (6) / Col (5)

Col (8): For non-demand metered classes, from relationship of sampled energy and demand values, applied to population energy usage

Col (9): Equal to Cols (5) * (8) or Billing Demand

Col (10): From Report 2

Col (11): Equal to Col (9) * (Col (10) / 100)

Orange & Rockland Utilities, Inc - Electric
 Report 4 - Estimated Class Demand Data
 Class - SC99 - Summer - 2019

Line No	Sample Strata	Stratification Variable pk mo kWh		Half Hour kW at Time of Class Peak Unadj at Cust	4 Hour Demands-kW				
					Unadjusted at the Customer	Adjusted at the Customer	Unadjusted at System Input	Adjusted at System Input	System Peak Respblty
		Low (3)	High (4)		(6)	(7)	(8)	(9)	(10)
1	99999 99	0	999,999,999	1,976	1,908	1,761	2,078	1,919	1,894
2	99-Company Use			1,976	1,908	1,761	2,078	1,919	1,894
3	SC99			1,976	1,908	1,761	2,078	1,919	1,894

Footnotes:

Col (5): Class Peak at 3:00pm

Col (6): Class 4 hour peak from 3:00pm-6:30pm

Col (7): Adjusted sum of component loads equals system loads

Col (8): Equal to (Col (6) / Efficiency Factor of 91.800000151) * 100

Col (9): Equal to (Col (7) / Efficiency Factor of 91.800000151) * 100

Col (10): System Peak Responsibility from 4:00pm-7:30pm

Orange & Rockland Utilities, Inc - Electric
Report 2 - Sample Test Customer Data
Class -SC1 - Winter - 2019

Line No	Sample Strata	Stratification Variable pk mo kWh		No of Test Customers	Strat Var Avg Per Test Cust	Avg Non-Coin kW Per Cust	Avg Coin kW Per Cust	Coincidence Factor Percentage
(1)	(2)	Low (3)	High (4)	(5)	(6)	(7)	(8)	(9)
1	1201 08	0	999,999,999	247	1,406	6.486	3.140	48.4120
2	1501 07	0	999,999,999	617	794	9.451	4.367	46.2068
3	1801 06	0	999,999,999	256	1,076	6.504	1.872	28.7823
4	01-ResiSpecProv			1,120				
5	1301 01	0	600	2,480	325	2.142	0.689	32.1662
6	1301 02	601	1,200	550	806	3.293	1.184	35.9551
7	1301 03	1,201	2,000	314	1,572	4.050	1.735	42.8395
8	1301 04	2,001	3,800	502	2,773	5.419	2.564	47.3150
9	1301 05	3,801	999,999,999	374	6,106	11.412	5.560	48.7206
10	01-Residential			4,220				
11	SC1			5,340				

Footnotes:

Col (9): Equal to 100 * (Col (8) / Col (7))

Orange & Rockland Utilities, Inc - Electric
Report 3 - Estimated Class Demand Data
Class - SC1 - Winter - 2019

Line No	Sample Strata	Stratification Variable pk mo kWh		Est Avg No of Custs	Total Annual kWh	Avg Annual Use Per Cust	Est Non-Coin kW Per Cust	Est Popul Non-Coin kW	Coincidence Factor Percentage	Est Popul Coin kW for Individual Strata
(1)	(2)	Low (3)	High (4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)
1	1201 08	0	999,999,999	1,707	16,432,883	9,627	6.015	10,268	48.4120	4,971
2	1501 07	0	999,999,999	2,227	28,662,880	12,871	9.715	21,635	46.2068	9,997
3	1801 06	0	999,999,999	2,187	19,582,866	8,954	6.615	14,467	28.7823	4,164
4	01-ResiSpecProv			6,121	64,678,629			46,370		19,132
5	1301 01	0	600	86,220	311,367,673	3,611	2.433	209,773	32.1662	67,476
6	1301 02	601	1,200	64,375	483,621,742	7,513	3.610	232,394	35.9551	83,557
7	1301 03	1,201	2,000	33,065	371,042,975	11,222	4.267	141,088	42.8395	60,441
8	1301 04	2,001	3,800	12,737	216,946,029	17,033	5.308	67,608	47.3150	31,989
9	1301 05	3,801	999,999,999	1,819	86,008,072	47,283	13.238	24,080	48.7206	11,732
10	01-Residential			198,216	1,468,986,491			674,943		255,195
11	SC1			204,337	1,533,665,120			721,313		274,327

Footnotes:

Col (7): Equal to Col (6) / Col (5)

Col (8): For non-demand metered classes, from relationship of sampled energy and demand values, applied to population energy usage

Col (9): Equal to Cols (5) * (8) or Billing Demand

Col (10): From Report 2

Col (11): Equal to Col (9) * (Col (10) / 100)

Orange & Rockland Utilities, Inc - Electric
Report 4 - Estimated Class Demand Data
Class - SC1 - Winter - 2019

Line No	Sample Strata		Stratification Variable pk mo kWh		Half Hour kW at Time of Class Peak Unadj at Cust	4 Hour Demands-kW				
						Unadjusted at the Customer	Adjusted at the Customer	Unadjusted at System Input	Adjusted at System Input	System Peak Respblty
			Low (3)	High (4)		(6)	(7)	(8)	(9)	(10)
1	1201	08	0	999,999,999	4,322	4,284	4,169	4,667	4,542	4,423
2	1501	07	0	999,999,999	9,595	9,510	9,255	10,360	10,081	9,904
3	1801	06	0	999,999,999	4,116	4,009	3,901	4,367	4,249	4,240
4	01-ResiSpecProv				18,033	17,803	17,325	19,394	18,872	18,567
5	1301	01	0	600	67,476	66,189	64,409	72,101	70,163	68,797
6	1301	02	601	1,200	83,450	81,898	79,702	89,213	86,822	84,513
7	1301	03	1,201	2,000	59,574	58,367	56,788	63,580	61,861	61,583
8	1301	04	2,001	3,800	31,405	31,004	30,168	33,773	32,863	32,564
9	1301	05	3,801	999,999,999	11,601	11,376	11,068	12,392	12,057	12,064
10	01-Residential				253,506	248,834	242,135	271,059	263,766	259,521
11	SC1				271,539	266,637	259,460	290,453	282,638	278,088

Footnotes:

Col (5): Class Peak at 8:00pm

Col (6): Class 4 hour peak from 6:30pm-10:00pm

Col (7): Adjusted sum of component loads equals system loads

Col (8): Equal to (Col (6) / Efficiency Factor of 91.800000000) * 100

Col (9): Equal to (Col (7) / Efficiency Factor of 91.800000000) * 100

Col (10): System Peak Responsibility from 5:30pm-9:00pm

Orange & Rockland Utilities, Inc - Electric
Report 2 - Sample Test Customer Data
Class - SC2 - Winter - 2019

Line No	Sample Strata	Stratification Variable pk mo kW (2102,2302,2602) max ann kW (2322,2612)		No of Test Customers	Strat Var Avg Per Test Cust	Avg Non-Coin kW Per Cust	Avg Coin kW Per Cust	Coincidence Factor Percentage
		Low (3)	High (4)					
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)
1	2102 09	0	6	222	2	2.787	1.452	52.0990
2	2102 10	7	16	145	10	7.874	4.649	59.0424
3	2102 11	17	35	131	22	14.664	9.076	61.8931
4	2102 12	36	80	59	52	91.789	75.144	81.8660
5	2102 13	81	999,999,999	47	125	88.327	67.334	76.2326
6	02-GenSmallSec			604				
7	2302 13	0	999,999,999	24	151	128.563	99.590	77.4640
8	2322 99	200	999,999,999	52	391	334.273	259.714	77.6952
9	02-LgCom			76				
10	2602 13	0	999,999,999	2	131	168.779	85.793	50.8316
11	2612 11	200	999,999,999	1	276	276.480	191.160	69.1406
12	02-LgInd			3				
13	SC2			683				

Footnotes:

Col (9): Equal to 100 * (Col (8) / Col (7))

Orange & Rockland Utilities, Inc - Electric
Report 3 - Estimated Class Demand Data
Class - SC2 - Winter - 2019

Line No	Sample Strata	Stratification Variable pk mo kW (2102,2302,2602) max ann kW (2322,2612)		Est Avg No of Custs	Total Annual kWh	Avg Annual Use Per Cust	Est Non- Coin kW Per Cust	Est Popul Non- Coin kW	Coincidence Factor Percentage	Est Popul Coin kW for Individual Strata
(1)	(2)	Low (3)	High (4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)
1	2102 09	0	6	13,570	89,919,530	6,626		39,186	52.0990	20,416
2	2102 10	7	16	6,764	148,710,028	21,986		57,639	59.0424	34,031
3	2102 11	17	35	2,856	171,097,364	59,908		49,643	61.8931	30,726
4	2102 12	36	80	991	147,157,627	148,494		38,728	81.8660	31,705
5	2102 13	81	999,999,999	365	137,582,433	376,938		32,813	76.2326	25,014
6	02-GenSmallSec			24,546	694,466,982			218,009		141,892
7	2302 13	0	999,999,999	94	44,751,651	476,081		10,483	77.4640	8,121
8	2322 99	200	999,999,999	59	100,502,730	1,703,436		19,677	77.6952	15,288
9	02-LgCom			153	145,254,381			30,160		23,409
10	2602 13	0	999,999,999	4	1,383,354	345,839		421	50.8316	214
11	2612 11	200	999,999,999	1	977,462	977,462		307	69.1406	212
12	02-LgInd			5	2,360,816			728		426
13	SC2			24,704	842,082,179			248,897		165,727

Footnotes:

Col (7): Equal to Col (6) / Col (5)

Col (8): For non-demand metered classes, from relationship of sampled energy and demand values, applied to population energy usage

Col (9): Equal to Cols (5) * (8) or Billing Demand

Col (10): From Report 2

Col (11): Equal to Col (9) * (Col (10) / 100)

Orange & Rockland Utilities, Inc - Electric
Report 4 - Estimated Class Demand Data
Class - SC2 - Winter - 2019

Line No	Sample Strata	4 Hour Demands-kW							
		Stratification Variable pk mo kW (2102,2302,2602) max ann kW (2322,2612)		Half Hour kW at Time of Class Peak Unadj at Cust	Unadjusted at the Customer	Adjusted at the Customer	Unadjusted at System Input	Adjusted at System Input	System Peak Respblty
		Low	High						
		(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)
1	2102 09	0	6	19,027	18,776	17,734	20,453	19,318	20,837
2	2102 10	7	16	33,607	33,334	31,483	36,311	34,295	27,037
3	2102 11	17	35	30,726	29,975	28,310	32,652	30,838	27,402
4	2102 12	36	80	30,752	30,864	29,149	33,621	31,753	23,264
5	2102 13	81	999,999,999	25,014	24,462	23,105	26,647	25,169	21,458
6	02-GenSmallSec			139,126	137,411	129,781	149,684	141,373	119,998
7	2302 13	0	999,999,999	7,994	7,973	7,531	8,685	8,204	7,627
8	2322 99	200	999,999,999	15,250	15,120	15,120	16,471	16,471	15,585
9	02-LgCom			23,244	23,093	22,651	25,156	24,675	23,212
10	2602 13	0	999,999,999	163	175	165	190	180	201
11	2612 11	200	999,999,999	193	198	198	215	215	151
12	02-LgInd			356	373	363	405	395	352
13	SC2			162,726	160,877	152,795	175,245	166,443	143,562

Footnotes:

Col (5): Class Peak at 12:00pm

Col (6): Class 4 hour peak from 10:30am-2:00pm

Col (7): Adjusted sum of component loads equals system loads

Col (8): Equal to (Col (6) / Efficiency Factor of 91.800000000) * 100

Col (9): Equal to (Col (7) / Efficiency Factor of 91.800000000) * 100

Col (10): System Peak Responsibility from 5:30pm-9:00pm

Orange & Rockland Utilities, Inc - Electric
 Report 2 - Sample Test Customer Data
 Class - SC2_SM_Pri - Winter - 2019

Line No	Sample Strata	Stratification Variable		No of Test Customers	Strat Var Avg Per Test Cust	Avg Non-Coin kW Per Cust	Avg Coin kW Per Cust	Coincidence Factor Percentage
		pk mo kW (2202) max ann kW(2712)						
(1)	(2)	Low (3)	High (4)	(5)	(6)	(7)	(8)	(9)
1	2202 09	0	6	6	1	29.131	23.953	82.2251
2	2202 10	7	16	9	11	13.028	6.284	48.2346
3	2202 11	17	35	9	25	38.891	29.652	76.2439
4	2202 12	36	80	28	60	63.235	46.512	73.5542
5	2202 13	81	999,999,999	18	117	111.810	69.046	61.7530
6	2712 99	200	999,999,999	5	479	460.618	397.852	86.3735
7	02-GenSmall			75				
8	SC2_SM_Pri			75				

Footnotes:

Col (9): Equal to 100 * (Col (8) / Col (7))

Orange & Rockland Utilities, Inc - Electric
Report 3 - Estimated Class Demand Data
Class - SC2_SM_Pri - Winter - 2019

Line No	Sample Strata	Stratification Variable pk mo kW (2202) max ann kW(2712)		Est Avg No of Custs	Total Annual kWh	Avg Annual Use Per Cust	Est Non-Coin kW Per Cust	Est Popul Non-Coin kW	Coincidence Factor Percentage	Est Popul Coin kW for Individual Strata
(1)	(2)	Low (3)	High (4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)
1	2202 09	0	6	22	886,127	40,279		242	82.2251	199
2	2202 10	7	16	24	1,031,989	43,000		301	48.2346	145
3	2202 11	17	35	27	2,947,321	109,160		879	76.2439	670
4	2202 12	36	80	56	12,611,773	225,210		3,280	73.5542	2,413
5	2202 13	81	999,999,999	51	18,840,037	369,412		4,659	61.7530	2,877
6	2712 99	200	999,999,999	7	14,004,602	2,000,657		2,620	86.3735	2,263
7	02-GenSmall			187	50,321,849			11,981		8,567
8	SC2_SM_Pri			187	50,321,849			11,981		8,567

Footnotes:

Col (7): Equal to Col (6) / Col (5)

Col (8): For non-demand metered classes, from relationship of sampled energy and demand values, applied to population energy usage

Col (9): Equal to Cols (5) * (8) or Billing Demand

Col (10): From Report 2

Col (11): Equal to Col (9) * (Col (10) / 100)

Orange & Rockland Utilities, Inc - Electric
 Report 4 - Estimated Class Demand Data
 Class - SC2_SM_Pri - Winter - 2019

Line No	Sample Strata	4 Hour Demands-kW							
		Stratification Variable		Half Hour kW at Time of Class Peak Unadj at Cust	Unadjusted at the Customer	Adjusted at the Customer	Unadjusted at System Input	Adjusted at System Input	System Peak Respbilty
		pk mo kW (2202)	max ann kW(2712)						
(1)	(2)	Low (3)	High (4)	(5)	(6)	(7)	(8)	(9)	(10)
1	2202 09	0	6	196	197	187	211	200	189
2	2202 10	7	16	131	132	126	142	135	145
3	2202 11	17	35	670	647	614	694	659	566
4	2202 12	36	80	2,381	2,379	2,259	2,553	2,424	2,251
5	2202 13	81	999,999,999	2,866	2,842	2,698	3,049	2,894	2,694
6	2712 99	200	999,999,999	2,187	2,205	2,093	2,366	2,246	2,160
7	02-GenSmall			8,431	8,402	7,977	9,015	8,558	8,005
8	SC2_SM_Pri			8,431	8,402	7,977	9,015	8,558	8,005

Footnotes:

Col (5): Class Peak at 10:30am

Col (6): Class 4 hour peak from 9:30am-1:00pm

Col (7): Adjusted sum of component loads equals system loads

Col (8): Equal to (Col (6) / Efficiency Factor of 93.200000000) * 100

Col (9): Equal to (Col (7) / Efficiency Factor of 93.200000000) * 100

Col (10): System Peak Responsibility from 5:30pm-9:00pm

Orange & Rockland Utilities, Inc - Electric
 Report 2 - Sample Test Customer Data
 Class - SC2_SMSH - Winter - 2019

Line No	Sample Strata	Stratification Variable pk mo kWh		No of Test Customers	Strat Var Avg Per Test Cust	Avg Non-Coin kW Per Cust	Avg Coin kW Per Cust	Coincidence Factor Percentage
(1)	(2)	Low (3)	High (4)	(5)	(6)	(7)	(8)	(9)
1	2402 14	0	4,000	93	1,090	14.058	8.650	61.5308
2	2402 15	4,001	20,000	13	8,584	23.729	17.625	74.2762
3	2402 16	20,001	100,000	5	41,768	191.323	166.395	86.9707
4	02-CI SepMtrSpHt10kW			111				
5	SC2_SMSH			111				

Footnotes:

Col (9): Equal to 100 * (Col (8) / Col (7))

Orange & Rockland Utilities, Inc - Electric
 Report 3 - Estimated Class Demand Data
 Class - SC2_SMSH - Winter - 2019

Line No	Sample Strata		Stratification Variable		Est Avg No of Custs	Total Annual kWh	Avg Annual Use Per Cust	Est Non-Coin kW Per Cust	Est Popul Non- Coin kW	Coincidence Factor Percentage	Est Popul Coin kW for Individual Strata
			Low (3)	High (4)							
(1)	(2)		(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)
1	2402	14	0	4,000	287	4,866,840	16,958	13.253	3,804	61.5308	2,341
2	2402	15	4,001	20,000	46	4,259,920	92,607	28.147	1,295	74.2762	962
3	2402	16	20,001	100,000	16	8,466,169	529,136	180.846	2,894	86.9707	2,517
4	02-CI SepMtrSpHt10kW				349	17,592,929			7,993		5,820
5	SC2_SMSH				349	17,592,929			7,993		5,820

Footnotes:

Col (7): Equal to Col (6) / Col (5)

Col (8): For non-demand metered classes, from relationship of sampled energy and demand values, applied to population energy usage

Col (9): Equal to Cols (5) * (8) or Billing Demand

Col (10): From Report 2

Col (11): Equal to Col (9) * (Col (10) / 100)

Orange & Rockland Utilities, Inc - Electric
 Report 4 - Estimated Class Demand Data
 Class - SC2_SMSH - Winter - 2019

Line No	Sample Strata	4 Hour Demands-kW							
		Stratification Variable pk mo kWh		Half Hour kW at Time of Class Peak Unadj at Cust	Unadjusted at the Customer	Adjusted at the Customer	Unadjusted at System Input	Adjusted at System Input	System Peak Respbilty
		Low (3)	High (4)						
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)
1	2402 14	0	4,000	2,270	2,233	2,156	2,433	2,349	1,719
2	2402 15	4,001	20,000	942	939	907	1,023	988	967
3	2402 16	20,001	100,000	2,500	2,408	2,326	2,624	2,534	2,283
4	02-CI SepMtrSpHt10kW			5,712	5,580	5,389	6,080	5,871	4,969
5	SC2_SMSH			5,712	5,580	5,389	6,080	5,871	4,969

Footnotes:

Col (5): Class Peak at 8:00am

Col (6): Class 4 hour peak from 7:00am-10:30am

Col (7): Adjusted sum of component loads equals system loads

Col (8): Equal to (Col (6) / Efficiency Factor of 91.800000000) * 100

Col (9): Equal to (Col (7) / Efficiency Factor of 91.800000000) * 100

Col (10): System Peak Responsibility from 5:30pm-9:00pm

Orange & Rockland Utilities, Inc - Electric
 Report 2 - Sample Test Customer Data
 Class - SC2_SNMT - Winter - 2019

Line No	Sample Strata		Stratification Variable		No of Test Customers	Strat Var Avg Per Test Cust	Avg Non-Coin kW Per Cust	Avg Coin kW Per Cust	Coincidence Factor Percentage
			Low pk mo kWh	High pk mo kWh					
(1)	(2)		(3)	(4)	(5)	(6)	(7)	(8)	(9)
1	2802	25	0	999,999,999	1	967,313	0.614	0.595	96.9055
2	2902	18	0	150	344	68	0.696	0.227	32.6149
3	2902	19	151	500	183	283	1.870	0.592	31.6578
4	2902	20	501	999,999,999	36	617	1.960	0.746	38.0612
5	02-GenSmall				564				
6	SC2_SNMT				564				

Footnotes:

Col (9): Equal to 100 * (Col (8) / Col (7))

Orange & Rockland Utilities, Inc - Electric
Report 3 - Estimated Class Demand Data
Class - SC2_SNMT - Winter - 2019

Line No	Sample Strata		Stratification Variable pk mo kWh		Est Avg No of Custs	Total Annual kWh	Avg Annual Use Per Cust	Est Non-Coin kW Per Cust	Est Popul Non-Coin kW	Coincidence Factor Percentage	Est Popul Coin kW for Individual Strata
(1)	(2)		Low (3)	High (4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)
1	2802	25	0	999,999,999	2,253	11,723,912	5,204	0.617	1,390	96.9055	1,347
2	2902	18	0	150	1,671	1,400,962	838	0.594	993	32.6149	324
3	2902	19	151	500	599	1,880,831	3,140	1.859	1,114	31.6578	353
4	2902	20	501	999,999,999	90	504,008	5,600	1.984	179	38.0612	68
5	02-GenSmall				4,613	15,509,713			3,676		2,092
6	SC2_SNMT				4,613	15,509,713			3,676		2,092

Footnotes:

Col (7): Equal to Col (6) / Col (5)

Col (8): For non-demand metered classes, from relationship of sampled energy and demand values, applied to population energy usage

Col (9): Equal to Cols (5) * (8) or Billing Demand

Col (10): From Report 2

Col (11): Equal to Col (9) * (Col (10) / 100)

Orange & Rockland Utilities, Inc - Electric
Report 4 - Estimated Class Demand Data
Class - SC2_SNMT - Winter - 2019

Line No	Sample Strata		Stratification Variable pk mo kWh		Half Hour kW at Time of Class Peak Unadj at Cust	4 Hour Demands-kW				
						Unadjusted at the Customer	Adjusted at the Customer	Unadjusted at System Input	Adjusted at System Input	System Peak Respbilty
			Low (3)	High (4)		(6)	(7)	(8)	(9)	(10)
1	2802	25	0	999,999,999	1,347	1,347	1,332	1,463	1,446	1,410
2	2902	18	0	150	310	313	309	340	336	330
3	2902	19	151	500	281	293	290	318	315	338
4	2902	20	501	999,999,999	60	62	61	67	66	69
5	02-GenSmall				1,998	2,015	1,992	2,188	2,163	2,147
6	SC2_SNMT				1,998	2,015	1,992	2,188	2,163	2,147

Footnotes:

Col (5): Class Peak at 12:00pm

Col (6): Class 4 hour peak from 8:30pm-12:00pm

Col (7): Adjusted sum of component loads equals system loads

Col (8): Equal to (Col (6) / Efficiency Factor of 92.100000000) * 100

Col (9): Equal to (Col (7) / Efficiency Factor of 92.100000000) * 100

Col (10): System Peak Responsibility from 5:30pm-9:00pm

Orange & Rockland Utilities, Inc - Electric
 Report 2 - Sample Test Customer Data
 Class - SC3 - Winter - 2019

Line No	Sample Strata	Stratification Variable pk mo kW (3203,3503,3423) max ann kW (3253,3553,3753)		No of Test Customers	Strat Var Avg Per Test Cust	Avg Non-Coin kW Per Cust	Avg Coin kW Per Cust	Coincidence Factor Percentage
		Low (3)	High (4)					
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)
1	3203 21	0	999,999,999	16	144	128.682	92.575	71.9409
2	3253 99	200	999,999,999	14	399	302.109	246.585	81.6212
3	03-GenSmall			30				
4	3503 22	0	999,999,999	30	173	155.581	111.981	71.9760
5	3553 99	200	999,999,999	119	409	331.814	262.946	79.2450
6	03-LgComm			149				
7	3423 23	0	999,999,999	5	192	173.734	144.022	82.8980
8	3753 99	200	999,999,999	15	428	371.646	305.549	82.2151
9	03-LgIndPri			20				
10	SC3			199				

Footnotes:

Col (9): Equal to 100 * (Col (8) / Col (7))

Orange & Rockland Utilities, Inc - Electric
Report 3 - Estimated Class Demand Data
Class - SC3 - Winter - 2019

Line No	Sample Strata		Stratification Variable		Est Avg No of Custs	Total Annual kWh	Avg Annual Use Per Cust	Est Non- Coin kW Per Cust	Est Popul Non- Coin kW	Coincidence Factor Percentage	Est Popul Coin kW for Individual Strata
			pk mo kW (3203,3503,3423) max ann kW (3253,3553,3753)								
(1)	(2)		Low (3)	High (4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)
1	3203 21		0	999,999,999	37	20,554,355	555,523		5,020	71.9409	3,611
2	3253 99		200	999,999,999	14	25,908,371	1,850,598		4,762	81.6212	3,887
3	03-GenSmall				51	46,462,726			9,782		7,498
4	3503 22		0	999,999,999	63	46,461,916	737,491		10,551	71.9760	7,594
5	3553 99		200	999,999,999	120	228,027,238	1,900,227		45,352	79.2450	35,939
6	03-LgComm				183	274,489,154			55,903		43,533
7	3423 23		0	999,999,999	10	7,101,149	710,115		1,950	82.8980	1,617
8	3753 99		200	999,999,999	15	29,377,250	1,958,483		6,435	82.2151	5,291
9	03-LgIndPri				25	36,478,399			8,385		6,908
10	SC3				259	357,430,279			74,070		57,939

Footnotes:

Col (7): Equal to Col (6) / Col (5)

Col (8): For non-demand metered classes, from relationship of sampled energy and demand values, applied to population energy usage

Col (9): Equal to Cols (5) * (8) or Billing Demand

Col (10): From Report 2

Col (11): Equal to Col (9) * (Col (10) / 100)

Orange & Rockland Utilities, Inc - Electric
Report 4 - Estimated Class Demand Data
Class - SC3 - Winter - 2019

Line No	Sample Strata	4 Hour Demands-kW							
		Stratification Variable pk mo kW (3203,3503,3423) max ann kW (3253,3553,3753)		Half Hour kW at Time of Class Peak Unadj at Cust	Unadjusted at the Customer	Adjusted at the Customer	Unadjusted at System Input	Adjusted at System Input	System Peak Respbilty
		Low (3)	High (4)						
		(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)
1	3203 21	0	999,999,999	3,611	3,543	3,355	3,802	3,599	3,223
2	3253 99	200	999,999,999	3,831	3,826	3,826	4,105	4,105	3,517
3	03-GenSmall			7,442	7,369	7,181	7,907	7,704	6,740
4	3503 22	0	999,999,999	7,501	7,463	7,064	8,007	7,580	6,864
5	3553 99	200	999,999,999	35,939	35,661	35,661	38,263	38,263	35,505
6	03-LgComm			43,440	43,124	42,725	46,270	45,843	42,369
7	3423 23	0	999,999,999	1,576	1,556	1,472	1,669	1,580	1,365
8	3753 99	200	999,999,999	5,267	5,223	5,223	5,605	5,605	4,513
9	03-LgIndPri			6,843	6,779	6,695	7,274	7,185	5,878
10	SC3			57,725	57,272	56,601	61,451	60,732	54,987

Footnotes:

Col (5): Class Peak at 11:00am

Col (6): Class 4 hour peak from 10:00am-1:30pm

Col (7): Adjusted sum of component loads equals system loads

Col (8): Equal to (Col (6) / Efficiency Factor of 93.200000000) * 100

Col (9): Equal to (Col (7) / Efficiency Factor of 93.200000000) * 100

Col (10): System Peak Responsibility from 5:30pm-9:00pm

Orange & Rockland Utilities, Inc - Electric
 Report 2 - Sample Test Customer Data
 Class - SC4 - Winter - 2019

Line No	Sample Strata	Stratification Variable pk mo kWh		No of Test Customers	Strat Var Avg Per Test Cust	Avg Non- Coin kW Per Cust	Avg Coin kW Per Cust	Coincidence Factor Percentage
(1)	(2)	Low (3)	High (4)	(5)	(6)	(7)	(8)	(9)
1	4104 24	0	999,999,999	1	173,495	43.785	43.785	100.0000
2	04-MunStreetLights			1				
3	SC4			1				

Footnotes:

Col (9): Equal to 100 * (Col (8) / Col (7))

Orange & Rockland Utilities, Inc - Electric
 Report 3 - Estimated Class Demand Data
 Class - SC4 - Winter - 2019

Line No	Sample Strata	Stratification Variable pk mo kWh		Est Avg No of Custs	Total Annual kWh	Avg Annual Use Per Cust	Est Non- Coin kW Per Cust	Est Popul Non- Coin kW	Coincidence Factor Percentage	Est Popul Coin kW for Individual Strata
(1)	(2)	Low (3)	High (4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)
1	4104 24	0	999,999,999	70	11,732,153	167,602	43.938	3,076	100.0000	3,076
2	04-MunStreetLights			70	11,732,153			3,076		3,076
3	SC4			70	11,732,153			3,076		3,076

Footnotes:

Col (7): Equal to Col (6) / Col (5)

Col (8): For non-demand metered classes, from relationship of sampled energy and demand values, applied to population energy usage

Col (9): Equal to Cols (5) * (8) or Billing Demand

Col (10): From Report 2

Col (11): Equal to Col (9) * (Col (10) / 100)

Orange & Rockland Utilities, Inc - Electric
 Report 4 - Estimated Class Demand Data
 Class - SC4 - Winter - 2019

Line No	Sample Strata	Stratification Variable pk mo kWh		Half Hour kW at Time of Class Peak Unadj at Cust	4 Hour Demands-kW				
					Unadjusted at the Customer	Adjusted at the Customer	Unadjusted at System Input	Adjusted at System Input	System Peak Respblty
(1)	(2)	Low (3)	High (4)	(5)	(6)	(7)	(8)	(9)	(10)
1	4104 24	0	999,999,999	3,076	3,076	3,076	3,336	3,336	3,262
2	04-MunStreetLights			3,076	3,076	3,076	3,336	3,336	3,262
3	SC4			3,076	3,076	3,076	3,336	3,336	3,262

Footnotes:

Col (5): Class Peak at 12:30am

Col (6): Class 4 hour peak from 12:30am-4:00am

Col (7): Adjusted sum of component loads equals system loads

Col (8): Equal to (Col (6) / Efficiency Factor of 92.200000000) * 100

Col (9): Equal to (Col (7) / Efficiency Factor of 92.200000000) * 100

Col (10): System Peak Responsibility from 5:30pm-9:00pm

Orange & Rockland Utilities, Inc - Electric
 Report 2 - Sample Test Customer Data
 Class - SC5 - Winter - 2019

Line No	Sample Strata	Stratification Variable		No of Test Customers	Strat Var Avg Per Test Cust	Avg Non-Coin kW Per Cust	Avg Coin kW Per Cust	Coincidence Factor Percentage
		Low (3)	High (4)					
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)
1	5105 26	0	999,999,999	6	836	0.271	0.265	97.7860
2	05-TrafficLights			6				
3	SC5			6				

Footnotes:

Col (9): Equal to 100 * (Col (8) / Col (7))

Orange & Rockland Utilities, Inc - Electric
 Report 3 - Estimated Class Demand Data
 Class - SC5 - Winter - 2019

Line No	Sample Strata	Stratification Variable pk mo kWh		Est Avg No of Custs	Total Annual kWh	Avg Annual Use Per Cust	Est Non- Coin kW Per Cust	Est Popul Non-Coin kW	Coincidence Factor Percentage	Est Popul Coin kW for Individual Strata
(1)	(2)	Low (3)	High (4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)
1	5105 26	0	999,999,999	502	2,249,389	4,481	0.515	259	97.7860	253
2	05-TrafficLights			502	2,249,389			259		253
3	SC5			502	2,249,389			259		253

Footnotes:

Col (7): Equal to Col (6) / Col (5)

Col (8): For non-demand metered classes, from relationship of sampled energy and demand values, applied to population energy usage

Col (9): Equal to Cols (5) * (8) or Billing Demand

Col (10): From Report 2

Col (11): Equal to Col (9) * (Col (10) / 100)

Orange & Rockland Utilities, Inc - Electric
Report 4 - Estimated Class Demand Data
Class - SC5 - Winter - 2019

Line No	Sample Strata	Stratification Variable		Half Hour kW at Time of Class Peak Unadj at Cust	4 Hour Demands-kW				
		pk	mo kWh		Unadjusted at the Customer	Adjusted at the Customer	Unadjusted at System Input	Adjusted at System Input	System Peak Respblty
		Low	High						
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)
1	5105 26	0	999,999,999	253	252	252	274	274	273
2	05-TrafficLights			253	252	252	274	274	273
3	SC5			253	252	252	274	274	273

Footnotes:

Col (5): Class Peak at 7:30am

Col (6): Class 4 hour peak from 6:30am-10:00am

Col (7): Adjusted sum of component loads equals system loads

Col (8): Equal to (Col (6) / Efficiency Factor of 92.200000000) * 100

Col (9): Equal to (Col (7) / Efficiency Factor of 92.200000000) * 100

Col (10): System Peak Responsibility from 5:30pm-9:00pm

Orange & Rockland Utilities, Inc - Electric
 Report 2 - Sample Test Customer Data
 Class - SC6 - Winter - 2019

Line No	Sample Strata	Stratification Variable pk mo kWh		No of Test Customers	Strat Var Avg Per Test Cust	Avg Non-Coin kW Per Cust	Avg Coin kW Per Cust	Coincidence Factor Percentage
		Low (3)	High (4)					
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)
1	6136 26	0	999,999,999	3	138,212	31.686	31.538	99.5329
2	06-MunOwnLights			3				
3	SC6			3				

Footnotes:

Col (9): Equal to 100 * (Col (8) / Col (7))

Orange & Rockland Utilities, Inc - Electric
 Report 3 - Estimated Class Demand Data
 Class - SC6 - Winter - 2019

Line No	Sample Strata	Stratification Variable pk mo kWh		Est Avg No of Custs	Total Annual kWh	Avg Annual Use Per Cust	Est Non- Coin kW Per Cust	Est Popul Non- Coin kW	Coincidence Factor Percentage	Est Popul Coin kW for Individual Strata
(1)	(2)	Low (3)	High (4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)
1	6136 26	0	999,999,999	7	3,065,945	437,992	92.963	651	99.5329	648
2	06-MunOwnLights			7	3,065,945			651		648
3	SC6			7	3,065,945			651		648

Footnotes:

Col (7): Equal to Col (6) / Col (5)

Col (8): For non-demand metered classes, from relationship of sampled energy and demand values, applied to population energy usage

Col (9): Equal to Cols (5) * (8) or Billing Demand

Col (10): From Report 2

Col (11): Equal to Col (9) * (Col (10) / 100)

Orange & Rockland Utilities, Inc - Electric
Report 4 - Estimated Class Demand Data
Class - SC6 - Winter - 2019

Line No	Sample Strata	Stratification Variable		Half Hour kW at Time of Class Peak Unadj at Cust	4 Hour Demands-kW				
		pk mo kWh			Unadjusted at the Customer	Adjusted at the Customer	Unadjusted at System Input	Adjusted at System Input	System Peak Respblty
		Low	High						
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)
1	6136 26	0	999,999,999	648	647	647	701	701	685
2	06-MunOwnLights			648	647	647	701	701	685
3	SC6			648	647	647	701	701	685

Footnotes:

Col (5): Class Peak at 5:00am

Col (6): Class 4 hour peak from 1:30am-5:00am

Col (7): Adjusted sum of component loads equals system loads

Col (8): Equal to (Col (6) / Efficiency Factor of 92.200000000) * 100

Col (9): Equal to (Col (7) / Efficiency Factor of 92.200000000) * 100

Col (10): System Peak Responsibility from 5:30pm-9:00pm

Orange & Rockland Utilities, Inc - Electric
 Report 2 - Sample Test Customer Data
 Class - SC9 - Winter - 2019

Line No	Sample Strata	Stratification Variable pk mo kW		No of Test Customers	Strat Var Avg Per Test Cust	Avg Non-Coin kW Per Cust	Avg Coin kW Per Cust	Coincidence Factor Percentage
		Low (3)	High (4)					
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)
1	9110 90	0	999,999,999	36	1,192	959.850	748.319	77.9621
2	09-CommPri			36				
3	9838 90	0	999,999,999	1	2,195	1,767.840	1,700.784	96.2069
4	09-CommSub			1				
5	9848 90	0	999,999,999	1	1,352	1,660.050	1,555.680	93.7128
6	09-CommTrans			1				
7	SC9			38				

Footnotes:

Col (9): Equal to 100 * (Col (8) / Col (7))

Orange & Rockland Utilities, Inc - Electric
 Report 3 - Estimated Class Demand Data
 Class - SC9 - Winter - 2019

Line No	Sample Strata	Stratification Variable pk mo kW		Est Avg No of Custs	Total Annual kWh	Avg Annual Use Per Cust	Est Non-Coin kW Per Cust	Est Popul Non-Coin kW	Coincidence Factor Percentage	Est Popul Coin kW for Individual Strata
(1)	(2)	Low (3)	High (4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)
1	9110 90	0	999,999,999	42	262,412,790	6,247,924		42,405	77.9621	33,060
2	09-CommPri			42	262,412,790			42,405		33,060
3	9838 90	0	999,999,999	8	182,111,796	22,763,975		24,299	96.2069	23,377
4	09-CommSub			8	182,111,796			24,299		23,377
5	9848 90	0	999,999,999	1	10,121,397	10,121,397		1,720	93.7128	1,612
6	09-CommTrans			1	10,121,397			1,720		1,612
7	SC9			51	454,645,983			68,424		58,049

Footnotes:

Col (7): Equal to Col (6) / Col (5)

Col (8): For non-demand metered classes, from relationship of sampled energy and demand values, applied to population energy usage

Col (9): Equal to Cols (5) * (8) or Billing Demand

Col (10): From Report 2

Col (11): Equal to Col (9) * (Col (10) / 100)

Orange & Rockland Utilities, Inc - Electric
Report 4 - Estimated Class Demand Data
Class - SC9 - Winter - 2019

Line No	Sample Strata	4 Hour Demands-kW							
		Stratification Variable		Half Hour kW at Time of Class Peak Unadj at Cust	Unadjusted at the Customer	Adjusted at the Customer	Unadjusted at System Input	Adjusted at System Input	System Peak Respbilty
		Low (3)	High (4)						
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)
1	9110 90	0	999,999,999	32,313	32,313	30,877	34,157	32,639	31,527
2	09-CommPri			32,313	32,313	30,877	34,157	32,639	31,527
3	9838 90	0	999,999,999	23,377	22,382	21,395	23,660	22,616	19,140
4	09-CommSub			23,377	22,382	21,395	23,660	22,616	19,140
5	9848 90	0	999,999,999	1,576	1,586	1,586	1,677	1,677	1,577
6	09-CommTrans			1,576	1,586	1,586	1,677	1,677	1,577
7	SC9			57,266	56,281	53,858	59,494	56,932	52,244

Footnotes:

Col (5): Class Peak at 9:30am

Col (6): Class 4 hour peak from 8:30am-12:00pm

Col (7): Adjusted sum of component loads equals system loads

Col (8): Equal to (Col (6) / Efficiency Factor of 94.600000000) * 100

Col (9): Equal to (Col (7) / Efficiency Factor of 94.600000000) * 100

Col (10): System Peak Responsibility from 5:30pm-9:00pm

Orange & Rockland Utilities, Inc - Electric
 Report 2 - Sample Test Customer Data
 Class - SC11 - Winter - 2019

Line No	Sample Strata	Stratification Variable pk mo kWh		No of Test Customers	Strat Var Avg Per Test Cust	Avg Non-Coin kW Per Cust	Avg Coin kW Per Cust	Coincidence Factor Percentage
(1)	(2)	Low (3)	High (4)	(5)	(6)	(7)	(8)	(9)
1	11111 111	0	999,999,999	1	17,613	13,882.080	12,686.880	91.3903
2	11-WEST_POINT			1				
3	SC11			1				

Footnotes:

Col (9): Equal to 100 * (Col (8) / Col (7))

Orange & Rockland Utilities, Inc - Electric
 Report 3 - Estimated Class Demand Data
 Class - SC11 - Winter - 2019

Line No	Sample Strata	Stratification Variable pk mo kWh		Est Avg No of Custs	Total Annual kWh	Avg Annual Use Per Cust	Est Non- Coin kW Per Cust	Est Popul Non- Coin kW	Coincidence Factor Percentage	Est Popul Coin kW for Individual Strata
(1)	(2)	Low (3)	High (4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)
1	11111 111	0	999,999,999	1	97,560,556	97,560,556		13,865	91.3903	12,671
2	11-WEST_POINT			1	97,560,556			13,865		12,671
3	SC11			1	97,560,556			13,865		12,671

Footnotes:

Col (7): Equal to Col (6) / Col (5)

Col (8): For non-demand metered classes, from relationship of sampled energy and demand values, applied to population energy usage

Col (9): Equal to Cols (5) * (8) or Billing Demand

Col (10): From Report 2

Col (11): Equal to Col (9) * (Col (10) / 100)

Orange & Rockland Utilities, Inc - Electric
 Report 4 - Estimated Class Demand Data
 Class - SC11 - Winter - 2019

Line No	Sample Strata	4 Hour Demands-kW							
		Stratification Variable		Half Hour kW at Time of Class Peak Unadj at Cust	Unadjusted at the Customer	Adjusted at the Customer	Unadjusted at System Input	Adjusted at System Input	System Peak Respblty
		Low pk mo kWh	High pk mo kWh						
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)
1	11111 111	0	999,999,999	12,671	12,347	12,347	13,248	13,248	13,039
2	11-WEST_POINT			12,671	12,347	12,347	13,248	13,248	13,039
3	SC11			12,671	12,347	12,347	13,248	13,248	13,039

Footnotes:

Col (5): Class Peak at 6:00pm

Col (6): Class 4 hour peak from 3:30pm-7:00pm

Col (7): Adjusted sum of component loads equals system loads

Col (8): Equal to (Col (6) / Efficiency Factor of 93.200000000) * 100

Col (9): Equal to (Col (7) / Efficiency Factor of 93.200000000) * 100

Col (10): System Peak Responsibility from 5:30pm-9:00pm

Orange & Rockland Utilities, Inc - Electric
 Report 2 - Sample Test Customer Data
 Class - SC16_PriD2d - Winter - 2019

Line No	Sample Strata	Stratification Variable pk mo kWh		No of Test Customers	Strat Var Avg Per Test Cust	Avg Non-Coin kW Per Cust	Avg Coin kW Per Cust	Coincidence Factor Percentage
		Low (3)	High (4)					
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)
1	16212 24	0	999,999,999	1	4,326	1.117	1.117	100.0000
2	16-PriOverD2D			1				
3	SC16_PriD2d			1				

Footnotes:

Col (9): Equal to 100 * (Col (8) / Col (7))

Orange & Rockland Utilities, Inc - Electric
 Report 3 - Estimated Class Demand Data
 Class - SC16_PriD2d - Winter - 2019

Line No	Sample Strata	Stratification Variable pk mo kWh		Est Avg No of Custs	Total Annual kWh	Avg Annual Use Per Cust	Est Non- Coin kW Per Cust	Est Popul Non-Coin kW	Coincidence Factor Percentage	Est Popul Coin kW for Individual Strata
(1)	(2)	Low (3)	High (4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)
1	16212 24	0	999,999,999	2,312	9,762,617	4,223	1.115	2,578	100.0000	2,578
2	16-PriOverD2D			2,312	9,762,617			2,578		2,578
3	SC16_PriD2d			2,312	9,762,617			2,578		2,578

Footnotes:

Col (7): Equal to Col (6) / Col (5)

Col (8): For non-demand metered classes, from relationship of sampled energy and demand values, applied to population energy usage

Col (9): Equal to Cols (5) * (8) or Billing Demand

Col (10): From Report 2

Col (11): Equal to Col (9) * (Col (10) / 100)

Orange & Rockland Utilities, Inc - Electric
 Report 4 - Estimated Class Demand Data
 Class - SC16_PriD2d - Winter - 2019

Line No	Sample Strata	Stratification Variable		Half Hour kW at Time of Class Peak Unadj at Cust	4 Hour Demands-kW				
					pk mo kWh	Unadjusted at the Customer	Adjusted at the Customer	Unadjusted at System Input	Adjusted at System Input
		Low	High						
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)
1	16212 24	0	999,999,999	2,578	2,578	2,578	2,796	2,796	2,734
2	16-PriOverD2D			2,578	2,578	2,578	2,796	2,796	2,734
3	SC16 PriD2d			2,578	2,578	2,578	2,796	2,796	2,734

Footnotes:

Col (5): Class Peak at 12:30am

Col (6): Class 4 hour peak from 12:30am-4:00am

Col (7): Adjusted sum of component loads equals system loads

Col (8): Equal to (Col (6) / Efficiency Factor of 92.200000000) * 100

Col (9): Equal to (Col (7) / Efficiency Factor of 92.200000000) * 100

Col (10): System Peak Responsibility from 5:30pm-9:00pm

Orange & Rockland Utilities, Inc - Electric
 Report 2 - Sample Test Customer Data
 Class - SC16_Enoly - Winter - 2019

Line No	Sample Strata	Stratification Variable pk mo kWh		No of Test Customers	Strat Var Avg Per Test Cust	Avg Non-Coin kW Per Cust	Avg Coin kW Per Cust	Coincidence Factor Percentage
		Low (3)	High (4)					
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)
1	16412 24	0	999,999,999	41	1,278	3.949	2.561	64.8519
2	16512 24	0	999,999,999	1	7,408	0.874	0.847	96.9108
3	16-EngyOnlyLght			42				
4	SC16_Enoly			42				

Footnotes:

Col (9): Equal to 100 * (Col (8) / Col (7))

Orange & Rockland Utilities, Inc - Electric
 Report 3 - Estimated Class Demand Data
 Class - SC16_Enoly - Winter - 2019

Line No	Sample Strata	Stratification Variable pk mo kWh		Est Avg No of Custs	Total Annual kWh	Avg Annual Use Per Cust	Est Non-Coin kW Per Cust	Est Popul Non-Coin kW	Coincidence Factor Percentage	Est Popul Coin kW for Individual Strata
(1)	(2)	Low (3)	High (4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)
1	16412 24	0	999,999,999	353	2,355,096	6,672	1.926	680	64.8519	441
2	16512 24	0	999,999,999	78	577,789	7,408	0.871	68	96.9108	66
3	16-EngyOnlyLght			431	2,932,885			748		507
4	SC16_Enoly			431	2,932,885			748		507

Footnotes:

Col (7): Equal to Col (6) / Col (5)

Col (8): For non-demand metered classes, from relationship of sampled energy and demand values, applied to population energy usage

Col (9): Equal to Cols (5) * (8) or Billing Demand

Col (10): From Report 2

Col (11): Equal to Col (9) * (Col (10) / 100)

Orange & Rockland Utilities, Inc - Electric
 Report 4 - Estimated Class Demand Data
 Class - SC16_Enoly - Winter - 2019

Line No	Sample Strata	4 Hour Demands-kW							
		Stratification Variable		Half Hour kW at Time of Class Peak Unadj at Cust	Unadjusted at the Customer	Adjusted at the Customer	Unadjusted at System Input	Adjusted at System Input	System Peak Respblty
		Low (3)	High (4)						
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)
1	16412 24	0	999,999,999	439	430	420	466	455	435
2	16512 24	0	999,999,999	66	66	66	72	72	72
3	16-EngyOnlyLght			505	496	486	538	527	507
4	SC16_Enoly			505	496	486	538	527	507

Footnotes:

Col (5): Class Peak at 8:00pm

Col (6): Class 4 hour peak from 7:00pm-10:30pm

Col (7): Adjusted sum of component loads equals system loads

Col (8): Equal to (Col (6) / Efficiency Factor of 92.200000000) * 100

Col (9): Equal to (Col (7) / Efficiency Factor of 92.200000000) * 100

Col (10): System Peak Responsibility from 5:30pm-9:00pm

Orange & Rockland Utilities, Inc - Electric
 Report 2 - Sample Test Customer Data
 Class - SC19 - Winter - 2019

Line No	Sample Strata		Stratification Variable		No of Test Customers	Strat Var Avg Per Test Cust	Avg Non-Coin kW Per Cust	Avg Coin kW Per Cust	Coincidence Factor Percentage
			Low pk mo kWh	High pk mo kWh					
(1)	(2)		(3)	(4)	(5)	(6)	(7)	(8)	(9)
1	19318	01	0	600	70	369	4.475	1.410	31.5084
2	19318	02	601	1,200	109	888	4.865	1.586	32.6002
3	19318	03	1,201	2,000	114	1,582	5.636	2.102	37.2960
4	19318	04	2,001	3,800	214	2,785	7.199	2.760	38.3387
5	19318	05	3,801	999,999,999	86	5,738	12.761	6.012	47.1123
6	19-VolResidential				593				
7	SC19				593				

Footnotes:

Col (9): Equal to 100 * (Col (8) / Col (7))

Orange & Rockland Utilities, Inc - Electric
Report 3 - Estimated Class Demand Data
Class - SC19 - Winter - 2019

Line No	Sample Strata	Stratification Variable pk mo kWh		Est Avg No of Custs	Total Annual kWh	Avg Annual Use Per Cust	Est Non-Coin kW Per Cust	Est Popul Non-Coin kW	Coincidence Factor Percentage	Est Popul Coin kW for Individual Strata
(1)	(2)	Low (3)	High (4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)
1	19318 01	0	600	321	1,979,082	6,165	5.190	1,666	31.5084	525
2	19318 02	601	1,200	577	5,751,479	9,968	5.300	3,058	32.6002	997
3	19318 03	1,201	2,000	901	12,081,746	13,409	5.743	5,174	37.2960	1,930
4	19318 04	2,001	3,800	1,109	22,412,674	20,210	7.416	8,224	38.3387	3,153
5	19318 05	3,801	999,999,999	413	26,795,212	64,879	18.502	7,641	47.1123	3,600
6	19-VolResidential			3,321	69,020,193			25,763		10,205
7	SC19			3,321	69,020,193			25,763		10,205

Footnotes:

Col (7): Equal to Col (6) / Col (5)

Col (8): For non-demand metered classes, from relationship of sampled energy and demand values, applied to population energy usage

Col (9): Equal to Cols (5) * (8) or Billing Demand

Col (10): From Report 2

Col (11): Equal to Col (9) * (Col (10) / 100)

Orange & Rockland Utilities, Inc - Electric
Report 4 - Estimated Class Demand Data
Class - SC19 - Winter - 2019

Line No	Sample Strata	4 Hour Demands-kW							
		Stratification Variable		Half Hour kW at Time of Class Peak Unadj at Cust	Unadjusted at the Customer	Adjusted at the Customer	Unadjusted at System Input	Adjusted at System Input	System Peak Respbilty
		Low pk mo kWh	High pk mo kWh						
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)
1	19318 01	0	600	525	503	490	548	533	529
2	19318 02	601	1,200	978	965	939	1,051	1,023	1,013
3	19318 03	1,201	2,000	1,883	1,858	1,808	2,024	1,969	1,961
4	19318 04	2,001	3,800	3,147	3,101	3,017	3,378	3,287	3,238
5	19318 05	3,801	999,999,999	3,600	3,438	3,345	3,745	3,644	3,641
6	19-VolResidential			10,133	9,865	9,599	10,746	10,456	10,382
7	SC19			10,133	9,865	9,599	10,746	10,456	10,382

Footnotes:

Col (5): Class Peak at 7:00pm

Col (6): Class 4 hour peak from 6:30pm-10:00pm

Col (7): Adjusted sum of component loads equals system loads

Col (8): Equal to (Col (6) / Efficiency Factor of 91.800000000) * 100

Col (9): Equal to (Col (7) / Efficiency Factor of 91.800000000) * 100

Col (10): System Peak Responsibility from 5:30pm-9:00pm

Orange & Rockland Utilities, Inc - Electric
 Report 2 - Sample Test Customer Data
 Class - SC20 - Winter - 2019

Line No	Sample Strata		Stratification Variable		No of Test Customers	Strat Var Avg Per Test Cust	Avg Non-Coin kW Per Cust	Avg Coin kW Per Cust	Coincidence Factor Percentage
			pk mo kW (20120)	max ann kW (20130)					
(1)	(2)		Low (3)	High (4)	(5)	(6)	(7)	(8)	(9)
1	20120	11	0	35	17	11	23.119	18.912	81.8028
2	20120	12	36	80	10	50	36.145	19.089	52.8123
3	20120	13	81	999,999,999	11	121	125.909	89.314	70.9354
4	20130	99	200	999,999,999	2	491	423.790	334.332	78.8910
5	20-VolComm2				40				
6	SC20				40				

Footnotes:

Col (9): Equal to 100 * (Col (8) / Col (7))

Orange & Rockland Utilities, Inc - Electric
Report 3 - Estimated Class Demand Data
Class - SC20 - Winter - 2019

Line No	Sample Strata	Stratification Variable pk mo kW (20120) max ann kW (20130)		Est Avg No of Custs	Total Annual kWh	Avg Annual Use Per Cust	Est Non-Coin kW Per Cust	Est Popul Non-Coin kW	Coincidence Factor Percentage	Est Popul Coin kW for Individual Strata
(1)	(2)	Low (3)	High (4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)
1	20120 11	0	35	348	21,017,648	60,396		3,676	81.8028	3,007
2	20120 12	36	80	144	24,514,628	170,240		4,678	52.8123	2,471
3	20120 13	81	999,999,999	59	27,303,176	462,766		4,755	70.9354	3,373
4	20130 99	200	999,999,999	4	5,410,525	1,352,631		903	78.8910	712
5	20-VolComm2			555	78,245,977			14,012		9,563
6	SC20			555	78,245,977			14,012		9,563

Footnotes:

Col (7): Equal to Col (6) / Col (5)

Col (8): For non-demand metered classes, from relationship of sampled energy and demand values, applied to population energy usage

Col (9): Equal to Cols (5) * (8) or Billing Demand

Col (10): From Report 2

Col (11): Equal to Col (9) * (Col (10) / 100)

Orange & Rockland Utilities, Inc - Electric
Report 4 - Estimated Class Demand Data
Class - SC20 - Winter - 2019

Line No	Sample Strata	4 Hour Demands-kW							
		Stratification Variable pk mo kW (20120) max ann kW (20130)		Half Hour kW at Time of Class Peak Unadj at Cust	Unadjusted at the Customer	Adjusted at the Customer	Unadjusted at System Input	Adjusted at System Input	System Peak Respblty
		Low (3)	High (4)						
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)
1	20120 11	0	35	2,910	2,736	2,598	2,980	2,830	2,809
2	20120 12	36	80	2,471	2,397	2,276	2,611	2,479	2,444
3	20120 13	81	999,999,999	3,185	3,224	3,061	3,513	3,334	3,338
4	20130 99	200	999,999,999	675	679	645	740	702	592
5	20-VolComm2			9,241	9,036	8,580	9,844	9,345	9,183
6	SC20			9,241	9,036	8,580	9,844	9,345	9,183

Footnotes:

Col (5): Class Peak at 10:00am

Col (6): Class 4 hour peak from 9:30am-1:00pm

Col (7): Adjusted sum of component loads equals system loads

Col (8): Equal to (Col (6) / Efficiency Factor of 91.800000000) * 100

Col (9): Equal to (Col (7) / Efficiency Factor of 91.800000000) * 100

Col (10): System Peak Responsibility from 5:30pm-9:00pm

Orange & Rockland Utilities, Inc - Electric
 Report 2 - Sample Test Customer Data
 Class - SC21 - Winter - 2019

Line No	Sample Strata	Stratification Variable pk mo kW (21121,21221) max ann kW (21131)		No of Test Customers	Strat Var Avg Per Test Cust	Avg Non-Coin kW Per Cust	Avg Coin kW Per Cust	Coincidence Factor Percentage
(1)	(2)	Low (3)	High (4)	(5)	(6)	(7)	(8)	(9)
1	21121 21	0	999,999,999	3	150	116.494	95.980	82.3905
2	21131 99	200	999,999,999	14	456	367.833	307.835	83.6888
3	21-VolCommPriTOU			17				
4	SC21			17				

Footnotes:

Col (9): Equal to 100 * (Col (8) / Col (7))

Orange & Rockland Utilities, Inc - Electric
 Report 3 - Estimated Class Demand Data
 Class - SC21 - Winter - 2019

Line No	Sample Strata	Stratification Variable pk mo kW (21121,21221) max ann kW (21131)		Est Avg No of Custs	Total Annual kWh	Avg Annual Use Per Cust	Est Non-Coin kW Per Cust	Est Popul Non- Coin kW	Coincidence Factor Percentage	Est Popul Coin kW for Individual Strata
		Low (3)	High (4)							
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)
1	21121 21	0	999,999,999	10	5,202,440	520,244		1,082	82.3905	891
2	21131 99	200	999,999,999	15	32,067,140	2,137,809		5,305	83.6888	4,440
3	21-VolCommPriTOU			25	37,269,580			6,387		5,331
4	SC21			25	37,269,580			6,387		5,331

Footnotes:

Col (7): Equal to Col (6) / Col (5)

Col (8): For non-demand metered classes, from relationship of sampled energy and demand values, applied to population energy usage

Col (9): Equal to Cols (5) * (8) or Billing Demand

Col (10): From Report 2

Col (11): Equal to Col (9) * (Col (10) / 100)

Orange & Rockland Utilities, Inc - Electric
 Report 4 - Estimated Class Demand Data
 Class - SC21 - Winter - 2019

Line No	Sample Strata	4 Hour Demands-kW							
		Stratification Variable pk mo kW (21121,21221) max ann kW (21131)		Half Hour kW at Time of Class Peak Unadj at Cust	Unadjusted at the Customer	Adjusted at the Customer	Unadjusted at System Input	Adjusted at System Input	System Peak Respblty
(1)	(2)	Low (3)	High (4)	(5)	(6)	(7)	(8)	(9)	(10)
1	21121 21	0	999,999,999	881	871	823	935	883	811
2	21131 99	200	999,999,999	4,440	4,365	4,365	4,684	4,684	4,501
3	21-VolCommPriTOU			5,321	5,236	5,188	5,619	5,567	5,312
4	SC21			5,321	5,236	5,188	5,619	5,567	5,312

Footnotes:

Col (5): Class Peak at 11:00am

Col (6): Class 4 hour peak from 10:30am-2:00pm

Col (7): Adjusted sum of component loads equals system loads

Col (8): Equal to (Col (6) / Efficiency Factor of 93.200000000) * 100

Col (9): Equal to (Col (7) / Efficiency Factor of 93.200000000) * 100

Col (10): System Peak Responsibility from 5:30pm-9:00pm

Orange & Rockland Utilities, Inc - Electric
 Report 2 - Sample Test Customer Data
 Class - SC22 - Winter - 2019

Line No	Sample Strata		Stratification Variable		No of Test Customers	Strat Var Avg Per Test Cust	Avg Non-Coin kW Per Cust	Avg Coin kW Per Cust	Coincidence Factor Percentage
			Low pk mo kW	High pk mo kW					
(1)	(2)		(3)	(4)	(5)	(6)	(7)	(8)	(9)
1	22211	22	0	999,999,999	21	1,493	1,343.475	1,053.015	78.3799
2	22868	22	0	999,999,999	2	2,612	1,714.200	1,385.304	80.8134
3	22961	22	0	999,999,999	5	17,298	3,880.898	1,191.440	30.7001
4	22-Industrial				28				
5	SC22				28				

Footnotes:

Col (9): Equal to 100 * (Col (8) / Col (7))

Orange & Rockland Utilities, Inc - Electric
Report 3 - Estimated Class Demand Data
Class - SC22 - Winter - 2019

Line No	Sample Strata	Stratification Variable pk mo kW		Est Avg No of Custs	Total Annual kWh	Avg Annual Use Per Cust	Est Non-Coin kW Per Cust	Est Popul Non-Coin kW	Coincidence Factor Percentage	Est Popul Coin kW for Individual Strata
(1)	(2)	Low (3)	High (4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)
1	22211 22	0	999,999,999	31	240,365,993	7,753,742		38,973	78.3799	30,547
2	22868 22	0	999,999,999	3	19,460,264	6,486,755		3,356	80.8134	2,712
3	22961 22	0	999,999,999	5	49,634,878	9,926,976		17,723	30.7001	5,441
4	22-Industrial			39	309,461,135			60,052		38,700
5	SC22			39	309,461,135			60,052		38,700

Footnotes:

Col (7): Equal to Col (6) / Col (5)

Col (8): For non-demand metered classes, from relationship of sampled energy and demand values, applied to population energy usage

Col (9): Equal to Cols (5) * (8) or Billing Demand

Col (10): From Report 2

Col (11): Equal to Col (9) * (Col (10) / 100)

Orange & Rockland Utilities, Inc - Electric
Report 4 - Estimated Class Demand Data
Class - SC22 - Winter - 2019

Line No	Sample Strata	4 Hour Demands-kW							
		Stratification Variable		Half Hour kW at Time of Class Peak Unadj at Cust	Unadjusted at the Customer	Adjusted at the Customer	Unadjusted at System Input	Adjusted at System Input	System Peak Respblty
		Low	High						
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)
1	22211 22	0	999,999,999	30,085	29,711	29,131	31,440	30,826	30,531
2	22868 22	0	999,999,999	2,612	2,627	2,576	2,780	2,726	2,695
3	22961 22	0	999,999,999	4,837	4,595	4,595	4,862	4,862	4,645
4	22-Industrial			37,534	36,932	36,301	39,082	38,414	37,871
5	SC22			37,534	36,932	36,301	39,082	38,414	37,871

Footnotes:

Col (5): Class Peak at 9:30pm

Col (6): Class 4 hour peak from 7:30pm-11:00pm

Col (7): Adjusted sum of component loads equals system loads

Col (8): Equal to (Col(6) / Efficiency Factor of 94.500000000) * 100

Col (9): Equal to (Col(7) / Efficiency Factor of 94.500000000) * 100

Col (10): System Peak Responsibility from 5:30pm-9:00pm

Orange & Rockland Utilities, Inc - Electric
 Report 2 - Sample Test Customer Data
 Class - SC99 - Winter - 2019

Line No	Sample Strata	Stratification Variable pk mo kWh		No of Test Customers	Strat Var Avg Per Test Cust	Avg Non-Coin kW Per Cust	Avg Coin kW Per Cust	Coincidence Factor Percentage
(1)	(2)	Low (3)	High (4)	(5)	(6)	(7)	(8)	(9)
1	99999 99	0	999,999,999	29	0	52.898	42.446	80.2412
2	99-Company Use			29				
3	SC99			29				

Footnotes:

Col (9): Equal to $100 * (\text{Col (8)} / \text{Col (7)})$

Orange & Rockland Utilities, Inc - Electric
 Report 3 - Estimated Class Demand Data
 Class - SC99 - Winter - 2019

Line No	Sample Strata	Stratification Variable		Est Avg No of Custs	Total Annual kWh	Avg Annual Use Per Cust	Est Non- Coin kW Per Cust	Est Popul Non- Coin kW	Coincidence Factor Percentage	Est Popul Coin kW for Individual Strata
		Low (3)	High (4)							
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)
1	99999 99	0	999,999,999	190	14,622,737	76,962	17.115	3,252	80.2412	2,609
2	99-Company Use			190	14,622,737			3,252		2,609
3	SC99			190	14,622,737			3,252		2,609

Footnotes:

Col (7): Equal to Col (6) / Col (5)

Col (8): For non-demand metered classes, from relationship of sampled energy and demand values, applied to population energy usage

Col (9): Equal to Cols (5) * (8) or Billing Demand

Col (10): From Report 2

Col (11): Equal to Col (9) * (Col (10) / 100)

Orange & Rockland Utilities, Inc - Electric
Report 4 - Estimated Class Demand Data
Class - SC99 - Winter - 2019

Line No	Sample Strata	Stratification Variable pk mo kWh		Half Hour kW at Time of Class Peak Unadj at Cust	4 Hour Demands-kW				
					Unadjusted at the Customer	Adjusted at the Customer	Unadjusted at System Input	Adjusted at System Input	System Peak Respblty
(1)	(2)	Low (3)	High (4)	(5)	(6)	(7)	(8)	(9)	(10)
1	99999 99	0	999,999,999	2,609	2,514	2,434	2,739	2,651	2,357
2	99-Company Use			2,609	2,514	2,434	2,739	2,651	2,357
3	SC99			2,609	2,514	2,434	2,739	2,651	2,357

Footnotes:

Col (5): Class Peak at 6:30am

Col (6): Class 4 hour peak from 6:00am-9:30am

Col (7): Adjusted sum of component loads equals system loads

Col (8): Equal to (Col (6) / Efficiency Factor of 91.800000151) * 100

Col (9): Equal to (Col (7) / Efficiency Factor of 91.800000151) * 100

Col (10): System Peak Responsibility from 5:30pm-9:00pm

Orange & Rockland Utilities, Inc - Electric
Class Demand Summary - 2019

4 Hour Demands-kW

Line No (1)	Customer Class (2)	Season (3)	Non-Coin kW (4)	Half Hour Demand at Time of Class Peak Unadjusted at Cust-kW (5)		Adjusted at the Customer (6)	Adjusted at System Input (7)	System Peak Respbly (8)
1	01-RESI	Summer2019	937,371	474,930	439,342	478,586	471,005	
2	01-RESI	Winter2019	721,313	271,539	259,460	282,638	278,088	
3	02-CI SECONDRY	Summer2019	298,900	219,712	196,316	213,850	198,905	
4	02-CI SECONDRY	Winter2019	248,897	162,726	152,795	166,443	143,562	
5	02-SMCI PRIMRY	Summer2019	12,814	9,976	8,930	9,582	9,292	
6	02-SMCI PRIMRY	Winter2019	11,981	8,431	7,977	8,558	8,005	
7	02-CI SMSH10	Summer2019	4,153	3,363	2,962	3,226	3,112	
8	02-CI SMSH10	Winter2019	7,993	5,712	5,389	5,871	4,969	
9	02-CI SEC NMET	Summer2019	2,994	1,844	1,812	1,967	1,747	
10	02-CI SEC NMET	Winter2019	3,676	1,998	1,992	2,163	2,147	

Footnotes:

Col (4): from Report 3 Col (9)
 Col (5): from Report 4 Col (5)
 Col (6): from Report 4 Col (7)
 Col (7): from Report 4 Col (9)
 Col (8): from Report 4 Col (10)

Orange & Rockland Utilities, Inc - Electric
Class Demand Summary - 2019

4 Hour Demands-kW

Line No (1)	Customer Class (2)	Season (3)	Non-Coin kW (4)	Half Hour Demand at Time of Class Peak Unadjusted at Cust-kW (5)		Adjusted at the Customer (6)	Adjusted at System Input (7)	System Peak Respbly (8)
11	03-CI PRIMARY	Summer2019	84,743	69,594	66,750	71,619	65,958	
12	03-CI PRIMARY	Winter2019	74,070	57,725	56,601	60,732	54,987	
13	04-MUNI STLT	Summer2019	2,849	2,849	2,849	3,090	68	
14	04-MUNI STLT	Winter2019	3,076	3,076	3,076	3,336	3,262	
15	OS-TRAFFIC LT	Summer2019	298	294	293	318	317	
16	OS-TRAFFIC LT	Winter2019	259	253	252	274	273	
17	06-MUN OWN LT	Summer2019	770	770	770	835	18	
18	06-MUN OWN LT	Winter2019	651	648	647	701	685	
19	09-C PRIM TOU	Summer2019	76,888	66,919	58,156	61,476	59,106	
20	09-C PRIM TOU	Winter2019	68,424	57,266	53,858	56,932	52,244	

Footnotes:
Col (4): from Report 3 Col (9)
Col (5): from Report 4 Col (5)
Col (6): from Report 4 Col (7)
Col (7): from Report 4 Col (9)
Col (8): from Report 4 Col (10)

Orange & Rockland Utilities, Inc - Electric
Class Demand Summary - 2019

4 Hour Demands-kW

Line No	Customer Class	Season	Non-Coin kW	Half Hour Demand at Time of Class Peak		Adjusted at the Customer	Adjusted at System Input	System Peak Respbly
				Unadjusted at Cust-kW				
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	
21	11-WEST POINT	Sumrner2019	18,967	15,941	15,752	16,902	16,217	
22	11-WEST POINT	Winter2019	13,865	12,671	12,347	13,248	13,039	
23	16-PRI OV D2D	Sumrner2019	2,254	2,254	2,254	2,445	54	
24	16-PRI OV D2D	Winter2019	2,578	2,578	2,578	2,796	2,734	
25	16-EN ONLY LT	Sumrner2019	2,172	1,043	831	901	368	
26	16-EN ONLY LT	Winter2019	748	505	486	527	507	
27	19-VOLRES TOW	Sumrner2019	33,909	19,879	18,567	20,225	20,144	
28	19-VOLRES TOW	Winter2019	25,763	10,133	9,599	10,456	10,382	
29	20-VOL CI S TOW	Sumrner2019	17,808	14,009	12,895	14,046	13,935	
30	20-VOL CI S TOW	Winter2019	14,012	9,241	8,580	9,345	9,183	

Footnotes:

Col (4): from Report 3 Col (9)
 Col (5): from Report 4 Col (5)
 Col (6): from Report 4 Col (7)
 Col (7): from Report 4 Col (9)
 Col (8): from Report 4 Col (10)

Orange & Rockland Utilities, Inc - Electric
Class Demand Summary - 2019

4 Hour Demands-kW

Line No (1)	Customer Class (2)	Season (3)	Non-Coin kW (4)	Half Hour		Adjusted at the Customer (6)	Adjusted at System Input (7)	System Peak Respbly (8)
				Demand at Time of Class Peak Unadjusted at Cust-kW (5)	Adjusted at the Customer (6)			
31	21-VOL_CI_P_TOU	Summer2019	8,161	6,910	6,769	7,263	7,203	7,203
32	21-VOL_CI_P_TOU	Winter2019	6,387	5,321	5,188	5,567	5,312	5,312
33	22-IND PRIM TOU	Summer2019	65,911	49,314	44,152	46,722	44,608	44,608
34	22-IND PRIM TOU	Winter2019	60,052	37,534	36,301	38,414	37,871	37,871
35	99-Company Use	Summer2019	2,191	1,976	1,761	1,919	1,894	1,894
36	99-Company Use	Winter2019	3,252	2,609	2,434	2,651	2,357	2,357
37	Total System	Summer2019	1,573,153	961,577	881,161	954,972	913,951	913,951
38	Total System	Winter2019	1,266,997	649,966	619,560	670,652	629,607	629,607

Footnotes:

Col (4): from Report 3 Col (9)
Col (5): from Report 4 Col (5)
Col (6): from Report 4 Col (7)
Col (7): from Report 4 Col (9)
Col (8): from Report 4 Col (10)