

From: Al Mitchell amitchell@phius.org
Subject: Re: PHIUS Non-Res Loads, Schedules ?
Date: October 7, 2021 at 10:00 AM
To: Ed May ed@bldgtyp.com



Hey Ed,

Sorry about the delay, been busy getting ready for the conference.

And yes, the EFLH overrides the lighting I believe, which is to our advantage for simplicity. Good to see a protocol coming together, and I think using the libraries is to our advantage.

Are you coming to the conference next week? I am going to see a buddy in Brooklyn this weekend, and then head to the conference.

Best,
Al

On Wed, Sep 29, 2021 at 9:38 AM Ed May <ed@bldgtyp.com> wrote:
Hey Al,

Thanks for taking a look at this and getting back to me.

Ah - that's a super interesting idea to use the EFLH value there! I wasn't familiar with that input.

For sure - that might simplify things a lot. So for using that value, can I ask: would we set the '**Part Use Factor of Operating Period for Lighting**' back in the 'Utilization-Pattern' as 1.0? Or does that value not matter at all and get completely ignored when we enter the EFLH directly?

That makes sense to use the COMNET stuff - that's all pretty good. I think if we can develop this methodology for converting the OpenStudio style schedules, that would mean that you could then point folks towards the [Honeybee Standards](#) library (which is huge at this point) and the [OpenStudio](#) catalog - but in way that is 'automatic' and doesn't require the user to know all that much or have much input there.

I'll build out a method for now that makes the occupancy schedule (Utilization Pattern) and then use that EFLH input for the lighting and equipment. I'll see if I can make that work.

best,
-Ed

Ed May
Certified Passive House Designer
Partner
bldgtyp
231 Park Place #22
Brooklyn, NY 11238
tel: 510-499-5191
fax: 718-228-9373
ed@bldgtyp.com
www.bldgtyp.com

On Tue, Sep 28, 2021 at 10:25 AM Al Mitchell <amitchell@phius.org> wrote:
Hi Ed,

Yeah, this is a problem I had pondered a little bit. The WUFI inputs are strange a confusing, especially coming from that EnergyPlus/OS background.

Currently I am the only person who reviews non-res projects, so I am not too afraid of reviewing this. I wonder if we could simplify it a bit though, with one pattern for the space covering occupancy, and then use the utilization full hours, EFLH in LEED speak, to cover the electrical and lighting loads.

Utilization patternOccupancyOffice equipmentKitchen equipmentLightingProcess loads

Name	Type	Utilization pattern	Quantity [-]	Within thermal envelope	Power rating [W]	Power rating (saving mode) [W]	
	User defined		1	☒			NewDeleteCopyInsertNew/Insert:after

Additional data

Utilization hours per year [hrs/yr]

One of the bigger issues in reviewing this kind of stuff anyways is just confirming where the inputs people put in there are coming from. Many CPHCs are not energy modelers outside WUFI, so coming up with the schedule is a little complicated for them. If people are unsure I have been referring them to COMNET schedules, because they are free, easy to use, and have EFLH calculated. (we have also used these to estimate demand controlled ventilation). These utilization patterns used to apply to calculating PHIUS+2018 non res targets via an external calculator, but this has been replaced in the 2021 calculator.

Hopefully this is fixed in C3RRO / New WUFI and this becomes a moot point. I do think that using these 90.1 libraries and building them in would help greatly.

Hope this helps,
Al

On Fri, Sep 24, 2021 at 10:33 AM Ed May <ed@bldgtyp.com> wrote:
Hi Al,

I hope that you are well. Great to talk with you a bit back - and glad to hear that you are interested in the stuff that Trevor and I have been working on. If you have a minute, I wonder if I might ask your opinion on something regarding Non-Residential modeling and see if you have any thoughts on it?

Some background:

1. As you know, modeling Non-Res occupancy, lighting and equipment usage is challenging. One of the things that I would like to do with our new Rhino tooling is make that easier, and also to open up the really nice library of existing space-types (loads and schedules) to WUFI users in the future.

2. In the Ladybug tool, currently they have already built in many, many [space types](#) into their software, all drawn from OpenStudio, as far as I know (see DOE data). However, the format of

2. In the Ladybug tool, currently they have already built in many, many [space types](#) into their software, all drawn from OpenStudio, as far as I know (so: DOE data). However, the format of this data is significantly different from the current WUFI configuration, and so one thing I'm working on is finding a translation mechanism so that we can use these libraries.

3. These Ladybug/OpenStudio libraries all break down the 'Program' of the space into three basic sectors:


- Occupancy
- Lighting
- Elec. Equipment Usage

each of these sectors then has:

- Load(s)
- Schedule

This method makes things quite a bit easier to manage, and allows for a lot more customization / organization, I think. It also makes the modeling more predictable, which is nice.

4. So, for translating all that into 'WUFI-speak', my thinking is that we can simply build out Utilization Patterns for each of the above Schedules (Occupancy, Lighting, Elec. Equip) for each space-type used. So for instance, we can get something like:



Where we have separate Occupancy, Lighting, and Elec. Equipment Schedules (Util. Patterns) for each space type in the model, which we then use in the later WUFI tabs.


Hopefully all the above makes sense? So, I wonder what you think about:

1. Doing this will result in more Utilization Patterns. We'd have three for each space type (well, 4 if you include the Ventilation Schedule for the space type as well...). Which is nice from a customization / control / accuracy perspective. But I wonder if you see a downside from this? Obviously more patterns means more to check and verify. But I actually think splitting apart the schedules in this manner probably makes it easier (I hope?) to check / adjust the various bits, as opposed to now where the schedules are all sort of joined together and there isn't clear separation between them?

2. The OpenStudio schedules and loads are all hourly. So they don't map to the 'start hour', 'end hour' WUFI thing very well. So my thought is that we can just set the start / end to 0 and 24 respectively, and 365 days, then calc the annual util factor based on the OpenStudio hourly values, and input that as the use-factor (or absence factor).

Do you think you see any significant issues with entering data this way? The start/end hours aren't important, other than for helping to define the use-pattern, are they? Do you think the reviewers will be unhappy if we don't include those somehow? Personally, I think just entering an annual factor makes a lot more sense than entering a factor of the use-period, as defined by start/end? But if you think those values are super important, then I can rethink that?

In general though, we would then have an easy method for taking 8670 hourly use-values, and turning those into an average annual-use-factor. This means we can then just use all those OpenStudio libraries which is nice. So long as we don't *have* to use the 'start hour/end hour' method of defining the use-period?



So yeah, just wondering if you have any strong feelings on the above? This is the method I'm currently building out, and so far so good. But of course if you see any Certification related issues with that method or think I'm off-target here, I'd appreciate any thoughts you might have on that.

regardless - hope all is well.
best,
-Ed

Ed May
Certified Passive House Designer
Partner
bldatvdo

231 Park Place #22
Brooklyn, NY 11238
tel: 510-499-5191
fax: 718-228-9373
ed@bldgtyp.com
www.bldgtyp.com

--
Al Mitchell
amitchell@phius.org

--
Al Mitchell
amitchell@phius.org