



ENGINEERING DEPARTMENT

200 NE Moe Street | Poulsbo, Washington 98370

(360) 394-9739 | fax (360) 697-8269

www.cityofpoulsbo.com

PRE-APPLICATION SUMMARY LETTER

Project Name: Parkview at Hostmark P-09-22-25-04

Applicant: Laughlin Development LLC

Staff Contact: Sherman Leddon
Engineering Technician
(360) 394-9740
sleddon@cityofpoulsbo.com

PreApp Date: October 7, 2025

Date: October 21, 2025

FEES AND PERMITS:

- Initial deposits / replenishment of deposits will occur periodically throughout project approval and construction.
- A Maintenance bond will be required before final construction approval for commercial buildings
- The Engineering Fees can be found here:
<https://cityofpoulsbo.com/wp-content/uploads/2025/02/Engineering-Fee-Schedule-2025-final-1.pdf>
- Applications can be found here:
<https://cityofpoulsbo.com/engineering-forms-documents/>
- All code references to the Poulsbo's Municipal Code can be accessed via:
www.codepublishing.com/WA/Poulsbo
- The City of Poulsbo assesses General Facility Charges for water, sewer and stormwater utilities (Reference PMC 13.70).
- The City does not issue sewer or water availability certificates. Water and sewer availability is guaranteed with building permit(s).

- GMA Transportation Impact Fee Ordinance (PMC 3.86) establishes a transportation impact fee assessment payable at time of Building permit issuance. The application shall provide accurate occupancy information for each building to assign accurate ADTs. Average weekday trips shall be determined using the latest version of the Trip Generation Manual published by the Institute of Transportation Engineers (ITE) for the land use(s) that are the subject of the permit.
- Peer reviews will likely be required for Stormwater and Geotech, and an initial escrow deposit will be required with application. Actual escrow needs will be updated with each task order. Unused escrow deposit will be returned.

ENGINEERING COMMENTS SPECIFIC TO THIS PROJECT

- E1 Grading and Tree Cutting & Clearing permits will be required for civil construction after the project has received land use approval.
- E2 Refer to PMC Ch.18.140 for required parking dimensions.
- E3 The applicant shall be responsible for ensuring ADA compliance on the existing property's frontage improvements. Any existing deficiencies in the frontage improvements shall be corrected.
- E4 Bike lane will need to be maintained with frontage improvements along Hostmark St.
- E5 The Rock wall along NE Hostmark St. will need to be assessed for improvements.
- E6 Site distance for egress of private road onto Hostmark St. will need to be assessed.

ENGINEERING GENERAL:

- E7 Pre-application comments are based on the information available at this time and subject to change if new, revised, or additional information is submitted or discovered by either the applicant or city staff during the pre-application and application process. While every effort is made to be as thorough as possible, these are pre-application comments and additional requirements may be imposed with the actual "conditions of approval."
- E8 Comments provided pursuant to pre-application review shall not be construed to relieve the applicant of conformance with all applicable fees, codes, policies, and standards in effect at the time of complete land use permit application. The

comments on this proposal do not represent or guarantee approval of any project or permit.

- E9 All water, wastewater, and stormwater facilities and streets shall be designed by a professional civil engineer licensed in the State of Washington. The applicant is responsible for the design and installation of the facilities. If there is a conflict between standards, the more restrictive standard shall apply as determined by the City Engineer.

Land use permit approval shall not waive any requirements for the applicant to (a) obtain all appropriate permits; (b) pay all required fees and deposits; and (c) provide the City with adequate construction plans for approval which conform to City codes and standards. Any utility plans, details, and drawing notes associated with the approved preliminary plat drawing are approved in concept only and are not considered approved for construction. Approval of the preliminary plat does not constitute approval of any construction drawings submitted with the preliminary plat approval documents. Civil construction drawings must be submitted directly to the Engineering Department.

- i. For site plans, it is not acceptable to submit the civil drawings with the building plans to the Building Department.

- E10 Construction plans for the following shall be reviewed and approved by the Engineering Department and Public Works Department: storm drainage and street improvements (including signage and pavement markings), sanitary sewer, water, and interim and permanent on-site erosion control systems. Prior to final project construction approval, the applicant shall: construct the required improvements per City standards and submit “as-built” drawings on paper, and electronically (compatible with the AutoCAD version utilized by the City at the time of submittal), dedicate easements, convey utility ownership as determined by the City, and post a maintenance bond(s).

- E11 All plan review and project inspection and administration expenses shall be paid for at the developer’s expense consistent with the fee and deposit schedule adopted by City ordinance in effect at the time of construction. Plan review fees shall apply to the original drawing submittal and one re-submittal. Subsequent submittals will require payment of hourly charges. Fees are non-refundable. Deposits are required for payment of actual expenses incurred by Engineering Department staff for project administration and inspection. If the City Engineer determines that the magnitude or complexity of the project requires full or part-time on-site inspection in addition to the inspection by City staff, he may contract with a duly qualified inspector or hire additional personnel to provide inspection, testing, or other professional services for the City in connection with the construction. Deposits for Engineering Department services or outside professional services shall be paid in advance. The deposits are

estimates and may require replenishment. Deposits may be required at the time of, or after, payment of any fees. Unused deposits are refundable.

- E12 At any point in the process of application approval, construction plan review, or construction, the City Engineer may hire an independent consultant to review and comment on any, or all, utilities or sitework (for example, storm sewer, sanitary sewer, water, roads/streets, retaining walls, slopes) proposed by the applicant. The applicant shall make a cash deposit which will be used to pay for any independent review required by the City Engineer. If additional funds are required, the applicant shall immediately deposit the requested amount. Any unused funds will be refunded. Acceptance of the proposal and consultant comments shall be at the discretion of the City Engineer.
- E13 Geotechnical investigation and report shall address all geotechnical hazards and limitations for the site and shall consider both historical records and field investigation/sampling. The report shall address global site stability as well as stability and suitability of walls, structures, cut slopes and structural fill proposed. The applicant shall adhere to all recommendations of the applicant's geo-technical engineer and the City's consultants as determined by the City Engineer.
- E14 The applicant shall adhere to all recommendations of the applicant's geotechnical engineer and the City's consultants as determined by the City Engineer.
- Construction drawings shall be reviewed and approved by the geotechnical engineer prior to City Grading Permit review.
- E15 "City of Poulsbo Construction Standards and Specifications, July 2008" is published on the City website within the Public Works/Engineering Department page. Unless specified otherwise within Conditions of Approval these standards shall be followed.
- E16 Other plans may be required depending on site-specific conditions. Profiles and details for the wet utilities shall also be provided.
- E17 Construction drawings will be rejected, without review, if the following drafting requirements are not met:
- Construction plan size shall not exceed 24"x36" (22"x34" is preferred). The minimum drawing scale shall be 1:40 horizontal and 1:5 vertical. A larger scale may be required for legibility.
- E18 Utilities shall be shown on plan/profile sheets. Each sheet shall have the corresponding plan/profiles on the same sheet with aligned stationing.
- E19 Labels from the various overlapping AutoCAD layer shall be legible.

- a) All elements on the drawings shall be legible as determined by the City Engineer.

E20 All proposed field changes must be brought to the attention of the City Inspector. He will determine if further approval is required by the city engineer. It is not acceptable to "notify" the city via "as-built" drawings. The applicant's engineer does not have the authority to direct the contractor to make design changes without city approval.

E21 All infrastructure must be installed before Final Building Inspection. If the applicant wishes to construct the project in phases, those phases must be defined as divisions in the preliminary approval. At the time of Final Building Inspection for each division, that division shall be "stand alone". A division shall be considered "stand alone" if it contains complete utilities and access for the future residents of that division and is not dependent on other as yet un-built divisions for this purpose. Any infrastructure outside of the plat that is necessary in order to serve the division or allow it to function must be completed as well.

CLEARING, GRADING, AND EROSION CONTROL (REFER TO CONSTRUCTION STANDARDS)

E22 A Clearing and/or Grading Permit is required prior to any land-disturbing activity on the site (PMC 15.40). The permit may include restrictions as to the limits of any particular area or phase that can be cleared and graded at any one time or during any construction season. Additional restrictions may be placed on the permit in regard to seasonal weather conditions. At any time, the City Engineer may restrict activities or access to portions of the site which would be detrimental to maintaining erosion and sediment control.

E23 The Department of Ecology requires project owners to obtain a Construction Stormwater General Permit for certain projects. Information may be obtained at the City permit counter or on-line at:

<http://www.ecy.wa.gov/programs/wq/stormwater/construction/index.html>

- a) Applications must be made on-line at:

<http://www.ecy.wa.gov/programs/wq/stormwater/construction/enoi.html>

- b) The Construction Stormwater General Permit is required prior to the issuance of the Grading Permit.

E24 The developer's engineer shall submit a completed NPDES Permit Appendix 7 Worksheet along with other required stormwater application documents. You may obtain the worksheet from Engineering staff or the Ecology website:

<http://www.ecy.wa.gov/programs/wq/stormwater/municipal/phaseIIww/MODIFIEDpermitDOCS/Appen dix7ww.pdf>

STORMWATER:

- E25 All temporary and permanent storm system and erosion control measures shall be designed, constructed, maintained, and governed per the following, as adopted by the City of Poulsbo:
- a) The currently adopted version of the Washington State Department of Ecology (DOE) Stormwater Management Manual for Western Washington (2019 edition as of the date of this memo).
 - b) City of Poulsbo standards and ordinances.
 - c) All conditions of approval associated with any clearing and/or grading permits.
 - d) Recommendations of the geo-technical engineer.

- E26 A preliminary Stormwater drainage report and plan shall be submitted with the preliminary plat application and include both an upstream analysis and an off-site analysis report per Section 1-3.5.3 APM2 of the stormwater manual. The stamping/cover page of this report shall include the following text.

"I hereby state that this Stormwater Drainage Report has been prepared by me or under my supervision and meets the standard of care and expertise which is usual and customary in this community of professional engineers. The analysis has been prepared utilizing procedures and practices specified by the City of Poulsbo and within the standard accepted practices of the industry. I understand that the City of Poulsbo does not and will not assume liability for the sufficiency, suitability or performance of stormwater drainage facilities prepared by me."

- E27 The preliminary & final site plan shall address management of upstream flows. Further levels of analysis may be required. The final stormwater drainage report shall include an analysis of the proposed stormwater drainage design which satisfies the City Engineer that the design complies with all City requirements and protects

downstream properties and the surrounding area from damage and any adverse impacts. Impervious surface calculations shall clearly account for proposed lots, internal street and sidewalks, offsite paved improvements, and the storm pond surface area. The applicant may be required to construct off-site downstream improvements to mitigate the impacts of the project. In the case of conflicts among the standards and manuals, the more restrictive shall apply unless determined otherwise at the discretion of the City Engineer. Requirements of the permit are a minimum. Other actions may be necessary to comply with State statutes for clean water. The applicant is ultimately responsible for compliance.

- E28 Ownership and maintenance of stormwater systems located on commercial private property will remain the responsibility of the property owner. Prior to the use of the development or redevelopment project, the owner shall sign and record a maintenance covenant, using the City's form, which guarantees the City of Poulsbo that the stormwater facilities shall be properly operated, maintained and inspected by the property owner, and which gives the City the right (1) to enter and inspect the facility for conformance with the covenant, and (2) to take any necessary action to cause correction, repair, replacement, or maintenance not fulfilled by the owner. The restrictions set forth in such covenant shall run with the land and be included in any instrument of conveyance of the subject property. Maintenance covenants shall remain in force for the life of the development.
- E29 Enhanced water quality treatment is required and will be a condition. The City prefers Modular Wetlands, allows Biopods and does not permit Filterra for treatment box units. Bioretention cells and swales are acceptable.
- E30 The City encourages use of Low Impact Development (LID) measures to the extent they are feasible for the proposed site conditions. PMC 12.02.010 has adopted "The Low Impact Development Guidance Manual, a Practical Guide to LID Implementation in Kitsap County", published by the Kitsap Home Builders Foundation as primary guidance for City LID measures within the allowances acknowledged by the NPDES Phase II Permit and the DOE Management Manual.
- E31 A general facility charge for stormwater has been established. This current charge is \$1,805.91 per impervious surface unit (ISU) and is payable at the time of building permit at the rate at permit time. One ISU is equal to 3000sf of impervious surface.

SANITARY SEWER AND WATER:

- E32 Refer to Public Works Department comments for water and sewer connection requirements and construction standards.

ALL UTILITIES:

- E33 All water mains and all primary sanitary sewer and storm drainage mains shall be within public right-of-way or within easements dedicated to the City which meet the City's criteria for dimensions and access. All water, sewer, and storm service laterals and all secondary sanitary sewer and storm drainage lines located within easements or private property shall remain privately owned and maintained by the Homeowner's Association or applicable lot owners.
- E34 For utilities not within City right-of-way, the Public Works Director may determine if the City assumes ownership and maintenance of the utility.
- E35 The applicant shall be required to provide easements and utility stubs for city-owned utilities which are necessary to serve adjacent properties.
- E36 The applicant shall be responsible for obtaining any off-site easements for installation, access, and maintenance of City utilities. Prior to Preliminary Plat Approval, the easement(s) shall be granted to the City or satisfactory evidence shall be provided to the City Engineer which indicates that the easement(s) will be granted. The easement(s) shall be legally described and dedicated to the City prior to Final Plat recording. Conveyance of ownership of the pipe and appurtenances shall be included with the easement dedication. The easement(s) shall be shown on the construction drawings, "as-built" drawings, and Final Plat drawings.
- E37 All easements which contain City-owned and maintained utilities shall be a minimum of 15 feet wide and be accessible to City equipment and crews with an all-weather access road. Additional width is required to accommodate turning radii, also refer to City Construction Standards Section 1-H.
- E38 Installation of any or all utilities may be required in association with any required street frontage improvements.
- E39 All public utilities shall be provided within the plat and shall include power, telephone, natural gas, and cable television. All utilities shall be placed underground (PMC 17.08.140A ten-foot easement fronting all lots shall be dedicated for public utilities. The developer shall provide and install a minimum of one additional empty four-inch conduit trunk line with road crossings, in parallel with the aforementioned utilities, with appropriate termination points within junction boxes, for future telecommunications use (PMC 12.02.015). Ownership of the conduit shall be conveyed to the City on the Final Plat drawings. All existing and new utilities shall be underground. A plan sheet titled Dry Utilities shall be included with Construction Plan submittal and include all the above-mentioned utilities.

- E40 In the event that there is a conflict between construction standards, the more restrictive standard shall apply as determined by the City Engineer.
- E39. No walls or structures shall be permitted in utility easements.
- E40. Placement of landscape plantings and/or street trees shall not interfere with utilities. Required landscape vegetation may need to be relocated in the final landscape plan. Landscape vegetation not required by city code may need to be relocated or removed from the final landscape plan.

STREETS:

- E41. Unless otherwise approved by the City Council, street sections shall conform to adopted City standards. (refer to Developer's Guide – Section 2 – Street Standards, revised Sept. 2009, available online;
<http://www.cityofpoulsbo.com/publicworks/ConstructionStandards.htm>).
- E42. The developer's engineer shall certify that there is adequate entering sight distance at the intersection of the project and Hostmark Street. Such certification shall note the minimum required sight distance, the actual sight distance provided, and a sight distance diagram showing the intersection geometry drawn to scale, topographic and landscaping features, and the sight triangle. The certification shall also note necessary measures to correct and maintain the minimum sight triangle.
- E43. A Transportation Concurrency Application is required to be submitted with the site plan in accordance with PMC 14.04.
- E44. Streetlights shall be installed per City of Poulsbo and Puget Sound Energy (PSE) specifications. Fc values for roadway lighting are 0.6 and 0.9 at intersections. Preliminary plat drawing package shall include lighting plan and show light placement along with street trees, utilities and sight distance triangles to demonstrate lack of conflict.
- E45. The applicant shall be responsible for the purchase and installation of all street signs and pavement markings.
- E46. All intersections, crosswalks at intersections, sidewalks and driveway drops shall meet current ADA standards in place at time of construction (including 28 CFR Part 36). Construction drawings shall include sufficient intersection grade and slope details to determine ADA compliance. Individual curb ramp details for each curb ramp sufficient to show compliance and provide sufficient details for construction shall be provided.

- E47. Street names shall be submitted to the City Engineer for approval.
- E48. The applicant's engineer shall obtain approval of the US Postmaster and the City Engineer for all mailbox installation locations. Mailbox and Hydrant locations shall be placed on NO PARKING side of streets.
- E49. Refer to the Planning department for street tree requirements. Placement of street trees should not interfere with any installed infrastructure or sight distance requirements.
- E50 The Frontage improvements shall be designed to accommodate and be in alignment with the City's 2024 Complete Streets Plan.

OTHER:

- E51. All bonds, conveyances, and easements dedicated to the City shall be in the City's forms.
- E52. Applicant shall be responsible for compliance with EV Charging station requirements of the currently adopted International Building Code.
- E53. A Public Property Construction Permit is required when connecting to City-owned utilities or performing other work within the City right-of-way or other public/City-owned property (PMC 12.08). The permittee shall be responsible for repair and/or restoration of any damage to City property (such as sidewalks, curbs, gutters, pavement, and utilities) that occurs due to permittee operations under this permit.
- E54. Any agreements made between the applicant and another property owner related to utilities, easements, rights-of-way, or ingress and egress shall not conflict with City codes or ordinances. No agreements between the applicant and the property owner shall exempt either party from obtaining proper City approval for land use activities regulated under the Poulsbo Municipal Code.
- E55. The preliminary site plans shall show topography, a conceptual utility plan for water, sanitary sewer, and storm sewer (including detention systems and treatment facilities, IE and RIM elevations for all Storm/Sewer structures), existing easements, structures, wells, and drain fields (including all structures, existing wells, sanitary sewer systems, septic tanks and drain fields within 100' of project boundaries). Plans shall include cross sections for all street categories proposed. The street layout shall show parking lane preliminary concepts. Preliminary road profiles, showing existing grade and proposed finished grade shall be provided. Contours shall be provided extending 50' beyond project boundaries and including the full width of adjacent ROW.
- E56. The applicant shall be responsible for obtaining all required easements and rights-of-way. Copies of all recorded easements shall be provided to the City Engineer.

- E57. Work hours shall be strictly adhered to as regulated by Poulsbo Municipal Code 15.32. Construction activity shall only be permitted between the hours of 7:00 a.m. and 7:00 p.m. Monday through Friday and the hours of 8:00 a.m. and 7:00 p.m. on Saturday, Sunday, and Federal, State, and City observed holidays. Work requiring inspection by the City must be performed between 7:00 a.m. and 3:30 p.m. weekdays.
- E58. All contractors and subcontractors conducting business in the City of Poulsbo shall have a valid City of Poulsbo business license and a State of Washington Contractor's License with appropriate endorsements.

PUBLIC WORKS:

WATER:

- PW1. All lots shall be connected to City water
- PW2. Water service to the area is currently supplied from a 8-inch main along NE Hostmark St.
- PW3. Water mains should be looped if feasible for water quality, redundancy and fire flow. Potential loop connection through adjacent property to West as discussed in preapplication meeting appears feasible.
- PW4. New services shall be installed for domestic, fire, and irrigation for the proposed project.
- PW5. Service connection to the City water system shall be the responsibility of the property owner and shall comply with state and local design and development standards.
- PW6. A double check valve assembly shall be installed within 18-inches of the downstream side of the water meter.
- PW7. Each unit if sold individually will require its own meter. Irrigation requires separate water meter.
- PW8. Pursuant to WAC 246-290-490, the water services for domestic, irrigation and fire suppression systems shall be installed with the proper backflow prevention facilities. The minimum backflow prevention device required for this type of application shall be a double check valve.

PW9. Individual PRV is required on the property owner side of the meter when pressure exceeds 80 psi.

PW10. All water systems shall be publicly owned up to and through the water meter. For fire mains, the City shall own up to and including the Post Indicator Valve. All water mains and fire hydrants shall be located in public right-of-way or easements dedicated to the City of Poulsbo. Dedicated water lines shall be centered in an easement of 15 feet in width. A fire hydrant shall be located within 25' of the FDC. Additional hydrants may be required to meet fire district requirements. Applicant shall demonstrate adequate fire flow to meet requirements.

SEWER:

PW11. All buildings shall be connected to City sewer.

PW12. Sewer is available from 8" main along Hostmark St.

PW13. Sewer connection fees are based on Equivalent Residential Units (ERUs) as stated in PMC 9.35 Based on your project's current unit count, you will be responsible for payment of ERUs (.85 ERUs per unit). ERU charges will be confirmed and collected at time of building permit.

PW14. Service connection to the City sewer system shall be the responsibility of the property owner and shall comply with state and local design and development standards.

PW15. Wastewater discharged from the proposed development into the City of Poulsbo's sanitary sewer system shall meet the requirements set forth in Section 13.06.340 of the Poulsbo Municipal Code with regard to waste strength and unlawful discharges.

PW16. All manholes will be required to have an insert installed. The insert shall be 'The Rainstopper' by Southwestern Packing & Seals, Inc. Further information is available upon request from the Public Works Department.

PW17. Sewer cleanouts for lateral services shall be installed at the ROW edge. Caps and boxes shall be cast iron and labeled "Sewer."

PW18. All septic systems located on site shall be decommissioned per the Department of Health requirements.

SOLID WASTE:

PW19. Solid waste service for this project will be provided by the City of Poulsbo.

PW20. Public works generally does not offer individual can service on private roads. If individual cans are used, cans must be staged on outside of the private road for public works pickup. Cans must have a dedicated staging area outside of city right of way. The location of this staging area should be approved by public works.

PW21. If a solid waste enclosure is used the enclosure location must be situated to provide screening from public access ways, with straight drive into the enclosure, and with a width to provide easy access motions for the collection vehicles. Generally, the following requirements apply:

- A. Solid waste pads for dumpster and recycle totes must be designed to City specifications.
- B. City solid waste collection vehicles will not back uphill onto city streets.
- C. If a dumpster is located down an incline in the parking garage, the collection vehicle must be able to exit the building moving forward.
- D. The minimum clearance height for dumping dumpsters is 21 feet.
- E. The minimum clearance height for maneuvering under an overhang is 16 feet.
- F. The minimum clearance width for truck access is 9 feet.
- G. Enclosure gates must swing 135 degrees from closed position for truck to access an enclosure.
- H. The dumpster pad must be flush with the truck ingress/egress.
- I. No other uses will be allowed in the solid waste enclosure other than to hold garbage and recycle totes.
- J. City collection staff will not maneuver commercial size solid waste receptacles as this is a common on the job injury cause.
- K. Care must be taken in the design of the solid waste enclosure to limit the drainage of untreated water to the City's stormwater system.

GENERAL CONDITIONS

PW22. Design: All water, wastewater, stormwater system facilities and streets shall be designed by a professional engineer registered in the State of Washington. Design and installation of the improvements shall be the property owner's responsibility.

PW23. Design shall be subject to the following Standards:

- City of Poulsbo Utility Comprehensive Plan
- City of Poulsbo Design, Development and Construction Standards
- City of Poulsbo Municipal Code
- Washington State Department of Health Design Standards
- Washington State Department of Ecology's Criteria for Sewage Works Design

- Washington State Department of Ecology Stormwater Management Manual for Western Washington
- American Public Works Association/Department of Transportation Standard Specifications

PW24. Placement of landscape plantings and/or street trees shall not interfere with utilities. Required landscape vegetation may need to be relocated in the final landscape plan. Landscape vegetation not required by city code may need to be relocated or removed from the final landscape plan.

PW25. Appropriate easements shall be provided for public and private utilities. 10' dry utility easement behind sidewalk required within plat.

PW26. City owned utilities shall be located in right-of-way or easements which are dedicated to the City.

PW27. Water and sewer mains and service lines shall not be located under or through stormwater treatment and/or infiltration in right-of-way, dedicated tract, or dedicated easement.

SUBMITTAL AND APPROVAL:

PW28. The applicant shall be required to submit to the City for approval, the plans and specifications associated with design and construction of utility system improvements.

PW29. Utility systems include, but are not limited to, distribution and collection mains, pumping facilities, storage reservoirs, detention/retention facilities or any improvements to be dedicated to the city under a deed of conveyance.

PW30. Upon completion of the project, the developer shall supply the Public Works Department with a copy of drawings of record; these drawings shall be in hard copy form and in electronic form compatible with the most recent version of AutoCAD.

CONNECTION FEES AND ASSESSMENTS:

PW31. Utility service for the noted property is subject to application and payment of the applicable fees and assessments.

PW32. Utility connection fees are paid based on the current fee at the time of building permit issuance. The connection fee is due at the time of building permit. Early

payment and reservation of water connection are not provided for in Poulsbo Municipal Code. Sewer connection fees are based on water meter size.