



IEE LIFTS >>

www.ieelifts.com 093566 13000

E 26, Phase 7,
Industrial Area, Sector 73,
Sahibzada Ajit Singh Nagar,
Punjab 140308

JON NO: 2024021
REPORT NO: #7654
Date: 22/5/2024
Type: Service E1
Callback ID: 65e6f701458a4ce49e974ef2

To:

Jack Wilson
14 Maple Street, Ludhiana Sydney, NSW 2000
+91-9465932244






Invoice

M/C Room













- | | |
|---|--|
| 1. M/C Room & Motor Area Check & Clean | |
| 2. Motor Main Rope Check & Clean | |
| 3. Rope Thimbal & U Clamp Ckeck & Tight | |
| 4. Motor & Pully Level Check | |
| 5. Osg Working Check & Clean | |
| 6. Controller Cover, Lock & Clean | |
| 7. Manual Rescue Lever Working Check | |
| 8. Three Supply & Earthing Proper Available | |

Cabin, Floors








- | | |
|--|--|
| 1. Working smooth when the lift ride up & down | |
| 2. All lop and cop with display working | |
| 3. Cabin light & fan working | |
| 4. Ard and alram working | |

- 5. Car door open,close smooth 
- 6. Floor level equal all floors 
- 7. All doors must mechanically lock 
- 8. All doors must electrically work with circuit (door bypass) 
- 9. All doors must open with lift key 

Cartop ,Shaft

- 1. Shaft light working 
- 2. Cartop up,down,stop all switch working 
- 3. Cartop light workin with switch 
- 4. Final limit switch all working 
- 5. Reed switch and magnet proper fix & aline 
- 6. Cartop pully rope gard proper setup 
- 7. Cartop OSG coupling with car cabin proper setup 
- 8. Car door safety switch must work in circuit (door bypass) 
- 9. Safety lock functionally check, mec,& ele. 
- 10. Car cabin main shoe liner check 
- 11. Cwt, main shoe liner check 
- 12. All nut and bolts checked and they are tighten 

Pit Area

- 1. Lift pit must clean and tidy 
- 2. Pit light wokning 
- 3. Car & cwt buffer proper fix 
- 4. OSG lower part proper fix and working 
- 5. Pit clean 
- 6. Oil cup refill car & cwt 
- 7. Get customer signature on service report 

false

Payment Data

Total Amount	0
Payment Method	Cash

Signature Name

Karan

Phone Number

1234567897

Client Signature

A handwritten signature in orange ink, appearing to read 'Karan', is shown within a rectangular box.

Thank You. Our team is committed to supporting you every step of the way. We appreciate and look forward to the opportunity to serve you again in the future. If you have any questions concerning the report, contact.

Prabhsimran Singh,
9887654344,
info@ieelifts.com