

Siemens KTP-400

6AV2 123-2DB03-0AX0

Introduction to HMI

- Understanding HMI hardware
- How to link HMI with PC / PLC?
- Configure the HMI
- Transfer the Program



Code and Compile
Learning Made Easy

www.codeandcompile.com



Siemens KTP-400

6AV2 123-2DB03-0AX0

Introduction to HMI

- Understanding HMI hardware
- How to link HMI with PC / PLC?
- Configure the HMI
- Transfer the Program



Code and Compile
Learning Made Easy

www.codeandcompile.com





Siemens KTP-400


6AV2 123-2DB03-0AX0

Touch Screen Interface



Function Keys

- **Global** – trigger same action regardless of current HMI Screen
- **Local** – only effective within the active screen. Function assign can vary from screen to screen.



Power Supply
24VDC

- USB Port**
- External mouse
 - External keyboard
 - USB memory stick

Profinet Interface

Siemens KTP-400

6AV2 123-2DB03-0AX0

Introduction to PLC

- Understanding HMI hardware
- How to link HMI with PC / PLC?
- Configure the HMI
- Transfer the Program



Code and Compile
Learning Made Easy

www.codeandcompile.com



PROFINET – Ethernet based Data Communication

High Speed bandwidth of 100Mbps



Step 1 – Download the Screen
from PC to HMI

Step 2 – Link HMI with PLC
Discussed later in the course



Set IP address in the project

IP address: 192 . 168 . 0 . 3

Subnet mask: 255 . 255 . 255 . 0

☐ Use router


Router address: 0 . 0 . 0 . 0

☐ IP address is set directly at the device

Interface PN X1

IP address: 192.168.0.3

Subnet mask: 255.255.255.0



Internet Protocol Version 4 (TCP/IPv4) Properties

General

You can get IP settings assigned automatically if your network supports this capability. Otherwise, you need to ask your network administrator for the appropriate IP settings.


☐ Obtain an IP address automatically

☒ Use the following IP address:

IP address: 192 . 168 . 0 . 2

Subnet mask: 255 . 255 . 255 . 0

Default gateway: . . .




To transfer the screens in HMI

To monitor and control the PLC



Start Up Screen

On turning ON the HMI you will see three options:



Press the "Transfer" button to set the HMI device to "Transfer" mode. The "Transfer" mode can only be activated when at least one data channel has been enabled for the transfer.

Press the "Start" button to start the project on the HMI device.

Press the "Settings" button to start the "Settings" page of the Start Center. You can change various settings on this page, for example, the transfer settings.



Siemens KTP-400

6AV2 123-2DB03-0AX0

Introduction to PLC

- Understanding HMI hardware
- How to link HMI with PC / PLC?
- Configure the HMI
- Transfer the Program



Code and Compile
Learning Made Easy

www.codeandcompile.com







Configuring the HMI

You can make the following settings:

- Settings for operation
- Communication settings
- Password protection
- Transfer settings
- Screen saver
- Acoustic signals



DID YOU
KNOW




If the device is configured in portrait, the navigation area is on the top and the work area on the bottom in the display.

Enter Date and Time

Settings -> Date & Time

Press "Date & Time" to open the "Date & Time" dialog.


1. Open the "Date & Time" tab.
2. Select the date and the required time in the drop-down lists.
3. If necessary, enter a time shift with the selection wheel under "Time shift".
4. The set time shift applies even if you fetch the time-of-day from a time server.
5. The resulting time is displayed under "Localtime".






Acoustic Signal

Settings -> Sound



1. Press "Sounds" to open the "Volume" dialog.
2. Set the "Sound" to "ON".
3. Once you have set the "Sound" to "ON" you receive an acoustic feedback in the running project each time you touch the touch screen.



www.codeandcompile.com


System Control/Info

Settings -> System & Info



Configuring Auto-start or wait time

1. Press "System Control/Info" to open the "System Control/Info" dialog.
2. The "Autostart Runtime" tab is open.
3. Switch on the "Autostart" function.
4. Set the wait time with the selection wheel under "Wait".
5. *The wait time is the time in seconds between the appearance of the Start Center and automatic start of the project.*
6. Value range: 0 ... 60 s



Note

Immediate start of the project with a delay time of 0 seconds


The project starts immediately if a delay time of 0 seconds is set. It is now no longer possible to call the Start Center after switching on the HMI device. To handle this situation, you need to configure an operating element with the "Close project" function.

System Control/Info

Settings -> Access Protection

Activating Password Protection

1. Press "System Control/Info" to open the "System Control/Info" dialog.
2. Switch to the "Access Protection" tab.
3. Enter a password in the "Password" text box. Touch the text box. The alphanumerical screen keyboard is displayed.
4. Confirm the password in the "Confirm Password" text box.





Network Interface

Settings -> Network Interface

Displaying information about Network parameters

- Choose either automatic address assignment via "**DHCP – Dynamic Host Configuration Protocol**", or user-specific address assignment.
- If assigning a **user-specific address**, use the screen keyboard to enter valid values in the "**IP address**", "**Subnet mask**" text boxes and if applicable in the "Default gateway" text box.
- Select the transmission rate in the PROFINET network and the transmission type in the "Mode and speed" selection box under "Ethernet parameters". Valid values are 10 Mbps or 100 Mbps and "HDX" (half duplex) or "FDX" (full duplex).
- If the "Auto Negotiation" entry is selected, the transmission type and transmission rate in the PROFINET network will be automatically detected and set.
- If the "LLDP" switch is selected, the HMI device exchanges information with other HMI devices.
- Enter a network name for your HMI device in the "Device name" field under "Profinet".

Interface PN X1

DHCP: OFF

IP address: 172.16.57.100

Subnet mask: 255.255.0.0

Default gateway: 0.0.0.0

Ethernet parameters

Mode and speed: Auto negotiation

LLDP: ON

DID YOU
KNOW





Communication errors can occur if several devices in a network share the same IP address. Assign a unique IP address to every HMI device in the network.



Transfer Settings

Settings -> Transfer Settings





1. Press "Transfer Settings" to open the "Transfer Settings" dialog.
2. Switch on "Enable transfer".
3. To enable automatic transfer, switch on "Automatic".
4. When the automatic transfer is activated, you can start a transfer from the configuring PC while the project is running. The running project is closed in this case and the new project is transferred.
5. The new project starts after it is transferred.



Touch Calibration

Settings -> Touch

1. Press "Touch" to open the "Touch" dialog.
2. Click the "Recalibrate" button.
3. Press any spot on the touch screen within the next 15 seconds.
4. Touch the five calibration crosses one after the other.
5. If you have not touched a calibration cross within the expected range, calibration will start once again.
6. If you have touched all calibration crosses within the expected range, calibration is complete and will be saved.






Display

Settings -> Display

1. Press "Display" to open the "Display" dialog.
2. Select the screen orientation:
 - – "0° (Landscape)" for landscape
 - – "90° (Portrait)" for portrait
3. Use the "Brightness" slider to set the screen brightness





Screen Saver

Settings -> Screen Saver

1. Press "Screensaver" to open the "Screensaver" dialog.
2. Switch on the screensaver with "Enable screensaver".
3. Enter the number of minutes with the selection wheel before the screen saver is to be activated under "Wait".
4. You may select values between 1 and 120 minutes.



www.codeandcompile.com

Siemens KTP-400

6AV2 123-2DB03-0AX0

Introduction to PLC

- Understanding HMI hardware
- How to link HMI with PC / PLC?
- Configure the HMI
- Transfer the Program



Code and Compile
Learning Made Easy

www.codeandcompile.com





Transfer – PC to HMI

You can start the "Transfer" mode **manually** or **automatically** on the HMI device. Transferred data is written directly to internal flash memory of the HMI device

AUTOMATIC TRANSFER MODE

If automatic transfer is activated, the HMI device automatically changes to **"Transfer" mode at runtime as soon as a transfer is started on the connected configuration PC.**

REQUIREMENTS

- The project is open in WinCC.
- The project is compiled.
- The HMI device is connected to a configuration PC.
- The data channel parameters are assigned on the HMI device.
- The automatic transfer is enabled in the Start Center.

DID YOU
KNOW




If automatic transfer is activated on the HMI device and a transfer is initiated on the configuration PC, the project currently running is automatically stopped. The HMI device then automatically switches to "Transfer" mode.






Transfer – Sample Program

**Step 1 – Open TIA
Add new Device**







Step 2 – Select your model





Transfer – Sample Program

Step 3 – Setup initial requirements




Transfer – Sample Program

Step 3 – Setup initial requirements



Transfer – Sample Program


Step 4 – Sample Screens are ready now confirm the IP Addresses



Transfer – Sample Program



Step 4 – Sample Screens are ready now confirm the IP Addresses



☒ Set IP address in the project

IP address: 192 . 168 . 0 . 3

Subnet mask: 255 . 255 . 255 . 0

☐ Use router

Router address: 0 . 0 . 0 . 0

☐ IP address is set directly at the device

IP address in TIA Software

Internet Protocol Version 4 (TCP/IPv4) Properties

General

You can get IP settings assigned automatically if your network supports this capability. Otherwise, you need to ask your network administrator for the appropriate IP settings.

☐ Obtain an IP address automatically

☒ Use the following IP address:

IP address: 192 . 168 . 0 . 2

Subnet mask: 255 . 255 . 255 . 0

Default gateway: . . .

☐ Obtain DNS server address automatically

☒ Use the following DNS server addresses:

Preferred DNS server: . . .


Alternate DNS server: . . .

☐ Validate settings upon exit

Advanced...


OK Cancel

IP address in PC



IP address in HMI Device


Step 5 – Click on 'Download to Device' icon






Transfer – Sample Program

Step 6 – Select your Ethernet device and Load the program



Find your Ethernet Device

Click Start Search




You will find your device soon

Click Load to start transfer

Make sure that you connect PC and HMI with Ethernet cable and your HMI device is assigned a unique address in the network.

Transfer – Sample Program

Congratulations! You just learned how to Download sample screen in HMI



Thank you

*Get copy of this presentation
in the course!*

Next Lesson !

- Understanding various HMI Elements to design and monitor control screens

www.codeandcompile.com



Code and Compile
Learning Made Easy

www.codeandcompile.com

