

Task3\_V15

Totally Integrated Automation Portal																																																																																																																																						
<div>Table of contents</div> <div>Task3_V15</div> <table><tr><td>PLC_1 [CPU 1212C AC/DC/Rly]</td><td>4 - 1</td></tr><tr><td>Program blocks</td><td></td></tr><tr><td>Main [OB1]</td><td>5 - 1</td></tr><tr><td>Operation_mode_DB [DB3]</td><td>6 - 1</td></tr><tr><td>Operation modes</td><td></td></tr><tr><td>Operation_modes [FB1]</td><td>7 - 1</td></tr><tr><td>Operation_modes_DB [DB2]</td><td>8 - 1</td></tr><tr><td>System blocks</td><td></td></tr><tr><td>Program resources</td><td></td></tr><tr><td>PUT_DB [DB4]</td><td>9 - 1</td></tr><tr><td>Put</td><td>10 - 1</td></tr><tr><td>Technology objects</td><td>11 - 1</td></tr><tr><td>PLC tags</td><td></td></tr><tr><td>Default tag table [43]</td><td></td></tr><tr><td>PLC tags</td><td>12 - 1</td></tr><tr><td>User constants</td><td>13 - 1</td></tr><tr><td>PLC data types</td><td></td></tr><tr><td>SignalLight</td><td>14 - 1</td></tr><tr><td>OperationModes</td><td>15 - 1</td></tr><tr><td>Watch and force tables</td><td></td></tr><tr><td>Force table</td><td>16 - 1</td></tr><tr><td>Watch table_1</td><td>17 - 1</td></tr><tr><td>Traces</td><td>18 - 1</td></tr><tr><td>Measurements</td><td>19 - 1</td></tr><tr><td>Combined measurements</td><td>20 - 1</td></tr><tr><td>PLC alarm text lists</td><td>21 - 1</td></tr><tr><td>Local modules</td><td>22 - 1</td></tr><tr><td>Distributed I/O</td><td></td></tr><tr><td>PROFINET IO-System (100): PN/IE_1</td><td>23 - 1</td></tr><tr><td>PLC_2 [CPU 1212C AC/DC/Rly]</td><td>24 - 1</td></tr><tr><td>Program blocks</td><td></td></tr><tr><td>Main [OB1]</td><td>25 - 1</td></tr><tr><td>Operation_mode_DB [DB3]</td><td>26 - 1</td></tr><tr><td>Operation modes</td><td></td></tr><tr><td>Operation_modes [FB1]</td><td>27 - 1</td></tr><tr><td>Operation_modes_DB [DB2]</td><td>28 - 1</td></tr><tr><td>Technology objects</td><td>29 - 1</td></tr><tr><td>PLC tags</td><td></td></tr><tr><td>Default tag table [41]</td><td></td></tr><tr><td>PLC tags</td><td>30 - 1</td></tr><tr><td>User constants</td><td>31 - 1</td></tr><tr><td>PLC data types</td><td></td></tr><tr><td>SignalLight</td><td>32 - 1</td></tr><tr><td>OperationModes</td><td>33 - 1</td></tr><tr><td>Watch and force tables</td><td></td></tr><tr><td>Force table</td><td>34 - 1</td></tr><tr><td>Watch table_1</td><td>35 - 1</td></tr><tr><td>Traces</td><td>36 - 1</td></tr><tr><td>Measurements</td><td>37 - 1</td></tr><tr><td>Combined measurements</td><td>38 - 1</td></tr><tr><td>PLC alarm text lists</td><td>39 - 1</td></tr><tr><td>Local modules</td><td>40 - 1</td></tr><tr><td>HMI_1 [KTP400 Basic PN]</td><td>41 - 1</td></tr><tr><td>Runtime settings</td><td>42 - 1</td></tr><tr><td>Screens</td><td></td></tr><tr><td>Root screen</td><td>43 - 1</td></tr><tr><td>Screen management</td><td></td></tr><tr><td>Templates</td><td></td></tr><tr><td>Template_1</td><td>44 - 1</td></tr><tr><td>Global screen</td><td>45 - 1</td></tr><tr><td>HMI tags</td><td></td></tr><tr><td>Default tag table [17]</td><td>46 - 1</td></tr><tr><td>Connections</td><td>47 - 1</td></tr><tr><td>HMI alarms</td><td></td></tr><tr><td>Discrete alarms</td><td>48 - 1</td></tr><tr><td>Analog alarms</td><td>49 - 1</td></tr></table>			PLC_1 [CPU 1212C AC/DC/Rly]	4 - 1	Program blocks		Main [OB1]	5 - 1	Operation_mode_DB [DB3]	6 - 1	Operation modes		Operation_modes [FB1]	7 - 1	Operation_modes_DB [DB2]	8 - 1	System blocks		Program resources		PUT_DB [DB4]	9 - 1	Put	10 - 1	Technology objects	11 - 1	PLC tags		Default tag table [43]		PLC tags	12 - 1	User constants	13 - 1	PLC data types		SignalLight	14 - 1	OperationModes	15 - 1	Watch and force tables		Force table	16 - 1	Watch table_1	17 - 1	Traces	18 - 1	Measurements	19 - 1	Combined measurements	20 - 1	PLC alarm text lists	21 - 1	Local modules	22 - 1	Distributed I/O		PROFINET IO-System (100): PN/IE_1	23 - 1	PLC_2 [CPU 1212C AC/DC/Rly]	24 - 1	Program blocks		Main [OB1]	25 - 1	Operation_mode_DB [DB3]	26 - 1	Operation modes		Operation_modes [FB1]	27 - 1	Operation_modes_DB [DB2]	28 - 1	Technology objects	29 - 1	PLC tags		Default tag table [41]		PLC tags	30 - 1	User constants	31 - 1	PLC data types		SignalLight	32 - 1	OperationModes	33 - 1	Watch and force tables		Force table	34 - 1	Watch table_1	35 - 1	Traces	36 - 1	Measurements	37 - 1	Combined measurements	38 - 1	PLC alarm text lists	39 - 1	Local modules	40 - 1	HMI_1 [KTP400 Basic PN]	41 - 1	Runtime settings	42 - 1	Screens		Root screen	43 - 1	Screen management		Templates		Template_1	44 - 1	Global screen	45 - 1	HMI tags		Default tag table [17]	46 - 1	Connections	47 - 1	HMI alarms		Discrete alarms	48 - 1	Analog alarms	49 - 1
PLC_1 [CPU 1212C AC/DC/Rly]	4 - 1																																																																																																																																					
Program blocks																																																																																																																																						
Main [OB1]	5 - 1																																																																																																																																					
Operation_mode_DB [DB3]	6 - 1																																																																																																																																					
Operation modes																																																																																																																																						
Operation_modes [FB1]	7 - 1																																																																																																																																					
Operation_modes_DB [DB2]	8 - 1																																																																																																																																					
System blocks																																																																																																																																						
Program resources																																																																																																																																						
PUT_DB [DB4]	9 - 1																																																																																																																																					
Put	10 - 1																																																																																																																																					
Technology objects	11 - 1																																																																																																																																					
PLC tags																																																																																																																																						
Default tag table [43]																																																																																																																																						
PLC tags	12 - 1																																																																																																																																					
User constants	13 - 1																																																																																																																																					
PLC data types																																																																																																																																						
SignalLight	14 - 1																																																																																																																																					
OperationModes	15 - 1																																																																																																																																					
Watch and force tables																																																																																																																																						
Force table	16 - 1																																																																																																																																					
Watch table_1	17 - 1																																																																																																																																					
Traces	18 - 1																																																																																																																																					
Measurements	19 - 1																																																																																																																																					
Combined measurements	20 - 1																																																																																																																																					
PLC alarm text lists	21 - 1																																																																																																																																					
Local modules	22 - 1																																																																																																																																					
Distributed I/O																																																																																																																																						
PROFINET IO-System (100): PN/IE_1	23 - 1																																																																																																																																					
PLC_2 [CPU 1212C AC/DC/Rly]	24 - 1																																																																																																																																					
Program blocks																																																																																																																																						
Main [OB1]	25 - 1																																																																																																																																					
Operation_mode_DB [DB3]	26 - 1																																																																																																																																					
Operation modes																																																																																																																																						
Operation_modes [FB1]	27 - 1																																																																																																																																					
Operation_modes_DB [DB2]	28 - 1																																																																																																																																					
Technology objects	29 - 1																																																																																																																																					
PLC tags																																																																																																																																						
Default tag table [41]																																																																																																																																						
PLC tags	30 - 1																																																																																																																																					
User constants	31 - 1																																																																																																																																					
PLC data types																																																																																																																																						
SignalLight	32 - 1																																																																																																																																					
OperationModes	33 - 1																																																																																																																																					
Watch and force tables																																																																																																																																						
Force table	34 - 1																																																																																																																																					
Watch table_1	35 - 1																																																																																																																																					
Traces	36 - 1																																																																																																																																					
Measurements	37 - 1																																																																																																																																					
Combined measurements	38 - 1																																																																																																																																					
PLC alarm text lists	39 - 1																																																																																																																																					
Local modules	40 - 1																																																																																																																																					
HMI_1 [KTP400 Basic PN]	41 - 1																																																																																																																																					
Runtime settings	42 - 1																																																																																																																																					
Screens																																																																																																																																						
Root screen	43 - 1																																																																																																																																					
Screen management																																																																																																																																						
Templates																																																																																																																																						
Template_1	44 - 1																																																																																																																																					
Global screen	45 - 1																																																																																																																																					
HMI tags																																																																																																																																						
Default tag table [17]	46 - 1																																																																																																																																					
Connections	47 - 1																																																																																																																																					
HMI alarms																																																																																																																																						
Discrete alarms	48 - 1																																																																																																																																					
Analog alarms	49 - 1																																																																																																																																					

Totally Integrated Automation Portal																																																						
<table><tr><td>Alarm groups</td><td>50 - 1</td></tr><tr><td>Alarm classes</td><td>51 - 1</td></tr><tr><td>System events</td><td>52 - 1</td></tr><tr><td>Recipes</td><td>53 - 1</td></tr><tr><td>Historical data</td><td></td></tr><tr><td>Datalogs</td><td>54 - 1</td></tr><tr><td>AlarmLogs</td><td>55 - 1</td></tr><tr><td>Scheduled tasks</td><td>56 - 1</td></tr><tr><td>Text and graphic lists</td><td></td></tr><tr><td>Text lists</td><td>57 - 1</td></tr><tr><td>Graphic lists</td><td>58 - 1</td></tr><tr><td>User administration</td><td></td></tr><tr><td>User</td><td>59 - 1</td></tr><tr><td>Groups</td><td>60 - 1</td></tr><tr><td>Authorizations</td><td>61 - 1</td></tr><tr><td>Ungrouped devices</td><td>62 - 1</td></tr><tr><td>Security settings</td><td>63 - 1</td></tr><tr><td>Common data</td><td></td></tr><tr><td>Alarm classes</td><td>64 - 1</td></tr><tr><td>Logs</td><td>65 - 1</td></tr><tr><td>Styles</td><td>66 - 1</td></tr><tr><td>Languages &amp; resources</td><td></td></tr><tr><td>Project languages</td><td>67 - 1</td></tr><tr><td>Project texts</td><td></td></tr><tr><td>Project texts</td><td>68 - 1</td></tr><tr><td>Project graphics</td><td>69 - 1</td></tr></table>			Alarm groups	50 - 1	Alarm classes	51 - 1	System events	52 - 1	Recipes	53 - 1	Historical data		Datalogs	54 - 1	AlarmLogs	55 - 1	Scheduled tasks	56 - 1	Text and graphic lists		Text lists	57 - 1	Graphic lists	58 - 1	User administration		User	59 - 1	Groups	60 - 1	Authorizations	61 - 1	Ungrouped devices	62 - 1	Security settings	63 - 1	Common data		Alarm classes	64 - 1	Logs	65 - 1	Styles	66 - 1	Languages & resources		Project languages	67 - 1	Project texts		Project texts	68 - 1	Project graphics	69 - 1
Alarm groups	50 - 1																																																					
Alarm classes	51 - 1																																																					
System events	52 - 1																																																					
Recipes	53 - 1																																																					
Historical data																																																						
Datalogs	54 - 1																																																					
AlarmLogs	55 - 1																																																					
Scheduled tasks	56 - 1																																																					
Text and graphic lists																																																						
Text lists	57 - 1																																																					
Graphic lists	58 - 1																																																					
User administration																																																						
User	59 - 1																																																					
Groups	60 - 1																																																					
Authorizations	61 - 1																																																					
Ungrouped devices	62 - 1																																																					
Security settings	63 - 1																																																					
Common data																																																						
Alarm classes	64 - 1																																																					
Logs	65 - 1																																																					
Styles	66 - 1																																																					
Languages & resources																																																						
Project languages	67 - 1																																																					
Project texts																																																						
Project texts	68 - 1																																																					
Project graphics	69 - 1																																																					

Totally Integrated Automation Portal							
Task3_V15							
Project							
Name:	Task3_V15	Creation time:	2/7/2019 8:23:08 PM	Last change	4/27/2019 12:31:37 PM	Author:	RV
Last modified by:	RV	Version:					
Comment:							
Operating system							
Name				Description			
Operating system				Microsoft Windows 8.1 Pro			
Version of the operating system				6.3.9600.0			
Operating system service pack							
Version of the Internet Explorer				11.0.9600.19236			
Computer name				RVHOME			
User name				RVHOME\RV			
Installation path of the TIA Portal				D:\Program Files\Siemens\Automation\Portal V15			
Components							
Name		Version		Release			
TIA Portal Multiuser Server V14 - TIA Portal Multiuser Server Single Setup-Package V14.0 SP1 (MUSERVERV14)		V14.0 + SP1		V14.00.01.00_12.01.00.01			
TIA Portal Multiuser Server V15 - TIA Portal Multiuser Server Single Setup-Package V15.0 (MUSERVERV15)		V15.0		V15.00.00.00_26.01.00.01			
TIA Administrator - AWB Licensing Module V1.0 (TIAADMIN)		V1.0		V01.00.00.00_01.25.00.02			
TIA Administrator - AWB Software Management V1.0 (TIAADMIN)		V1.0		V01.00.00.00_01.25.00.02			
TIA Administrator - TIA UMC Agent Configurator Module V1.0 (TIAADMIN)		V1.0		V01.00.00.00_01.25.00.02			
TIA Administrator - TIA Administrator V1.0 (TIAADMIN)		V1.0		V01.00.00.00_01.25.00.02			
Totally Integrated Automation Portal V15 - TIA Portal Single SetupPackage V15.0 (TIAP15)		V15.0		V15.00.00.00_26.01.00.01			
Siemens Totally Integrated Automation Portal V15 - HM All Editions Single SetupPackage V15.0 (TIAP15)		V15.0		V15.00.00.00_26.01.00.01			
Siemens Totally Integrated Automation Portal V15 - HM NoBasic Single SetupPackage V15.0 (TIAP15)		V15.0		V15.00.00.00_26.01.00.01			
Siemens Totally Integrated Automation Portal V15 - Hardware Support Base Package 0 V15.0 (TIAP15)		V15.0		V15.00.00.00_01.01.00.02			
Siemens Totally Integrated Automation Portal V15 - Multiuser Client Single SetupPackage V15.0 (TIAP15)		V15.0		V15.00.00.00_26.01.00.01			
Siemens Totally Integrated Automation Portal V15 - STEP 7 Single Setup-Package V15.0 (TIAP15)		V15.0		V15.00.00.00_26.01.00.01			
Siemens Totally Integrated Automation Portal V15 - Hardware Support Base Package 02 V15.0 (TIAP15)		V15.0		V15.00.00.00_01.01.00.02			
Siemens Totally Integrated Automation Portal V15 - Hardware Support Base Package 03 V15.0 (TIAP15)		V15.0		V15.00.00.00_01.01.00.02			
Siemens Totally Integrated Automation Portal V15 - Hardware Support Base Package 04 V15.0 (TIAP15)		V15.0		V15.00.00.00_01.01.00.02			
Siemens Totally Integrated Automation Portal V15 - Support Base Package TO-01 V15.0 (TIAP15)		V15.0		V15.00.00.00_01.01.00.02			
Siemens Totally Integrated Automation Portal V15 - Support Base Package TO-02 V15.0 (TIAP15)		V15.0		V15.00.00.00_01.01.00.02			
Siemens Totally Integrated Automation Portal V15 - Hardware Support Base Package WCF-01 V15.0 (TIAP15)		V15.0		V15.00.00.00_01.01.00.02			
Siemens Totally Integrated Automation Portal V15 - TIACOMP CHECK Single SetupPackage V15.0 (TIAP15)		V15.0		V15.00.00.00_26.01.00.01			
Siemens Totally Integrated Automation Portal V15 - Simatic Single Setup-Package V15.0 (TIAP15)		V15.0		V15.00.00.00_26.01.00.01			
Siemens Totally Integrated Automation Portal V15 - WinCC Single Setup-Package V15.0 (TIAP15)		V15.0		V15.00.00.00_26.01.00.01			
Siemens Totally Integrated Automation Portal V15 - Openness SetupPackage V15.0 (TIAP15)		V15.0		V15.00.00.00_26.01.00.01			
Siemens Totally Integrated Automation Portal V15 - WinCC Transfer Current All Single SetupPackage V15.0 (TIAP15)		V15.0		V15.00.00.00_26.01.00.01			
Siemens Totally Integrated Automation Portal V15 - WinCC Transfer Current CAP Single SetupPackage V15.0 (TIAP15)		V15.0		V15.00.00.00_26.01.00.01			
Siemens Totally Integrated Automation Portal V15 - WinCC Transfer Mandatory Single SetupPackage V15.0 (TIAP15)		V15.0		V15.00.00.00_26.01.00.01			
User Management Component - UserManagementComponentx64 01.9 (UMC64)		V01.9		V01.09.00.00_04.13.00.03			
WinCC Runtime Advanced V15.0 - SIMATIC WinCC Runtime Advanced V15.0 (HMIRTM_V11)		V15.0		V15.00.00.00_26.01.00.01			
WinCC Runtime Advanced V15.0 - HMIRTM Tagging Package 01 Single SetupPackage V15.0 (HMIRTM_V11)		V15.0		V15.00.00.00_26.01.00.01			
SIMATIC S7-PLCSIM (S7_PLCSIM_V13)		V13.0 + SP1 + Upd1		V13.00.01.01_01.75.00.01			
Siemens Totally Integrated Automation Portal V13 - SIMATIC S7-PLCSIM V13.0 + SP1 + Upd1 (S7_PLCSIM_V13)		V13.0 + SP1 + Upd1		V13.00.01.01_01.75.00.01			
Siemens Totally Integrated Automation Portal V15 - Simatic Single Setup-Package 32 Bit V15.0 (TIAP15)		V15.0		V15.00.00.00_26.01.00.01			
Siemens Totally Integrated Automation Portal V15 - WinCC Single Setup-Package 32 Bit V15.0 (TIAP15)		V15.0		V15.00.00.00_26.01.00.01			
SIMATIC HMI License Manager Panel Plugin (x64)		15.0.0.0		V15.00.00.00_26.01.00.01			
SIMATIC WinCC Runtime Advanced Driver (x64)		15.0.0.0		V15.00.00.00_26.01.00.01			
SIMATIC NCM FWL 64		5.6.0.3		K5.6.0.3_1.1.0.2			
NCM GPRS 64		01.02.00.00		V1.2.0.0_2.1.0.1			
SIMATIC PLCSIM 64		14.00		14.00.00.00_29.01.00.01			
PlcSimPlus64		13.01		V13.00.01.00_25.01.00.01			
SIMATIC Device Drivers		9.2		09.02.00.00_01.15.00.04			
Automation Software Updater		02.03.0000		V02.03.00.00_01.01.00.48			
SIEMENS OPC		3.9		03.09.08.00_01.07.00.01			

Totally Integrated Automation Portal																																																		
<table><tr><th>Name</th><th>Version</th><th>Release</th></tr><tr><td>SIMATIC HMI ProSave</td><td>15.0.0.0</td><td>V15.00.00.00_26.01.00.01</td></tr><tr><td>SIMATIC HMI Symbol Library</td><td>15.0.0.0</td><td>V15.00.00.00_26.01.00.01</td></tr><tr><td>SIMATIC HMI Touch Input</td><td>15.0.0.0</td><td>V15.00.00.00_26.01.00.01</td></tr><tr><td>SIMATIC Device Drivers WoW</td><td>29.2</td><td>29.02.00.00_01.15.00.04</td></tr><tr><td>SIMATIC Event Database</td><td>5.6</td><td>05.06.00.00_03.01.00.01</td></tr><tr><td>SeCon</td><td>2.5</td><td>V02.05.00.00_01.05.00.04</td></tr><tr><td>WinCC Runtime Advanced Simulator</td><td>15.0.0.0</td><td>V15.00.00.00_26.01.00.01</td></tr></table>	Name	Version	Release	SIMATIC HMI ProSave	15.0.0.0	V15.00.00.00_26.01.00.01	SIMATIC HMI Symbol Library	15.0.0.0	V15.00.00.00_26.01.00.01	SIMATIC HMI Touch Input	15.0.0.0	V15.00.00.00_26.01.00.01	SIMATIC Device Drivers WoW	29.2	29.02.00.00_01.15.00.04	SIMATIC Event Database	5.6	05.06.00.00_03.01.00.01	SeCon	2.5	V02.05.00.00_01.05.00.04	WinCC Runtime Advanced Simulator	15.0.0.0	V15.00.00.00_26.01.00.01																										
Name	Version	Release																																																
SIMATIC HMI ProSave	15.0.0.0	V15.00.00.00_26.01.00.01																																																
SIMATIC HMI Symbol Library	15.0.0.0	V15.00.00.00_26.01.00.01																																																
SIMATIC HMI Touch Input	15.0.0.0	V15.00.00.00_26.01.00.01																																																
SIMATIC Device Drivers WoW	29.2	29.02.00.00_01.15.00.04																																																
SIMATIC Event Database	5.6	05.06.00.00_03.01.00.01																																																
SeCon	2.5	V02.05.00.00_01.05.00.04																																																
WinCC Runtime Advanced Simulator	15.0.0.0	V15.00.00.00_26.01.00.01																																																
<table><tr><th colspan="3">Products</th></tr><tr><th>Name</th><th>Version</th><th>Release</th></tr><tr><td>TIA Portal Multiuser Server</td><td>V14.0 SP1</td><td>V14.00.01.00_12.01.00.01</td></tr><tr><td>TIA Portal Multiuser Server</td><td>V15.0</td><td>V15.00.00.00_26.01.00.01</td></tr><tr><td>TIA Administrator</td><td>V1.0</td><td>V01.00.00.00_01.00.00.01</td></tr><tr><td>SIMATIC STEP 7 Professional</td><td>V14.0 SP1</td><td>V14.00.01.00_12.01.00.01</td></tr><tr><td>SIMATIC WinCC Basic</td><td>V14.0 SP1</td><td>V14.00.01.00_12.01.00.01</td></tr><tr><td>SIMATIC STEP 7 Professional - WinCC Advanced</td><td>V15.0</td><td>V15.00.00.00_26.01.00.01</td></tr><tr><td>User Management Component x64</td><td>V1.9</td><td>V01.09.00.00_04.12.00.03</td></tr><tr><td>SIMATIC WinCC Runtime Advanced Simulation</td><td>V15.0</td><td>V15.00.00.00_26.01.00.01</td></tr><tr><td>SIMATIC S7-PLCSIM</td><td>V13.0 SP1 Upd1</td><td>V13.00.01.01_01.75.00.01</td></tr><tr><td>SIMATIC STEP 7 Professional</td><td>V13.0 SP1</td><td>V13.00.01.00_25.01.00.01</td></tr><tr><td>SIMATIC WinCC Basic</td><td>V13.0 SP1</td><td>V13.00.01.00_25.01.00.01</td></tr><tr><td>Automation License Manager</td><td>V6.0</td><td>06.00.00.00_01.22.00.08</td></tr><tr><td>S7-PLCSIM</td><td>V5.4 + SP7</td><td>V05.04.07.00_01.44.00.01</td></tr><tr><td>SIMATIC ProSave</td><td>V15.0</td><td>V15.00.00.00_26.01.00.01</td></tr></table>	Products			Name	Version	Release	TIA Portal Multiuser Server	V14.0 SP1	V14.00.01.00_12.01.00.01	TIA Portal Multiuser Server	V15.0	V15.00.00.00_26.01.00.01	TIA Administrator	V1.0	V01.00.00.00_01.00.00.01	SIMATIC STEP 7 Professional	V14.0 SP1	V14.00.01.00_12.01.00.01	SIMATIC WinCC Basic	V14.0 SP1	V14.00.01.00_12.01.00.01	SIMATIC STEP 7 Professional - WinCC Advanced	V15.0	V15.00.00.00_26.01.00.01	User Management Component x64	V1.9	V01.09.00.00_04.12.00.03	SIMATIC WinCC Runtime Advanced Simulation	V15.0	V15.00.00.00_26.01.00.01	SIMATIC S7-PLCSIM	V13.0 SP1 Upd1	V13.00.01.01_01.75.00.01	SIMATIC STEP 7 Professional	V13.0 SP1	V13.00.01.00_25.01.00.01	SIMATIC WinCC Basic	V13.0 SP1	V13.00.01.00_25.01.00.01	Automation License Manager	V6.0	06.00.00.00_01.22.00.08	S7-PLCSIM	V5.4 + SP7	V05.04.07.00_01.44.00.01	SIMATIC ProSave	V15.0	V15.00.00.00_26.01.00.01		
Products																																																		
Name	Version	Release																																																
TIA Portal Multiuser Server	V14.0 SP1	V14.00.01.00_12.01.00.01																																																
TIA Portal Multiuser Server	V15.0	V15.00.00.00_26.01.00.01																																																
TIA Administrator	V1.0	V01.00.00.00_01.00.00.01																																																
SIMATIC STEP 7 Professional	V14.0 SP1	V14.00.01.00_12.01.00.01																																																
SIMATIC WinCC Basic	V14.0 SP1	V14.00.01.00_12.01.00.01																																																
SIMATIC STEP 7 Professional - WinCC Advanced	V15.0	V15.00.00.00_26.01.00.01																																																
User Management Component x64	V1.9	V01.09.00.00_04.12.00.03																																																
SIMATIC WinCC Runtime Advanced Simulation	V15.0	V15.00.00.00_26.01.00.01																																																
SIMATIC S7-PLCSIM	V13.0 SP1 Upd1	V13.00.01.01_01.75.00.01																																																
SIMATIC STEP 7 Professional	V13.0 SP1	V13.00.01.00_25.01.00.01																																																
SIMATIC WinCC Basic	V13.0 SP1	V13.00.01.00_25.01.00.01																																																
Automation License Manager	V6.0	06.00.00.00_01.22.00.08																																																
S7-PLCSIM	V5.4 + SP7	V05.04.07.00_01.44.00.01																																																
SIMATIC ProSave	V15.0	V15.00.00.00_26.01.00.01																																																

Totally Integrated Automation Portal		
--------------------------------------	--	--

Task3\_V15


PLC\_1 [CPU 1212C AC/DC/Rly]

PLC_1					
General\Project information					
Name	PLC_1	Author	RV	Comment	
Slot	1	Rack	0		
General\Catalog information					
Short designation	CPU 1212C AC/DC/Rly	Description	Work memory 75 KB; 120/240VAC power supply with DI8 x 24VDC SINK/ SOURCE, DQ6 x relay and AI2 on board; 4 high-speed counters (expandable with digital signal board) and 4 pulse outputs on board; signal board expands on-board I/O; up to 3 communication modules for serial communication; up to 2 signal modules for I/O expansion; 0.04 ms/1000 instructions; PROFINET interface for programming, HMI and PLC to PLC communication	Article number	6ES7 212-1BE40-0XB0
Firmware version	V4.1				
General\Identification & Maintenance					
Plant designation		Location identifier		Installation date	2019-02-07 20:23:25.154
Additional information					
PROFINET interface [X1]\General					
Name	PROFINET interface_1	Author	RV	Comment	
PROFINET interface [X1]\General\Project information					
Name	DI 8/DQ 6_1	Comment		Name	AI 2_1
Comment					
PROFINET interface [X1]\Ethernet addresses\Interface networked with					
Subnet:	PN/IE_1				
PROFINET interface [X1]\Ethernet addresses\IP protocol					
IP configuration	Set IP address in the project	IP address:	192.168.1.100	Subnet mask:	255.255.255.0
Use router	False				
PROFINET interface [X1]\Ethernet addresses\PROFINET					
PROFINET device name is set directly at the device	False	Generate PROFINET device name automatically	True	PROFINET device name:	plc_1
Converted name:	plcxb1d0ed	Device number:	0		
PROFINET interface [X1]\Time synchronization					
Enable time synchronization via NTP server	Enable time synchronization via NTP server		IP addresses	Server 1	0.0.0.0
Server 2	0.0.0.0	Server 3	0.0.0.0	Server 4	0.0.0.0
Update interval	10sec				
PROFINET interface [X1]\Digital inputs\Channel0					
Channel address	I0.0	Input filters	6.4 millisec	Enable pulse catch	0
PROFINET interface [X1]\Digital inputs\Channel0\					
Enable rising edge detection	0	RidPrefixRisingEdgeEvent	49152	Event name:	0
Hardware interrupt:	0	Rising edge0	Rising edge0		
PROFINET interface [X1]\Digital inputs\Channel0\					
Enable falling edge detection	0	RidPrefixFallingEdgeEvent	49280	Event name:	0
Hardware interrupt:	0	Falling edge0	Falling edge0		
PROFINET interface [X1]\Digital inputs\Channel1					
Channel address	I0.1	Input filters	6.4 millisec	Enable pulse catch	0
PROFINET interface [X1]\Digital inputs\Channel1\					
Enable rising edge detection	0	RidPrefixRisingEdgeEvent	49153	Event name:	0
Hardware interrupt:	0	Rising edge1	Rising edge1		
PROFINET interface [X1]\Digital inputs\Channel1\					
Enable falling edge detection	0	RidPrefixFallingEdgeEvent	49281	Event name:	0
Hardware interrupt:	0	Falling edge1	Falling edge1		
PROFINET interface [X1]\Digital inputs\Channel2					
Channel address	I0.2	Input filters	6.4 millisec	Enable pulse catch	0
PROFINET interface [X1]\Digital inputs\Channel2\					
Enable rising edge detection	0	RidPrefixRisingEdgeEvent	49154	Event name:	0
Hardware interrupt:	0	Rising edge2	Rising edge2		
PROFINET interface [X1]\Digital inputs\Channel2\					
Enable falling edge detection	0	RidPrefixFallingEdgeEvent	49282	Event name:	0
Hardware interrupt:	0	Falling edge2	Falling edge2		
PROFINET interface [X1]\Digital inputs\Channel3					
Channel address	I0.3	Input filters	6.4 millisec	Enable pulse catch	0
PROFINET interface [X1]\Digital inputs\Channel3\					
Enable rising edge detection	0	RidPrefixRisingEdgeEvent	49155	Event name:	0
Hardware interrupt:	0	Rising edge3	Rising edge3		
PROFINET interface [X1]\Digital inputs\Channel3\					
Enable falling edge detection	0	RidPrefixFallingEdgeEvent	49283	Event name:	0
Hardware interrupt:	0	Falling edge3	Falling edge3		

--	--	--

Totally Integrated Automation Portal						
PROFINET interface [X1]\Digital inputs\Channel4						
Channel address	I0.4	Input filters	6.4 millise	Enable pulse catch	0	
PROFINET interface [X1]\Digital inputs\Channel4\						
Enable rising edge detection	0	RidPrefixRisingEdgeEvent	49156	Event name:	0	
Hardware interrupt:	0	Rising edge4	Rising edge4			
PROFINET interface [X1]\Digital inputs\Channel4\						
Enable falling edge detection	0	RidPrefixFallingEdgeEvent	49284	Event name:	0	
Hardware interrupt:	0	Falling edge4	Falling edge4			
PROFINET interface [X1]\Digital inputs\Channel5						
Channel address	I0.5	Input filters	6.4 millise	Enable pulse catch	0	
PROFINET interface [X1]\Digital inputs\Channel5\						
Enable rising edge detection	0	RidPrefixRisingEdgeEvent	49157	Event name:	0	
Hardware interrupt:	0	Rising edge5	Rising edge5			
PROFINET interface [X1]\Digital inputs\Channel5\						
Enable falling edge detection	0	RidPrefixFallingEdgeEvent	49285	Event name:	0	
Hardware interrupt:	0	Falling edge5	Falling edge5			
PROFINET interface [X1]\Digital inputs\Channel6						
Channel address	I0.6	Input filters	6.4 millise	Enable pulse catch	0	
PROFINET interface [X1]\Digital inputs\Channel6\						
Enable rising edge detection	0	RidPrefixRisingEdgeEvent	49158	Event name:	0	
Hardware interrupt:	0	Rising edge6	Rising edge6			
PROFINET interface [X1]\Digital inputs\Channel6\						
Enable falling edge detection	0	RidPrefixFallingEdgeEvent	49286	Event name:	0	
Hardware interrupt:	0	Falling edge6	Falling edge6			
PROFINET interface [X1]\Digital inputs\Channel7						
Channel address	I0.7	Input filters	6.4 millise	Enable pulse catch	0	
PROFINET interface [X1]\Digital inputs\Channel7\						
Enable rising edge detection	0	RidPrefixRisingEdgeEvent	49159	Event name:	0	
Hardware interrupt:	0	Rising edge7	Rising edge7			
PROFINET interface [X1]\Digital inputs\Channel7\						
Enable falling edge detection	0	RidPrefixFallingEdgeEvent	49287	Event name:	0	
Hardware interrupt:	0	Falling edge7	Falling edge7			
PROFINET interface [X1]\Analog inputs\Noise reduction						
Integration time	50 Hz (20 ms)					
PROFINET interface [X1]\Analog inputs\Channel0						
Channel address	IW64	Measurement type	Voltage	Voltage range	0..10 V	
Smoothing	Weak (4 cycles)			Enable overflow diagnostics	1	
PROFINET interface [X1]\Analog inputs\Channel1						
Channel address	IW66	Measurement type	Voltage	Voltage range	0..10 V	
Smoothing	Weak (4 cycles)			Enable overflow diagnostics	1	
PROFINET interface [X1]\Digital outputs						
Reaction to CPU STOP	Use substitute value					
PROFINET interface [X1]\Digital outputs\Channel0						
Channel address	Q0.0	Substitute a value of 1 on a change from RUN to STOP.	0			
PROFINET interface [X1]\Digital outputs\Channel1						
Channel address	Q0.1	Substitute a value of 1 on a change from RUN to STOP.	0			
PROFINET interface [X1]\Digital outputs\Channel2						
Channel address	Q0.2	Substitute a value of 1 on a change from RUN to STOP.	0			
PROFINET interface [X1]\Digital outputs\Channel3						
Channel address	Q0.3	Substitute a value of 1 on a change from RUN to STOP.	0			
PROFINET interface [X1]\Digital outputs\Channel4						
Channel address	Q0.4	Substitute a value of 1 on a change from RUN to STOP.	0			
PROFINET interface [X1]\Digital outputs\Channel5						
Channel address	Q0.5	Substitute a value of 1 on a change from RUN to STOP.	0			
PROFINET interface [X1]\Operating mode						
IO controller	True	IO system	PROFINET IO-System (100)	Device number	0	
IO device	False					
PROFINET interface [X1]\I/O addresses\Input addresses						
Start address	0.0	End address	0.7	Organization block	0	
Process image	0					
PROFINET interface [X1]\I/O addresses\Input addresses						
Start address	64	End address	67	Organization block	0	
Process image	0					
PROFINET interface [X1]\I/O addresses\Output addresses						
Start address	0.0	End address	0.7	Organization block	0	
Process image	0					



Totally Integrated Automation Portal						
PROFINET interface [X1]\Advanced options\Interface options						
Support device re- placement without exchangeable medi- um	True	Permit overwriting of device names of all assigned IO devices	False	Use IEC V2.2 LLDP mode	False	
Keep-Alive connec- tion monitoring	30s					
PROFINET interface [X1]\Advanced options\Real time settings\IO communication						
Send clock:	1.000ms					
PROFINET interface [X1]\Advanced options\Real time settings\Real time options						
Calculated bandwidth for cyclic IO data:	0.000ms	Calculated bandwidth for cyclic IO data:	0.000%			
PROFINET interface [X1]\Advanced options\Port [X1 P1]\General						
Name	Port_1	Author	RV	Comment		
PROFINET interface [X1]\Advanced options\Port [X1 P1]\Port interconnection\Local port:						
Local port:	PLC_1\PROFINET interface_1 [X1]\Port_1 [X1 P1]	Medium:	Copper	Cable name:	---	
						
PROFINET interface [X1]\Advanced options\Port [X1 P1]\Port interconnection\Partner port:						
	Monitoring of partner port is not pos- sible	Partner port:	Any partner			
PROFINET interface [X1]\Advanced options\Port [X1 P1]\Port options\Activate						
Activate this port for use	True					
PROFINET interface [X1]\Advanced options\Port [X1 P1]\Port options\Connection						
Transmission rate / duplex:	Automatic	Monitor	False	Enable autonegotia- tion	True	
PROFINET interface [X1]\Advanced options\Port [X1 P1]\Port options\Boundaries						
End of detection of accessible devices	False	End of topology dis- covery	False	End of the sync do- main	False	
PROFINET interface [X1]\Web server access						
Enable Web server us- ing this interface	False	The Web server must also be activated in the properties of the PLC.				
High speed counters (HSC)\HSC1\General\Enable						
Enable this high speed counter	0	Enable this high speed counter	0	Enable this high speed counter	0	
Enable this high speed counter	0	Enable this high speed counter	0	Enable this high speed counter	0	
High speed counters (HSC)\HSC1\General\Project information						
Name	HSC_1	Comment		Name	HSC_2	
Comment		Name	HSC_3	Comment		
Name	HSC_4	Comment		Name	HSC_5	
Comment		Name	HSC_6	Comment		
High speed counters (HSC)\HSC1\I/O addresses\Input addresses						
Start address	1000.0	End address	1003.7	Start address	1004.0	
End address	1007.7	Organization block	0	Start address	1008.0	
End address	1011.7	Organization block	0	Process image	0	
Start address	1012.0	End address	1015.7	Organization block	0	
Process image	0	Start address	1016.0	End address	1019.7	
Organization block	0	Process image	0	Start address	1020.0	
End address	1023.7	Organization block	0	Process image	0	
Organization block	0	Process image	0	Process image	0	
Pulse generators (PTO/PWM)\PTO1/PWM1\General\Enable						
Enable this pulse gen- erator	0	Enable this pulse gen- erator	0			
Pulse generators (PTO/PWM)\PTO1/PWM1\General\Project information						
Name	Pulse_1	Comment		Name	Pulse_2	
Comment						
Pulse generators (PTO/PWM)\PTO1/PWM1\I/O addresses\Output addresses						
Start address	1000.0	End address	1001.7	Start address	1002.0	
End address	1003.7	Organization block	0	Organization block	0	
Process image	0	Process image	0			
Startup						
Startup after POWER ON	Warm restart - mode before POWER OFF	Comparison preset to actual configuration	Startup CPU even if mismatch	Configuration time	60000ms	
OBs should be inter- ruptible	1					
Cycle						
Cycle monitoring time	150ms			Enable minimum cy- cle time for cyclic OBs	0	
Minimum cycle time	1ms					
Communication load						
Cycle load due to communication	20%					
System and clock memory\System memory bits						
Enable the use of sys- tem memory byte	1	Address of system memory byte (MBx)	1	First cycle	%M1.0 (FirstScan)	
Diagnostic status changed	%M1.1 (DiagStatusUpdate)	Always 1 (high)	%M1.2 (AlwaysTRUE)	Always 0 (low)	%M1.3 (AlwaysFALSE)	



Totally Integrated Automation Portal

System and clock memory\Clock memory bits

Enable the use of clock memory byte	1	Address of clock memory byte (MBx)	0	10 Hz clock	%M0.0
5 Hz clock	%M0.1 (Clock_5Hz)	2.5 Hz clock	%M0.2 (Clock_2.5Hz)	2 Hz clock	%M0.3 (Clock_2Hz)
1.25 Hz clock	%M0.4 (Clock_1.25Hz)	1 Hz clock	%M0.5 (Clock_1Hz)	0.625 Hz clock	%M0.6 (Clock_0.625Hz)
0.5 Hz clock	%M0.7 (Clock_0.5Hz)				

Web server\General

Activate Web server on all modules of this device	False	Permit access only with HTTPS	True		
---	-------	-------------------------------	------	--	--

Web server\Automatic update

Enable automatic update	True	Update interval	0s		
-------------------------	------	-----------------	----	--	--

Web server\User interface languages

Assign project language		User interface languages
English (United States)		German
English (United States)		English
English (United States)		French
English (United States)		Spanish
English (United States)		Italian
English (United States)		Chinese (simplified)

Web server\User management

User name		User rights
Everybody		

Web server\User defined web pages

Application name	HTML source path	Default HTML page	Files with dynamic content	Web DB number	Fragment DB number
		index.htm	.htm;.html	333	334

Web server\Overview of interfaces

Device	Interface	Enabled web server access
PLC_1	PROFINET interface_1	False

User interface languages

Assign project language		User interface languages
English (United States)		German
English (United States)		English
English (United States)		French
English (United States)		Spanish
English (United States)		Italian
English (United States)		Chinese (simplified)

Time of day\Local time

Time zone	(UTC +01:00) Berlin, Bern, Brussels, Rome, Stockholm, Vienna	
-----------	--	--

Time of day\Daylight saving time

Activate daylight saving time	1	Difference between standard and daylight saving time	60mins	
-------------------------------	---	--	--------	--

Time of day\Daylight saving time\Start of daylight saving time

Starting week of the month:	Last		Sunday	of	March
at	01:00 a.m.				

Time of day\Daylight saving time\Start of standard time

	Last		Sunday	of	October
at	02:00 a.m.				

Protection & Security

Level of protection	No protection	
---------------------	---------------	--

Protection & Security\Connection mechanisms

Permit access with PUT/GET communication from remote partner	True	
--	------	--

Configuration control\Configuration control for central configuration

Allow to reconfigure the device via the user program	0	
--	---	--

Connection resources\

	Station resources - Reserved - Maximum	Station resources - Reserved - Configured	Station resources - Dynamic - Configured	Module resources - PLC_1 [CPU 1212C AC/DC/Rly] - Configured
Maximum number of resources:		62	6	68
	Maximum	Configured	Configured	Configured
PG communication:	4	-	-	-
HMI communication:	12	1	0	1
S7 communication:	8	1	0	1
Open user communication:	8	0	0	0
Web communication:	30	-	-	-
Other communication:	-	-	0	0
Total resources used:		2	0	2
Available resources:		60	6	66

Overview of addresses\Overview of addresses\Overview of addresses

Inputs	True	Outputs	True	Address gaps	False
Slot	True				

Totally Integrated Automation Portal											
Type	Addr. from	Addr. to	Module	PIP	Device name	Device number	Size	Master / IO system	Rack	Slot	
I	0	0	DI 8/DQ 6_1	Automatic update	PLC_1 [CPU 1212C AC/DC/Rly]	-	1 Bytes	-	0	1 1	
O	0	0	DI 8/DQ 6_1	Automatic update	PLC_1 [CPU 1212C AC/DC/Rly]	-	1 Bytes	-	0	1 1	
I	64	67	AI 2_1	Automatic update	PLC_1 [CPU 1212C AC/DC/Rly]	-	4 Bytes	-	0	1 2	
I	1000	1003	HSC_1	Automatic update	PLC_1 [CPU 1212C AC/DC/Rly]	-	4 Bytes	-	0	1 16	
I	1004	1007	HSC_2	Automatic update	PLC_1 [CPU 1212C AC/DC/Rly]	-	4 Bytes	-	0	1 17	
I	1008	1011	HSC_3	Automatic update	PLC_1 [CPU 1212C AC/DC/Rly]	-	4 Bytes	-	0	1 18	
I	1012	1015	HSC_4	Automatic update	PLC_1 [CPU 1212C AC/DC/Rly]	-	4 Bytes	-	0	1 19	
I	1016	1019	HSC_5	Automatic update	PLC_1 [CPU 1212C AC/DC/Rly]	-	4 Bytes	-	0	1 20	
I	1020	1023	HSC_6	Automatic update	PLC_1 [CPU 1212C AC/DC/Rly]	-	4 Bytes	-	0	1 21	
O	1000	1001	Pulse_1	Automatic update	PLC_1 [CPU 1212C AC/DC/Rly]	-	2 Bytes	-	0	1 32	
O	1002	1003	Pulse_2	Automatic update	PLC_1 [CPU 1212C AC/DC/Rly]	-	2 Bytes	-	0	1 33	
O	1004	1005	Pulse_3	Automatic update	PLC_1 [CPU 1212C AC/DC/Rly]	-	2 Bytes	-	0	1 34	
O	1006	1007	Pulse_4	Automatic update	PLC_1 [CPU 1212C AC/DC/Rly]	-	2 Bytes	-	0	1 35	


Task3\_V15 / PLC\_1 [CPU 1212C AC/DC/Rly] / Program blocks

Main [OB1]


Main Properties							
General							
Name	Main	Number	1	Type	OB	Language	LAD
Numbering	Automatic						
Information							
Title	"Main Program Sweep (Cycle)"	Author		Comment		Family	
Version	0.1	User-defined ID					

Name	Data type	Default value	Comment
▼ Input			
Initial_Call	Bool		Initial call of this OB
Remanence	Bool		=True, if remanent data are available
Temp			
Constant			

Network 1: Put in PLC\_2



Network 2: Operation mode



Task3\_V15 / PLC\_1 [CPU 1212C AC/DC/Rly] / Program blocks

Operation\_mode\_DB [DB3]


Operation_mode_DB Properties										
General										
Name	Operation_mode_DB	Number	3	Type	DB			Language	DB	
Numbering	Automatic									
Information										
Title		Author		Comment				Family		
Version	0.1	User-defined ID								
Name		Data type	Start value	Retain	Accessible from HMI/OPC UA	Writ-able from HMI/ OPC UA	Visible in HMI engi-neering	Setpoint	Supervi-sion	Comment
▼ Static										
▼ OperatingModes		"OperationModes"		False	True	True	True	False		
▼ Input		Struct		False	True	True	True	False		
automatic		Bool	false	False	True	True	True	False		
manual		Bool	false	False	True	True	True	False		
start		Bool	false	False	True	True	True	False		
stop		Bool	false	False	True	True	True	False		
estop		Bool	false	False	True	True	True	False		
user_interaction		Bool	false	False	True	True	True	False		
reset_estop		Bool	false	False	True	True	True	False		
error		Bool	false	False	True	True	True	False		
warning		Bool	false	False	True	True	True	False		
reset_error		Bool	false	False	True	True	True	False		
▼ Output		Struct		False	True	True	True	False		
automatic_selected		Bool	false	False	True	True	True	False		
manual_selected		Bool	false	False	True	True	True	False		
estop_active		Bool	false	False	True	True	True	False		
started		Bool	false	False	True	True	True	False		
automatic		Bool	false	False	True	True	True	False		
manual		Bool	false	False	True	True	True	False		
error_active		Bool	false	False	True	True	True	False		

Task3\_V15 / PLC\_1 [CPU 1212C AC/DC/Rly] / Program blocks / Operation modes


Operation\_modes [FB1]

Operation_modes Properties										
General										
Name	Operation_modes	Number	1	Type	FB			Language	FBD	
Numbering	Automatic									
Information										
Title	Operation modes	Author		Comment				Family		
Version	0.1	User-defined ID								
Name		Data type	Default value	Retain	Accessible from HMI/OPC UA	Writ-able from HMI/OPC UA	Visible in HMI engi-neering	Setpoint	Supervi-sion	Comment
▼ Input										
in_start		Bool	false	Non-retain	True	True	True	False		
in_stop		Bool	false	Non-retain	True	True	True	False		
in_automatic		Bool	false	Non-retain	True	True	True	False		
in_manual		Bool	false	Non-retain	True	True	True	False		
in_estop		Bool	false	Non-retain	True	True	True	False		
in_reset_estop		Bool	false	Non-retain	True	True	True	False		
in_error		Bool	false	Non-retain	True	True	True	False		
in_reset_error		Bool	false	Non-retain	True	True	True	False		
in_user_interaction		Bool	false	Non-retain	True	True	True	False		
▼ Output										
out_automatic		Bool	false	Non-retain	True	True	True	False		
out_manual		Bool	false	Non-retain	True	True	True	False		
▼ InOut										
out_start		Bool	false	Non-retain	True	True	True	False		
out_automatic_selected		Bool	false	Non-retain	True	True	True	False		
out_manual_selected		Bool	false	Non-retain	True	True	True	False		
estop_active		Bool	false	Non-retain	True	True	True	False		
warning		Bool	false	Non-retain	True	True	True	False		
error_active		Bool	false	Non-retain	True	True	True	False		
Static										
Temp										
Constant										

Network 1: Start/Stop operation



Network 2: Automatic/Manual mode



Network 3: E-Stop



Network 4: Error





## Operation\_modes\_DB [DB2]

Operation_modes_DB Properties							
General							
Name	Operation_modes_DB	Number	2	Type	DB	Language	DB
Numbering	Automatic						
Information							
Title		Author		Comment		Family	
Version	0.1	User-defined ID					

Name	Data type	Start value	Retain	Accessible from HMI/OPC UA	Writ-able from HMI/OPC UA	Visible in HMI engi-neering	Setpoint	Supervi-sion	Comment
▼ Input									
in_start	Bool	false	False	True	True	True	False		
in_stop	Bool	false	False	True	True	True	False		
in_automatic	Bool	false	False	True	True	True	False		
in_manual	Bool	false	False	True	True	True	False		
in_estop	Bool	false	False	True	True	True	False		
in_reset_estop	Bool	false	False	True	True	True	False		
in_error	Bool	false	False	True	True	True	False		
in_reset_error	Bool	false	False	True	True	True	False		
in_user_interaction	Bool	false	False	True	True	True	False		
▼ Output									
out_automatic	Bool	false	False	True	True	True	False		
out_manual	Bool	false	False	True	True	True	False		
▼ InOut									
out_start	Bool	false	False	True	True	True	False		
out_automatic_selected	Bool	false	False	True	True	True	False		
out_manual_selected	Bool	false	False	True	True	True	False		
estop_active	Bool	false	False	True	True	True	False		
warning	Bool	false	False	True	True	True	False		
error_active	Bool	false	False	True	True	True	False		
Static									

## Task3\_V15 / PLC\_1 [CPU 1212C AC/DC/Rly] / Program blocks / System blocks / Program resources

## PUT\_DB [DB4]

PUT_DB Properties							
General							
Name	PUT_DB	Number	4	Type	DB	Language	DB
Numbering	Automatic						
Information							
Title		Author	SIMATIC	Comment		Family	COM_FUNC
Version	1.1	User-defined ID	PUT				















Name	Data type	Start value	Retain	Accessible from HMI/OPC UA	Writ-able from HMI/OPC UA	Visible in HMI engi-neering	Setpoint	Supervi-sion	Comment
▼ Input									
REQ	Bool	false	False	True	True	True	False		
ID	Word	16#0	False	True	True	True	False		
▼ Output									
DONE	Bool	false	False	True	True	True	False		
ERROR	Bool	false	False	True	True	True	False		
STATUS	Word	16#0	False	True	True	True	False		
▼ InOut									
ADDR_1	Remote		False	True	True	True	False		
ADDR_2	Remote		False	True	True	True	False		
ADDR_3	Remote		False	True	True	True	False		
ADDR_4	Remote		False	True	True	True	False		
SD_1	Variant		False	False	False	False	False		
SD_2	Variant		False	False	False	False	False		
SD_3	Variant		False	False	False	False	False		
SD_4	Variant		False	False	False	False	False		
Static									

Totally Integrated Automation Portal		
<div>Task3_V15 / PLC_1 [CPU 1212C AC/DC/Rly] / Program blocks</div> <div>Put</div> <div>This folder is empty.</div>		

Totally Integrated Automation Portal		
<div>Task3_V15 / PLC_1 [CPU 1212C AC/DC/Rly]</div> <div>Technology objects</div> <div>This folder is empty.</div>		

Task3\_V15 / PLC\_1 [CPU 1212C AC/DC/Rly] / PLC tags / Default tag table [43]

PLC tags

PLC tags									
	Name	Data type	Address	Retain	Accessi-ble from HMI/OPC UA	Writable from HMI/OPC UA	Visible in HMI engi-neering	Supervision	Comment
	System_Byte	Byte	%MB1	False	True	True	True		
	FirstScan	Bool	%M1.0	False	True	True	True		
	DiagStatusUpdate	Bool	%M1.1	False	True	True	True		
	AlwaysTRUE	Bool	%M1.2	False	True	True	True		
	AlwaysFALSE	Bool	%M1.3	False	True	True	True		
	Clock_Byte	Byte	%MB0	False	True	True	True		
	Clock_5Hz	Bool	%M0.1	False	True	True	True		
	Clock_2.5Hz	Bool	%M0.2	False	True	True	True		
	Clock_2Hz	Bool	%M0.3	False	True	True	True		
	Clock_1.25Hz	Bool	%M0.4	False	True	True	True		
	Clock_1Hz	Bool	%M0.5	False	True	True	True		
	Clock_0.625Hz	Bool	%M0.6	False	True	True	True		
	Clock_0.5Hz	Bool	%M0.7	False	True	True	True		
	Enable_Control	Bool	%M10.0	False	True	True	True		

Task3\_V15 / PLC\_1 [CPU 1212C AC/DC/Rly] / PLC tags / Default tag table [43]

User constants

User constants				
	Name	Data type	Value	Comment

Task3\_V15 / PLC\_1 [CPU 1212C AC/DC/Rly] / PLC data types

SignalLight

SignalLight Properties									
General									
Name	SignalLight	Number	1	Type	UDT			Language	
Numbering									
Information									
Title		Author		Comment				Family	
Version		User-defined ID							
Name	Data type	Offset	Default value	Accessible from HMI/OPC UA	Writ able from HMI/ OPC UA	Visible in HMI engi- neering	Setpoint	Comment	
Segment1	Byte		16#0	True	True	True	False		
Segment2	Byte		16#0	True	True	True	False		
Segment3	Byte		16#0	True	True	True	False		
Segment4	Byte		16#0	True	True	True	False		
Segment5	Byte		16#0	True	True	True	False		
Buzzer	Byte		16#0	True	True	True	False		



Totally Integrated Automation Portal

Task3\_V15 / PLC\_1 [CPU 1212C AC/DC/Rly] / PLC data types

OperationModes

OperationModes Properties

General

Name	OperationModes	Number	2	Type	UDT	Language	
Numbering							

Information

Title		Author		Comment		Family	
Version		User-defined ID					

Name	Data type	Offset	Default value	Accessible from HMI/OPC UA	Writ able from HMI/ OPC UA	Visible in HMI engi- neering	Setpoint	Comment
▼ Input	Struct			True	True	True	False	
automatic	Bool		false	True	True	True	False	
manual	Bool		false	True	True	True	False	
start	Bool		false	True	True	True	False	
stop	Bool		false	True	True	True	False	
estop	Bool		false	True	True	True	False	
user_interaction	Bool		false	True	True	True	False	
reset_estop	Bool		false	True	True	True	False	
error	Bool		false	True	True	True	False	
warning	Bool		false	True	True	True	False	
reset_error	Bool		false	True	True	True	False	
▼ Output	Struct			True	True	True	False	
automatic_selected	Bool		false	True	True	True	False	
manual_selected	Bool		false	True	True	True	False	
estop_active	Bool		false	True	True	True	False	
started	Bool		false	True	True	True	False	
automatic	Bool		false	True	True	True	False	
manual	Bool		false	True	True	True	False	
error_active	Bool		false	True	True	True	False	

Totally Integrated Automation Portal							
<div>Task3_V15 / PLC_1 [CPU 1212C AC/DC/Rly] / Watch and force tables</div> <div>Force table</div> <table><thead><tr><th>Name</th><th>Address</th><th>Display format</th><th>Force value</th><th>Comment</th></tr></thead><tbody></tbody></table>			Name	Address	Display format	Force value	Comment
Name	Address	Display format	Force value	Comment			

Totally Integrated Automation Portal

### Task3\_V15 / PLC\_1 [CPU 1212C AC/DC/Rly] / Watch and force tables

#### Watch table\_1

Name	Address	Display format	Modify value	Comment
"i_command_value"	%IB90	DEC		command value
	%IB91	Bin		status
"i_read_value_0"	%IW92	DEC		read value 0
"i_read_value_1"	%IW94	DEC		read value 1
"i_read_value_2"	%IW96	DEC		read value 2
"i_read_value_3"	%IW98	DEC		read value 3
	%IW100	Hex		
	%IW102	Hex		
	%IW104	Hex		
	%IW106	Hex		
"q_command_value"	%QB84	Bin	2#0000_0001	command value
	%QB85	Hex		operation command
"q_write_value_0"	%QW86	Hex		write value 0
"q_write_value_1"	%QW88	Hex		write value 1
"q_write_value_2"	%QW90	Hex		write value 2
"q_write_value_3"	%QW92	Hex		write value 3
	%QW94	Hex		
	%QW96	Hex		
	%QW98	Hex		
	%Q84.0	Bool	TRUE	
	%Q84.3	Bool		

Totally Integrated Automation Portal		
<div>Task3_V15 / PLC_1 [CPU 1212C AC/DC/Rly]</div> <div>Traces</div> <div><div>Name</div></div>		

Totally Integrated Automation Portal		
<div>Task3_V15 / PLC_1 [CPU 1212C AC/DC/Rly] / Traces</div> <div>Measurements</div> <div>This folder is empty.</div>		

Totally Integrated Automation Portal		
<div>Task3_V15 / PLC_1 [CPU 1212C AC/DC/Rly] / Traces</div> <div>Combined measurements</div> <div><div>Name</div></div>		

Totally Integrated Automation Portal		
<div>Task3_V15 / PLC_1 [CPU 1212C AC/DC/Rly]</div> <div>PLC alarm text lists</div> <div>This folder is empty.</div>		



Totally Integrated Automation Portal		
<div>Task3_V15 / PLC_1 [CPU 1212C AC/DC/Rly]</div> <div>Local modules</div> <div>This folder is empty.</div>		

Totally Integrated Automation Portal

# Task3\_V15 / PLC\_1 [CPU 1212C AC/DC/Rly] / Distributed I/O

## PROFINET IO-System (100): PN/IE\_1

PROFINET IO-System

General

IO controller:

PLC\_1

Name:

PROFINET IO-System

Number:

100

Use name as extension for the PROFINET device name.

False

Hardware identifier

Hardware identifier

269

Overview of addresses\Overview of addresses\Overview of addresses

Inputs

True

Outputs

True

Address gaps

False

Slot

True

Type	Addr. from	Addr. to	Module	PIP	Device name	Device number	Size	Master / IO system	Rack	Slot
I	0	0	DI 8/DQ 6_1	Automatic update	PLC_1 [CPU 1212C AC/DC/Rly]	-	1 Bytes	-	0	1 1
O	0	0	DI 8/DQ 6_1	Automatic update	PLC_1 [CPU 1212C AC/DC/Rly]	-	1 Bytes	-	0	1 1
I	64	67	AI 2_1	Automatic update	PLC_1 [CPU 1212C AC/DC/Rly]	-	4 Bytes	-	0	1 2
I	1000	1003	HSC_1	Automatic update	PLC_1 [CPU 1212C AC/DC/Rly]	-	4 Bytes	-	0	1 16
I	1004	1007	HSC_2	Automatic update	PLC_1 [CPU 1212C AC/DC/Rly]	-	4 Bytes	-	0	1 17
I	1008	1011	HSC_3	Automatic update	PLC_1 [CPU 1212C AC/DC/Rly]	-	4 Bytes	-	0	1 18
I	1012	1015	HSC_4	Automatic update	PLC_1 [CPU 1212C AC/DC/Rly]	-	4 Bytes	-	0	1 19
I	1016	1019	HSC_5	Automatic update	PLC_1 [CPU 1212C AC/DC/Rly]	-	4 Bytes	-	0	1 20
I	1020	1023	HSC_6	Automatic update	PLC_1 [CPU 1212C AC/DC/Rly]	-	4 Bytes	-	0	1 21
O	1000	1001	Pulse_1	Automatic update	PLC_1 [CPU 1212C AC/DC/Rly]	-	2 Bytes	-	0	1 32
O	1002	1003	Pulse_2	Automatic update	PLC_1 [CPU 1212C AC/DC/Rly]	-	2 Bytes	-	0	1 33
O	1004	1005	Pulse_3	Automatic update	PLC_1 [CPU 1212C AC/DC/Rly]	-	2 Bytes	-	0	1 34
O	1006	1007	Pulse_4	Automatic update	PLC_1 [CPU 1212C AC/DC/Rly]	-	2 Bytes	-	0	1 35

Totally Integrated Automation Portal						
--------------------------------------	--	--	--	--	--	--

Task3\_V15

PLC\_2 [CPU 1212C AC/DC/Rly]

PLC_2					
General\Project information					
Name	PLC_2	Author	RV	Comment	
Slot	1	Rack	0		
General\Catalog information					
Short designation	CPU 1212C AC/DC/Rly	Description	Work memory 75 KB; 120/240VAC power supply with DI8 x 24VDC SINK/ SOURCE, DQ6 x relay and AI2 on board; 4 high-speed counters (expandable with digital signal board) and 4 pulse outputs on board; signal board expands on-board I/O; up to 3 communication modules for serial communication; up to 2 signal modules for I/O expansion; 0.04 ms/1000 instructions; PROFINET interface for programming, HMI and PLC to PLC communication	Article number	6ES7 212-1BE40-0XB0
Firmware version	V4.1				
General\Identification & Maintenance					
Plant designation		Location identifier		Installation date	2019-04-20 13:55:42.993
Additional information					
PROFINET interface [X1]\General					
Name	PROFINET interface_1	Author	RV	Comment	
PROFINET interface [X1]\General\Project information					
Name	DI 8/DQ 6_1	Comment		Name	AI 2_1
Comment					
PROFINET interface [X1]\Ethernet addresses\Interface networked with					
Subnet:	PN/IE_1				
PROFINET interface [X1]\Ethernet addresses\IP protocol					
IP configuration	Set IP address in the project	IP address:	192.168.1.107	Subnet mask:	255.255.255.0
Use router	False				
PROFINET interface [X1]\Ethernet addresses\PROFINET					
PROFINET device name is set directly at the device	False	Generate PROFINET device name automatically	True	PROFINET device name:	plc_2
Converted name:	plcxb2d1ad	Device number:	0		
PROFINET interface [X1]\Time synchronization					
Enable time synchronization via NTP server	Enable time synchronization via NTP server		IP addresses	Server 1	0.0.0.0
Server 2	0.0.0.0	Server 3	0.0.0.0	Server 4	0.0.0.0
Update interval	10sec				
PROFINET interface [X1]\Digital inputs\Channel0					
Channel address	I0.0	Input filters	6.4 millisec	Enable pulse catch	0
PROFINET interface [X1]\Digital inputs\Channel0\					
Enable rising edge detection	0	RidPrefixRisingEdgeEvent	49152	Event name:	0
Hardware interrupt:	0	Rising edge0	Rising edge0		
PROFINET interface [X1]\Digital inputs\Channel0\					
Enable falling edge detection	0	RidPrefixFallingEdgeEvent	49280	Event name:	0
Hardware interrupt:	0	Falling edge0	Falling edge0		
PROFINET interface [X1]\Digital inputs\Channel1					
Channel address	I0.1	Input filters	6.4 millisec	Enable pulse catch	0
PROFINET interface [X1]\Digital inputs\Channel1\					
Enable rising edge detection	0	RidPrefixRisingEdgeEvent	49153	Event name:	0
Hardware interrupt:	0	Rising edge1	Rising edge1		
PROFINET interface [X1]\Digital inputs\Channel1\					
Enable falling edge detection	0	RidPrefixFallingEdgeEvent	49281	Event name:	0
Hardware interrupt:	0	Falling edge1	Falling edge1		
PROFINET interface [X1]\Digital inputs\Channel2					
Channel address	I0.2	Input filters	6.4 millisec	Enable pulse catch	0
PROFINET interface [X1]\Digital inputs\Channel2\					
Enable rising edge detection	0	RidPrefixRisingEdgeEvent	49154	Event name:	0
Hardware interrupt:	0	Rising edge2	Rising edge2		
PROFINET interface [X1]\Digital inputs\Channel2\					
Enable falling edge detection	0	RidPrefixFallingEdgeEvent	49282	Event name:	0
Hardware interrupt:	0	Falling edge2	Falling edge2		
PROFINET interface [X1]\Digital inputs\Channel3					
Channel address	I0.3	Input filters	6.4 millisec	Enable pulse catch	0
PROFINET interface [X1]\Digital inputs\Channel3\					
Enable rising edge detection	0	RidPrefixRisingEdgeEvent	49155	Event name:	0
Hardware interrupt:	0	Rising edge3	Rising edge3		
PROFINET interface [X1]\Digital inputs\Channel3\					
Enable falling edge detection	0	RidPrefixFallingEdgeEvent	49283	Event name:	0
Hardware interrupt:	0	Falling edge3	Falling edge3		

--	--	--

Totally Integrated Automation Portal						
PROFINET interface [X1]\Digital inputs\Channel4						
Channel address	I0.4	Input filters	6.4 millisec	Enable pulse catch	0	
PROFINET interface [X1]\Digital inputs\Channel4\						
Enable rising edge detection	0	RidPrefixRisingEdgeEvent	49156	Event name:	0	
Hardware interrupt:	0	Rising edge4	Rising edge4			
PROFINET interface [X1]\Digital inputs\Channel4\						
Enable falling edge detection	0	RidPrefixFallingEdgeEvent	49284	Event name:	0	
Hardware interrupt:	0	Falling edge4	Falling edge4			
PROFINET interface [X1]\Digital inputs\Channel5						
Channel address	I0.5	Input filters	6.4 millisec	Enable pulse catch	0	
PROFINET interface [X1]\Digital inputs\Channel5\						
Enable rising edge detection	0	RidPrefixRisingEdgeEvent	49157	Event name:	0	
Hardware interrupt:	0	Rising edge5	Rising edge5			
PROFINET interface [X1]\Digital inputs\Channel5\						
Enable falling edge detection	0	RidPrefixFallingEdgeEvent	49285	Event name:	0	
Hardware interrupt:	0	Falling edge5	Falling edge5			
PROFINET interface [X1]\Digital inputs\Channel6						
Channel address	I0.6	Input filters	6.4 millisec	Enable pulse catch	0	
PROFINET interface [X1]\Digital inputs\Channel6\						
Enable rising edge detection	0	RidPrefixRisingEdgeEvent	49158	Event name:	0	
Hardware interrupt:	0	Rising edge6	Rising edge6			
PROFINET interface [X1]\Digital inputs\Channel6\						
Enable falling edge detection	0	RidPrefixFallingEdgeEvent	49286	Event name:	0	
Hardware interrupt:	0	Falling edge6	Falling edge6			
PROFINET interface [X1]\Digital inputs\Channel7						
Channel address	I0.7	Input filters	6.4 millisec	Enable pulse catch	0	
PROFINET interface [X1]\Digital inputs\Channel7\						
Enable rising edge detection	0	RidPrefixRisingEdgeEvent	49159	Event name:	0	
Hardware interrupt:	0	Rising edge7	Rising edge7			
PROFINET interface [X1]\Digital inputs\Channel7\						
Enable falling edge detection	0	RidPrefixFallingEdgeEvent	49287	Event name:	0	
Hardware interrupt:	0	Falling edge7	Falling edge7			
PROFINET interface [X1]\Analog inputs\Noise reduction						
Integration time	50 Hz (20 ms)					
PROFINET interface [X1]\Analog inputs\Channel0						
Channel address	IW64	Measurement type	Voltage	Voltage range	0..10 V	
Smoothing	Weak (4 cycles)			Enable overflow diagnostics	1	
PROFINET interface [X1]\Analog inputs\Channel1						
Channel address	IW66	Measurement type	Voltage	Voltage range	0..10 V	
Smoothing	Weak (4 cycles)			Enable overflow diagnostics	1	
PROFINET interface [X1]\Digital outputs						
Reaction to CPU STOP	Use substitute value					
PROFINET interface [X1]\Digital outputs\Channel0						
Channel address	Q0.0	Substitute a value of 1 on a change from RUN to STOP.	0			
PROFINET interface [X1]\Digital outputs\Channel1						
Channel address	Q0.1	Substitute a value of 1 on a change from RUN to STOP.	0			
PROFINET interface [X1]\Digital outputs\Channel2						
Channel address	Q0.2	Substitute a value of 1 on a change from RUN to STOP.	0			
PROFINET interface [X1]\Digital outputs\Channel3						
Channel address	Q0.3	Substitute a value of 1 on a change from RUN to STOP.	0			
PROFINET interface [X1]\Digital outputs\Channel4						
Channel address	Q0.4	Substitute a value of 1 on a change from RUN to STOP.	0			
PROFINET interface [X1]\Digital outputs\Channel5						
Channel address	Q0.5	Substitute a value of 1 on a change from RUN to STOP.	0			
PROFINET interface [X1]\Operating mode						
IO controller	True	IO system		Device number	0	
IO device	False					
PROFINET interface [X1]\I/O addresses\Input addresses						
Start address	0.0	End address	0.7	Organization block	0	
Process image	0					
PROFINET interface [X1]\I/O addresses\Input addresses						
Start address	64	End address	67	Organization block	0	
Process image	0					
PROFINET interface [X1]\I/O addresses\Output addresses						
Start address	0.0	End address	0.7	Organization block	0	
Process image	0					

Totally Integrated Automation Portal

PROFINET interface [X1]\Advanced options\Interface options

Support device re-  
placement without  
exchangeable medi-  
um

True

Permit overwriting of  
device names of all  
assigned IO devices

False

Use IEC V2.2 LLDP  
mode

False

Keep-Alive connec-  
tion monitoring

30s

PROFINET interface [X1]\Advanced options\Real time settings\IO communication

Send clock:

1.000ms

PROFINET interface [X1]\Advanced options\Real time settings\Real time options

Calculated bandwidth  
for cyclic IO data:

0.000ms

Calculated bandwidth  
for cyclic IO data:

0.000%

PROFINET interface [X1]\Advanced options\Port [X1 P1]\General

Name

Port\_1

Author

RV

Comment

PROFINET interface [X1]\Advanced options\Port [X1 P1]\Port interconnection\Local port:

Local port:


PLC\_2\PROFINET interface\_1  
[X1]\Port\_1 [X1 P1]

Medium:

Copper

Cable name:

---



PROFINET interface [X1]\Advanced options\Port [X1 P1]\Port interconnection\Partner port:

Monitoring of partner port is not pos-  
sible

Partner port:

Any partner

PROFINET interface [X1]\Advanced options\Port [X1 P1]\Port options\Activate

Activate this port for  
use

True

PROFINET interface [X1]\Advanced options\Port [X1 P1]\Port options\Connection

Transmission rate /  
duplex:

Automatic

Monitor

False

Enable autonegotia-  
tion

True

PROFINET interface [X1]\Advanced options\Port [X1 P1]\Port options\Boundaries

End of detection of  
accessible devices

False

End of topology dis-  
covery

False

End of the sync do-  
main

False

PROFINET interface [X1]\Web server access

Enable Web server us-  
ing this interface

False

The Web server must  
also be activated in  
the properties of the  
PLC.

High speed counters (HSC)\HSC1\General\Enable

Enable this high  
speed counter

0

Enable this high  
speed counter

0

Enable this high  
speed counter

0

Enable this high  
speed counter

0

Enable this high  
speed counter

0

Enable this high  
speed counter

0

High speed counters (HSC)\HSC1\General\Project information

Name

HSC\_1

Comment

Name

HSC\_2

Comment

Name

HSC\_3

Comment

Name

HSC\_4

Comment

Name

HSC\_5

Comment

Name

HSC\_6

Comment

High speed counters (HSC)\HSC1\I/O addresses\Input addresses

Start address

1000.0

End address

1003.7

Start address

1004.0

End address

1007.7

Organization block

0

Start address

1008.0

End address

1011.7

Organization block

0

Process image

0

Start address

1012.0

End address

1015.7

Organization block

0

Process image

0

Start address

1016.0

End address

1019.7

Organization block

0

Process image

0

Start address

1020.0

End address

1023.7

Organization block

0

Process image

0

Organization block

0

Process image

0

Process image

0

Pulse generators (PTO/PWM)\PTO1/PWM1\General\Enable

Enable this pulse gen-  
erator

0

Enable this pulse gen-  
erator

0

Pulse generators (PTO/PWM)\PTO1/PWM1\General\Project information

Name

Pulse\_1

Comment

Name

Pulse\_2

Comment

Pulse generators (PTO/PWM)\PTO1/PWM1\I/O addresses\Output addresses

Start address

1000.0

End address

1001.7

Start address

1002.0

End address

1003.7

Organization block

0

Organization block

0

Process image

0

Process image

0

Startup

Startup after POWER  
ON

Warm restart - mode before POWER  
OFF

Comparison preset to  
actual configuration

Startup CPU even if mismatch

Configuration time

60000ms

OBs should be inter-  
ruptible

1

Cycle

Cycle monitoring  
time

150ms

Enable minimum cy-  
cle time for cyclic OBs

0

Minimum cycle time

1ms

Communication load

Cycle load due to  
communication

20%

System and clock memory\System memory bits

Enable the use of sys-  
tem memory byte

1

Address of system  
memory byte (MBx)

1

First cycle

%M1.0 (FirstScan)

Diagnostic status  
changed

%M1.1 (DiagStatusUpdate)

Always 1 (high)

%M1.2 (AlwaysTRUE)

Always 0 (low)

%M1.3 (AlwaysFALSE)

Totally Integrated Automation Portal						
--------------------------------------	--	--	--	--	--	--

System and clock memory\Clock memory bits

Enable the use of clock memory byte	1	Address of clock memory byte (MBx)	0	10 Hz clock	%M0.0
5 Hz clock	%M0.1 (Clock_5Hz)	2.5 Hz clock	%M0.2 (Clock_2.5Hz)	2 Hz clock	%M0.3 (Clock_2Hz)
1.25 Hz clock	%M0.4 (Clock_1.25Hz)	1 Hz clock	%M0.5 (Clock_1Hz)	0.625 Hz clock	%M0.6 (Clock_0.625Hz)
0.5 Hz clock	%M0.7 (Clock_0.5Hz)				

Web server\General

Activate Web server on all modules of this device	False	Permit access only with HTTPS	True		
---	-------	-------------------------------	------	--	--

Web server\Automatic update

Enable automatic up-date	True	Update interval	0s		
--------------------------	------	-----------------	----	--	--

Web server\User interface languages

Assign project language			User interface languages		
English (United States)			German		
English (United States)			English		
English (United States)			French		
English (United States)			Spanish		
English (United States)			Italian		
English (United States)			Chinese (simplified)		

Web server\User management

User name			User rights		
Everybody					

Web server\User defined web pages

Application name	HTML source path	Default HTML page	Files with dynamic content	Web DB number	Fragment DB number
		index.htm	.htm;.html	333	334

Web server\Overview of interfaces

Device	Interface		Enabled web server access		
PLC_2	PROFINET interface_1		False		

User interface languages

Assign project language			User interface languages		
English (United States)			German		
English (United States)			English		
English (United States)			French		
English (United States)			Spanish		
English (United States)			Italian		
English (United States)			Chinese (simplified)		

Time of day\Local time

Time zone	(UTC +01:00) Berlin, Bern, Brussels, Rome, Stockholm, Vienna				
-----------	--	--	--	--	--

Time of day\Daylight saving time

Activate daylight saving time	1	Difference between standard and daylight saving time	60mins		
-------------------------------	---	--	--------	--	--

Time of day\Daylight saving time\Start of daylight saving time

Starting week of the month:	Last		Sunday	of	March
at	01:00 a.m.				

Time of day\Daylight saving time\Start of standard time

	Last		Sunday	of	October
at	02:00 a.m.				

Protection & Security

Level of protection	No protection				
---------------------	---------------	--	--	--	--

Protection & Security\Connection mechanisms

Permit access with PUT/GET communication from remote partner	True				
--	------	--	--	--	--

Configuration control\Configuration control for central configuration

Allow to reconfigure the device via the user program	0				
--	---	--	--	--	--

Connection resources\

	Station resources - Reserved - Maximum	Station resources - Reserved - Configured	Station resources - Dynamic - Configured	Module resources - PLC_2 [CPU 1212C AC/DC/Rly] - Configured	
Maximum number of resources:		62	6	68	
	Maximum	Configured	Configured	Configured	
PG communication:	4	-	-	-	
HMI communication:	12	0	0	0	
S7 communication:	8	2	0	2	
Open user communication:	8	0	0	0	
Web communication:	30	-	-	-	
Other communication:	-	-	0	0	
Total resources used:		2	0	2	
Available resources:		60	6	66	

Overview of addresses\Overview of addresses\Overview of addresses

Inputs	True	Outputs	True	Address gaps	False
Slot	True				

Totally Integrated Automation Portal											
Type	Addr. from	Addr. to	Module	PIP	Device name	Device number	Size	Master / IO system	Rack	Slot	
I	64	67	AI 2_1	Automatic update	PLC_2 [CPU 1212C AC/DC/Rly]	-	4 Bytes	-	0	1 2	
I	0	0	DI 8/DQ 6_1	Automatic update	PLC_2 [CPU 1212C AC/DC/Rly]	-	1 Bytes	-	0	1 1	
O	0	0	DI 8/DQ 6_1	Automatic update	PLC_2 [CPU 1212C AC/DC/Rly]	-	1 Bytes	-	0	1 1	
I	1000	1003	HSC_1	Automatic update	PLC_2 [CPU 1212C AC/DC/Rly]	-	4 Bytes	-	0	1 16	
I	1004	1007	HSC_2	Automatic update	PLC_2 [CPU 1212C AC/DC/Rly]	-	4 Bytes	-	0	1 17	
I	1008	1011	HSC_3	Automatic update	PLC_2 [CPU 1212C AC/DC/Rly]	-	4 Bytes	-	0	1 18	
I	1012	1015	HSC_4	Automatic update	PLC_2 [CPU 1212C AC/DC/Rly]	-	4 Bytes	-	0	1 19	
I	1016	1019	HSC_5	Automatic update	PLC_2 [CPU 1212C AC/DC/Rly]	-	4 Bytes	-	0	1 20	
I	1020	1023	HSC_6	Automatic update	PLC_2 [CPU 1212C AC/DC/Rly]	-	4 Bytes	-	0	1 21	
O	1000	1001	Pulse_1	Automatic update	PLC_2 [CPU 1212C AC/DC/Rly]	-	2 Bytes	-	0	1 32	
O	1002	1003	Pulse_2	Automatic update	PLC_2 [CPU 1212C AC/DC/Rly]	-	2 Bytes	-	0	1 33	
O	1004	1005	Pulse_3	Automatic update	PLC_2 [CPU 1212C AC/DC/Rly]	-	2 Bytes	-	0	1 34	
O	1006	1007	Pulse_4	Automatic update	PLC_2 [CPU 1212C AC/DC/Rly]	-	2 Bytes	-	0	1 35	



Totally Integrated Automation Portal

### Task3\_V15 / PLC\_2 [CPU 1212C AC/DC/Rly] / Program blocks

#### Main [OB1]

Main Properties

General


Name	Main	Number	1	Type	OB	Language	LAD
Numbering	Automatic						

Information

Title	"Main Program Sweep (Cycle)"	Author		Comment		Family	
Version	0.1	User-defined ID					

Name	Data type	Default value	Comment
▼ Input			
Initial_Call	Bool		Initial call of this OB
Remanence	Bool		=True, if remanent data are available
Temp			
Constant			

Network 1: Operation mode



Task3\_V15 / PLC\_2 [CPU 1212C AC/DC/Rly] / Program blocks

Operation\_mode\_DB [DB3]


Operation_mode_DB Properties											
General											
Name	Operation_mode_DB	Number	3	Type	DB			Language	DB		
Numbering	Automatic										
Information											
Title		Author		Comment				Family			
Version	0.1	User-defined ID									
Name		Data type	Offset	Start value	Retain	Accessi-ble from HMI/OPC UA	Writ-able from HMI/OPC UA	Visible in HMI engi-neering	Setpoint	Supervi-sion	Comment
▼ Static											
▼ OperatingModes		"OperationModes"	0.0		False	True	True	True	False		
▼ Input		Struct	0.0		False	True	True	True	False		
automatic		Bool	0.0	false	False	True	True	True	False		
manual		Bool	0.1	false	False	True	True	True	False		
start		Bool	0.2	false	False	True	True	True	False		
stop		Bool	0.3	false	False	True	True	True	False		
estop		Bool	0.4	false	False	True	True	True	False		
user_interaction		Bool	0.5	false	False	True	True	True	False		
reset_estop		Bool	0.6	false	False	True	True	True	False		
error		Bool	0.7	false	False	True	True	True	False		
warning		Bool	1.0	false	False	True	True	True	False		
reset_error		Bool	1.1	false	False	True	True	True	False		
▼ Output		Struct	2.0		False	True	True	True	False		
automatic_selected		Bool	2.0	false	False	True	True	True	False		
manual_selected		Bool	2.1	false	False	True	True	True	False		
estop_active		Bool	2.2	false	False	True	True	True	False		
started		Bool	2.3	false	False	True	True	True	False		
automatic		Bool	2.4	false	False	True	True	True	False		
manual		Bool	2.5	false	False	True	True	True	False		
error_active		Bool	2.6	false	False	True	True	True	False		

Task3\_V15 / PLC\_2 [CPU 1212C AC/DC/Rly] / Program blocks / Operation modes


Operation\_modes [FB1]

Operation_modes Properties									
General									
Name	Operation_modes	Number	1	Type	FB			Language	FBD
Numbering	Automatic								
Information									
Title	Operation modes	Author		Comment				Family	
Version	0.1	User-defined ID							
Name	Data type	Default value	Retain	Accessible from HMI/OPC UA	Writ-able from HMI/OPC UA	Visible in HMI engi-neering	Setpoint	Supervi-sion	Comment
▼ Input									
in_start	Bool	false	Non-retain	True	True	True	False		
in_stop	Bool	false	Non-retain	True	True	True	False		
in_automatic	Bool	false	Non-retain	True	True	True	False		
in_manual	Bool	false	Non-retain	True	True	True	False		
in_estop	Bool	false	Non-retain	True	True	True	False		
in_reset_estop	Bool	false	Non-retain	True	True	True	False		
in_error	Bool	false	Non-retain	True	True	True	False		
in_reset_error	Bool	false	Non-retain	True	True	True	False		
in_user_interaction	Bool	false	Non-retain	True	True	True	False		
▼ Output									
out_automatic	Bool	false	Non-retain	True	True	True	False		
out_manual	Bool	false	Non-retain	True	True	True	False		
▼ InOut									
out_start	Bool	false	Non-retain	True	True	True	False		
out_automatic_selected	Bool	false	Non-retain	True	True	True	False		
out_manual_selected	Bool	false	Non-retain	True	True	True	False		
estop_active	Bool	false	Non-retain	True	True	True	False		
warning	Bool	false	Non-retain	True	True	True	False		
error_active	Bool	false	Non-retain	True	True	True	False		
Static									
Temp									
Constant									

Network 1: Start/Stop operation



Network 2: Automatic/Manual mode



Network 3: E-Stop



Network 4: Error



Task3\_V15 / PLC\_2 [CPU 1212C AC/DC/Rly] / Program blocks / Operation modes

Operation\_modes\_DB [DB2]














Operation_modes_DB Properties							
General							
Name	Operation_modes_DB	Number	2	Type	DB	Language	DB
Numbering	Automatic						
Information							
Title		Author		Comment		Family	
Version	0.1	User-defined ID					

Name	Data type	Start value	Retain	Accessible from HMI/OPC UA	Writ-able from HMI/ OPC UA	Visible in HMI engi-neering	Setpoint	Supervi-sion	Comment
▼ Input									
in_start	Bool	false	False	True	True	True	False		
in_stop	Bool	false	False	True	True	True	False		
in_automatic	Bool	false	False	True	True	True	False		
in_manual	Bool	false	False	True	True	True	False		
in_estop	Bool	false	False	True	True	True	False		
in_reset_estop	Bool	false	False	True	True	True	False		
in_error	Bool	false	False	True	True	True	False		
in_reset_error	Bool	false	False	True	True	True	False		
in_user_interaction	Bool	false	False	True	True	True	False		
▼ Output									
out_automatic	Bool	false	False	True	True	True	False		
out_manual	Bool	false	False	True	True	True	False		
▼ InOut									
out_start	Bool	false	False	True	True	True	False		
out_automatic_selected	Bool	false	False	True	True	True	False		
out_manual_selected	Bool	false	False	True	True	True	False		
estop_active	Bool	false	False	True	True	True	False		
warning	Bool	false	False	True	True	True	False		
error_active	Bool	false	False	True	True	True	False		
Static									

Totally Integrated Automation Portal		
<div>Task3_V15 / PLC_2 [CPU 1212C AC/DC/Rly]</div> <div>Technology objects</div> <div>This folder is empty.</div>		

Task3\_V15 / PLC\_2 [CPU 1212C AC/DC/Rly] / PLC tags / Default tag table [41]

PLC tags

PLC tags									
	Name	Data type	Address	Retain	Accessi-ble from HMI/OPC UA	Writable from HMI/OPC UA	Visible in HMI engi-neering	Supervision	Comment
	System_Byte	Byte	%MB1	False	True	True	True		
	FirstScan	Bool	%M1.0	False	True	True	True		
	DiagStatusUpdate	Bool	%M1.1	False	True	True	True		
	AlwaysTRUE	Bool	%M1.2	False	True	True	True		
	AlwaysFALSE	Bool	%M1.3	False	True	True	True		
	Clock_Byte	Byte	%MB0	False	True	True	True		
	Clock_5Hz	Bool	%M0.1	False	True	True	True		
	Clock_2.5Hz	Bool	%M0.2	False	True	True	True		
	Clock_2Hz	Bool	%M0.3	False	True	True	True		
	Clock_1.25Hz	Bool	%M0.4	False	True	True	True		
	Clock_1Hz	Bool	%M0.5	False	True	True	True		
	Clock_0.625Hz	Bool	%M0.6	False	True	True	True		
	Clock_0.5Hz	Bool	%M0.7	False	True	True	True		





Task3\_V15 / PLC\_2 [CPU 1212C AC/DC/Rly] / PLC data types

SignalLight

SignalLight Properties									
General									
Name	SignalLight	Number	1	Type	UDT	Language			
Numbering									
Information									
Title		Author		Comment		Family			
Version		User-defined ID							
Name	Data type	Offset	Default value	Accessible from HMI/OPC UA	Writ able from HMI/ OPC UA	Visible in HMI engi- neering	Setpoint	Comment	
Segment1	Byte		16#0	True	True	True	False		
Segment2	Byte		16#0	True	True	True	False		
Segment3	Byte		16#0	True	True	True	False		
Segment4	Byte		16#0	True	True	True	False		
Segment5	Byte		16#0	True	True	True	False		
Buzzer	Byte		16#0	True	True	True	False		

Totally Integrated Automation Portal

Task3\_V15 / PLC\_2 [CPU 1212C AC/DC/Rly] / PLC data types

OperationModes

OperationModes Properties

General

Name	OperationModes	Number	2	Type	UDT	Language	
Numbering							

Information

Title		Author		Comment		Family	
Version		User-defined ID					

Name	Data type	Offset	Default value	Accessible from HMI/OPC UA	Writ able from m HMI/ OPC UA	Visible in HMI engi- neering	Setpoint	Comment
▼ Input	Struct			True	True	True	False	
automatic	Bool		false	True	True	True	False	
manual	Bool		false	True	True	True	False	
start	Bool		false	True	True	True	False	
stop	Bool		false	True	True	True	False	
estop	Bool		false	True	True	True	False	
user_interaction	Bool		false	True	True	True	False	
reset_estop	Bool		false	True	True	True	False	
error	Bool		false	True	True	True	False	
warning	Bool		false	True	True	True	False	
reset_error	Bool		false	True	True	True	False	
▼ Output	Struct			True	True	True	False	
automatic_selected	Bool		false	True	True	True	False	
manual_selected	Bool		false	True	True	True	False	
estop_active	Bool		false	True	True	True	False	
started	Bool		false	True	True	True	False	
automatic	Bool		false	True	True	True	False	
manual	Bool		false	True	True	True	False	
error_active	Bool		false	True	True	True	False	

Totally Integrated Automation Portal							
<div>Task3_V15 / PLC_2 [CPU 1212C AC/DC/Rly] / Watch and force tables</div> <div>Force table</div> <table><thead><tr><th>Name</th><th>Address</th><th>Display format</th><th>Force value</th><th>Comment</th></tr></thead><tbody></tbody></table>			Name	Address	Display format	Force value	Comment
Name	Address	Display format	Force value	Comment			

Totally Integrated Automation Portal

### Task3\_V15 / PLC\_2 [CPU 1212C AC/DC/Rly] / Watch and force tables

#### Watch table\_1

Name	Address	Display format	Modify value	Comment
"i_command_value"	%IB90	DEC		command value
	%IB91	Bin		status
"i_read_value_0"	%IW92	DEC		read value 0
"i_read_value_1"	%IW94	DEC		read value 1
"i_read_value_2"	%IW96	DEC		read value 2
"i_read_value_3"	%IW98	DEC		read value 3
	%IW100	Hex		
	%IW102	Hex		
	%IW104	Hex		
	%IW106	Hex		
"q_command_value"	%QB84	Bin	2#0000_0001	command value
	%QB85	Hex		operation command
"q_write_value_0"	%QW86	Hex		write value 0
"q_write_value_1"	%QW88	Hex		write value 1
"q_write_value_2"	%QW90	Hex		write value 2
"q_write_value_3"	%QW92	Hex		write value 3
	%QW94	Hex		
	%QW96	Hex		
	%QW98	Hex		
	%Q84.0	Bool	TRUE	
	%Q84.3	Bool		

Totally Integrated Automation Portal			
<div>Task3_V15 / PLC_2 [CPU 1212C AC/DC/Rly]</div> <div>Traces</div> <table><tr><th>Name</th></tr></table>			Name
Name			

Totally Integrated Automation Portal		
<div>Task3_V15 / PLC_2 [CPU 1212C AC/DC/Rly] / Traces</div> <div>Measurements</div> <div>This folder is empty.</div>		

Totally Integrated Automation Portal		
<div>Task3_V15 / PLC_2 [CPU 1212C AC/DC/Rly] / Traces</div> <div>Combined measurements</div> <div><div>Name</div></div>		



Totally Integrated Automation Portal		
<div>Task3_V15 / PLC_2 [CPU 1212C AC/DC/Rly]</div> <div>PLC alarm text lists</div> <div>This folder is empty.</div>		

Totally Integrated Automation Portal		
<div>Task3_V15 / PLC_2 [CPU 1212C AC/DC/Rly]</div> <div>Local modules</div> <div>This folder is empty.</div>		

Totally Integrated Automation Portal		
--------------------------------------	--	--

Task3\_V15

HMI\_1 [KTP400 Basic PN]

HMI\_1

General

Name	HMI_1
------	-------

Totally Integrated Automation Portal

### Task3\_V15 / HMI\_1 [KTP400 Basic PN]

#### Runtime settings

##### General

Start screen	Root screen	Default template		UseDefaultPanelStyle	Unchecked
SelectedPanelStyle	WinCC Dark V 1.0.1	AdjustStyleFontsToDeviceSize	Checked	Screen resolution	480, 272
Project ID	0	Logging language	Startup language		

##### Screens

Bit selection for text and graphic lists	Off	User-defined pictogram size	Unchecked	X,Y:	64, 45
--	-----	-----------------------------	-----------	------	--------

##### Keyboard

Use screen keyboard	Checked	Release button on exit	Unchecked	Disable dialog window function keys	Unchecked
---------------------	---------	------------------------	-----------	-------------------------------------	-----------

##### Alarms

##### Controller alarms

Buffer overflow	10 %	Acknowledgment group text	QGR	Use alarm class color	Unchecked
Use help texts for system diagnostics	Checked	System event duration	2 Seconds	Connection	HMI_Connection_1

##### User administration

Enable limit for logon attempts	Checked	Invalid logon attempts	3	Logon with password	Unchecked
Group-specific rights	Unchecked	Password aging	Unchecked	Validity period	90
Warning period	7	Password generations	3	At least one special character	Unchecked
At least one number	Unchecked	Minimum password length	3		

##### Language & font

Preset runtime language	English (United States)
-------------------------	-------------------------

English (United States)

Runtime language	Checked	Fixed font 1	Tahoma	Default font	Tahoma, 11 Pixel
Configured font 1					

##### Tag settings

Replace the separators on each sub-level of the path of the PLC tag:	Checked	Compatibility mode: Set '_' between the PLC tags and the first-level element.	Unchecked	Replace the '.' character if the name of the HMI tag is created from the PLC tag name	Checked
Use '_' as the replacement character	Checked	Use ';' as the replacement character	Unchecked	Replace the characters '[' and ']' if the name of the HMI tag is created from the PLC tag name	Checked
Use '{' and '}' as replacement characters	Checked	Use '(' and ')' as replacement characters	Unchecked		


Settings for the prefix 'PLC' in the HMI tag name

Connection	HMI_Connection_1	PLC name as prefix in the HMI tag name	Unchecked
------------	------------------	--	-----------

Task3\_V15 / HMI\_1 [KTP400 Basic PN] / Screens

Root screen

Hardcopy of Root screen



General					
Name	Root screen	Background color	255, 255, 255	Grid color	0, 0, 0
Number	1	Template	Template_1	Tooltip	
Layers					
Active layer	0				

Layer_0	Checked
Layer_1	Checked
Layer_2	Checked
Layer_3	Checked
Layer_4	Checked
Layer_5	Checked
Layer_6	Checked
Layer_7	Checked
Layer_8	Checked
Layer_9	Checked
Layer_10	Checked
Layer_11	Checked
Layer_12	Checked
Layer_13	Checked
Layer_14	Checked
Layer_15	Checked
Layer_16	Checked
Layer_17	Checked
Layer_18	Checked
Layer_19	Checked
Layer_20	Checked
Layer_21	Checked
Layer_22	Checked
Layer_23	Checked
Layer_24	Checked
Layer_25	Checked
Layer_26	Checked
Layer_27	Checked
Layer_28	Checked
Layer_29	Checked
Layer_30	Checked
Layer_31	Checked

Text field_1					
Type	Text field				
General					
Text	Operation Modes				
Appearance					
Background color	255, 255, 255	Background fill pattern	Transparent	Corner radius (border)	3
Foreground color	49, 52, 74	Border width	0	Line style	Double line
Border color	66, 73, 82	Border background color	99, 101, 115		
Layout					
X position	18	Y position	7	Width	143
Height	23	Left margin	3	Top margin	2
Right margin	2	Bottom margin	2	Fit object to contents	Checked
Text format					
Font	Tahoma, 16px, style=Bold	Orientation	Horizontal	Horizontal alignment	Left
Vertical alignment	Middle	Line break	Unchecked		
Flashing					
Flashing	Disabled				
Styles/Designs					
Use style/design	Unchecked	Style item appearance			

Totally Integrated Automation Portal						
--------------------------------------	--	--	--	--	--	--

Miscellaneous

Name	Text field_1	Layer	0 - Layer_0		
------	--------------	-------	-------------	--	--

Button\_1

Type	Button				
General					
Mode	Text	Hotkey	None	Text OFF	Start
Text ON	Text	Text list		Graphic OFF	
Graphic ON		Graphic list		Process value	
Bit number	0				
Appearance					
Background color	99, 101, 115	Background fill pattern	Vertical gradient	Corner radius (border)	3
Foreground color	255, 255, 255	Border width	2	Line style	Solid
Border color	66, 73, 82	Border background color	107, 105, 107		
Fill pattern					
Background color gradient (fill pattern)	99, 101, 115	Gradient 1 (fill pattern)	Checked	Color gradient 1 (fill pattern)	132, 134, 140
Offset gradient 1 (fill pattern)	15	Gradient 2 (fill pattern)	Checked	Color gradient 2 (fill pattern)	90, 89, 99
Offset gradient 2 (fill pattern)	15				
Design					
Focus width	2	Focus color	148, 182, 231		
Layout					
X position	22	Y position	37	Width	96
Height	32	Fit graphic to size	Stretch graphic	Horizontal alignment of the graphic	Centered
Vertical alignment of the graphic	Middle	Fit object to contents	Unchecked	Margin left text (layout)	0
Margin top text (layout)	0	Margin right text (layout)	0	Margin bottom text (layout)	0
Margin left graphic (layout)	0	Margin top graphic (layout)	0	Margin right graphic (layout)	0
Margin bottom graphic (layout)	0				
Text format					
Font	Tahoma, 13px, style=Bold	Orientation	Horizontal	Horizontal alignment of the text	Centered
Vertical alignment of the text	Middle				
Styles/Designs					
Use style/design	Unchecked	Style item appearance			
Miscellaneous					
Name	Button_1	Layer	0 - Layer_0	Tooltip	
Security					
Authorization		Allow operator control	Checked		

Dynamizations\Event

Event name	Press
------------	-------

Function list\SetBitWhileKeyPressed

Tag	in_start	Bit	0
-----	----------	-----	---

Dynamizations\Appearance

Tag - Cycle	out_started -	Data type	Range	Range	0..0
Foreground color	255, 255, 255	Background color	99, 101, 113	Flashing	No
Range	1..1	Foreground color	255, 255, 255	Background color	0, 255, 0
Flashing	No				

Button\_2

Type	Button				
General					
Mode	Text	Hotkey	None	Text OFF	Stop
Text ON	Text	Text list		Graphic OFF	
Graphic ON		Graphic list		Process value	
Bit number	0				
Appearance					
Background color	99, 101, 115	Background fill pattern	Vertical gradient	Corner radius (border)	3
Foreground color	255, 255, 255	Border width	2	Line style	Solid
Border color	66, 73, 82	Border background color	107, 105, 107		
Fill pattern					
Background color gradient (fill pattern)	99, 101, 115	Gradient 1 (fill pattern)	Checked	Color gradient 1 (fill pattern)	132, 134, 140
Offset gradient 1 (fill pattern)	15	Gradient 2 (fill pattern)	Checked	Color gradient 2 (fill pattern)	90, 89, 99
Offset gradient 2 (fill pattern)	15				
Design					
Focus width	2	Focus color	148, 182, 231		
Layout					
X position	22	Y position	74	Width	96

Totally Integrated Automation Portal						
--------------------------------------	--	--	--	--	--	--

Height	32	Fit graphic to size	Stretch graphic	Horizontal alignment of the graphic	Centered
Vertical alignment of the graphic	Middle	Fit object to contents	Unchecked	Margin left text (layout)	0
Margin top text (layout)	0	Margin right text (layout)	0	Margin bottom text (layout)	0
Margin left graphic (layout)	0	Margin top graphic (layout)	0	Margin right graphic (layout)	0
Margin bottom graphic (layout)	0				
Text format					
Font	Tahoma, 13px, style=Bold	Orientation	Horizontal	Horizontal alignment of the text	Centered
Vertical alignment of the text	Middle				
Styles/Designs					
Use style/design	Unchecked	Style item appearance			
Miscellaneous					
Name	Button_2	Layer	0 - Layer_0	Tooltip	
Security					
Authorization		Allow operator control	Checked		

Dynamizations\Event					
Event name		Press			

Function list\SetBitWhileKeyPressed					
-------------------------------------	--	--	--	--	--

Tag	in_stop	Bit	0		
-----	---------	-----	---	--	--

Dynamizations\Appearance					
Tag - Cycle	out_started -	Data type	Range	Range	1..1
Foreground color	255, 255, 255	Background color	99, 101, 115	Flashing	No
Range	0..0	Foreground color	255, 255, 255	Background color	255, 0, 0
Flashing	No				

Button_3					
----------	--	--	--	--	--

Type	Button				
General					
Mode	Text	Hotkey	None	Text OFF	Automatic
Text ON	Text	Text list		Graphic OFF	
Graphic ON		Graphic list		Process value	
Bit number	0				
Appearance					
Background color	99, 101, 115	Background fill pattern	Vertical gradient	Corner radius (border)	3
Foreground color	255, 255, 255	Border width	2	Line style	Solid
Border color	66, 73, 82	Border background color	107, 105, 107		
Fill pattern					
Background color gradient (fill pattern)	99, 101, 115	Gradient 1 (fill pattern)	Checked	Color gradient 1 (fill pattern)	132, 134, 140
Offset gradient 1 (fill pattern)	15	Gradient 2 (fill pattern)	Checked	Color gradient 2 (fill pattern)	90, 89, 99
Offset gradient 2 (fill pattern)	15				
Design					
Focus width	2	Focus color	148, 182, 231		
Layout					
X position	22	Y position	112	Width	96
Height	32	Fit graphic to size	Stretch graphic	Horizontal alignment of the graphic	Centered
Vertical alignment of the graphic	Middle	Fit object to contents	Unchecked	Margin left text (layout)	0
Margin top text (layout)	0	Margin right text (layout)	0	Margin bottom text (layout)	0
Margin left graphic (layout)	0	Margin top graphic (layout)	0	Margin right graphic (layout)	0
Margin bottom graphic (layout)	0				
Text format					
Font	Tahoma, 13px, style=Bold	Orientation	Horizontal	Horizontal alignment of the text	Centered
Vertical alignment of the text	Middle				
Styles/Designs					
Use style/design	Unchecked	Style item appearance			
Miscellaneous					
Name	Button_3	Layer	0 - Layer_0	Tooltip	
Security					
Authorization		Allow operator control	Checked		

Dynamizations\Event					
Event name		Press			

--	--	--	--	--	--

Totally Integrated Automation Portal						
--------------------------------------	--	--	--	--	--	--

Function list\SetBitWhileKeyPressed

Tag	in_automatic	Bit	0
-----	--------------	-----	---

Dynamizations\Appearance

Tag - Cycle	out_automatic_selected -	Data type	Range	Range	0..0
Foreground color	255, 255, 255	Background color	99, 101, 115	Flashing	No
Range	1..1	Foreground color	255, 255, 255	Background color	0, 255, 0
Flashing	No				

Button\_4

Type	Button				
General					
Mode	Text	Hotkey	None	Text OFF	Manual
Text ON	Text	Text list		Graphic OFF	
Graphic ON		Graphic list		Process value	
Bit number	0				
Appearance					
Background color	99, 101, 115	Background fill pattern	Vertical gradient	Corner radius (border)	3
Foreground color	255, 255, 255	Border width	2	Line style	Solid
Border color	66, 73, 82	Border background color	107, 105, 107		
Fill pattern					
Background color gradient (fill pattern)	99, 101, 115	Gradient 1 (fill pattern)	Checked	Color gradient 1 (fill pattern)	132, 134, 140
Offset gradient 1 (fill pattern)	15	Gradient 2 (fill pattern)	Checked	Color gradient 2 (fill pattern)	90, 89, 99
Offset gradient 2 (fill pattern)	15				
Design					
Focus width	2	Focus color	148, 182, 231		
Layout					
X position	22	Y position	149	Width	96
Height	32	Fit graphic to size	Stretch graphic	Horizontal alignment of the graphic	Centered
Vertical alignment of the graphic	Middle	Fit object to contents	Unchecked	Margin left text (layout)	0
Margin top text (layout)	0	Margin right text (layout)	0	Margin bottom text (layout)	0
Margin left graphic (layout)	0	Margin top graphic (layout)	0	Margin right graphic (layout)	0
Margin bottom graphic (layout)	0				
Text format					
Font	Tahoma, 13px, style=Bold	Orientation	Horizontal	Horizontal alignment of the text	Centered
Vertical alignment of the text	Middle				
Styles/Designs					
Use style/design	Unchecked	Style item appearance			
Miscellaneous					
Name	Button_4	Layer	0 - Layer_0	Tooltip	
Security					
Authorization		Allow operator control	Checked		

Dynamizations\Event

Event name	Press
------------	-------

Function list\SetBitWhileKeyPressed

Tag	in_manual	Bit	0
-----	-----------	-----	---

Dynamizations\Appearance

Tag - Cycle	out_manual_selected -	Data type	Range	Range	0..0
Foreground color	255, 255, 255	Background color	99, 101, 115	Flashing	No
Range	1..1	Foreground color	255, 255, 255	Background color	0, 255, 0
Flashing	No				

Switch\_1

Type	Switch				
General					
Process value		Value status ON	1	Mode	Switch with text
Text ON	Simulate E-Stop OFF	Text OFF	Simulate E-Stop ON	Graphic ON	
Graphic OFF					
Appearance					
Foreground color	255, 255, 255	Background color	99, 101, 115	Inner background color ON	247, 243, 247
Inner background color OFF	247, 243, 247	Border width	2	Line style	Solid
Border color	66, 73, 82	Border background color	107, 105, 107	Corner radius	3
Fill pattern					
Background fill pattern	Vertical gradient	Background color gradient (fill pattern)	99, 101, 115	Gradient 1 (fill pattern)	Checked
Color gradient 1 (fill pattern)	132, 134, 140	Offset gradient 1 (fill pattern)	15	Gradient 2 (fill pattern)	Checked



Totally Integrated Automation Portal						
--------------------------------------	--	--	--	--	--	--

Color gradient 2 (fill pattern)	90, 89, 99	Offset gradient 2 (fill pattern)	15		
Design					
Focus width	2	Focus color	148, 182, 231		
Layout					
X position	235	Y position	36	Width	161
Height	32	Fit graphic to size	Stretch graphic	Horizontal alignment of the graphic	Centered
Vertical alignment of the graphic	Middle	Switch orientation	Left to right	Fit object to contents	Unchecked
Margin left text (layout)	0	Margin top text (layout)	0	Margin right text (layout)	0
Margin bottom text (layout)	0	Margin left graphic (layout)	0	Margin top graphic (layout)	0
Margin right graphic (layout)	0	Margin bottom graphic (layout)	0		
Text format					
Font	Tahoma, 13px, style=Bold	Orientation	Horizontal	Horizontal alignment of the text	Centered
Vertical alignment of the text	Middle				
Limits					
Color for High limit violated	239, 97, 99	Color for Low limit violated	255, 219, 41		
Styles/Designs					
Use style/design	Unchecked	Style item appearance			
Miscellaneous					
Name	Switch_1	Layer	0 - Layer_0	Tooltip	
Security					
Authorization		Allow operator control	Checked		
Dynamizations\Tag connection					
Property name	Process value	Tag	in_e-stop		
Dynamizations\Appearance					
Tag - Cycle	out_e-stop-active -	Data type	Range	Range	0..0
Foreground color	255, 255, 255	Background color	99, 101, 115	Flashing	No
Range	1..1	Foreground color	255, 255, 255	Background color	255, 0, 0
Flashing	No				

Switch\_2

Type	Switch				
General					
Process value		Value status ON	1	Mode	Switch with text
Text ON	Simulate Error OFF	Text OFF	Simulate Error ON	Graphic ON	
Graphic OFF					
Appearance					
Foreground color	255, 255, 255	Background color	99, 101, 115	Inner background color ON	247, 243, 247
Inner background color OFF	247, 243, 247	Border width	2	Line style	Solid
Border color	66, 73, 82	Border background color	107, 105, 107	Corner radius	3
Fill pattern					
Background fill pattern	Vertical gradient	Background color gradient (fill pattern)	99, 101, 115	Gradient 1 (fill pattern)	Checked
Color gradient 1 (fill pattern)	132, 134, 140	Offset gradient 1 (fill pattern)	15	Gradient 2 (fill pattern)	Checked
Color gradient 2 (fill pattern)	90, 89, 99	Offset gradient 2 (fill pattern)	15		
Design					
Focus width	2	Focus color	148, 182, 231		
Layout					
X position	235	Y position	73	Width	162
Height	32	Fit graphic to size	Stretch graphic	Horizontal alignment of the graphic	Centered
Vertical alignment of the graphic	Middle	Switch orientation	Left to right	Fit object to contents	Unchecked
Margin left text (layout)	0	Margin top text (layout)	0	Margin right text (layout)	0
Margin bottom text (layout)	0	Margin left graphic (layout)	0	Margin top graphic (layout)	0
Margin right graphic (layout)	0	Margin bottom graphic (layout)	0		
Text format					
Font	Tahoma, 13px, style=Bold	Orientation	Horizontal	Horizontal alignment of the text	Centered
Vertical alignment of the text	Middle				
Limits					
Color for High limit violated	239, 97, 99	Color for Low limit violated	255, 219, 41		
Styles/Designs					
Use style/design	Unchecked	Style item appearance			
Miscellaneous					
Name	Switch_2	Layer	0 - Layer_0	Tooltip	

Totally Integrated Automation Portal						
--------------------------------------	--	--	--	--	--	--

Security

Authorization		Allow operator control	Checked		
---------------	--	------------------------	---------	--	--

Dynamizations\Tag connection

Property name	Process value	Tag	in_error		
---------------	---------------	-----	----------	--	--

Dynamizations\Appearance

Tag - Cycle	out_error_active -	Data type	Range	Range	0..0
Foreground color	255, 255, 255	Background color	99, 101, 115	Flashing	No
Range	1..1	Foreground color	255, 255, 255	Background color	255, 0, 0
Flashing	No				

Button\_5

Type	Button				
General					
Mode	Text	Hotkey	None	Text OFF	Reset Error
Text ON	Text	Text list		Graphic OFF	
Graphic ON		Graphic list		Process value	
Bit number	0				
Appearance					
Background color	99, 101, 115	Background fill pattern	Vertical gradient	Corner radius (border)	3
Foreground color	255, 255, 255	Border width	2	Line style	Solid
Border color	66, 73, 82	Border background color	107, 105, 107		
Fill pattern					
Background color gradient (fill pattern)	99, 101, 115	Gradient 1 (fill pattern)	Checked	Color gradient 1 (fill pattern)	132, 134, 140
Offset gradient 1 (fill pattern)	15	Gradient 2 (fill pattern)	Checked	Color gradient 2 (fill pattern)	90, 89, 99
Offset gradient 2 (fill pattern)	15				
Design					
Focus width	2	Focus color	148, 182, 231		
Layout					
X position	128	Y position	37	Width	96
Height	32	Fit graphic to size	Stretch graphic	Horizontal alignment of the graphic	Centered
Vertical alignment of the graphic	Middle	Fit object to contents	Unchecked	Margin left text (layout)	0
Margin top text (layout)	0	Margin right text (layout)	0	Margin bottom text (layout)	0
Margin left graphic (layout)	0	Margin top graphic (layout)	0	Margin right graphic (layout)	0
Margin bottom graphic (layout)	0				
Text format					
Font	Tahoma, 13px, style=Bold	Orientation	Horizontal	Horizontal alignment of the text	Centered
Vertical alignment of the text	Middle				
Styles/Designs					
Use style/design	Unchecked	Style item appearance			
Miscellaneous					
Name	Button_5	Layer	0 - Layer_0	Tooltip	

Security

Authorization		Allow operator control	Checked		
---------------	--	------------------------	---------	--	--

Dynamizations\Event

Event name	Press				
------------	-------	--	--	--	--

Function list\SetBitWhileKeyPressed

Tag	in_reset_error	Bit	0		
-----	----------------	-----	---	--	--

Button\_6

Type	Button				
General					
Mode	Text	Hotkey	None	Text OFF	Reset E-stop
Text ON	Text	Text list		Graphic OFF	
Graphic ON		Graphic list		Process value	
Bit number	0				
Appearance					
Background color	99, 101, 115	Background fill pattern	Vertical gradient	Corner radius (border)	3
Foreground color	255, 255, 255	Border width	2	Line style	Solid
Border color	66, 73, 82	Border background color	107, 105, 107		
Fill pattern					
Background color gradient (fill pattern)	99, 101, 115	Gradient 1 (fill pattern)	Checked	Color gradient 1 (fill pattern)	132, 134, 140
Offset gradient 1 (fill pattern)	15	Gradient 2 (fill pattern)	Checked	Color gradient 2 (fill pattern)	90, 89, 99
Offset gradient 2 (fill pattern)	15				
Design					
Focus width	2	Focus color	148, 182, 231		

Totally Integrated Automation Portal						
Layout						
X position	128	Y position	74	Width	96	
Height	32	Fit graphic to size	Stretch graphic	Horizontal alignment of the graphic	Centered	
Vertical alignment of the graphic	Middle	Fit object to contents	Unchecked	Margin left text (layout)	0	
Margin top text (layout)	0	Margin right text (layout)	0	Margin bottom text (layout)	0	
Margin left graphic (layout)	0	Margin top graphic (layout)	0	Margin right graphic (layout)	0	
Margin bottom graphic (layout)	0					
Text format						
Font	Tahoma, 13px, style=Bold	Orientation	Horizontal	Horizontal alignment of the text	Centered	
Vertical alignment of the text	Middle					
Styles/Designs						
Use style/design	Unchecked	Style item appearance				
Miscellaneous						
Name	Button_6	Layer	0 - Layer_0	Tooltip		
Security						
Authorization		Allow operator control	Checked			
Dynamizations\Event						
Event name		Press				
Function list\SetBitWhileKeyPressed						
Tag	in_reset_e-stop	Bit	0			
Switch_3						
Type	Switch					
General						
Process value		Value status ON	1	Mode	Switch with text	
Text ON	Simulate User Interaction OFF	Text OFF	Simulate User Interaction ON	Graphic ON		
Graphic OFF						
Appearance						
Foreground color	255, 255, 255	Background color	99, 101, 115	Inner background color ON	247, 243, 247	
Inner background color OFF	247, 243, 247	Border width	2	Line style	Solid	
Border color	66, 73, 82	Border background color	107, 105, 107	Corner radius	3	
Fill pattern						
Background fill pattern	Vertical gradient	Background color gradient (fill pattern)	99, 101, 115	Gradient 1 (fill pattern)	Checked	
Color gradient 1 (fill pattern)	132, 134, 140	Offset gradient 1 (fill pattern)	15	Gradient 2 (fill pattern)	Checked	
Color gradient 2 (fill pattern)	90, 89, 99	Offset gradient 2 (fill pattern)	15			
Design						
Focus width	2	Focus color	148, 182, 231			
Layout						
X position	235	Y position	149	Width	209	
Height	32	Fit graphic to size	Stretch graphic	Horizontal alignment of the graphic	Centered	
Vertical alignment of the graphic	Middle	Switch orientation	Left to right	Fit object to contents	Unchecked	
Margin left text (layout)	0	Margin top text (layout)	0	Margin right text (layout)	0	
Margin bottom text (layout)	0	Margin left graphic (layout)	0	Margin top graphic (layout)	0	
Margin right graphic (layout)	0	Margin bottom graphic (layout)	0			
Text format						
Font	Tahoma, 13px, style=Bold	Orientation	Horizontal	Horizontal alignment of the text	Centered	
Vertical alignment of the text	Middle					
Limits						
Color for High limit violated	239, 97, 99	Color for Low limit violated	255, 219, 41			
Styles/Designs						
Use style/design	Unchecked	Style item appearance				
Miscellaneous						
Name	Switch_3	Layer	0 - Layer_0	Tooltip		
Security						
Authorization		Allow operator control	Checked			
Dynamizations\Tag connection						
Property name	Process value	Tag	in_user_interaction			
Dynamizations\Appearance						
Tag - Cycle	in_user_interaction -	Data type	Range	Range	0..0	
Foreground color	255, 255, 255	Background color	99, 101, 115	Flashing	No	
Range	1..1	Foreground color	255, 255, 255	Background color	49, 101, 255	



Totally Integrated Automation Portal

Task3\_V15 / HMI\_1 [KTP400 Basic PN] / Screen management / Templates

Template\_1

Hardcopy of Template\_1

General

Name

Template\_1

Background color

181, 182, 181

Grid color

0, 0, 0

Tab sequence in foreground

Checked

Layers

Active layer

0

Layer\_0

Checked

Layer\_1

Checked

Layer\_2

Checked

Layer\_3

Checked

Layer\_4

Checked

Layer\_5

Checked

Layer\_6

Checked

Layer\_7

Checked

Layer\_8

Checked

Layer\_9

Checked

Layer\_10

Checked

Layer\_11

Checked

Layer\_12

Checked

Layer\_13

Checked

Layer\_14

Checked

Layer\_15

Checked

Layer\_16

Checked

Layer\_17

Checked

Layer\_18

Checked

Layer\_19

Checked

Layer\_20

Checked

Layer\_21

Checked

Layer\_22

Checked

Layer\_23

Checked

Layer\_24

Checked

Layer\_25

Checked

Layer\_26

Checked

Layer\_27

Checked

Layer\_28

Checked

Layer\_29

Checked

Layer\_30

Checked

Layer\_31

Checked

Template\_Button

Type

Button

General

Mode

Graphic

Hotkey

None

Text OFF

ExitRuntime

Text ON

ExitRuntime

Text list

Graphic OFF

ExitRuntime\_KTP400\_Basic\_PN\_TR

Graphic ON

ExitRuntime\_KTP400\_Basic\_PN\_TR

Graphic list

Process value

Bit number

0

Appearance

Background color

239, 235, 239

Background fill pattern

Vertical gradient

Corner radius (border)

3

Foreground color

49, 52, 74

Border width

1

Line style

Solid

Border color

156, 154, 165

Border background color

107, 105, 107

Fill pattern

Background color gradient (fill pattern)

231, 227, 231

Gradient 1 (fill pattern)

Checked

Color gradient 1 (fill pattern)

247, 247, 247

Offset gradient 1 (fill pattern)

15

Gradient 2 (fill pattern)

Checked

Color gradient 2 (fill pattern)

222, 215, 214

Offset gradient 2 (fill pattern)

15

Design

Focus width

2

Focus color

148, 182, 231

Totally Integrated Automation Portal						
Layout						
X position	388	Y position	227	Width	63	
Height	44	Fit graphic to size	Stretch graphic	Horizontal alignment of the graphic	Centered	
Vertical alignment of the graphic	Middle	Fit object to contents	Unchecked	Margin left text (layout)	0	
Margin top text (layout)	0	Margin right text (layout)	0	Margin bottom text (layout)	0	
Margin left graphic (layout)	0	Margin top graphic (layout)	0	Margin right graphic (layout)	0	
Margin bottom graphic (layout)	0					
Text format						
Font	Tahoma, 13px, style=Bold	Orientation	Horizontal	Horizontal alignment of the text	Centered	
Vertical alignment of the text	Middle					
Styles/Designs						
Use style/design	Unchecked	Style item appearance				
Miscellaneous						
Name	Template_Button	Layer	0 - Layer_0	Tooltip		
Security						
Authorization		Allow operator control	Checked			
Dynamizations\Event						
Event name		Release				
Function list\StopRuntime						
Mode		Runtime				
Template_Button_1						
Type	Button					
General						
Mode	Text	Hotkey	None	Text OFF		
Text ON		Text list		Graphic OFF		
Graphic ON		Graphic list		Process value		
Bit number	0					
Appearance						
Background color	239, 235, 239	Background fill pattern	Vertical gradient	Corner radius (border)	3	
Foreground color	49, 52, 74	Border width	1	Line style	Solid	
Border color	156, 154, 165	Border background color	107, 105, 107			
Fill pattern						
Background color gradient (fill pattern)	231, 227, 231	Gradient 1 (fill pattern)	Checked	Color gradient 1 (fill pattern)	247, 247, 247	
Offset gradient 1 (fill pattern)	15	Gradient 2 (fill pattern)	Checked	Color gradient 2 (fill pattern)	222, 215, 214	
Offset gradient 2 (fill pattern)	15					
Design						
Focus width	2	Focus color	148, 182, 231			
Layout						
X position	268	Y position	227	Width	63	
Height	44	Fit graphic to size	Stretch graphic	Horizontal alignment of the graphic	Centered	
Vertical alignment of the graphic	Middle	Fit object to contents	Unchecked	Margin left text (layout)	0	
Margin top text (layout)	0	Margin right text (layout)	0	Margin bottom text (layout)	0	
Margin left graphic (layout)	0	Margin top graphic (layout)	0	Margin right graphic (layout)	0	
Margin bottom graphic (layout)	0					
Text format						
Font	Tahoma, 13px, style=Bold	Orientation	Horizontal	Horizontal alignment of the text	Centered	
Vertical alignment of the text	Middle					
Styles/Designs						
Use style/design	Unchecked	Style item appearance				
Miscellaneous						
Name	Template_Button_1	Layer	0 - Layer_0	Tooltip		
Security						
Authorization		Allow operator control	Checked			
Template_Button_2						
Type	Button					
General						
Mode	Text	Hotkey	None	Text OFF		
Text ON		Text list		Graphic OFF		
Graphic ON		Graphic list		Process value		
Bit number	0					



Totally Integrated Automation Portal						
Appearance						
Background color	239, 235, 239	Background fill pattern	Vertical gradient	Corner radius (border)	3	
Foreground color	49, 52, 74	Border width	1	Line style	Solid	
Border color	156, 154, 165	Border background color	107, 105, 107			
Fill pattern						
Background color gradient (fill pattern)	231, 227, 231	Gradient 1 (fill pattern)	Checked	Color gradient 1 (fill pattern)	247, 247, 247	
Offset gradient 1 (fill pattern)	15	Gradient 2 (fill pattern)	Checked	Color gradient 2 (fill pattern)	222, 215, 214	
Offset gradient 2 (fill pattern)	15					
Design						
Focus width	2	Focus color	148, 182, 231			
Layout						
X position	148	Y position	227	Width	63	
Height	44	Fit graphic to size	Stretch graphic	Horizontal alignment of the graphic	Centered	
Vertical alignment of the graphic	Middle	Fit object to contents	Unchecked	Margin left text (layout)	0	
Margin top text (layout)	0	Margin right text (layout)	0	Margin bottom text (layout)	0	
Margin left graphic (layout)	0	Margin top graphic (layout)	0	Margin right graphic (layout)	0	
Margin bottom graphic (layout)	0					
Text format						
Font	Tahoma, 13px, style=Bold	Orientation	Horizontal	Horizontal alignment of the text	Centered	
Vertical alignment of the text	Middle					
Styles/Designs						
Use style/design	Unchecked	Style item appearance				
Miscellaneous						
Name	Template_Button_2	Layer	0 - Layer_0	Tooltip		
Security						
Authorization		Allow operator control	Checked			
Template_Button_3						
Type	Button					
General						
Mode	Graphic	Hotkey	None	Text OFF	NavigateHome	
Text ON	NavigateHome	Text list		Graphic OFF	NavigateHome_KTP400_Basic_PN_TR	
Graphic ON	NavigateHome_KTP400_Basic_PN_TR	Graphic list		Process value		
Bit number	0					
Appearance						
Background color	239, 235, 239	Background fill pattern	Vertical gradient	Corner radius (border)	3	
Foreground color	49, 52, 74	Border width	1	Line style	Solid	
Border color	156, 154, 165	Border background color	107, 105, 107			
Fill pattern						
Background color gradient (fill pattern)	231, 227, 231	Gradient 1 (fill pattern)	Checked	Color gradient 1 (fill pattern)	247, 247, 247	
Offset gradient 1 (fill pattern)	15	Gradient 2 (fill pattern)	Checked	Color gradient 2 (fill pattern)	222, 215, 214	
Offset gradient 2 (fill pattern)	15					
Design						
Focus width	2	Focus color	148, 182, 231			
Layout						
X position	28	Y position	227	Width	63	
Height	44	Fit graphic to size	Stretch graphic	Horizontal alignment of the graphic	Centered	
Vertical alignment of the graphic	Middle	Fit object to contents	Unchecked	Margin left text (layout)	0	
Margin top text (layout)	0	Margin right text (layout)	0	Margin bottom text (layout)	0	
Margin left graphic (layout)	0	Margin top graphic (layout)	0	Margin right graphic (layout)	0	
Margin bottom graphic (layout)	0					
Text format						
Font	Tahoma, 13px, style=Bold	Orientation	Horizontal	Horizontal alignment of the text	Centered	
Vertical alignment of the text	Middle					
Styles/Designs						
Use style/design	Unchecked	Style item appearance				
Miscellaneous						
Name	Template_Button_3	Layer	0 - Layer_0	Tooltip		
Security						
Authorization		Allow operator control	Checked			

Totally Integrated Automation Portal		
Dynamizations\Event		
Event name	Release	
Function list\ActivateScreen		
Screen name	Root screen	Object number
		0



Totally Integrated Automation Portal		
--------------------------------------	--	--

Task3\_V15 / HMI\_1 [KTP400 Basic PN] / Screen management

Global screen

Hardcopy of Global screen

General					
Name	Global screen	Background color	181, 182, 181	Grid color	0, 0, 0

Totally Integrated Automation Portal

### Task3\_V15 / HMI\_1 [KTP400 Basic PN] / HMI tags

#### Default tag table [17]

in\_automatic

General					
Name	in_automatic	Connection	HMI_Connection_1	Data type	Bool
Array elements	0	Length	1	Address	
Access mode	<symbolic access>	PLC tag	Operation_mode_DB.OperatingModes.Input.automatic	Coding	Binary
PLC name	PLC_1				
Settings					
Acquisition cycle	1 s	Acquisition mode	Cyclic in operation		
Limits					
Upper 2		Lower 2			
Linear scaling					
Linear scaling	Unchecked	PLC value range end value	10	PLC value range start value	0
HMI device value range end value	100	HMI device value range start value	0		
Values					
ID tag		Start value			
Comment					
Comment		Source comment			
Multiplexing					
Multiplexing	Unchecked	Index tag			

in\_manual

General					
Name	in_manual	Connection	HMI_Connection_1	Data type	Bool
Array elements	0	Length	1	Address	
Access mode	<symbolic access>	PLC tag	Operation_mode_DB.OperatingModes.Input.manual	Coding	Binary
PLC name	PLC_1				
Settings					
Acquisition cycle	1 s	Acquisition mode	Cyclic in operation		
Limits					
Upper 2		Lower 2			
Linear scaling					
Linear scaling	Unchecked	PLC value range end value	10	PLC value range start value	0
HMI device value range end value	100	HMI device value range start value	0		
Values					
ID tag		Start value			
Comment					
Comment		Source comment			
Multiplexing					
Multiplexing	Unchecked	Index tag			

in\_start

General					
Name	in_start	Connection	HMI_Connection_1	Data type	Bool
Array elements	0	Length	1	Address	
Access mode	<symbolic access>	PLC tag	Operation_mode_DB.OperatingModes.Input.start	Coding	Binary
PLC name	PLC_1				
Settings					
Acquisition cycle	1 s	Acquisition mode	Cyclic in operation		
Limits					
Upper 2		Lower 2			
Linear scaling					
Linear scaling	Unchecked	PLC value range end value	10	PLC value range start value	0
HMI device value range end value	100	HMI device value range start value	0		
Values					
ID tag		Start value			
Comment					
Comment		Source comment			
Multiplexing					
Multiplexing	Unchecked	Index tag			

in\_stop

General					
Name	in_stop	Connection	HMI_Connection_1	Data type	Bool
Array elements	0	Length	1	Address	
Access mode	<symbolic access>	PLC tag	Operation_mode_DB.OperatingModes.Input.stop	Coding	Binary
PLC name	PLC_1				
Settings					
Acquisition cycle	1 s	Acquisition mode	Cyclic in operation		
Limits					
Upper 2		Lower 2			

Totally Integrated Automation Portal

Linear scaling

Linear scaling	Unchecked	PLC value range end value	10	PLC value range start value	0
HMI device value range end value	100	HMI device value range start value	0		
Values					
ID tag		Start value			
Comment					
Comment		Source comment			
Multiplexing					
Multiplexing	Unchecked	Index tag			

in\_e-stop

General

Name	in_e-stop	Connection	HMI_Connection_1	Data type	Bool
Array elements	0	Length	1	Address	
Access mode	<symbolic access>	PLC tag	Operation_mode_DB.OperatingModes.Input.estop	Coding	Binary
PLC name	PLC_1				

Settings

Acquisition cycle	1 s	Acquisition mode	Cyclic in operation		
-------------------	-----	------------------	---------------------	--	--

Limits

Upper 2		Lower 2			
---------	--	---------	--	--	--

Linear scaling

Linear scaling	Unchecked	PLC value range end value	10	PLC value range start value	0
HMI device value range end value	100	HMI device value range start value	0		
Values					
ID tag		Start value			
Comment					
Comment		Source comment			
Multiplexing					
Multiplexing	Unchecked	Index tag			

in\_user\_interaction

General

Name	in_user_interaction	Connection	HMI_Connection_1	Data type	Bool
Array elements	0	Length	1	Address	
Access mode	<symbolic access>	PLC tag	Operation_mode_DB.OperatingModes.Input.user_interaction	Coding	Binary
PLC name	PLC_1				

Settings

Acquisition cycle	1 s	Acquisition mode	Cyclic in operation		
-------------------	-----	------------------	---------------------	--	--

Limits

Upper 2		Lower 2			
---------	--	---------	--	--	--

Linear scaling

Linear scaling	Unchecked	PLC value range end value	10	PLC value range start value	0
HMI device value range end value	100	HMI device value range start value	0		
Values					
ID tag		Start value			
Comment					
Comment		Source comment			
Multiplexing					
Multiplexing	Unchecked	Index tag			

in\_reset\_e-stop

General

Name	in_reset_e-stop	Connection	HMI_Connection_1	Data type	Bool
Array elements	0	Length	1	Address	
Access mode	<symbolic access>	PLC tag	Operation_mode_DB.OperatingModes.Input.reset_estop	Coding	Binary
PLC name	PLC_1				

Settings

Acquisition cycle	1 s	Acquisition mode	Cyclic in operation		
-------------------	-----	------------------	---------------------	--	--

Limits

Upper 2		Lower 2			
---------	--	---------	--	--	--

Linear scaling

Linear scaling	Unchecked	PLC value range end value	10	PLC value range start value	0
HMI device value range end value	100	HMI device value range start value	0		
Values					
ID tag		Start value			
Comment					
Comment		Source comment			
Multiplexing					
Multiplexing	Unchecked	Index tag			

in\_error

General

Name	in_error	Connection	HMI_Connection_1	Data type	Bool
Array elements	0	Length	1	Address	

Totally Integrated Automation Portal

Access mode

<symbolic access>

PLC tag

Operation\_mode\_DB.OperatingModes.Input.error

Coding

Binary

PLC name

PLC\_1

Settings

Acquisition cycle

1 s

Acquisition mode

Cyclic in operation

Limits

Upper 2

Lower 2

Linear scaling

Linear scaling

Unchecked

PLC value range end value

10

PLC value range start value

0

HMI device value range end value

100

HMI device value range start value

0

Values

ID tag

Start value

Comment

Comment

Source comment

Multiplexing

Multiplexing

Unchecked

Index tag

in\_warning

General

Name

in\_warning

Connection

HMI\_Connection\_1

Data type

Bool

Array elements

0

Length

1

Address

Access mode

<symbolic access>

PLC tag

Operation\_mode\_DB.OperatingModes.Input.warning

Coding

Binary

PLC name

PLC\_1

Settings

Acquisition cycle

1 s

Acquisition mode

Cyclic in operation

Limits

Upper 2

Lower 2

Linear scaling

Linear scaling

Unchecked

PLC value range end value

10

PLC value range start value

0

HMI device value range end value

100

HMI device value range start value

0

Values

ID tag

Start value

Comment

Comment

Source comment

Multiplexing

Multiplexing

Unchecked

Index tag

in\_reset\_error

General

Name

in\_reset\_error

Connection

HMI\_Connection\_1

Data type

Bool

Array elements

0

Length

1

Address

Access mode

<symbolic access>

PLC tag

Operation\_mode\_DB.OperatingModes.Input.reset\_error

Coding

Binary

PLC name

PLC\_1

Settings

Acquisition cycle

1 s

Acquisition mode

Cyclic in operation

Limits

Upper 2

Lower 2

Linear scaling

Linear scaling

Unchecked

PLC value range end value

10

PLC value range start value

0

HMI device value range end value

100

HMI device value range start value

0

Values

ID tag

Start value

Comment

Comment

Source comment

Multiplexing

Multiplexing

Unchecked

Index tag

out\_automatic\_selected

General

Name

out\_automatic\_selected

Connection

HMI\_Connection\_1

Data type

Bool

Array elements

0

Length

1

Address

Access mode

<symbolic access>

PLC tag

Operation\_mode\_DB.OperatingModes.Output.automatic\_selected

Coding

Binary

PLC name

PLC\_1

Settings

Acquisition cycle

1 s

Acquisition mode

Cyclic in operation

Limits

Upper 2

Lower 2

Linear scaling

Linear scaling

Unchecked

PLC value range end value

10

PLC value range start value

0

HMI device value range end value

100

HMI device value range start value

0

Values

ID tag

Start value

Comment

Comment

Source comment

Totally Integrated Automation Portal						
--------------------------------------	--	--	--	--	--	--

Multiplexing

Multiplexing	Unchecked	Index tag			
--------------	-----------	-----------	--	--	--

out\_manual\_selected

General

Name	out_manual_selected	Connection	HMI_Connection_1	Data type	Bool
Array elements	0	Length	1	Address	
Access mode	<symbolic access>	PLC tag	Operation_mode_DB.OperatingModes.Output.manual_selected	Coding	Binary

PLC name	PLC_1				
----------	-------	--	--	--	--

Settings

Acquisition cycle	1 s	Acquisition mode	Cyclic in operation		
-------------------	-----	------------------	---------------------	--	--

Limits

Upper 2		Lower 2			
---------	--	---------	--	--	--

Linear scaling

Linear scaling	Unchecked	PLC value range end value	10	PLC value range start value	0
HMI device value range end value	100	HMI device value range start value	0		

Values

ID tag		Start value			
--------	--	-------------	--	--	--

Comment

Comment		Source comment			
---------	--	----------------	--	--	--

Multiplexing

Multiplexing	Unchecked	Index tag			
--------------	-----------	-----------	--	--	--

out\_e-stop-active

General

Name	out_e-stop-active	Connection	HMI_Connection_1	Data type	Bool
Array elements	0	Length	1	Address	
Access mode	<symbolic access>	PLC tag	Operation_mode_DB.OperatingModes.Output.estop_active	Coding	Binary

PLC name	PLC_1				
----------	-------	--	--	--	--

Settings

Acquisition cycle	1 s	Acquisition mode	Cyclic in operation		
-------------------	-----	------------------	---------------------	--	--

Limits

Upper 2		Lower 2			
---------	--	---------	--	--	--

Linear scaling

Linear scaling	Unchecked	PLC value range end value	10	PLC value range start value	0
HMI device value range end value	100	HMI device value range start value	0		

Values

ID tag		Start value			
--------	--	-------------	--	--	--

Comment

Comment		Source comment			
---------	--	----------------	--	--	--

Multiplexing

Multiplexing	Unchecked	Index tag			
--------------	-----------	-----------	--	--	--

out\_started

General

Name	out_started	Connection	HMI_Connection_1	Data type	Bool
Array elements	0	Length	1	Address	
Access mode	<symbolic access>	PLC tag	Operation_mode_DB.OperatingModes.Output.started	Coding	Binary

PLC name	PLC_1				
----------	-------	--	--	--	--

Settings

Acquisition cycle	1 s	Acquisition mode	Cyclic in operation		
-------------------	-----	------------------	---------------------	--	--

Limits

Upper 2		Lower 2			
---------	--	---------	--	--	--

Linear scaling

Linear scaling	Unchecked	PLC value range end value	10	PLC value range start value	0
HMI device value range end value	100	HMI device value range start value	0		

Values

ID tag		Start value			
--------	--	-------------	--	--	--

Comment

Comment		Source comment			
---------	--	----------------	--	--	--

Multiplexing

Multiplexing	Unchecked	Index tag			
--------------	-----------	-----------	--	--	--

out\_automatic

General

Name	out_automatic	Connection	HMI_Connection_1	Data type	Bool
Array elements	0	Length	1	Address	
Access mode	<symbolic access>	PLC tag	Operation_mode_DB.OperatingModes.Output.automatic	Coding	Binary

PLC name	PLC_1				
----------	-------	--	--	--	--

Settings

Acquisition cycle	1 s	Acquisition mode	Cyclic in operation		
-------------------	-----	------------------	---------------------	--	--

Limits

Upper 2		Lower 2			
---------	--	---------	--	--	--

Linear scaling

Linear scaling	Unchecked	PLC value range end value	10	PLC value range start value	0
----------------	-----------	---------------------------	----	-----------------------------	---

Totally Integrated Automation Portal

HMI device value range end value	100	HMI device value range start value	0		
Values					
ID tag		Start value			
Comment					
Comment		Source comment			
Multiplexing					
Multiplexing	Unchecked	Index tag			

out\_manual

General					
Name	out_manual	Connection	HMI_Connection_1	Data type	Bool
Array elements	0	Length	1	Address	
Access mode	<symbolic access>	PLC tag	Operation_mode_DB.OperatingModes.Output.manual	Coding	Binary
PLC name	PLC_1				
Settings					
Acquisition cycle	1 s	Acquisition mode	Cyclic in operation		
Limits					
Upper 2		Lower 2			
Linear scaling					
Linear scaling	Unchecked	PLC value range end value	10	PLC value range start value	0
HMI device value range end value	100	HMI device value range start value	0		
Values					
ID tag		Start value			
Comment					
Comment		Source comment			
Multiplexing					
Multiplexing	Unchecked	Index tag			

out\_error\_active

General					
Name	out_error_active	Connection	HMI_Connection_1	Data type	Bool
Array elements	0	Length	1	Address	
Access mode	<symbolic access>	PLC tag	Operation_mode_DB.OperatingModes.Output.error_active	Coding	Binary
PLC name	PLC_1				
Settings					
Acquisition cycle	1 s	Acquisition mode	Cyclic in operation		
Limits					
Upper 2		Lower 2			
Linear scaling					
Linear scaling	Unchecked	PLC value range end value	10	PLC value range start value	0
HMI device value range end value	100	HMI device value range start value	0		
Values					
ID tag		Start value			
Comment					
Comment		Source comment			
Multiplexing					
Multiplexing	Unchecked	Index tag			

Totally Integrated Automation Portal

### Task3\_V15 / HMI\_1 [KTP400 Basic PN]

#### Connections

##### HMI\_Connection\_1

Name	HMI_Connection_1	Communication driver	SIMATIC S7 1200	Comment	
Online	Checked	Station	S7-1200 station_1	Partner	PLC_1
Node	CPU 1212C AC/DC/Rly, PROFINET interface (R0/S1)	HMI time synchronization mode	None		

##### Parameter

HMI device					
Interface	PROFINET (X1)	Address	192.168.1.101	Access point	S7ONLINE
PLC					
Address	192.168.1.100				

Totally Integrated Automation Portal		
<div>Task3_V15 / HMI_1 [KTP400 Basic PN] / HMI alarms</div> <div>Discrete alarms</div> <div>This folder is empty.</div>		



Totally Integrated Automation Portal		
<div>Task3_V15 / HMI_1 [KTP400 Basic PN] / HMI alarms</div> <div>Analog alarms</div> <div>This folder is empty.</div>		

Totally Integrated Automation Portal		
--------------------------------------	--	--

Task3\_V15 / HMI\_1 [KTP400 Basic PN] / HMI alarms

Alarm groups

Alarm\_group\_1

General			
Name	Alarm_group_1	ID	1

Alarm\_group\_10

General			
Name	Alarm_group_10	ID	10

Alarm\_group\_11

General			
Name	Alarm_group_11	ID	11

Alarm\_group\_12

General			
Name	Alarm_group_12	ID	12

Alarm\_group\_13

General			
Name	Alarm_group_13	ID	13

Alarm\_group\_14

General			
Name	Alarm_group_14	ID	14

Alarm\_group\_15

General			
Name	Alarm_group_15	ID	15

Alarm\_group\_16

General			
Name	Alarm_group_16	ID	16

Alarm\_group\_2

General			
Name	Alarm_group_2	ID	2

Alarm\_group\_3

General			
Name	Alarm_group_3	ID	3

Alarm\_group\_4

General			
Name	Alarm_group_4	ID	4

Alarm\_group\_5

General			
Name	Alarm_group_5	ID	5

Alarm\_group\_6

General			
Name	Alarm_group_6	ID	6

Alarm\_group\_7

General			
Name	Alarm_group_7	ID	7

Alarm\_group\_8

General			
Name	Alarm_group_8	ID	8

Alarm\_group\_9

General			
Name	Alarm_group_9	ID	9

--	--	--

Totally Integrated Automation Portal

### Task3\_V15 / HMI\_1 [KTP400 Basic PN] / HMI alarms

#### Alarm classes

##### Acknowledgement

General					
Name	Acknowledgement	Display name	A	ID	33
Common alarm class	Acknowledgement	Alarm log	<No log>		
Acknowledgment					
State machine	Alarm with single-mode acknowledg-ment				
State texts					
Text for "Incoming"	I	Text for "Outgoing"	O	Text for "Acknowl- edged"	A
Colors					
Background "Incom- ing/Acknowledged"	255, 255, 255	Background "Incom- ing"	255, 0, 0	Background "Incom- ing/Outgoing/ Acknowledged"	255, 255, 255
Background "Incom- ing/Outgoing"	255, 0, 0				

##### Errors

General					
Name	Errors	Display name	!	ID	1
Common alarm class	<No alarm class>	Alarm log	<No log>		
Acknowledgment					
State machine	Alarm with single-mode acknowledg-ment				
State texts					
Text for "Incoming"	I	Text for "Outgoing"	O	Text for "Acknowl- edged"	A
Colors					
Background "Incom- ing/Acknowledged"	255, 255, 255	Background "Incom- ing"	255, 0, 0	Background "Incom- ing/Outgoing/ Acknowledged"	255, 255, 255
Background "Incom- ing/Outgoing"	255, 0, 0				

##### No Acknowledgement

General					
Name	No Acknowledgement	Display name	NA	ID	34
Common alarm class	No Acknowledgement	Alarm log	<No log>		
Acknowledgment					
State machine	Alarm without acknowledgment				
State texts					
Text for "Incoming"	I	Text for "Outgoing"	O	Text for "Acknowl- edged"	A
Colors					
Background "Incom- ing/Acknowledged"	255, 255, 255	Background "Incom- ing"	255, 0, 0	Background "Incom- ing/Outgoing/ Acknowledged"	255, 255, 255
Background "Incom- ing/Outgoing"	255, 0, 0				

##### System

General					
Name	System	Display name	\$	ID	3
Common alarm class	<No alarm class>	Alarm log	<No log>		
Acknowledgment					
State machine	Alarm without acknowledgment				
State texts					
Text for "Incoming"	I	Text for "Outgoing"	O	Text for "Acknowl- edged"	A
Colors					
Background "Incom- ing/Acknowledged"	255, 255, 255	Background "Incom- ing"	255, 255, 255	Background "Incom- ing/Outgoing/ Acknowledged"	255, 255, 255
Background "Incom- ing/Outgoing"	255, 255, 255				

##### Warnings

General					
Name	Warnings	Display name		ID	2
Common alarm class	<No alarm class>	Alarm log	<No log>		
Acknowledgment					
State machine	Alarm without acknowledgment				
State texts					
Text for "Incoming"	I	Text for "Outgoing"	O	Text for "Acknowl- edged"	A
Colors					
Background "Incom- ing/Acknowledged"	255, 255, 255	Background "Incom- ing"	255, 255, 255	Background "Incom- ing/Outgoing/ Acknowledged"	255, 255, 255

Totally Integrated Automation Portal		
Background "Incoming/Outgoing"	255, 255, 255	

Totally Integrated Automation Portal		
<div>Task3_V15 / HMI_1 [KTP400 Basic PN] / HMI alarms</div> <div>System events</div> <div>This folder is empty.</div>		

Totally Integrated Automation Portal		
<div>Task3_V15 / HMI_1 [KTP400 Basic PN]</div> <div>Recipes</div> <div>This folder is empty.</div>		

Totally Integrated Automation Portal		
<div>Task3_V15 / HMI_1 [KTP400 Basic PN] / Historical data</div> <div>Datalogs</div> <div>This folder is empty.</div>		

Totally Integrated Automation Portal		
<div>Task3_V15 / HMI_1 [KTP400 Basic PN] / Historical data</div> <div>AlarmLogs</div> <div>This folder is empty.</div>		



Totally Integrated Automation Portal		
<div>Task3_V15 / HMI_1 [KTP400 Basic PN]</div> <div>Scheduled tasks</div> <div>This folder is empty.</div>		

Totally Integrated Automation Portal		
<div>Task3_V15 / HMI_1 [KTP400 Basic PN] / Text and graphic lists</div> <div>Text lists</div> <div>This folder is empty.</div>		

Totally Integrated Automation Portal		
<div>Task3_V15 / HMI_1 [KTP400 Basic PN] / Text and graphic lists</div> <div>Graphic lists</div> <div>This folder is empty.</div>		

Totally Integrated Automation Portal

Task3\_V15 / HMI\_1 [KTP400 Basic PN] / User administration

User

Administrator

General

Name

Administrator

Number

1

Automatic logoff

Automatic logoff

Checked

Logoff time

5

Comment

Comment

The user 'Administrator' is assigned to the 'Administrator' group.

Groups

Groups

Administrator group;

Totally Integrated Automation Portal

# Task3\_V15 / HMI\_1 [KTP400 Basic PN] / User administration

## Groups

### Administrator group

General					
Name	Administrator group	Display name	Administrator group	Number	1
Password aging	Unchecked				
Comment					
Comment	The 'Administrator' group is initially granted all rights.				
Authorizations					
Authorizations	User administration; Monitor; Oper-ate;				

### Users

General					
Name	Users	Display name	Users	Number	2
Password aging	Unchecked				
Comment					
Comment	The 'Users' group is initially granted 'Operating' rights.				
Authorizations					
Authorizations	Operate;				

Totally Integrated Automation Portal		
--------------------------------------	--	--

Task3\_V15 / HMI\_1 [KTP400 Basic PN] / User administration

Authorizations

Monitor

General				
Name	Monitor	Authorization	Monitor	Authorization number2
Comment				
Comment	'Monitor' authorization.			

Operate

General				
Name	Operate	Authorization	Operate	Authorization number3
Comment				
Comment	'Operate' authorization.			

User administration

General				
Name	User administration	Authorization	User administration	Authorization number1
Comment				
Comment	Authorization 'User administration' for managing users in the user view in-rRuntime.			

--	--	--

Totally Integrated Automation Portal		
<div>Task3_V15</div> <div>Ungrouped devices</div> <div>This folder is empty.</div>		

Totally Integrated Automation Portal		
<div>Task3_V15</div> <div>Security settings</div> <div>This folder is empty.</div>		



Totally Integrated Automation Portal

Task3\_V15 / Common data

Alarm classes

Alarm classes			
Name	Display name	Acknowledgment	Priority
Acknowledgement	A	True	0
No Acknowledgement	NA	False	0

Totally Integrated Automation Portal		
<div>Task3_V15 / Common data</div> <div>Logs</div> <div>This folder is empty.</div>		

Totally Integrated Automation Portal		
<div>Task3_V15 / Common data</div> <div>Styles</div> <div>This folder is empty.</div>		

Totally Integrated Automation Portal		
--------------------------------------	--	--

Task3\_V15 / Languages & resources

Project languages

Languages

Reference language

English (United States)

Editing language

English (United States)

Other project languages





































Empty

--	--	--

Totally Integrated Automation Portal																																																																																																																																																																																									
<div>Task3_V15 / Languages &amp; resources / Project texts</div> <div>Project texts</div> <table><tr><th colspan="3">Project texts</th></tr><tr><th>English (United States)</th><th>Category</th><th>Reference</th></tr><tr><td></td><td>Other text category</td><td>Task3_V15\Comment</td></tr><tr><td></td><td>HMI screen</td><td>Task3_V15\HMI_1 [KTP400 Basic PN]\Screen management\Templates\Template_1\Tem-plate_Button_1\Text OFF</td></tr><tr><td></td><td>HMI screen</td><td>Task3_V15\HMI_1 [KTP400 Basic PN]\Screen management\Templates\Template_1\Tem-plate_Button_1\Text ON</td></tr><tr><td></td><td>HMI screen</td><td>Task3_V15\HMI_1 [KTP400 Basic PN]\Screen management\Templates\Template_1\Tem-plate_Button_2\Text OFF</td></tr><tr><td></td><td>HMI screen</td><td>Task3_V15\HMI_1 [KTP400 Basic PN]\Screen management\Templates\Template_1\Tem-plate_Button_2\Text ON</td></tr><tr><td></td><td>Alarm text</td><td>Task3_V15\HMI_1 [KTP400 Basic PN]\HMI alarms\Warnings\alarmclass name not set_1\Alarm-ClassData_IDisplayNaming_DisplayName</td></tr><tr><td></td><td>Alarm text</td><td>Task3_V15\HMI_1 [KTP400 Basic PN]\HMI alarms\Acknowledgement\alarmclass name not set_5\AlarmClassData_IDisplayNaming_DisplayName</td></tr><tr><td></td><td>Alarm text</td><td>Task3_V15\HMI_1 [KTP400 Basic PN]\HMI alarms\No Acknowledgement\alarmclass name not set_6\AlarmClassData_IDisplayNaming_DisplayName</td></tr><tr><td>!</td><td>Alarm text</td><td>Task3_V15\HMI_1 [KTP400 Basic PN]\HMI alarms\Errors\alarmclass name not set\AlarmClass-Data_IDisplayNaming_DisplayName</td></tr><tr><td>!!</td><td>Alarm text</td><td>Task3_V15\HMI_1 [KTP400 Basic PN]\HMI alarms\Safety warnings\alarmclass name not set_4\AlarmClassData_IDisplayNaming_DisplayName</td></tr><tr><td>"Main Program Sweep (Cycle)"</td><td>Block comment</td><td>Task3_V15\PLC_1 [CPU 1212C AC/DC/Rly]\Program blocks\Main [OB1]\Block title</td></tr><tr><td>"Main Program Sweep (Cycle)"</td><td>Block comment</td><td>Task3_V15\PLC_2 [CPU 1212C AC/DC/Rly]\Program blocks\Main [OB1]\Block title</td></tr><tr><td>\$</td><td>Alarm text</td><td>Task3_V15\HMI_1 [KTP400 Basic PN]\HMI alarms\System\alarmclass name not set_2\Alarm-ClassData_IDisplayNaming_DisplayName</td></tr><tr><td>=True, if remanent data are available</td><td>Block comment</td><td>Task3_V15\PLC_1 [CPU 1212C AC/DC/Rly]\Program blocks\Main [OB1]\Remanence</td></tr><tr><td>=True, if remanent data are available</td><td>Block comment</td><td>Task3_V15\PLC_2 [CPU 1212C AC/DC/Rly]\Program blocks\Main [OB1]\Remanence</td></tr><tr><td>A</td><td>Alarm class text</td><td>Task3_V15\Acknowledgement\AlarmClassData_IDisplayNaming_DisplayName</td></tr><tr><td>A</td><td>Alarm class text</td><td>Task3_V15\Acknowledgement\ShortName</td></tr><tr><td>A</td><td>Alarm text</td><td>Task3_V15\HMI_1 [KTP400 Basic PN]\HMI alarms\Errors\AcknowledgedText</td></tr><tr><td>A</td><td>Alarm text</td><td>Task3_V15\HMI_1 [KTP400 Basic PN]\HMI alarms\Warnings\AcknowledgedText</td></tr><tr><td>A</td><td>Alarm text</td><td>Task3_V15\HMI_1 [KTP400 Basic PN]\HMI alarms\System\AcknowledgedText</td></tr><tr><td>A</td><td>Alarm text</td><td>Task3_V15\HMI_1 [KTP400 Basic PN]\HMI alarms\Diagnosis events\AcknowledgedText</td></tr><tr><td>A</td><td>Alarm text</td><td>Task3_V15\HMI_1 [KTP400 Basic PN]\HMI alarms\Safety warnings\AcknowledgedText</td></tr><tr><td>A</td><td>Alarm text</td><td>Task3_V15\HMI_1 [KTP400 Basic PN]\HMI alarms\Acknowledgement\AcknowledgedText</td></tr><tr><td>A</td><td>Alarm text</td><td>Task3_V15\HMI_1 [KTP400 Basic PN]\HMI alarms\No Acknowledgement\AcknowledgedText</td></tr><tr><td>Administrator group</td><td>HMI runtime</td><td>Task3_V15\HMI_1 [KTP400 Basic PN]\User administration\Administrator group\DisplayName</td></tr><tr><td>Authorization 'User administration' for manag- ing users in the user view inrRuntime.</td><td>HMI comment</td><td>Task3_V15\HMI_1 [KTP400 Basic PN]\User administration\User administration\Comment</td></tr><tr><td>Automatic</td><td>HMI screen</td><td>Task3_V15\HMI_1 [KTP400 Basic PN]\Screens\Root screen\Button_3\Text OFF</td></tr><tr><td>Automatic/Manual mode</td><td>Block comment</td><td>Task3_V15\PLC_2 [CPU 1212C AC/DC/Rly]\Program blocks\Operation modes\Operation_modes [FB1]\Network 2\Title</td></tr><tr><td>Automatic/Manual mode</td><td>Block comment</td><td>Task3_V15\PLC_1 [CPU 1212C AC/DC/Rly]\Program blocks\Operation modes\Operation_modes [FB1]\Network 2\Title</td></tr><tr><td>command value</td><td>Block comment</td><td>Task3_V15\PLC_1 [CPU 1212C AC/DC/Rly]\Watch and force tables\Watch table_1\Row 1\Com-ment</td></tr><tr><td>command value</td><td>Block comment</td><td>Task3_V15\PLC_1 [CPU 1212C AC/DC/Rly]\Watch and force tables\Watch table_1\Row 1\Com-ment</td></tr><tr><td>command value</td><td>Block comment</td><td>Task3_V15\PLC_2 [CPU 1212C AC/DC/Rly]\Watch and force tables\Watch table_1\Row 1\Com-ment</td></tr><tr><td>command value</td><td>Block comment</td><td>Task3_V15\PLC_2 [CPU 1212C AC/DC/Rly]\Watch and force tables\Watch table_1\Row 1\Com-ment</td></tr><tr><td>Error</td><td>Block comment</td><td>Task3_V15\PLC_2 [CPU 1212C AC/DC/Rly]\Program blocks\Operation modes\Operation_modes [FB1]\Network 4\Title</td></tr><tr><td>Error</td><td>Block comment</td><td>Task3_V15\PLC_1 [CPU 1212C AC/DC/Rly]\Program blocks\Operation modes\Operation_modes [FB1]\Network 4\Title</td></tr><tr><td>E-Stop</td><td>Block comment</td><td>Task3_V15\PLC_2 [CPU 1212C AC/DC/Rly]\Program blocks\Operation modes\Operation_modes [FB1]\Network 3\Title</td></tr><tr><td>E-Stop</td><td>Block comment</td><td>Task3_V15\PLC_1 [CPU 1212C AC/DC/Rly]\Program blocks\Operation modes\Operation_modes [FB1]\Network 3\Title</td></tr><tr><td>ExitRuntime</td><td>HMI screen</td><td>Task3_V15\HMI_1 [KTP400 Basic PN]\Screen management\Templates\Template_1\Tem-plate_Button\Text OFF</td></tr><tr><td>ExitRuntime</td><td>HMI screen</td><td>Task3_V15\HMI_1 [KTP400 Basic PN]\Screen management\Templates\Template_1\Tem-plate_Button\Text ON</td></tr><tr><td>I</td><td>Alarm text</td><td>Task3_V15\HMI_1 [KTP400 Basic PN]\HMI alarms\Errors\ComingText</td></tr><tr><td>I</td><td>Alarm text</td><td>Task3_V15\HMI_1 [KTP400 Basic PN]\HMI alarms\Warnings\ComingText</td></tr><tr><td>I</td><td>Alarm text</td><td>Task3_V15\HMI_1 [KTP400 Basic PN]\HMI alarms\System\ComingText</td></tr><tr><td>I</td><td>Alarm text</td><td>Task3_V15\HMI_1 [KTP400 Basic PN]\HMI alarms\Diagnosis events\ComingText</td></tr><tr><td>I</td><td>Alarm text</td><td>Task3_V15\HMI_1 [KTP400 Basic PN]\HMI alarms\Safety warnings\ComingText</td></tr><tr><td>I</td><td>Alarm text</td><td>Task3_V15\HMI_1 [KTP400 Basic PN]\HMI alarms\Acknowledgement\ComingText</td></tr><tr><td>I</td><td>Alarm text</td><td>Task3_V15\HMI_1 [KTP400 Basic PN]\HMI alarms\No Acknowledgement\ComingText</td></tr><tr><td>Initial call of this OB</td><td>Block comment</td><td>Task3_V15\PLC_1 [CPU 1212C AC/DC/Rly]\Program blocks\Main [OB1]\Initial_Call</td></tr><tr><td>Initial call of this OB</td><td>Block comment</td><td>Task3_V15\PLC_2 [CPU 1212C AC/DC/Rly]\Program blocks\Main [OB1]\Initial_Call</td></tr><tr><td>IO</td><td>Alarm text</td><td>Task3_V15\HMI_1 [KTP400 Basic PN]\HMI alarms\Errors\ComingGoingText</td></tr><tr><td>IO</td><td>Alarm text</td><td>Task3_V15\HMI_1 [KTP400 Basic PN]\HMI alarms\Warnings\ComingGoingText</td></tr><tr><td>IO</td><td>Alarm text</td><td>Task3_V15\HMI_1 [KTP400 Basic PN]\HMI alarms\System\ComingGoingText</td></tr><tr><td>IO</td><td>Alarm text</td><td>Task3_V15\HMI_1 [KTP400 Basic PN]\HMI alarms\Diagnosis events\ComingGoingText</td></tr><tr><td>IO</td><td>Alarm text</td><td>Task3_V15\HMI_1 [KTP400 Basic PN]\HMI alarms\Safety warnings\ComingGoingText</td></tr><tr><td>IO</td><td>Alarm text</td><td>Task3_V15\HMI_1 [KTP400 Basic PN]\HMI alarms\Acknowledgement\ComingGoingText</td></tr><tr><td>IO</td><td>Alarm text</td><td>Task3_V15\HMI_1 [KTP400 Basic PN]\HMI alarms\No Acknowledgement\ComingGoingText</td></tr><tr><td>Manual</td><td>HMI screen</td><td>Task3_V15\HMI_1 [KTP400 Basic PN]\Screens\Root screen\Button_4\Text OFF</td></tr><tr><td>Monitor</td><td>HMI runtime</td><td>Task3_V15\HMI_1 [KTP400 Basic PN]\User administration\Monitor\ShortName</td></tr><tr><td>'Monitor' authorization.</td><td>HMI comment</td><td>Task3_V15\HMI_1 [KTP400 Basic PN]\User administration\Monitor\Comment</td></tr><tr><td>NA</td><td>Alarm class text</td><td>Task3_V15\No Acknowledgement\AlarmClassData_IDisplayNaming_DisplayName</td></tr></table>	Project texts			English (United States)	Category	Reference		Other text category	Task3_V15\Comment		HMI screen	Task3_V15\HMI_1 [KTP400 Basic PN]\Screen management\Templates\Template_1\Tem-plate_Button_1\Text OFF		HMI screen	Task3_V15\HMI_1 [KTP400 Basic PN]\Screen management\Templates\Template_1\Tem-plate_Button_1\Text ON		HMI screen	Task3_V15\HMI_1 [KTP400 Basic PN]\Screen management\Templates\Template_1\Tem-plate_Button_2\Text OFF		HMI screen	Task3_V15\HMI_1 [KTP400 Basic PN]\Screen management\Templates\Template_1\Tem-plate_Button_2\Text ON		Alarm text	Task3_V15\HMI_1 [KTP400 Basic PN]\HMI alarms\Warnings\alarmclass name not set_1\Alarm-ClassData_IDisplayNaming_DisplayName		Alarm text	Task3_V15\HMI_1 [KTP400 Basic PN]\HMI alarms\Acknowledgement\alarmclass name not set_5\AlarmClassData_IDisplayNaming_DisplayName		Alarm text	Task3_V15\HMI_1 [KTP400 Basic PN]\HMI alarms\No Acknowledgement\alarmclass name not set_6\AlarmClassData_IDisplayNaming_DisplayName	!	Alarm text	Task3_V15\HMI_1 [KTP400 Basic PN]\HMI alarms\Errors\alarmclass name not set\AlarmClass-Data_IDisplayNaming_DisplayName	!!	Alarm text	Task3_V15\HMI_1 [KTP400 Basic PN]\HMI alarms\Safety warnings\alarmclass name not set_4\AlarmClassData_IDisplayNaming_DisplayName	"Main Program Sweep (Cycle)"	Block comment	Task3_V15\PLC_1 [CPU 1212C AC/DC/Rly]\Program blocks\Main [OB1]\Block title	"Main Program Sweep (Cycle)"	Block comment	Task3_V15\PLC_2 [CPU 1212C AC/DC/Rly]\Program blocks\Main [OB1]\Block title	\$	Alarm text	Task3_V15\HMI_1 [KTP400 Basic PN]\HMI alarms\System\alarmclass name not set_2\Alarm-ClassData_IDisplayNaming_DisplayName	=True, if remanent data are available	Block comment	Task3_V15\PLC_1 [CPU 1212C AC/DC/Rly]\Program blocks\Main [OB1]\Remanence	=True, if remanent data are available	Block comment	Task3_V15\PLC_2 [CPU 1212C AC/DC/Rly]\Program blocks\Main [OB1]\Remanence	A	Alarm class text	Task3_V15\Acknowledgement\AlarmClassData_IDisplayNaming_DisplayName	A	Alarm class text	Task3_V15\Acknowledgement\ShortName	A	Alarm text	Task3_V15\HMI_1 [KTP400 Basic PN]\HMI alarms\Errors\AcknowledgedText	A	Alarm text	Task3_V15\HMI_1 [KTP400 Basic PN]\HMI alarms\Warnings\AcknowledgedText	A	Alarm text	Task3_V15\HMI_1 [KTP400 Basic PN]\HMI alarms\System\AcknowledgedText	A	Alarm text	Task3_V15\HMI_1 [KTP400 Basic PN]\HMI alarms\Diagnosis events\AcknowledgedText	A	Alarm text	Task3_V15\HMI_1 [KTP400 Basic PN]\HMI alarms\Safety warnings\AcknowledgedText	A	Alarm text	Task3_V15\HMI_1 [KTP400 Basic PN]\HMI alarms\Acknowledgement\AcknowledgedText	A	Alarm text	Task3_V15\HMI_1 [KTP400 Basic PN]\HMI alarms\No Acknowledgement\AcknowledgedText	Administrator group	HMI runtime	Task3_V15\HMI_1 [KTP400 Basic PN]\User administration\Administrator group\DisplayName	Authorization 'User administration' for manag- ing users in the user view inrRuntime.	HMI comment	Task3_V15\HMI_1 [KTP400 Basic PN]\User administration\User administration\Comment	Automatic	HMI screen	Task3_V15\HMI_1 [KTP400 Basic PN]\Screens\Root screen\Button_3\Text OFF	Automatic/Manual mode	Block comment	Task3_V15\PLC_2 [CPU 1212C AC/DC/Rly]\Program blocks\Operation modes\Operation_modes [FB1]\Network 2\Title	Automatic/Manual mode	Block comment	Task3_V15\PLC_1 [CPU 1212C AC/DC/Rly]\Program blocks\Operation modes\Operation_modes [FB1]\Network 2\Title	command value	Block comment	Task3_V15\PLC_1 [CPU 1212C AC/DC/Rly]\Watch and force tables\Watch table_1\Row 1\Com-ment	command value	Block comment	Task3_V15\PLC_1 [CPU 1212C AC/DC/Rly]\Watch and force tables\Watch table_1\Row 1\Com-ment	command value	Block comment	Task3_V15\PLC_2 [CPU 1212C AC/DC/Rly]\Watch and force tables\Watch table_1\Row 1\Com-ment	command value	Block comment	Task3_V15\PLC_2 [CPU 1212C AC/DC/Rly]\Watch and force tables\Watch table_1\Row 1\Com-ment	Error	Block comment	Task3_V15\PLC_2 [CPU 1212C AC/DC/Rly]\Program blocks\Operation modes\Operation_modes [FB1]\Network 4\Title	Error	Block comment	Task3_V15\PLC_1 [CPU 1212C AC/DC/Rly]\Program blocks\Operation modes\Operation_modes [FB1]\Network 4\Title	E-Stop	Block comment	Task3_V15\PLC_2 [CPU 1212C AC/DC/Rly]\Program blocks\Operation modes\Operation_modes [FB1]\Network 3\Title	E-Stop	Block comment	Task3_V15\PLC_1 [CPU 1212C AC/DC/Rly]\Program blocks\Operation modes\Operation_modes [FB1]\Network 3\Title	ExitRuntime	HMI screen	Task3_V15\HMI_1 [KTP400 Basic PN]\Screen management\Templates\Template_1\Tem-plate_Button\Text OFF	ExitRuntime	HMI screen	Task3_V15\HMI_1 [KTP400 Basic PN]\Screen management\Templates\Template_1\Tem-plate_Button\Text ON	I	Alarm text	Task3_V15\HMI_1 [KTP400 Basic PN]\HMI alarms\Errors\ComingText	I	Alarm text	Task3_V15\HMI_1 [KTP400 Basic PN]\HMI alarms\Warnings\ComingText	I	Alarm text	Task3_V15\HMI_1 [KTP400 Basic PN]\HMI alarms\System\ComingText	I	Alarm text	Task3_V15\HMI_1 [KTP400 Basic PN]\HMI alarms\Diagnosis events\ComingText	I	Alarm text	Task3_V15\HMI_1 [KTP400 Basic PN]\HMI alarms\Safety warnings\ComingText	I	Alarm text	Task3_V15\HMI_1 [KTP400 Basic PN]\HMI alarms\Acknowledgement\ComingText	I	Alarm text	Task3_V15\HMI_1 [KTP400 Basic PN]\HMI alarms\No Acknowledgement\ComingText	Initial call of this OB	Block comment	Task3_V15\PLC_1 [CPU 1212C AC/DC/Rly]\Program blocks\Main [OB1]\Initial_Call	Initial call of this OB	Block comment	Task3_V15\PLC_2 [CPU 1212C AC/DC/Rly]\Program blocks\Main [OB1]\Initial_Call	IO	Alarm text	Task3_V15\HMI_1 [KTP400 Basic PN]\HMI alarms\Errors\ComingGoingText	IO	Alarm text	Task3_V15\HMI_1 [KTP400 Basic PN]\HMI alarms\Warnings\ComingGoingText	IO	Alarm text	Task3_V15\HMI_1 [KTP400 Basic PN]\HMI alarms\System\ComingGoingText	IO	Alarm text	Task3_V15\HMI_1 [KTP400 Basic PN]\HMI alarms\Diagnosis events\ComingGoingText	IO	Alarm text	Task3_V15\HMI_1 [KTP400 Basic PN]\HMI alarms\Safety warnings\ComingGoingText	IO	Alarm text	Task3_V15\HMI_1 [KTP400 Basic PN]\HMI alarms\Acknowledgement\ComingGoingText	IO	Alarm text	Task3_V15\HMI_1 [KTP400 Basic PN]\HMI alarms\No Acknowledgement\ComingGoingText	Manual	HMI screen	Task3_V15\HMI_1 [KTP400 Basic PN]\Screens\Root screen\Button_4\Text OFF	Monitor	HMI runtime	Task3_V15\HMI_1 [KTP400 Basic PN]\User administration\Monitor\ShortName	'Monitor' authorization.	HMI comment	Task3_V15\HMI_1 [KTP400 Basic PN]\User administration\Monitor\Comment	NA	Alarm class text	Task3_V15\No Acknowledgement\AlarmClassData_IDisplayNaming_DisplayName		
Project texts																																																																																																																																																																																									
English (United States)	Category	Reference																																																																																																																																																																																							
	Other text category	Task3_V15\Comment																																																																																																																																																																																							
	HMI screen	Task3_V15\HMI_1 [KTP400 Basic PN]\Screen management\Templates\Template_1\Tem-plate_Button_1\Text OFF																																																																																																																																																																																							
	HMI screen	Task3_V15\HMI_1 [KTP400 Basic PN]\Screen management\Templates\Template_1\Tem-plate_Button_1\Text ON																																																																																																																																																																																							
	HMI screen	Task3_V15\HMI_1 [KTP400 Basic PN]\Screen management\Templates\Template_1\Tem-plate_Button_2\Text OFF																																																																																																																																																																																							
	HMI screen	Task3_V15\HMI_1 [KTP400 Basic PN]\Screen management\Templates\Template_1\Tem-plate_Button_2\Text ON																																																																																																																																																																																							
	Alarm text	Task3_V15\HMI_1 [KTP400 Basic PN]\HMI alarms\Warnings\alarmclass name not set_1\Alarm-ClassData_IDisplayNaming_DisplayName																																																																																																																																																																																							
	Alarm text	Task3_V15\HMI_1 [KTP400 Basic PN]\HMI alarms\Acknowledgement\alarmclass name not set_5\AlarmClassData_IDisplayNaming_DisplayName																																																																																																																																																																																							
	Alarm text	Task3_V15\HMI_1 [KTP400 Basic PN]\HMI alarms\No Acknowledgement\alarmclass name not set_6\AlarmClassData_IDisplayNaming_DisplayName																																																																																																																																																																																							
!	Alarm text	Task3_V15\HMI_1 [KTP400 Basic PN]\HMI alarms\Errors\alarmclass name not set\AlarmClass-Data_IDisplayNaming_DisplayName																																																																																																																																																																																							
!!	Alarm text	Task3_V15\HMI_1 [KTP400 Basic PN]\HMI alarms\Safety warnings\alarmclass name not set_4\AlarmClassData_IDisplayNaming_DisplayName																																																																																																																																																																																							
"Main Program Sweep (Cycle)"	Block comment	Task3_V15\PLC_1 [CPU 1212C AC/DC/Rly]\Program blocks\Main [OB1]\Block title																																																																																																																																																																																							
"Main Program Sweep (Cycle)"	Block comment	Task3_V15\PLC_2 [CPU 1212C AC/DC/Rly]\Program blocks\Main [OB1]\Block title																																																																																																																																																																																							
\$	Alarm text	Task3_V15\HMI_1 [KTP400 Basic PN]\HMI alarms\System\alarmclass name not set_2\Alarm-ClassData_IDisplayNaming_DisplayName																																																																																																																																																																																							
=True, if remanent data are available	Block comment	Task3_V15\PLC_1 [CPU 1212C AC/DC/Rly]\Program blocks\Main [OB1]\Remanence																																																																																																																																																																																							
=True, if remanent data are available	Block comment	Task3_V15\PLC_2 [CPU 1212C AC/DC/Rly]\Program blocks\Main [OB1]\Remanence																																																																																																																																																																																							
A	Alarm class text	Task3_V15\Acknowledgement\AlarmClassData_IDisplayNaming_DisplayName																																																																																																																																																																																							
A	Alarm class text	Task3_V15\Acknowledgement\ShortName																																																																																																																																																																																							
A	Alarm text	Task3_V15\HMI_1 [KTP400 Basic PN]\HMI alarms\Errors\AcknowledgedText																																																																																																																																																																																							
A	Alarm text	Task3_V15\HMI_1 [KTP400 Basic PN]\HMI alarms\Warnings\AcknowledgedText																																																																																																																																																																																							
A	Alarm text	Task3_V15\HMI_1 [KTP400 Basic PN]\HMI alarms\System\AcknowledgedText																																																																																																																																																																																							
A	Alarm text	Task3_V15\HMI_1 [KTP400 Basic PN]\HMI alarms\Diagnosis events\AcknowledgedText																																																																																																																																																																																							
A	Alarm text	Task3_V15\HMI_1 [KTP400 Basic PN]\HMI alarms\Safety warnings\AcknowledgedText																																																																																																																																																																																							
A	Alarm text	Task3_V15\HMI_1 [KTP400 Basic PN]\HMI alarms\Acknowledgement\AcknowledgedText																																																																																																																																																																																							
A	Alarm text	Task3_V15\HMI_1 [KTP400 Basic PN]\HMI alarms\No Acknowledgement\AcknowledgedText																																																																																																																																																																																							
Administrator group	HMI runtime	Task3_V15\HMI_1 [KTP400 Basic PN]\User administration\Administrator group\DisplayName																																																																																																																																																																																							
Authorization 'User administration' for manag- ing users in the user view inrRuntime.	HMI comment	Task3_V15\HMI_1 [KTP400 Basic PN]\User administration\User administration\Comment																																																																																																																																																																																							
Automatic	HMI screen	Task3_V15\HMI_1 [KTP400 Basic PN]\Screens\Root screen\Button_3\Text OFF																																																																																																																																																																																							
Automatic/Manual mode	Block comment	Task3_V15\PLC_2 [CPU 1212C AC/DC/Rly]\Program blocks\Operation modes\Operation_modes [FB1]\Network 2\Title																																																																																																																																																																																							
Automatic/Manual mode	Block comment	Task3_V15\PLC_1 [CPU 1212C AC/DC/Rly]\Program blocks\Operation modes\Operation_modes [FB1]\Network 2\Title																																																																																																																																																																																							
command value	Block comment	Task3_V15\PLC_1 [CPU 1212C AC/DC/Rly]\Watch and force tables\Watch table_1\Row 1\Com-ment																																																																																																																																																																																							
command value	Block comment	Task3_V15\PLC_1 [CPU 1212C AC/DC/Rly]\Watch and force tables\Watch table_1\Row 1\Com-ment																																																																																																																																																																																							
command value	Block comment	Task3_V15\PLC_2 [CPU 1212C AC/DC/Rly]\Watch and force tables\Watch table_1\Row 1\Com-ment																																																																																																																																																																																							
command value	Block comment	Task3_V15\PLC_2 [CPU 1212C AC/DC/Rly]\Watch and force tables\Watch table_1\Row 1\Com-ment																																																																																																																																																																																							
Error	Block comment	Task3_V15\PLC_2 [CPU 1212C AC/DC/Rly]\Program blocks\Operation modes\Operation_modes [FB1]\Network 4\Title																																																																																																																																																																																							
Error	Block comment	Task3_V15\PLC_1 [CPU 1212C AC/DC/Rly]\Program blocks\Operation modes\Operation_modes [FB1]\Network 4\Title																																																																																																																																																																																							
E-Stop	Block comment	Task3_V15\PLC_2 [CPU 1212C AC/DC/Rly]\Program blocks\Operation modes\Operation_modes [FB1]\Network 3\Title																																																																																																																																																																																							
E-Stop	Block comment	Task3_V15\PLC_1 [CPU 1212C AC/DC/Rly]\Program blocks\Operation modes\Operation_modes [FB1]\Network 3\Title																																																																																																																																																																																							
ExitRuntime	HMI screen	Task3_V15\HMI_1 [KTP400 Basic PN]\Screen management\Templates\Template_1\Tem-plate_Button\Text OFF																																																																																																																																																																																							
ExitRuntime	HMI screen	Task3_V15\HMI_1 [KTP400 Basic PN]\Screen management\Templates\Template_1\Tem-plate_Button\Text ON																																																																																																																																																																																							
I	Alarm text	Task3_V15\HMI_1 [KTP400 Basic PN]\HMI alarms\Errors\ComingText																																																																																																																																																																																							
I	Alarm text	Task3_V15\HMI_1 [KTP400 Basic PN]\HMI alarms\Warnings\ComingText																																																																																																																																																																																							
I	Alarm text	Task3_V15\HMI_1 [KTP400 Basic PN]\HMI alarms\System\ComingText																																																																																																																																																																																							
I	Alarm text	Task3_V15\HMI_1 [KTP400 Basic PN]\HMI alarms\Diagnosis events\ComingText																																																																																																																																																																																							
I	Alarm text	Task3_V15\HMI_1 [KTP400 Basic PN]\HMI alarms\Safety warnings\ComingText																																																																																																																																																																																							
I	Alarm text	Task3_V15\HMI_1 [KTP400 Basic PN]\HMI alarms\Acknowledgement\ComingText																																																																																																																																																																																							
I	Alarm text	Task3_V15\HMI_1 [KTP400 Basic PN]\HMI alarms\No Acknowledgement\ComingText																																																																																																																																																																																							
Initial call of this OB	Block comment	Task3_V15\PLC_1 [CPU 1212C AC/DC/Rly]\Program blocks\Main [OB1]\Initial_Call																																																																																																																																																																																							
Initial call of this OB	Block comment	Task3_V15\PLC_2 [CPU 1212C AC/DC/Rly]\Program blocks\Main [OB1]\Initial_Call																																																																																																																																																																																							
IO	Alarm text	Task3_V15\HMI_1 [KTP400 Basic PN]\HMI alarms\Errors\ComingGoingText																																																																																																																																																																																							
IO	Alarm text	Task3_V15\HMI_1 [KTP400 Basic PN]\HMI alarms\Warnings\ComingGoingText																																																																																																																																																																																							
IO	Alarm text	Task3_V15\HMI_1 [KTP400 Basic PN]\HMI alarms\System\ComingGoingText																																																																																																																																																																																							
IO	Alarm text	Task3_V15\HMI_1 [KTP400 Basic PN]\HMI alarms\Diagnosis events\ComingGoingText																																																																																																																																																																																							
IO	Alarm text	Task3_V15\HMI_1 [KTP400 Basic PN]\HMI alarms\Safety warnings\ComingGoingText																																																																																																																																																																																							
IO	Alarm text	Task3_V15\HMI_1 [KTP400 Basic PN]\HMI alarms\Acknowledgement\ComingGoingText																																																																																																																																																																																							
IO	Alarm text	Task3_V15\HMI_1 [KTP400 Basic PN]\HMI alarms\No Acknowledgement\ComingGoingText																																																																																																																																																																																							
Manual	HMI screen	Task3_V15\HMI_1 [KTP400 Basic PN]\Screens\Root screen\Button_4\Text OFF																																																																																																																																																																																							
Monitor	HMI runtime	Task3_V15\HMI_1 [KTP400 Basic PN]\User administration\Monitor\ShortName																																																																																																																																																																																							
'Monitor' authorization.	HMI comment	Task3_V15\HMI_1 [KTP400 Basic PN]\User administration\Monitor\Comment																																																																																																																																																																																							
NA	Alarm class text	Task3_V15\No Acknowledgement\AlarmClassData_IDisplayNaming_DisplayName																																																																																																																																																																																							

Totally Integrated Automation Portal		
English (United States)	Category	Reference
NA	Alarm class text	Task3_V15\No Acknowledgement\ShortName
NavigateHome	HMI screen	Task3_V15\HMI_1 [KTP400 Basic PN]\Screen management\Templates\Template_1\Tem-plate_Button_3\Text OFF
NavigateHome	HMI screen	Task3_V15\HMI_1 [KTP400 Basic PN]\Screen management\Templates\Template_1\Tem-plate_Button_3\Text ON
O	Alarm text	Task3_V15\HMI_1 [KTP400 Basic PN]\HMI alarms\Errors\GoingText
O	Alarm text	Task3_V15\HMI_1 [KTP400 Basic PN]\HMI alarms\Warnings\GoingText
O	Alarm text	Task3_V15\HMI_1 [KTP400 Basic PN]\HMI alarms\System\GoingText
O	Alarm text	Task3_V15\HMI_1 [KTP400 Basic PN]\HMI alarms\Diagnosis events\GoingText
O	Alarm text	Task3_V15\HMI_1 [KTP400 Basic PN]\HMI alarms\Safety warnings\GoingText
O	Alarm text	Task3_V15\HMI_1 [KTP400 Basic PN]\HMI alarms\Acknowledgement\GoingText
O	Alarm text	Task3_V15\HMI_1 [KTP400 Basic PN]\HMI alarms\No Acknowledgement\GoingText
Operate	HMI runtime	Task3_V15\HMI_1 [KTP400 Basic PN]\User administration\Operate\ShortName
'Operate' authorization.	HMI comment	Task3_V15\HMI_1 [KTP400 Basic PN]\User administration\Operate\Comment
operation command	Block comment	Task3_V15\PLC_1 [CPU 1212C AC/DC/Rly]\Watch and force tables\Watch table_1\Row 12\Com-ment
operation command	Block comment	Task3_V15\PLC_2 [CPU 1212C AC/DC/Rly]\Watch and force tables\Watch table_1\Row 12\Com-ment
Operation mode	Block comment	Task3_V15\PLC_1 [CPU 1212C AC/DC/Rly]\Program blocks\Main [OB1]\Network 2\Title
Operation mode	Block comment	Task3_V15\PLC_2 [CPU 1212C AC/DC/Rly]\Program blocks\Main [OB1]\Network 1\Title
Operation modes	Block comment	Task3_V15\PLC_2 [CPU 1212C AC/DC/Rly]\Program blocks\Operation modes\Operation_modes [FB1]\Block title
Operation modes	Block comment	Task3_V15\PLC_1 [CPU 1212C AC/DC/Rly]\Program blocks\Operation modes\Operation_modes [FB1]\Block title
Operation Modes	HMI screen	Task3_V15\HMI_1 [KTP400 Basic PN]\Screens\Root screen\Text field_1\Text
Put in PLC_2	Block comment	Task3_V15\PLC_1 [CPU 1212C AC/DC/Rly]\Program blocks\Main [OB1]\Network 1\Title
QGR	Alarm text	Task3_V15\HMI_1 [KTP400 Basic PN]\Runtime settings\HmiAlarmSettingsData\Acknowledge-mentGroupText
read value 0	Block comment	Task3_V15\PLC_1 [CPU 1212C AC/DC/Rly]\Watch and force tables\Watch table_1\Row 3\Com-ment
read value 0	Block comment	Task3_V15\PLC_2 [CPU 1212C AC/DC/Rly]\Watch and force tables\Watch table_1\Row 3\Com-ment
read value 1	Block comment	Task3_V15\PLC_1 [CPU 1212C AC/DC/Rly]\Watch and force tables\Watch table_1\Row 4\Com-ment
read value 1	Block comment	Task3_V15\PLC_2 [CPU 1212C AC/DC/Rly]\Watch and force tables\Watch table_1\Row 4\Com-ment
read value 2	Block comment	Task3_V15\PLC_1 [CPU 1212C AC/DC/Rly]\Watch and force tables\Watch table_1\Row 5\Com-ment
read value 2	Block comment	Task3_V15\PLC_2 [CPU 1212C AC/DC/Rly]\Watch and force tables\Watch table_1\Row 5\Com-ment
read value 3	Block comment	Task3_V15\PLC_1 [CPU 1212C AC/DC/Rly]\Watch and force tables\Watch table_1\Row 6\Com-ment
read value 3	Block comment	Task3_V15\PLC_2 [CPU 1212C AC/DC/Rly]\Watch and force tables\Watch table_1\Row 6\Com-ment
Reset Error	HMI screen	Task3_V15\HMI_1 [KTP400 Basic PN]\Screens\Root screen\Button_5\Text OFF
Reset E-stop	HMI screen	Task3_V15\HMI_1 [KTP400 Basic PN]\Screens\Root screen\Button_6\Text OFF
S7	Alarm text	Task3_V15\HMI_1 [KTP400 Basic PN]\HMI alarms\Diagnosis events\alarmclass name not set_3\AlarmClassData_IDisplayNaming_DisplayName
Simulate Error ON	HMI screen	Task3_V15\HMI_1 [KTP400 Basic PN]\Screens\Root screen\Switch_2\Text OFF
Simulate Error OFF	HMI screen	Task3_V15\HMI_1 [KTP400 Basic PN]\Screens\Root screen\Switch_2\Text ON
Simulate E-Stop OFF	HMI screen	Task3_V15\HMI_1 [KTP400 Basic PN]\Screens\Root screen\Switch_1\Text ON
Simulate E-Stop ON	HMI screen	Task3_V15\HMI_1 [KTP400 Basic PN]\Screens\Root screen\Switch_1\Text OFF
Simulate User Interaction OFF	HMI screen	Task3_V15\HMI_1 [KTP400 Basic PN]\Screens\Root screen\Switch_3\Text ON
Simulate User Interaction ON	HMI screen	Task3_V15\HMI_1 [KTP400 Basic PN]\Screens\Root screen\Switch_3\Text OFF
Simulate Warning OFF	HMI screen	Task3_V15\HMI_1 [KTP400 Basic PN]\Screens\Root screen\Switch_4\Text ON
Simulate Warning ON	HMI screen	Task3_V15\HMI_1 [KTP400 Basic PN]\Screens\Root screen\Switch_4\Text OFF
Start	HMI screen	Task3_V15\HMI_1 [KTP400 Basic PN]\Screens\Root screen\Button_1\Text OFF
Start/Stop operation	Block comment	Task3_V15\PLC_2 [CPU 1212C AC/DC/Rly]\Program blocks\Operation modes\Operation_modes [FB1]\Network 1\Title
Start/Stop operation	Block comment	Task3_V15\PLC_1 [CPU 1212C AC/DC/Rly]\Program blocks\Operation modes\Operation_modes [FB1]\Network 1\Title
status	Block comment	Task3_V15\PLC_1 [CPU 1212C AC/DC/Rly]\Watch and force tables\Watch table_1\Row 2\Com-ment
status	Block comment	Task3_V15\PLC_2 [CPU 1212C AC/DC/Rly]\Watch and force tables\Watch table_1\Row 2\Com-ment
Stop	HMI screen	Task3_V15\HMI_1 [KTP400 Basic PN]\Screens\Root screen\Button_2\Text OFF
Switch	HMI screen	Task3_V15\HMI_1 [KTP400 Basic PN]\Screens\Root screen\Switch_1\Caption text
Switch	HMI screen	Task3_V15\HMI_1 [KTP400 Basic PN]\Screens\Root screen\Switch_2\Caption text
Switch	HMI screen	Task3_V15\HMI_1 [KTP400 Basic PN]\Screens\Root screen\Switch_3\Caption text
Switch	HMI screen	Task3_V15\HMI_1 [KTP400 Basic PN]\Screens\Root screen\Switch_4\Caption text
Text	HMI screen	Task3_V15\HMI_1 [KTP400 Basic PN]\Screens\Root screen\Button_1\Text ON
Text	HMI screen	Task3_V15\HMI_1 [KTP400 Basic PN]\Screens\Root screen\Button_2\Text ON
Text	HMI screen	Task3_V15\HMI_1 [KTP400 Basic PN]\Screens\Root screen\Button_3\Text ON
Text	HMI screen	Task3_V15\HMI_1 [KTP400 Basic PN]\Screens\Root screen\Button_4\Text ON
Text	HMI screen	Task3_V15\HMI_1 [KTP400 Basic PN]\Screens\Root screen\Button_5\Text ON
Text	HMI screen	Task3_V15\HMI_1 [KTP400 Basic PN]\Screens\Root screen\Button_6\Text ON
The 'Administrator' group is initially granted all rights.	HMI comment	Task3_V15\HMI_1 [KTP400 Basic PN]\User administration\Administrator group\Comment
The user 'Administrator' is assigned to the 'Ad-ministrator' group.	HMI comment	Task3_V15\HMI_1 [KTP400 Basic PN]\User administration\Administrator\Comment
The 'Users' group is initially granted 'Operat-ing' rights.	HMI comment	Task3_V15\HMI_1 [KTP400 Basic PN]\User administration\Users\Comment
User administration	HMI runtime	Task3_V15\HMI_1 [KTP400 Basic PN]\User administration\User administration\ShortName
Users	HMI runtime	Task3_V15\HMI_1 [KTP400 Basic PN]\User administration\Users\DisplayName
write value 0	Block comment	Task3_V15\PLC_1 [CPU 1212C AC/DC/Rly]\Watch and force tables\Watch table_1\Row 13\Com-ment
write value 0	Block comment	Task3_V15\PLC_2 [CPU 1212C AC/DC/Rly]\Watch and force tables\Watch table_1\Row 13\Com-ment



Totally Integrated Automation Portal		
English (United States)	Category	Reference
write value 1	Block comment	Task3_V15\PLC_1 [CPU 1212C AC/DC/Rly]\Watch and force tables\Watch table_1\Row 14\Comment
write value 1	Block comment	Task3_V15\PLC_2 [CPU 1212C AC/DC/Rly]\Watch and force tables\Watch table_1\Row 14\Comment
write value 2	Block comment	Task3_V15\PLC_1 [CPU 1212C AC/DC/Rly]\Watch and force tables\Watch table_1\Row 15\Comment
write value 2	Block comment	Task3_V15\PLC_2 [CPU 1212C AC/DC/Rly]\Watch and force tables\Watch table_1\Row 15\Comment
write value 3	Block comment	Task3_V15\PLC_1 [CPU 1212C AC/DC/Rly]\Watch and force tables\Watch table_1\Row 16\Comment
write value 3	Block comment	Task3_V15\PLC_2 [CPU 1212C AC/DC/Rly]\Watch and force tables\Watch table_1\Row 16\Comment

Totally Integrated Automation Portal																																																																												
<div>Task3_V15 / Languages &amp; resources</div> <div>Project graphics</div> <div>Down_Arrow</div> <table><tr><th>Standard graphic</th><th>English (United States)</th></tr><tr><td></td><td></td></tr><tr><td colspan="2">▶ <i>Dithering mode</i></td></tr><tr><td>Same color</td><td>Same color</td></tr><tr><td colspan="2">▶ <i>Smoothing</i></td></tr><tr><td>Unchecked</td><td>Unchecked</td></tr></table> <div>ExitRuntime_KTP400_Basic_PN_TR</div> <table><tr><th>Standard graphic</th><th>English (United States)</th></tr><tr><td></td><td></td></tr><tr><td colspan="2">▶ <i>Dithering mode</i></td></tr><tr><td>Same color</td><td>Same color</td></tr><tr><td colspan="2">▶ <i>Smoothing</i></td></tr><tr><td>Unchecked</td><td>Unchecked</td></tr></table> <div>Home</div> <table><tr><th>Standard graphic</th><th>English (United States)</th></tr><tr><td></td><td></td></tr><tr><td colspan="2">▶ <i>Dithering mode</i></td></tr><tr><td>Same color</td><td>Same color</td></tr><tr><td colspan="2">▶ <i>Smoothing</i></td></tr><tr><td>Unchecked</td><td>Unchecked</td></tr></table> <div>Left_Arrow</div> <table><tr><th>Standard graphic</th><th>English (United States)</th></tr><tr><td></td><td></td></tr><tr><td colspan="2">▶ <i>Dithering mode</i></td></tr><tr><td>Same color</td><td>Same color</td></tr><tr><td colspan="2">▶ <i>Smoothing</i></td></tr><tr><td>Unchecked</td><td>Unchecked</td></tr></table> <div>NavigateHome_KTP400_Basic_PN_TR</div> <table><tr><th>Standard graphic</th><th>English (United States)</th></tr><tr><td></td><td></td></tr><tr><td colspan="2">▶ <i>Dithering mode</i></td></tr><tr><td>Same color</td><td>Same color</td></tr><tr><td colspan="2">▶ <i>Smoothing</i></td></tr><tr><td>Unchecked</td><td>Unchecked</td></tr></table> <div>Right_Arrow</div> <table><tr><th>Standard graphic</th><th>English (United States)</th></tr><tr><td></td><td></td></tr><tr><td colspan="2">▶ <i>Dithering mode</i></td></tr><tr><td>Same color</td><td>Same color</td></tr><tr><td colspan="2">▶ <i>Smoothing</i></td></tr><tr><td>Unchecked</td><td>Unchecked</td></tr></table>			Standard graphic	English (United States)			▶ <i>Dithering mode</i>		Same color	Same color	▶ <i>Smoothing</i>		Unchecked	Unchecked	Standard graphic	English (United States)			▶ <i>Dithering mode</i>		Same color	Same color	▶ <i>Smoothing</i>		Unchecked	Unchecked	Standard graphic	English (United States)			▶ <i>Dithering mode</i>		Same color	Same color	▶ <i>Smoothing</i>		Unchecked	Unchecked	Standard graphic	English (United States)			▶ <i>Dithering mode</i>		Same color	Same color	▶ <i>Smoothing</i>		Unchecked	Unchecked	Standard graphic	English (United States)			▶ <i>Dithering mode</i>		Same color	Same color	▶ <i>Smoothing</i>		Unchecked	Unchecked	Standard graphic	English (United States)			▶ <i>Dithering mode</i>		Same color	Same color	▶ <i>Smoothing</i>		Unchecked	Unchecked		
Standard graphic	English (United States)																																																																											
																																																																												
▶ <i>Dithering mode</i>																																																																												
Same color	Same color																																																																											
▶ <i>Smoothing</i>																																																																												
Unchecked	Unchecked																																																																											
Standard graphic	English (United States)																																																																											
																																																																												
▶ <i>Dithering mode</i>																																																																												
Same color	Same color																																																																											
▶ <i>Smoothing</i>																																																																												
Unchecked	Unchecked																																																																											
Standard graphic	English (United States)																																																																											
																																																																												
▶ <i>Dithering mode</i>																																																																												
Same color	Same color																																																																											
▶ <i>Smoothing</i>																																																																												
Unchecked	Unchecked																																																																											
Standard graphic	English (United States)																																																																											
																																																																												
▶ <i>Dithering mode</i>																																																																												
Same color	Same color																																																																											
▶ <i>Smoothing</i>																																																																												
Unchecked	Unchecked																																																																											
Standard graphic	English (United States)																																																																											
																																																																												
▶ <i>Dithering mode</i>																																																																												
Same color	Same color																																																																											
▶ <i>Smoothing</i>																																																																												
Unchecked	Unchecked																																																																											
Standard graphic	English (United States)																																																																											
																																																																												
▶ <i>Dithering mode</i>																																																																												
Same color	Same color																																																																											
▶ <i>Smoothing</i>																																																																												
Unchecked	Unchecked																																																																											



Totally Integrated Automation Portal		
--------------------------------------	--	--

Up\_Arrow

Standard graphic	English (United States)
	
▶ <i>Dithering mode</i>	
Same color	Same color
▶ <i>Smoothing</i>	
Unchecked	Unchecked