

Quiz 3 - Interfacing SmartLight with Siemens PLC via IO-Link

1. How is Signal Light (Smart light) better than Tower light?
 - It can change the segment color unlike Tower Light
 - It has inbuilt buzzer
 - It can be controlled over PROFINET via IO-Link master unlike Tower light
 - **All of the above**

2. It is possible to change the parameters of Signal Light (Smart light) while the device is operational
 - **True**
 - False

3. It is possible to change the intensity of Signal Light while it is operating.
 - **True**
 - False