

CAIXA Report

Wind Resource Assessment

by Francisco Costa

2026-06-16

This report presents a mini wind resource assessment for the CAIXA wind farm, a hypothetical 9-turbine coastal wind project located on the western coast of Denmark. Meteorological observations from the Høvsøre reference mast are used to characterise the wind climate, while terrain elevation and surface roughness data are employed to model spatial variations in wind conditions across the site. The study includes data quality control, wind climate characterisation, terrain and flow modelling, wake loss estimation, annual energy production (AEP) calculations, and uncertainty analysis. The report provides an integrated overview of the site's wind energy potential.

Table of contents

1 Executive summary	1
2 Project description	2
3 Mast data and Quality Control (QC)	2
4 Site & terrain description	3
5 Measurement & wind climate	4
6 Resource map at CAIXA	5
7 Methodology	6
8 Gross, potential, and net AEP	6
9 Uncertainty assessment	8
10 Methodology appendix	9
10.1 Software versions	9
10.2 Git revision and pixi lockfile	10
10.3 Input assumptions	10
11 References	10

1 Executive summary

The CAIXA 9-turbine coastal wind farm is estimated to achieve a net annual energy production (AEP) of **121.98 GWh/yr** at P50 exceedance level. The bankable P90 lies at **109.70 GWh/yr**, a gap of 10.1 % below P50, driven by a combined relative uncertainty of $\sigma = 7.9\%$. The assessment uses the PARK2 wake model at an air density of 1.230 kg/m^3 .

Table 1: Headline P-value summary (farm total).

P-value	AEP [GWh/yr]	Δ vs P50
P50	121.98	—
P75	115.52	5.30 %
P90	109.7	10.07 %

2 Project description

The site comprises **9 turbines** of model VESTAS 3.0MW V112, 84 m hub height, distributed in three rows of three turbines each along the North Sea coast line in western Denmark. The layout is shown in Figure [1](#).




Figure 1: CAIXA 9 layout (UTM32N coordinates).

3 Mast data and Quality Control (QC)

The assessment is based on measurements acquired at the Høvsøre meteorological mast, located at approximately 447.64 km Easting and 6255.43 km Northing EPSG:25832 UTM32N. The measurement campaign spans the period from 2013-01-01 00:06:00 to 2014-12-31 23:56:00, corresponding to a total monitoring period of 1.996 years.




Figure 2: Monthly data recovery before boom switching.

Wind observations at 80 m above ground level (AGL) are selected as reference dataset for the resource assessment due to their superior data availability and representativeness of the target hub height. To maximise data recovery and minimise mast-induced flow distortion, a boom-switching procedure is applied. Wind direction measurements are derived from the 60 m wind vane, while wind speed measurements at 80 m AGL are obtained from a combined dataset comprising cup and sonic anemometer observations. Monthly recovery data before boom switching is shown in Figure 2. QC and boom-switching results in an overall data coverage of 98.13%.

4 Site & terrain description

The RUNE reference location is situated on the western coast of Denmark within a predominantly agricultural landscape adjacent to the North Sea coastline. The site is located near a pronounced coastal escarpment that introduces measurable orographic acceleration effects under selected wind directions.

Terrain characteristics within the study area were represented using spatially coincident NASADEM digital elevation data (~30 m resolution) and CORINE land-cover-derived roughness data (~100 m resolution), both projected in EPSG:25832. The CAIXA wind farm facility sits approximately 1.5 km inland from RUNE and is oriented along an east-west (E-W) axis.

The dominant terrain-induced flow modification is associated with coastal escarpment speed-up effects, whereas overall terrain complexity remains low ($RIX \sim 0.003$) at CAIXA area, indicating a relatively simple topographic setting with minimal flow distortions. Elevation, roughness, mast and wind farm locations are shown in Figure 3.




Figure 3: Elevation, roughness and mast and wind farm location.

5 Measurement & wind climate

A single meteorological mast equipped with sonic and cup anemometeres (MEASNET standard calibration) at 60, 80, 100 and 116 m and vanes at 10, 60 and 100 m recorded wind speed and direction through a two-year campaign meeting MEASNET v3.1 (2022) minimum recovery thresholds (2013: 96.1%, 2014: 98.6%, with overall recovery (24 months) : 97.3%). The hub-height wind rose at CAIXA wind farm is shown in Figure 4.




Figure 4: Wind rose at hub-height (CAIXA).

6 Resource map at CAIXA

The resource grid consists of a 200 m spatial resolution domain centered on RUNE, extended by a 5 km buffer, and subsequently clipped to the spatial extent of the available elevation dataset. Mean wind speed and power density resource maps are shown in Figure 5.




Figure 5: Wind velocity and power density resource grids at RUNE.

7 Methodology

After QC, Høvsøre binned wind climate (bwc) is derived from 80 m height mast records. Weibull wind climate is derived and used to predict climate at CAIXA wind farm. The generalised wind climate was applied to the 9 turbine positions through the WAsP linearised flow model (`pywasp.wasp.predict_wwc`, vNA) and mesoclimate corrections, producing a per-turbine, per-sector wind climate. The PARK2 wake model (`pywake.deficit_models`, vNA) combined the climate with the turbine power curve at an air density of 1.230 kg/m^3 to produce gross and potential AEP per turbine per sector. Operational losses were applied as a multiplicative retention factor; uncertainty was projected to P50/P75/P90 assuming normally distributed uncertainty with combined relative standard deviation of $\sigma = 7.86 \%$.

8 Gross, potential, and net AEP

Gross AEP (no wake interaction) is **134.44 GWh/yr**, summed across 9 turbines. PARK2 wake losses deduct 4.94 % to give a potential AEP of **127.80 GWh/yr**. The loss table (Table 2) applies a combined retention of 0.9554 (total loss 4.46 %) to produce a net AEP of **121.98 GWh/yr**. The full chain is visualised in Figure 6.

Table 2: Operational loss table. DTU default.

loss_name	loss_percentage	loss_category
turbine_availability	1	Availability
balance_plant_availability	0	Availability
grid_availability	0.5	Availability
electrical_operation	0.5	Electrical
wf_consumption	0.2	Electrical
sub_optimal_performance	0	Turbine_performance
power_curve	1	Turbine_performance
hysteresis	0	Turbine_performance
icing	0	Environmental
blade_degradation	0.25	Environmental
other_environmental_losses	0.1	Environmental
exposure_changes	0	Environmental
load_grid_curtailments	0.5	Curtailments
noise_visual_curtailments	0	Curtailments
sector_management	0.5	Operational_strategies




Figure 6: AEP waterfall: gross $\rightarrow$ potential $\rightarrow$ net.

The largest deduction in the chain corresponds to PARK2 wake modelling, followed by data availability and turbine performance losses.




Figure 7: Yearly per-sector AEP at CAIXA.

9 Uncertainty assessment

Combining the wind-kind and energy-kind contributions in quadrature yields a single relative $\sigma = 7.9\%$.

Table 3: Uncertainty table. DTU default.

uncertainty_kind	uncertainty_name	uncertainty_percentage
wind	representativeness_long_term_period	2
wind	reference_data_consistency	0.5
wind	long_term_adjustment_mcp	1.5
wind	ws_distribution_uncertainty	0.5
wind	on_site_data_synthesis	0.2
wind	measurements_representativeness	0.1
wind	iav_variability	0.21
wind	ws_measurements_uncertainty	2
wind	wd_measurements_uncertainty	1
wind	other_atm_param_uncertainty	0.5
wind	data_integrity	0.5
wind	he_model_inputs	1.08
wind	he_model_sensitivity	2.64
wind	he_model_appropriateness	2.17
wind	ve_model_uncertainty	0.8
wind	ve_propagated_measurement_uncertainty	0.73
energy	turbine_interaction_wake_blockage_effects	1.76
energy	turbine	2.5
energy	balance_of_plant	1.17
energy	grid	0.5
energy	electrical_efficiency	0.5
energy	parasitic_consumption	0

Table 3: Uncertainty table. DTU default.

uncertainty_kind	uncertainty_name	uncertainty_percentage
energy	sub_optimal_performance	0.71
energy	generic_power_curve_adjustments	2
energy	site_specific_power_curve_adjustments	0.87
energy	high_wind_hysteresis	0
energy	icing	0.01
energy	degradation	0.25
energy	environmental_loss_uncertainty	0.01
energy	exposure_changes	0
energy	load_curtailment	0.01
energy	grid_curtailment	0
energy	environmental_curtailment	0.01
energy	operational_strategies	0.01

Under a Gaussian assumption applied multiplicatively to net AEP, P50 lands on the net value (121.98 GWh), with P75 and P90 sitting 5.30 % and 10.07 % below. Built-in `pywasp.estimate_sensitivity_factor` estimates a sensitivity factor of $sf = 1.31$. Table 3 illustrates uncertainty kind and considered uncertainty percentage. Figure 8 shows the spread.




Figure 8: Farm-total P50, P75, P90 exceedance AEP.

The bankable headline for project finance is the **P90**: lenders size debt against a value the project is expected to exceed in 90 % of years.

10 Methodology appendix

10.1 Software versions

Table 4: Software versions used for this assessment.

package	version
python	3.13.13
windkit	2.1.0
pywasp	2.0.0
pywake	2.6.12
quarto	(not available)

10.2 Git revision and pixi lockfile

- **Git SHA:** ee9ac02
- **Pixi lockfile SHA-256[:12]:** 91c14e266d87

10.3 Input assumptions

Table 5: Input parameters and assumptions.

Parameter	Value
Turbine model	V112
Number of turbines	9
Hub height [m]	84
Air density [kg/m ³]	1.230
Ambient TI	0.12
Wake model	park2_onshore
Loss table	DTU-default
Uncertainty σ (relative)	7.9 %
Git SHA	ee9ac02
Pixi lockfile SHA-256[:12]	91c14e266d87

11 References

- IEC 61400-15-1:2025 — Site suitability input conditions for wind power plants.
- IEC 61400-15-2 (draft) — Energy yield assessment; includes the EYA DEF JSON exchange format.
- MEASNET v3.1 (2022) — Evaluation of Site-Specific Wind Conditions.