

















DRUG SUBSTANCE
EMS - INPUT AND OUTPUT LIST

											 		 					
1	ISSUE FOR CONSTRUCTION CONSIDERING COMMENTS										DOC NR: 569-DB7B-AIC-330-002				CLIENT NR: PRD-AIC-LIS-005			
0	ISSUED FOR CONSTRUCTION																	
B	90% DD ISSUE																	
A	30% DD ISSUE										CLIENT: TAKEDA / BAXALTA							
REV	DESCRIPTION																	
REVIEW	REV. A	REV. B	REV. 0	REV. 1							PROJECT: BURITI EPCMV PROJECT							
DATE	08FEB2021	24JUN2021	30JUL2021	26JAN2022														
EXEC	MAB	MAB	MAB	MAV							REV.: 1							
CHECK	MAF	MAF	MAF	MAF														
APPROV	MAJ	RSP	RSP	RSP														




			 		TITLE: DRUG SUBSTANCE EMS - INPUT AND OUTPUT LIST						DOC NR.: 569-DB7B-AIC-330-002 CLIENT NR.: PRD-AIC-LIS-005		SHEET.: 3 / 8 REV.: 1
ID	REV	TAG Nr.	SERVICE	ANALOG INPUT AI	ANALOG OUTPUT AO	DIGITAL INPUT DI	DIGITAL OUTPUT DO	POWER SUPPLY PS	ETHERNET COMM.	LOCATION DRAWING	WIRING DIAGRAMS PANEL LAYOUT	PLC/REMOTE	NOTES
1	1	PDIT-B1021-01	PRESSURE DIFERENTIAL TRANSMITTER - MEN'S LOCKER - ROOM B1021	1	-	-	-	1	-	7B-I-1-3-15	7B-I-0-3-11 7B-I-0-3-07	CP-B2600-4	1
2	1	PDIT-B1023-01	PRESSURE DIFERENTIAL TRANSMITTER - GRADE D STAIR - ROOM B1023	1	-	-	-	1	-	7B-I-1-3-15	7B-I-0-3-11 7B-I-0-3-07	CP-B2600-4	1
3	1	PDIT-B1023-02	PRESSURE DIFERENTIAL TRANSMITTER - GRADE D STAIR - ROOM B1023	1	-	-	-	1	-	7B-I-1-3-15	7B-I-0-3-11 7B-I-0-3-07	CP-B2600-4	1
4	1	PDIT-B1023-03	PRESSURE DIFERENTIAL TRANSMITTER - GRADE D STAIR - ROOM B1023	1	-	-	-	1	-	7B-I-2-3-25	7B-I-0-3-11 7B-I-0-3-07	CP-B2600-4	1
5	1	PDIT-B1026-01	PRESSURE DIFERENTIAL TRANSMITTER - WOMEN'S LOCKER - ROOM B1026	1	-	-	-	1	-	7B-I-1-3-15	7B-I-0-3-11 7B-I-0-3-07	CP-B2600-4	1
6	1	PDIT-B2005-01	PRESSURE DIFERENTIAL TRANSMITTER - DSP 2 ROOM B2005	1	-	-	-	1	-	7B-I-2-3-25	7B-I-0-3-11 7B-I-0-3-07	CP-B2600-4	1
7	1	TIT-B2005-01	TEMPERATURE TRANSMITTER - DSP 2 ROOM B2005	1	-	-	-		-	7B-I-2-3-25	7B-I-0-3-11 7B-I-0-3-07	CP-B2600-4	1
8	1	MIT-B2005-01	HUMIDITY TRANSMITTER - DSP 2 ROOM B2005	1	-	-	-		-	7B-I-2-3-25	7B-I-0-3-11 7B-I-0-3-07	CP-B2600-4	1
9	1	PDIT-B2006-01	PRESSURE DIFERENTIAL TRANSMITTER - MEDIA BUFFER HOLD - ROOM B2006	1	-	-	-	1	-	7B-I-2-3-25	7B-I-0-3-11 7B-I-0-3-07	CP-B2600-4	1
10	1	TIT-B2006-01	TEMPERATURE TRANSMITTER - MEDIA BUFFER HOLD - ROOM B2006	1	-	-	-		-	7B-I-2-3-25	7B-I-0-3-11 7B-I-0-3-07	CP-B2600-4	1
11	1	MIT-B2006-01	HUMIDITY TRANSMITTER - MEDIA BUFFER HOLD - ROOM B2006	1	-	-	-		-	7B-I-2-3-25	7B-I-0-3-11 7B-I-0-3-07	CP-B2600-4	1
12	1	PDIT-B2007-01	PRESSURE DIFERENTIAL TRANSMITTER - DSP 1 - ROOM B2007	1	-	-	-	1	-	7B-I-2-3-25	7B-I-0-3-11 7B-I-0-3-07	CP-B2600-4	1
13	1	TIT-B2007-01	TEMPERATURE TRANSMITTER - DSP 1 ROOM B2007	1	-	-	-		-	7B-I-2-3-25	7B-I-0-3-11 7B-I-0-3-07	CP-B2600-4	1
14	1	MIT-B2007-01	HUMIDITY TRANSMITTER - DSP 1 ROOM B2007	1	-	-	-		-	7B-I-2-3-25	7B-I-0-3-11 7B-I-0-3-07	CP-B2600-4	1
15	1	PDIT-B2015-01	PRESSURE DIFERENTIAL TRANSMITTER - CELL BANK - ROOM B2015	1	-	-	-	1	-	7B-I-2-3-25	7B-I-0-3-11 7B-I-0-3-07	CP-B2600-4	1
16	1	TIT-B2015-01	TEMPERATURE TRANSMITTER - CELL BANK ROOM B2015	1	-	-	-		-	7B-I-2-3-25	7B-I-0-3-11 7B-I-0-3-07	CP-B2600-4	1
17	1	MIT-B2015-01	HUMIDITY TRANSMITTER - CELL BANK ROOM B2015	1	-	-	-		-	7B-I-2-3-25	7B-I-0-3-11 7B-I-0-3-07	CP-B2600-4	1
18	1	PDIT-B2016-01	PRESSURE DIFERENTIAL TRANSMITTER - STERILE STAGING - ROOM B2016	1	-	-	-	1	-	7B-I-2-3-25	7B-I-0-3-11 7B-I-0-3-07	CP-B2600-4	1
19	1	TIT-B2016-01	TEMPERATURE TRANSMITTER - STERILE STAGING	1	-	-	-		-	7B-I-2-3-25	7B-I-0-3-11 7B-I-0-3-07	CP-B2600-4	1
20	1	MIT-B2016-01	HUMIDITY TRANSMITTER - STERILE STAGING ROOM B2016	1	-	-	-		-	7B-I-2-3-25	7B-I-0-3-11 7B-I-0-3-07	CP-B2600-4	1
21	1	PDIT-B2028-01	PRESSURE DIFERENTIAL TRANSMITTER - CORRIDOR - ROOM B2028	1	-	-	-	1	-	7B-I-2-3-25	7B-I-0-3-11 7B-I-0-3-07	CP-B2600-4	1
22	1	TIT-B2028-01	TEMPERATURE TRANSMITTER - CORRIDOR ROOM B2028	1	-	-	-		-	7B-I-2-3-25	7B-I-0-3-11 7B-I-0-3-07	CP-B2600-4	1
23	1	MIT-B2028-01	HUMIDITY TRANSMITTER - CORRIDOR ROOM B2028	1	-	-	-		-	7B-I-2-3-25	7B-I-0-3-11 7B-I-0-3-07	CP-B2600-4	1

			 		TITLE: DRUG SUBSTANCE EMS - INPUT AND OUTPUT LIST						DOC NR.: 569-DB7B-AIC-330-002		SHEET.: 4 / 8
											CLIENT NR.: PRD-AIC-LIS-005		REV.: 1
ID	REV	TAG Nr.	SERVICE	ANALOG INPUT AI	ANALOG OUTPUT AO	DIGITAL INPUT DI	DIGITAL OUTPUT DO	POWER SUPPLY PS	ETHERNET COMM.	LOCATION DRAWING	WIRING DIAGRAMS PANEL LAYOUT	PLC/REMOTE	NOTES
24	1	PDIT-B2037-01	PRESSURE DIFERENTIAL TRANSMITTER - TANK HOLD -ROOM B2037	1	-	-	-	1	-	7B-I-2-3-25	7B-I-0-3-11 7B-I-0-3-07	CP-B2600-4	1
25	1	TIT-B2037-01	TEMPERATURE TRANSMITTER - TANK HOLD ROOM B2037	1	-	-	-		-	7B-I-2-3-25	7B-I-0-3-11 7B-I-0-3-07	CP-B2600-4	1
26	1	MIT-B2037-01	HUMIDITY TRANSMITTER - TANK HOLD ROOM B2037	1	-	-	-		-	7B-I-2-3-25	7B-I-0-3-11 7B-I-0-3-07	CP-B2600-4	1
27	1	PDIT-B2039-01	PRESSURE DIFERENTIAL TRANSMITTER - CELL CULTURE - ROOM B2039	1	-	-	-	1	-	7B-I-2-3-25	7B-I-0-3-11 7B-I-0-3-07	CP-B2600-4	1
28	1	TIT-B2039-01	TEMPERATURE TRANSMITTER - CELL CULTURE - ROOM B2039	1	-	-	-		-	7B-I-2-3-25	7B-I-0-3-11 7B-I-0-3-07	CP-B2600-4	1
29	1	MIT-B2039-01	HUMIDITY TRANSMITTER - CELL CULTURE - ROOM B2039	1	-	-	-		-	7B-I-2-3-25	7B-I-0-3-11 7B-I-0-3-07	CP-B2600-4	1
30	1	PDIT-B2046-01	PRESSURE DIFERENTIAL TRANSMITTER - JC ROOM B2046	1	-	-	-	1	-	7B-I-2-3-25	7B-I-0-3-11 7B-I-0-3-07	CP-B2600-4	1
31	1	TIT-B2046-01	TEMPERATURE TRANSMITTER - JC ROOM B2046	1	-	-	-		-	7B-I-2-3-25	7B-I-0-3-11 7B-I-0-3-07	CP-B2600-4	1
32	1	MIT-B2046-01	HUMIDITY TRANSMITTER - JC ROOM B2046	1	-	-	-		-	7B-I-2-3-25	7B-I-0-3-11 7B-I-0-3-07	CP-B2600-4	1
33	1	PDIT-B2048-01	PRESSURE DIFERENTIAL TRANSMITTER - MEDIA BUFFER PREP - ROOM B2048	1	-	-	-	1	-	7B-I-2-3-25	7B-I-0-3-11 7B-I-0-3-07	CP-B2600-4	1
34	1	TIT-B2048-01	TEMPERATURE TRANSMITTER - MEDIA BUFFER PREP - ROOM B2048	1	-	-	-		-	7B-I-2-3-25	7B-I-0-3-11 7B-I-0-3-07	CP-B2600-4	1
35	1	MIT-B2048-01	HUMIDITY TRANSMITTER - MEDIA BUFFER PREP	1	-	-	-		-	7B-I-2-3-25	7B-I-0-3-11 7B-I-0-3-07	CP-B2600-4	1
36	1	PDIT-B2057-01	PRESSURE DIFERENTIAL TRANSMITTER - JC ROOM B2057	1	-	-	-	1	-	7B-I-2-3-25	7B-I-0-3-11 7B-I-0-3-07	CP-B2600-4	1
37	1	TIT-B2057-01	TEMPERATURE TRANSMITTER - JC ROOM B2057	1	-	-	-		-	7B-I-2-3-25	7B-I-0-3-11 7B-I-0-3-07	CP-B2600-4	1
38	1	MIT-B2057-01	HUMIDITY TRANSMITTER - JC ROOM B2057	1	-	-	-		-	7B-I-2-3-25	7B-I-0-3-11 7B-I-0-3-07	CP-B2600-4	1
39	1	TIT-B2009-01	TEMPERATURE TRANSMITTER - COLUMN PACK	1	-	-	-	1	-	7B-I-2-3-25	7B-I-0-3-11 7B-I-0-3-07	CP-B2600-4	1
40	1	MIT-B2009-01	HUMIDITY TRANSMITTER - COLUMN PACK ROOM B2009	1	-	-	-		-	7B-I-2-3-25	7B-I-0-3-11 7B-I-0-3-07	CP-B2600-4	1
41	1	TIT-B2028-02	TEMPERATURE TRANSMITTER - CORRIDOR - ROOM B2028	1	-	-	-	1	-	7B-I-2-3-25	7B-I-0-3-11 7B-I-0-3-07	CP-B2600-4	1
42	1	MIT-B2028-02	HUMIDITY TRANSMITTER - CORRIDOR - ROOM B2028	1	-	-	-		-	7B-I-2-3-25	7B-I-0-3-11 7B-I-0-3-07	CP-B2600-4	1
43	1	TIT-B2031-01	TEMPERATURE TRANSMITTER - STAGE - ROOM B2031	1	-	-	-	1	-	7B-I-2-3-25	7B-I-0-3-11 7B-I-0-3-07	CP-B2600-4	1
44	1	MIT-B2031-01	HUMIDITY TRANSMITTER - STAGE - ROOM B2031	1	-	-	-		-	7B-I-2-3-25	7B-I-0-3-11 7B-I-0-3-07	CP-B2600-4	1
45	1	TIT-B2044-01	TEMPERATURE TRANSMITTER - INNOCULUM ROOM B2044	1	-	-	-	1	-	7B-I-2-3-25	7B-I-0-3-11 7B-I-0-3-07	CP-B2600-4	1
46	1	MIT-B2044-01	HUMIDITY TRANSMITTER - INNOCULUM ROOM B2044	1	-	-	-		-	7B-I-2-3-25	7B-I-0-3-11 7B-I-0-3-07	CP-B2600-4	1
47	1	TIT-B2045-01	TEMPERATURE TRANSMITTER - IPT ROOM B2045	1	-	-	-	1	-	7B-I-2-3-25	7B-I-0-3-11 7B-I-0-3-07	CP-B2600-4	1
48	1	MIT-B2045-01	HUMIDITY TRANSMITTER - IPT ROOM B2045	1	-	-	-		-	7B-I-2-3-25	7B-I-0-3-11 7B-I-0-3-07	CP-B2600-4	1

			 		TITLE: DRUG SUBSTANCE EMS - INPUT AND OUTPUT LIST						DOC NR.: 569-DB7B-AIC-330-002		SHEET.: 5 / 8
											CLIENT NR.: PRD-AIC-LIS-005		REV.: 1
ID	REV	TAG Nr.	SERVICE	ANALOG INPUT AI	ANALOG OUTPUT AO	DIGITAL INPUT DI	DIGITAL OUTPUT DO	POWER SUPPLY PS	ETHERNET COMM.	LOCATION DRAWING	WIRING DIAGRAMS PANEL LAYOUT	PLC/REMOTE	NOTES
49	1	TIT-B2053-01	TEMPERATURE TRANSMITTER - QC STORAGE ROOM B2053	1	-	-	-	1	-	7B-I-2-3-25	7B-I-0-3-11 7B-I-0-3-07	CP-B2600-4	1
50	1	MIT-B2053-01	HUMIDITY TRANSMITTER - QC STORAGE ROOM B2053	1	-	-	-		-	7B-I-2-3-25	7B-I-0-3-11 7B-I-0-3-07	CP-B2600-4	1
51	1	PDIT-B2001-01	PRESSURE DIFERENTIAL TRANSMITTER - CLEAN EQUIPMENT - ROOM B2001	1	-	-	-	1	-	7B-I-2-3-25	7B-I-0-3-11 7B-I-0-3-07	CP-B2600-4	1
52	1	PDIT-B2002-01	PRESSURE DIFERENTIAL TRANSMITTER - CIP/SIP - ROOM B2002	1	-	-	-	1	-	7B-I-2-3-25	7B-I-0-3-11 7B-I-0-3-07	CP-B2600-4	1
53	1	PDIT-B2003-01	PRESSURE DIFERENTIAL TRANSMITTER - JC ROOM B2003	1	-	-	-	1	-	7B-I-2-3-25	7B-I-0-3-11 7B-I-0-3-07	CP-B2600-4	1
54	1	PDIT-B2010-01	PRESSURE DIFERENTIAL TRANSMITTER - JC ROOM B2010	1	-	-	-	1	-	7B-I-2-3-25	7B-I-0-3-11 7B-I-0-3-07	CP-B2600-4	1
55	1	PDIT-B2011-01	PRESSURE DIFERENTIAL TRANSMITTER - PAL IN	1	-	-	-	1	-	7B-I-2-3-25	7B-I-0-3-11 7B-I-0-3-07	CP-B2600-4	1
56	1	PDIT-B2011-02	PRESSURE DIFERENTIAL TRANSMITTER - PAL IN	1	-	-	-	1	-	7B-I-2-3-25	7B-I-0-3-11 7B-I-0-3-07	CP-B2600-4	1
57	1	PDIT-B2012-01	PRESSURE DIFERENTIAL TRANSMITTER - MAL IN - ROOM B2012	1	-	-	-	1	-	7B-I-2-3-25	7B-I-0-3-11 7B-I-0-3-07	CP-B2600-4	1
58	1	PDIT-B2013-01	PRESSURE DIFERENTIAL TRANSMITTER - MAL OUT - ROOM B2013	1	-	-	-	1	-	7B-I-2-3-25	7B-I-0-3-11 7B-I-0-3-07	CP-B2600-4	1
59	1	PDIT-B2013-02	PRESSURE DIFERENTIAL TRANSMITTER - MAL OUT - ROOM B2013	1	-	-	-	1	-	7B-I-2-3-25	7B-I-0-3-11 7B-I-0-3-07	CP-B2600-4	1
60	1	PDIT-B2014-01	PRESSURE DIFERENTIAL TRANSMITTER - PAL OUT - ROOM B2014	1	-	-	-	1	-	7B-I-2-3-25	7B-I-0-3-11 7B-I-0-3-07	CP-B2600-4	1
61	1	PDIT-B2014-02	PRESSURE DIFERENTIAL TRANSMITTER - PAL OUT - ROOM B2014	1	-	-	-	1	-	7B-I-2-3-25	7B-I-0-3-11 7B-I-0-3-07	CP-B2600-4	1
62	1	PDIT-B2017-01	PRESSURE DIFERENTIAL TRANSMITTER - JC ROOM B2017	1	-	-	-	1	-	7B-I-2-3-25	7B-I-0-3-11 7B-I-0-3-07	CP-B2600-4	1
63	1	PDIT-B2018-01	PRESSURE DIFERENTIAL TRANSMITTER - PAL OUT - ROOM B2018	1	-	-	-	1	-	7B-I-2-3-25	7B-I-0-3-11 7B-I-0-3-07	CP-B2600-4	1
64	1	PDIT-B2018-02	PRESSURE DIFERENTIAL TRANSMITTER - PAL OUT - ROOM B2018	1	-	-	-	1	-	7B-I-2-3-25	7B-I-0-3-11 7B-I-0-3-07	CP-B2600-4	1
65	1	PDIT-B2019-01	PRESSURE DIFERENTIAL TRANSMITTER - PAL IN	1	-	-	-	1	-	7B-I-2-3-25	7B-I-0-3-11 7B-I-0-3-07	CP-B2600-4	1
66	1	PDIT-B2020-01	PRESSURE DIFERENTIAL TRANSMITTER - MAL ROOM B2020	1	-	-	-	1	-	7B-I-2-3-25	7B-I-0-3-11 7B-I-0-3-07	CP-B2600-4	1
67	1	PDIT-B2020-02	PRESSURE DIFERENTIAL TRANSMITTER - MAL ROOM B2020	1	-	-	-	1	-	7B-I-2-3-25	7B-I-0-3-11 7B-I-0-3-07	CP-B2600-4	1
68	1	PDIT-B2022-01	PRESSURE DIFERENTIAL TRANSMITTER - AL ROOM B2022	1	-	-	-	1	-	7B-I-2-3-25	7B-I-0-3-11 7B-I-0-3-07	CP-B2600-4	1
69	1	PDIT-B2022-02	PRESSURE DIFERENTIAL TRANSMITTER - AL ROOM B2022	1	-	-	-	1	-	7B-I-2-3-25	7B-I-0-3-11 7B-I-0-3-07	CP-B2600-4	1
70	1	PDIT-B2023-01	PRESSURE DIFERENTIAL TRANSMITTER - PAL IN	1	-	-	-	1	-	7B-I-2-3-25	7B-I-0-3-11 7B-I-0-3-07	CP-B2600-4	1
71	1	PDIT-B2023-02	PRESSURE DIFERENTIAL TRANSMITTER - PAL IN	1	-	-	-	1	-	7B-I-2-3-25	7B-I-0-3-11 7B-I-0-3-07	CP-B2600-4	1
72	1	PDIT-B2024-01	PRESSURE DIFERENTIAL TRANSMITTER - MAL IN - ROOM B2024	1	-	-	-	1	-	7B-I-2-3-25	7B-I-0-3-11 7B-I-0-3-07	CP-B2600-4	1
73	1	PDIT-B2025-01	PRESSURE DIFERENTIAL TRANSMITTER - MAL OUT - ROOM B2025	1	-	-	-	1	-	7B-I-2-3-25	7B-I-0-3-11 7B-I-0-3-07	CP-B2600-4	1

			 		TITLE: DRUG SUBSTANCE EMS - INPUT AND OUTPUT LIST						DOC NR.: 569-DB7B-AIC-330-002		SHEET.: 6 / 8
											CLIENT NR.: PRD-AIC-LIS-005		REV.: 1
ID	REV	TAG Nr.	SERVICE	ANALOG INPUT AI	ANALOG OUTPUT AO	DIGITAL INPUT DI	DIGITAL OUTPUT DO	POWER SUPPLY PS	ETHERNET COMM.	LOCATION DRAWING	WIRING DIAGRAMS	PLC/REMOTE	NOTES
											PANEL LAYOUT		
74	1	PDIT-B2025-02	PRESSURE DIFERENTIAL TRANSMITTER - MAL OUT - ROOM B2025	1	-	-	-	1	-	7B-I-2-3-25	7B-I-0-3-11 7B-I-0-3-07	CP-B2600-4	1
75	1	PDIT-B2026-01	PRESSURE DIFERENTIAL TRANSMITTER - PAL OUT - ROOM B2026	1	-	-	-	1	-	7B-I-2-3-25	7B-I-0-3-11 7B-I-0-3-07	CP-B2600-4	1
76	1	PDIT-B2026-02	PRESSURE DIFERENTIAL TRANSMITTER - PAL OUT - ROOM B2026	1	-	-	-	1	-	7B-I-2-3-25	7B-I-0-3-11 7B-I-0-3-07	CP-B2600-4	1
77	1	PDIT-B2027-01	PRESSURE DIFERENTIAL TRANSMITTER - MAL IN - ROOM B2027	1	-	-	-	1	-	7B-I-2-3-25	7B-I-0-3-11 7B-I-0-3-07	CP-B2600-4	1
78	1	PDIT-B2027-02	PRESSURE DIFERENTIAL TRANSMITTER - MAL IN - ROOM B2027	1	-	-	-	1	-	7B-I-2-3-25	7B-I-0-3-11 7B-I-0-3-07	CP-B2600-4	1
79	1	PDIT-B2030-01	PRESSURE DIFERENTIAL TRANSMITTER - MAL OUT - ROOM B2030	1	-	-	-	1	-	7B-I-2-3-25	7B-I-0-3-11 7B-I-0-3-07	CP-B2600-4	1
80	1	PDIT-B2030-02	PRESSURE DIFERENTIAL TRANSMITTER - MAL OUT - ROOM B2030	1	-	-	-	1	-	7B-I-2-3-25	7B-I-0-3-11 7B-I-0-3-07	CP-B2600-4	1
81	1	PDIT-B2032-01	PRESSURE DIFERENTIAL TRANSMITTER - JC ROOM B2032	1	-	-	-	1	-	7B-I-2-3-25	7B-I-0-3-11 7B-I-0-3-07	CP-B2600-4	1
82	1	PDIT-B2033-01	PRESSURE DIFERENTIAL TRANSMITTER - PAL OUT - ROOM B2033	1	-	-	-	1	-	7B-I-2-3-25	7B-I-0-3-11 7B-I-0-3-07	CP-B2600-4	1
83	1	PDIT-B2033-02	PRESSURE DIFERENTIAL TRANSMITTER - PAL OUT - ROOM B2033	1	-	-	-	1	-	7B-I-2-3-25	7B-I-0-3-11 7B-I-0-3-07	CP-B2600-4	1
84	1	PDIT-B2034-01	PRESSURE DIFERENTIAL TRANSMITTER - PAL IN - ROOM B2034	1	-	-	-	1	-	7B-I-2-3-25	7B-I-0-3-11 7B-I-0-3-07	CP-B2600-4	1
85	1	PDIT-B2035-01	PRESSURE DIFERENTIAL TRANSMITTER - MAL IN - ROOM B2035	1	-	-	-	1	-	7B-I-2-3-25	7B-I-0-3-11 7B-I-0-3-07	CP-B2600-4	1
86	1	PDIT-B2036-01	PRESSURE DIFERENTIAL TRANSMITTER - MAL OUT - ROOM B2036	1	-	-	-	1	-	7B-I-2-3-25	7B-I-0-3-11 7B-I-0-3-07	CP-B2600-4	1
87	1	PDIT-B2036-02	PRESSURE DIFERENTIAL TRANSMITTER - MAL OUT - ROOM B2036	1	-	-	-	1	-	7B-I-2-3-25	7B-I-0-3-11 7B-I-0-3-07	CP-B2600-4	1
88	1	PDIT-B2040-01	PRESSURE DIFERENTIAL TRANSMITTER - MAL IN - ROOM B2040	1	-	-	-	1	-	7B-I-2-3-25	7B-I-0-3-11 7B-I-0-3-07	CP-B2600-4	1
89	1	PDIT-B2040-02	PRESSURE DIFERENTIAL TRANSMITTER - MAL IN - ROOM B2040	1	-	-	-	1	-	7B-I-2-3-25	7B-I-0-3-11 7B-I-0-3-07	CP-B2600-4	1
90	1	PDIT-B2041-01	PRESSURE DIFERENTIAL TRANSMITTER - PAL IN - ROOM B2041	1	-	-	-	1	-	7B-I-2-3-25	7B-I-0-3-11 7B-I-0-3-07	CP-B2600-4	1
91	1	PDIT-B2041-02	PRESSURE DIFERENTIAL TRANSMITTER - PAL IN - ROOM B2041	1	-	-	-	1	-	7B-I-2-3-25	7B-I-0-3-11 7B-I-0-3-07	CP-B2600-4	1
92	1	PDIT-B2042-01	PRESSURE DIFERENTIAL TRANSMITTER - MAL OUT - ROOM B2042	1	-	-	-	1	-	7B-I-2-3-25	7B-I-0-3-11 7B-I-0-3-07	CP-B2600-4	1
93	1	PDIT-B2042-02	PRESSURE DIFERENTIAL TRANSMITTER - MAL OUT - ROOM B2042	1	-	-	-	1	-	7B-I-2-3-25	7B-I-0-3-11 7B-I-0-3-07	CP-B2600-4	1
94	1	PDIT-B2043-01	PRESSURE DIFERENTIAL TRANSMITTER - PAL OUT - ROOM B2043	1	-	-	-	1	-	7B-I-2-3-25	7B-I-0-3-11 7B-I-0-3-07	CP-B2600-4	1
95	1	PDIT-B2043-02	PRESSURE DIFERENTIAL TRANSMITTER - PAL OUT - ROOM B2043	1	-	-	-	1	-	7B-I-2-3-25	7B-I-0-3-11 7B-I-0-3-07	CP-B2600-4	1
96	1	PDIT-B2050-01	PRESSURE DIFERENTIAL TRANSMITTER - OFFICE - ROOM B2050	1	-	-	-	1	-	7B-I-2-3-25	7B-I-0-3-11 7B-I-0-3-07	CP-B2600-4	1
97	1	PDIT-B2059-01	PRESSURE DIFERENTIAL TRANSMITTER - TECH SPACE ROOM B2059	1	-	-	-	1	-	7B-I-2-3-25	7B-I-0-3-11 7B-I-0-3-07	CP-B2600-4	1
98													

[illegible]

			 		TITLE: DRUG SUBSTANCE EMS - INPUT AND OUTPUT LIST						DOC NR.: 569-DB7B-AIC-330-002		SHEET.: 8 / 8
											CLIENT NR.: PRD-AIC-LIS-005		REV.: 1
ID	REV	TAG Nr.	SERVICE	ANALOG INPUT AI	ANALOG OUTPUT AO	DIGITAL INPUT DI	DIGITAL OUTPUT DO	POWER SUPPLY PS	ETHERNET COMM.	LOCATION DRAWING	WIRING DIAGRAMS PANEL LAYOUT	PLC/REMOTE	NOTES
124	1	TIT-FS-2001-01	TEMPERATURE FREEZER FS-2001 - ROOM B2015						1	7B-I-2-3-25	7B-I-0-3-11 7B-I-0-3-07	CP-B2600-4	1
125	1	TIT-FS-2002-01	TEMPERATURE FREEZER FR-2002 - ROOM B2015						1	7B-I-2-3-25	7B-I-0-3-11 7B-I-0-3-07	CP-B2600-4	1
126	1	TIT-INC-2001-01	TEMPERATURE CO2 INCUBATOR INC-2001 - ROOM B2044						1	7B-I-2-3-25	7B-I-0-3-11 7B-I-0-3-07	CP-B2600-4	1
127													
128													
129													
130													
131													
132													
133													
134													
135			TOTAL I/O PARA CP-B2600-4	AI	AO	DI	DO	PS	ETHERN.				
136				99	0	0	16		3				
137													
138													
139													
140			GENERAL TOTAL I/O	AI	AO	DI	DO	PS	ETHERN.				
141				99	0	0	16		3				