

1 DRUG SUBSTANCE - ACCESS CONTROL FIRST FLOOR

7B-1-2-3-22 SCALE: 1:100

REVISION C NOTES / NOTAS REVISÃO C

ADDED ACU TAG NUMBER
ADICIONADO TAG NUMÉRICA NO ACU

ADDED UTP CABLES FOR ACU
ADICIONADO CABOS UTP PARA ACU

RENAMED CABLE TRAY IT CCTV + ACS TO UTP CABLE TRAY RENOMEADA A ELETROCALHA IT CCTV + ACS PARA ELETROCALHA UTP

CHANGE POWER SUPPLY TO 220VAC
ALTERADA ALIMENTAÇÃO PARA 220VAC

REVISION 0 NOTES / NOTAS REVISÃO 0

 ADDED ACCESS CONTROL BETWEEN B07A AND B07B
 ADICIONADO CONTROLE DE ACESSO ENTRE B07A E B07B

REVISION 1 NOTES / NOTAS REVISÃO 1

TRANSLATED TO PORTUGUESE:



Project
Services
Engineering Design/Build Compliance Consulting

Project
721 ARBOR WAY, SUITE 100
BLUE BELL
PENNSYLVANIA 19422
PHONE: 610.828.4090
FAX: 610.828.3656
www.ipsdb.com


IPS Professional Engineers and Architects, PC.

REV	DATE	DESCRIPTION	BY	CHECK	APP
Α	28AUG2020	90% BD ISSUE	MAV	MAF	MSS
В	16OCT2020	FINAL BD ISSUE	MAV	MAF	MSS
С	03MAI2021	90% DD ISSUE	ACC	MAF	RSF
0	06OCT2021	ISSUE FOR CONSTRUCTION	ACC	MAF	RSF
1	16NOV2021	ISSUED FOR CONSTRUCTION CONSIDERING COMMENTS	ACC	MAF	RSF
			-		
	1	1	1		1





GENERAL NOTES / NOTAS GERAIS:

1. FOR LEGEND, ABBREVIATIONS AND SYMBOL SEE SHEETS 7B-I-0-0-01. PARA LEGENDA, ABREVIATURAS E SÍMBOLOS, VER DES. 7B-I-0-0-01. 2. FOR SECURITY ACS RISER DIAGRAM, SEE SHEET 7B-I-0-7-06 PARA DIAGRAMA DE SEGURANÇA ACS RISER, CONSULTAR 7B-I-0-7-06 3. ALL CONDUIT SHALL BE Ø3/4" UNLESS NOTED OTHERWISE. TODOS CONDUITES DEVEM SER Ø3/4", SALVO ONDE INDICADOS. 4. SUPORTES TO CABLE TRAYS AND CONDUITS SHALL BE PROVIDE TO EACH 2,00 METERS.
SUPORTES P/ BANDEJAS, ELETROD. DEVEM SER MONTADOS A CADA 2m 5. MATERIAL LIST SEE DOCUMENT NUMBER PRD-AIC-LIS-040. LISTA DE MATERIAIS, VER DOCUMENTO № PRD-AIC-LIS-040. 6. INTERCONNECTION BETWEEN ACU AND COMPONENTS WILL BE DONE BY ACS CONTRACTOR ACCORDING TO DRAWING 07-I-0-6-02 SECURITY ACCESS CONTROL - TYPICAL DETAILS AS INTERLIGAÇÕES ENTRE ACU E OS COMPONENTES SERÃO FEITOS PELA CONTRATADA DE ACS DE ACORDO COM OS DETALHES TÍPICOS DE ACS.DES. № 07-1-0-6-02. 7. ALL DIMENSIONS SHALL BE IN MILLIMETERS UNLESS NOTED TODAS DIMENSÕES EM MILÍMETROS, SALVO ONDE INDICADAS. 8. TO DRAWING LIST SEE DOCUMENT 7B-I-0-0-01. PARA LISTA DE DESENHOS, VER O DOCUMENTO 7B-I-0-0-01. 9. FOR TECHNICAL SPECIFICATION OF ACS SEE DOCUMENT PRD-AIC-TSP-003. PARA ESPECIFICAÇÕES TÉCNICAS DO ACS VER DOCUMENTO PRD-AIC-TSP-003.



KEY P





CONFIDENTIAL

THE INFORMATION CONTAINED HEREIN MAY NOT BE USED OR REPRODUCED IN ANY MANNER WITHOUT WRITTEN PERMISSION OF

INTEGRATED PROJECT SERVICES.



BURITI EPCMV PROJECT

DRAWING TITLE

DRUG SUBSTANCE
ACCESS CONTROL
FIRST FLOOR

ENGINEER ARCHITECT DESIGNER II
MAF MS FJT II
DRAWN BY REVIEWED BY SCALE CO
JHA MSS AS NOTED

7B-I-2-3-22