







DOC NUMBER:

569-DB7A-MEC-731-001

CLIENT NUMBER:

PRD-MEC-DSH-010

CLIENT: **TAKEDA**

PROJECT:

BURITI EPCVM PROJECT

DATA SHEET BUFFER TANK BT-7A-1

| 0 | 30/JUL/2021 | ISSUED FOR CONSTRUCTION | | | |
|-----|-------------|-------------------------|------|-------|--------|
| В | 27/APR/2021 | 90% DD ISSUE | ASO | LFF | RSP |
| Α | 12/FEB/2021 | 30% DD ISSUE | ASO | LFF | MAJ |
| REV | DATE | DESCRIPTION | EXEC | CHECK | APPROV |









NUMBER: 569-DB7A-MEC-731-001 CLIENT NR PRD-MEC-DSH-010

TITLE

SHEET: 2/5

REV.:

BUFFER TANK - BT-7A-1

1. REVISION HISTORY

| Rev | Reason For Change | | | | | |
|-----|--|--|--|--|--|--|
| Α | ORIGINAL ISSUE | | | | | |
| | PAGE 03, item 2.1 : changed capacity from 6.0 m ³ to 8.0 m ³ | | | | | |
| | PAGE 03, item 2.2 : changed internal diameter from 2,400 mm to 2,000 mm | | | | | |
| | PAGE 03, item 2.3: changed height from 1,850 mm to 3,190 mm | | | | | |
| В | PAGE 03, item 2.3 : changed temperature from 15.0/5.0 °C to 11.0/5.0 °C | | | | | |
| l B | PAGE 03, item 2.3 : informed design temperature | | | | | |
| | PAGE 03, Note 6 : added | | | | | |
| | PAGE 04: Adjusted nozzles, diameter and height in the sketch | | | | | |
| | PAGE 05: included nozzles orientation | | | | | |
| | ISSUED FOR CONSTRUCTION | | | | | |
| | PAGE 03, item 2.1: changed capacity from 8.0 m³ to 12.0 m³ | | | | | |
| 0 | PAGE 03, item 2.2 : changed internal diameter from 2,000 mm to 2,500 mm | | | | | |
| 0 | PAGE 03, item 2.3 : changed height from 3,190 mm to 3,140 mm | | | | | |
| | PAGE 03, item 2.3 : changed temperature from 11.0/5.0 °C to 9.5/5.0 °C | | | | | |
| | PAGE 04: Adjusted nozzles, diameter and height in the sketch | | | | | |









PRD-MEC-DSH-010 569-DB7A-MEC-731-001 CLIENT NR

TITLE

3/5

BUFFER TANK - BT-7A-1

| | | | 0 | | | | | |
|-----|---|----------------------------|-----------------------|--|--|--|--|--|
| 1 | GENERAL | | | | | | | |
| 1.1 | SERVICE: CHILLED WATER ITEM Nº: | | BT-7A-1 | | | | | |
| 1.2 | LOCAL: DRUG PRODUCT BUILDING QUANTITY: | | 1 | | | | | |
| 1.3 | MANUFACTURER: (Note 1) MANUFACTU | RING STANDARD: | - | | | | | |
| 1.4 | APPLICABLE: PROPOSAL | | | | | | | |
| 2 | OPERATION CONDITIONS (Note 2) | | | | | | | |
| 2.1 | CAPACITY (m ³): 12.0 STORED PRODUCT: | WATER | | | | | | |
| 2.2 | P. INTERNAL DIAM. (mm): 2,500 CYLINDRICAL HEIGHT (| (mm): 3,140 | | | | | | |
| 2.3 | OPERAT. TEMPER HOT/COLD SIDE (°C): 9.5/5.0 DESIGN TEMPER. (°C): | -10 @ 40° | | | | | | |
| 2.4 | DESIGN PRESS (barg): ATM HIDROSTATIC TEST: | FULL OF WATER | | | | | | |
| 3 | CONSTRUCTION (Note 2) | | | | | | | |
| 3.1 | TYPE OF TANK: VERTICAL SUPPORT: | NO (ON CONCRETE | NO (ON CONCRETE BASE) | | | | | |
| 3.2 | PLAN BOTTOM: | PLAN | | | | | | |
| 4 | MATERIAL | | | | | | | |
| 4.1 | SHELL: ASME/ASTM A-36 HEAD: ASME/ASTM A-36 | 6 BOTTOM: ASME/ASTM | 1 A-36 | | | | | |
| 4.2 | NOZZLE FLANGES: ASME/ASTM A-105 NOZZLE NECK: ASME/ASTM A-10 | 06 GR. B | | | | | | |
| 4.3 | DIVISORY PLATE: ASME/ASTM A-36 | | | | | | | |
| 4.3 | BOLTS: ASME/ASTM A-193 GR. B7 NUTS: ASME/ASTM A-19 | 94 GR. 2H | | | | | | |
| 5 | MATERIALS INSPECTION | MATERIALS INSPECTION | | | | | | |
| 5.1 | IN THE PLATE SUPPLIER: YES | | | | | | | |
| 5.2 | IN THE EQUIPMENT MANUFACTURER: YES | | | | | | | |
| 5.3 | IN THE CLIENT'S SITE: YES | | | | | | | |
| 6 | TANK WEIGHT | | | | | | | |
| 6.1 | EMPTY (kg): Note 1 FULL OF WATER (kg): Note 1 | | | | | | | |
| 7 | MINIMUM THICKNESS OF PLATES | | | | | | | |
| 7.1 | MINIMUM THCKNESS (mm): 5 | | | | | | | |
| 7.2 | CORROSION OVERTHICKNESS (mm): 1 | | | | | | | |

Notes:

- 1) To be confirmed by supplier.
- 2) The supplier shall be responsible for all equipment dimensioning according to the operational conditions,

as well as for the equipment support design.

- 3) Dimensional drawing of the equipment shall be part of the proposal.
- 4) A 150 mm projection should be expected until the face of the flanged nozzles.
- 5) Lifting lugs and grounding clips shall be included in the supply.
- 6) The tank shall have an internal and external painting (only primer coat in epoxy, minimum thk of 100 µm). Clips should be provided in the equipment for fixing the thermal insulation.









569-DB7A-MEC-731-001

CLIENT NR

PRD-MEC-DSH-010

SHEET


4/5 REV.:

0

BUFFER TANK - BT-7A-1

TITLE

| NOZLLES | | | | | | | | |
|---------|--------|-----|------|------|------|-----------|--------------------------------|-----------------|
| POS | DIAM | QTY | CLAS | TYPE | FACE | THICKNESS | SERVICE | OBSERVATION |
| N1 | 6" | 1 | 150# | WN | RF | SCH40 | HOT WATER INLET | ASME/ANSI B16.5 |
| N2 | 6" | 1 | 150# | WN | RF | SCH40 | HOT WATER OUTLET | ASME/ANSI B16.5 |
| N3 | 1 1/2" | 1 | 150# | WN | RF | SCH40 | MAKE-UP WATER INLET | ASME/ANSI B16.5 |
| N4 | 2" | 1 | 150# | WN | RF | SCH40 | HOT WATER SIDE - DRAIN | ASME/ANSI B16.5 |
| N5 | 1 1/2" | 1 | 150# | WN | RF | SCH40 | LIT-9800051 | ASME/ANSI B16.5 |
| N6 | 6" | 1 | 150# | WN | RF | SCH40 | COLD WATER INLET | ASME/ANSI B16.5 |
| N7 | 6" | 1 | 150# | WN | RF | SCH40 | COLD WATER OUTLET | ASME/ANSI B16.5 |
| N8 | 2" | 1 | 150# | WN | RF | SCH40 | COLD WATER SIDE - DRAIN | ASME/ANSI B16.5 |
| N9 | 1 1/2" | 1 | 150# | WN | RF | SCH40 | LIT-9800052 | ASME/ANSI B16.5 |
| N10 | 2" | 1 | 150# | WN | RF | SCH40 | OVERFLOW | ASME/ANSI B16.5 |
| N11 | 18" | 1 | 150# | SO | RF | SCH40 | MANHOLE (HOT SIDE) | ASME/ANSI B16.5 |
| N12 | 18" | 1 | 150# | SO | RF | SCH40 | MANHOLE (COLD SIDE) | ASME/ANSI B16.5 |
| N13 | 3" | 1 | - | - | - | SCH40 | VENT | ASME/ANSI B15.5 |
| N14 | 1 1/2" | 2 | 150# | SO | RF | SCH40 | LEVEL GAUGE 980070 (COLD SIDE) | ASME/ANSI B16.5 |
| | | | | | | | | |











569-DB7A-MEC-731-001 CLIENT NR PRD-MEC-DSH-010 NUMBER:

TITLE

5/5

REV.: 0

BUFFER TANK - BT-7A-1

SKETCH - NOZZLES ORIENTATION

