







DOC NUMBER:

569-DB7A-AIC-712-001

CLIENT NUMBER:

PRD-AIC-DSH-010

CLIENT:

TAKEDA/BAXALTA

PROJECT:

**BURITI EPCVM PROJECT** 

# DATA SHEET PRESSURE INDICATING TRANSMITTER-NON SANITARY

2	26JAN2022	ISSUED FOR CONSTRUCTION UPDATED AS PER NOTES	MAB	MAF	RSP
1	17NOV2021	ISSUED FOR CONSTRUCTION UPDATED AS PER NOTES	MAB	MAF	RSP
0	13SEP2021	ISSUED FOR CONSTRUCTION	MAB	MAF	RSP
Α	31MAR2021	60% DD ISSUE	MAB	MAF	RSP
REV	DATE	DESCRIPTION	EXEC	CHECK	APPROV









NUMBER: 569-DB7A-AIC-712-001 TITLE

CLIENT NR:

PRD-AIC-DSH-010

2 de 4

REV.:

2

### PRESSURE INDICATING TRANSMITTER-NON SANITARY

DOCUMENT REVIEW CONTROL																				
Revision	А	0	1	2	3	4	Revision	Α	В	0	1	2	3	Revision	Α	В	0	1	2	3
Page							Page							Page						
1	$oldsymbol{ imes}$	$\boxtimes$	$\mathbb{X}$	$\mathbb{X}$			26							51						
2	$oldsymbol{ imes}$	$\boxtimes$	$\mathbf{X}$	$\boxtimes$			27							52						
3	${}^{\perp}$	$\times$	$\boxtimes$	$\boxtimes$			28							53						
4	${}^{\perp}$	$\times$	$\boxtimes$	$\boxtimes$			29							54						
5	$\times$	$\times$	$\boxtimes$				30							55						
6	$\times$	$\times$	$\boxtimes$				31							56						
7	-X	$\times$	$\boxtimes$				32							57						
8	$\times$	X	$\boxtimes$				33							58						
9	${}^{\perp}$	$\times$	$\boxtimes$				34							59						
10	${}^{\perp}$	$\times$					35							60						
11							36							61						
12							37							62						
13							38							63						
14							39							64						
15							40							65						
16							41							66						
17							42							67						
18							43							68						
19							44							69						
20							45							70						
21							46							71						
22							47							72						
23							48							73					П	
24							49							74	1				П	
25							50							75						

The information contained in this document is the property of TESSLER Engenharia and is provided to the customer under the condition that they are not used for other purposes other than those contractually established.









NUMBER: 569-DB7A-AIC-712-001 CLIENT NR: PRD-AIC-DSH-010

TITLE

3 de 4

PRESSURE INDICATING TRANSMITTER-NON SANITARY

REV.:

#### REFERENCE DOCUMENTS

7A-Z-0-2-01 DRUG PRODUCT - BUFFER PREP 7A-Z-0-2-02 DRUG PRODUCT - FORMULATION

7A-Z-0-2-03 DRUG PRODUCT - STERILE FILTRATION - FIL-3901
7A-Z-0-2-25 DRUG PRODUCT - HOT WFI STORAGE TANK - TQ-6401

PRD-AIC-LIS-046 INTEGRATED PROJECT SERVICES - INSTRUMENT SUGGESTED SUPPLIER LIST

#### **GENERAL NOTES**

- 1 Transmitters must have the following characteristics:
- a) They must be electronic, intelligent and programmable, with signal transmission from 4 to 20mA to two galvanically isolated wires from the power supply;
- b) Withstand the respective maximum static design pressures;
- c) They must be able to identify internal failures;
- d) Be able to define the output signal value, programmable in 0% or 100% of the range, in case of failure of the sensor element;
- e) External supply at 24Vdc
- 2 All transmitters must have enclosures, whose parts exposed to the atmosphere are resistant to environmental conditions, including those generated by the condition of the process, enabling light external cleaning.
- 3 The identification plates must be manufactured in stainless steel AISI 304, permanently attached to the instruments with tag and serial number. The serial number of the instrument, when possible, can be engraved on the body itself.
- 4 The identification plates must be manufactured in stainless steel AISI 304, permanently attached to the instruments with tag and serial number. The serial number of the instrument, when possible, can be engraved on the body itself.
- 5 The manufacturer must inform in the catalog of the transmitter the dimensions of the same for installation in the place indicated in the project.
- 6 The liquid crystal instrument display with internal illumination for all the information that is necessary for its calibration and indication of necessary variables.
- 7 All transmitters must be provided with protection type certificates compatible with the respective area classification. If the enclosure requires certificates regarding type and degree of protection, both proofs must be explicit in the same certificate. The certificates must be issued by INMETRO or an accredited body.
- 8 Grounding rings must be provided in compatible material, with the instrument box and easy access for assembly, being at least AISI 316.

REVISION 0 - NOTES

1- REVISED AS PER INSTRUMENT LIST NUMBER PRD-AIC-LIS010\_B\_PCS\_INSTRUMENT\_INDEX AND BACKLOG NUMBER 99000-184.0
2021.03.30 - A&IC DOCUMENTS - COMMENTS\_REV.01

REVISION 1 - NOTES

1 - ACCORDING NEW ARQUITECTURE UPDATED

REVISION 2 - NOTES

1 - ADDED INSTRUMENT: PIT-650101









NUMBER: **569-DB7A-AIC-712-001**TITLE

CLIENT NR:

PRD-AIC-DSH-010

SHEET: 4 de 4

## PRESSURE INDICATING TRANSMITTER-NON SANITARY

REV.:

								2			
	1	INSTRUMENT TAG NUMBER	र			Pl	T-650101				
	2	SERVIÇE			FROM GENERATION CLEAN STEAM						
	3	P&ID				7A	-Z-0-2-28				
٩L	4	PIPE LINE	EQUIPMENT NUM	IBER	3"-SFI-65010	01-SS10-HC		-			
GENERAL	5	EQUIPMENT MATERIAL / PIF	PE PE				316SS				
GE	6	AREA CLASSIFICATION				NOT (	CLASSIFIED				
	7	ENCLOSURE CLASSIFICATI	ON		1	P 65 (MÍN.) C	ONF. NBR IEC 6052	9			
	8	CERTIFICATES			(\$	SEE GENERA	L NOTES 7 - PAGE	3)			
	9										
	10	TYPE				MICRO	PROCESSED				
	11	MOUNTING				R	EMOTE				
	12	BODY MATERIAL					316SS				
	13	BODY PRESSURE CLASS				BY MAN					
	14	METER CASING				ALUMINIO	(COPPER FREE)				
	15	POWER SUPPLY				24 V	cc - 2 FIOS				
	16	OUTPUT SIGNAL				4 - 20 mA (50	00 ohms @ 24 Vcc)				
띪	17	COMMUNICATION PROTOC	OL			<u> </u>	HART				
TRANSMITTER	18	PRECISION				± 0.0	075% F.E.				
NSN	19	REPEATABILITY				BY MAN					
IRA	20	ELEMENT TYPE				DIAPHRAG	GM (CAPACITIVE)				
	21	SENSOR ELEMENT MATERI	AL		316LSS						
	22	CALIBRATION RANGE			0 - 10 barG						
	23	CALIBRATED RANGE			2 barG						
	24	CONNECTION TO PROCESS	S (HIGH / LOW)		1/2" NPT (F) 1/2" NPT (F)						
	25	ELECTRICAL CONNECTION			1/2" NPT (F)						
	26										
	27	ADJUSTABLE RANGE / AJ. L	OCAL ZERO AND SPA	N		YE	ES / YES				
	28	DIAPHRAGM SEAL				HIGIE	NIC CLAMP				
_	29	SEAL MATERIAL				ASTM A	270 Gr.TP316L				
DIAPHRAGM SEAL	30	CONNECTION TO PROCESS	3				2"				
MΘ	31	FLANGE FACE FINISH			FLAT EN	DS FOR ORBI	TAL WELDING X TR	RI-CLAMP			
HA F	32	FILLING FLUID				MANUFACT	TURE STANDARD				
APF	33	CAPILLARY MATERIAL					-				
	34	CAPILLARY LENGTH					-				
	35						-				
S	36	MOUNTING ACCESSORIES			YE	S, STAINLES	S STEEL FOR 2" TU	BE			
NE	37	MANIFOLD					NOT				
SSC	38	LOCAL INDICATION				LCD ( NC	TE 6 - PAGE 3)				
ACCESSORIES	39	TAGGING				(NOTE	4 - PAGE 3)				
¥	40	SURGE PROTECTOR					YES				
S	41	FLUID	PHYSICAL STATUS		STEA	М	VAI	POR			
NO.	42	MINIMUM TEMPERATURE	NORMAL	MAXIMUM	80	-	-	°C			
OPERATING CONDITIONS	43	MINIMUM PRESSURE	NORMAL	MAXIMUM	2	-	-	barG-g			
ő	44	DESIGN PRESSURE	DESIGN TEMPER	ATURE	-	barG		°C			
9 N	45	VISCOSITY @ OPERATING (	CONDITION		-		Ср				
₹	46	DENSITY @ OPERATING CO	ONDITION		-		kg/m³				
PEF	47	SUSPENDED SOLIDS (%)					-				
0	48	M.M. / Z / Cp/Cv									
	50	MANUFACTURER				Endress + Ha	user (E+H) or Similaı				
	51	MODEL									