



GENERAL NOTES:

- ALL COMPONENT & EQUIPMENT NUMBER ARE PRECEDED BY "TA" TO REPRESENT THE FINAL DRUG PRODUCT (FDP) BUILDING.
- MOTORIZED PRESSURE INDEPENDENT BALANCING AND TEMPERATURE CONTROL VALVES.
- ALL MOTORIZED VALVES - STATIONARY FAILURE.
- LAST LINE NUMBER.

LINE NUMBER NOT USED:

CONDENSATE HEADER  
7A-M-0-5-62  
1,103.5 KGHR @ 0.1 BARG

RE-HEATED WATER SUPPLY  
7A-M-0-5-48  
746.67 LPM (44.8 M3/HR)  
@ 3.33 BARG

RE-HEATED WATER RETURN  
7A-M-0-5-49  
746.67 LPM (44.8 M3/HR)  
@ 1.25 BARG

SHEET NOTES

- CANCELED
- THE FOLLOWING PURGE POINTS SHALL BE PROVIDED AT:
  - ALL LOW POINTS
  - THE EQUIPMENT INLET
  - THE CONTROL VALVE
- CENTRIFUGAL PUMP - ONE OPERATING AND THE OTHER - STANDBY
- PUMP CONTROLLED BY DIFFERENTIAL PRESSURE TRANSMITTER (PDT-97005), MAINTAINING CONSTANT THE PRESSURE DROP OF 1.27 BAR
- CENTRIFUGAL PUMP - ONE OPERATING AND THE OTHER - STANDBY
- THE LOW LOW PRESSURE SHUT DOWN THE PUMP, PRESSURE MOTO BARRA PRESSÃO A FOMBA
- PIT PLUG
- BY PASS VALVE - BALANCING VALVE TO KEEP THE FLOW RATE OF 0.37 M3/HR
- MOTORIZED PRESSURE INDEPENDENT BALANCING AND TEMPERATURE CONTROL VALVES WITH ON/OFF CONTROL FOR DIAMETER OF 3/4" FOR DIAMETERS FROM 1" WERE USED THE SAME VALVES WITH MODULATING CONTROL
- SYMBOLS REFERENCE - SEE DOCUMENT 07-M-0-5-01
- PROVIDE AIR VENT AT THE HIGH POINT OF EACH DROP IN THE HOT WATER PIPING SYSTEM. ALL PIPING SHALL GRADE TO LOW POINTS. PROVIDE HOSE END DRAIN VALVES AT THE BOTTOM OF ALL RISERS AND LOW POINTS
- TEMPERATURE CONTROL VALVE (TV-970005) CONTROLLED BY THE TEMPERATURE TRANSMITTER (TT-97005) AT THE HEAT EXCHANGER OUTLET TO MAINTAIN CONSTANT THE TEMPERATURE OF 61.1 °C. IN CASE OF HIGH TEMPERATURE, THE ON-OFF VALVE (OV-97005) BLOCKS THE STEAM INLET UNTIL THE TEMPERATURE RETURNS TO THE NORMAL CONDITION
- THE HEAT EXCHANGER WAS SIZED TO HEAT 66 M3/HR OF WATER FROM 52.5 °C TO 61.1 °C. USING SUPERHEATED INDUSTRIAL STEAM
- THE HEAT EXCHANGER WAS SIZED TO HEAT 66 M3/HR OF WATER FROM 52.5 °C TO 61.1 °C. USING SUPERHEATED INDUSTRIAL STEAM

**Integrated Project Services**  
Engineering Design/Build Compliance Consulting  
IPS Professional Engineers and Architects, LLC.

721 Arbor Way Suite 100  
BLUE BELL, PA 19422  
PHONE: (610) 828-4090  
FAX: (610) 828-3656  
www.ipsd.com

REV	DATE	DESCRIPTION	BY	CHECK	APPR
A	28/04/2020	90% RFI ISSUE	LFT	-	-
B	10/05/2020	FINAL RFI ISSUE	LFT	-	-
C	16/06/2021	90% RFI ISSUE	JRM	CCD	MSS
D	03/08/2021	ISSUED FOR CONSTRUCTION	JRM	LFE	MSS

R. Dr. Cesarino Mota Júnior, 424 - Vila Buarque, São Paulo - SP, 01221-020

REVISION C NOTES

- ALL DATA WERE UPDATED ACCORDING TO HVAC EQUIPMENT LIST AND CALCULATION REPORT
- LIST AND CALCULATION REPORT
- VAZÃO E DIÂMETRO DO VAPOR INDUSTRIAL FORAM ATUALIZADOS DE ACORDO COM MEMORIAL DE CÁLCULO DO VAPOR

REVISION D NOTES

- ADD NEW REHEAT COIL RHA1005-1
- ADICIONADO NOVA SERPENTINA RHA1005-1
- PLANT STEAM FLOWRATE AND DIAMETER WERE UPDATED ACCORDING PLANT STEAM CALCULATION REPORT
- VAZÃO E DIÂMETRO DO VAPOR INDUSTRIAL FORAM ATUALIZADOS DE ACORDO COM MEMORIAL DE CÁLCULO DO VAPOR
- NOTA GERAL: A ADICIONADA
- GENERAL NOTES NUMBER 6 WAS ADD
- NOTA GERAL: A ADICIONADA
- FLAGS DATA HAS BEEN UPDATED
- ATUALIZAÇÃO DOS DADOS DAS BANDEIRAS

HOLD LIST

**CONFIDENTIAL**  
THE INFORMATION CONTAINED HEREIN MAY NOT BE USED OR REPRODUCED IN ANY MANNER WITHOUT WRITTEN PERMISSION OF INTEGRATED PROJECT SERVICES.

Buriti EPCMV

ENGINEER	ARCHITECT	DESIGNER	IPS PROJECT #
LFF	BUE	FJT	ITD19430.01

DRAWN BY	REVIEWED BY	SCALE	CADD FILE NAME
JRM	CCO	NONE	7A-M-0-5-47-0

REVISION 0 A VERSION

DRAWING NUMBER  
**7A-M-0-5-47**