

Integrated Project Services 721 ARBOR WAY, SUITE 100 BLUE BELL PENNSYLVANIA 19422 Engineering
Design/Build
Compliance
Consulting FAX: 610.828.3656 www.ipsdb.com IPS Professional Engineers and Architects, PC.
 REV
 DATE
 DESCRIPTION

 A
 09JUL2020
 50% BD ISSUE

 B
 28AUG2020
 90% BD ISSUE

 C
 16OCT2020
 FINAL BD ISSUE

 D
 30MAR2021
 30% DD ISSUE

 E
 06OCT2021
 90% DD ISSUE

 0
 19OCT2021
 ISSUE FOR CONSTRUCTION
 TESSLER engenharia R. Dr. Cesário Mota Júnior, 424 - Vila Buarque, São Paulo - SP, 01221-020 **GENERAL NOTES:** 1. FOR LEGEND, ABBREVIATIONS AND SYMBOL SEE SHEETS 7B-I-0-0-01. 2. FOR B07-FACP-01 SEE SHEET 7A-I-0-7-02 3. ALL ROOMS ARE BEING MONITORED WITH SMOKE DETECTOR **REVISION E NOTES** CANCELLED PRE-ACTION IN ELECTRICAL ROOMS CANCELLED SMOKE DETECTOR IN DUCT FOR AHU EXHAUST UPDATED QUANTITY OF THE FIRE ALARM COMPONENTS. ADDED THERMO DETECTOR IN AUTOCLAVE ROOM. CANCELLED B07B - FACP **REVISION 0 NOTES** ADDED LOOP SCL 9. **CONFIDENTIAL** THE INFORMATION CONTAINED HEREIN MAY NOT BE USED OR REPRODUCED IN ANY MANNER WITHOUT WRITTEN PERMISSION OF INTEGRATED PROJECT SERVICES. **BURITI EPCMV PROJECT DRUG SUBSTANCE** FIRE ALARM RISER DIAGRAM

DRAWN BY REVIEWED BY SCALE

DRAWING NUMBER

XREF FILE(S)

7B-I-0-7-02