







	
DOC NUMBER: 569-DB7B-PRO-500-002		CLIENT NUMBER: PRD-MEC-MDE-005	
CLIENT: TAKEDA			
PROJECT BURITI EPCMV PROJECT			

BULK DRUG SUBSTANCE HEATING HOT WATER SYSTEM DESCRIPTION REPORT

0	30JUL2021	ISSUED FOR CONSTRUCTION	MPA	LFF	MSS
A	25JUN2021	90% DD ISSUE	MSN	CCO	MSS
RE	DATE	DESCRIPTION	EXEC	CHECK	APPROV

 		 	
DOC NR: 569-DB7B-PRO-500-002		CLIENT NR: PRD-PRO-MDE-005	
TITLE:		SHEET 2 of 12	
HEATING HOT WATER SYSTEM (HVAC) – DESCRIPTION REPORT		REV.: 0	

1. REVISION HISTORY	3
2. PURPOSE	3
3. REFERENCE.....	3
4. PROCESS DESCRIPTION.....	3
5. CONSUMERS.....	9

 		 
DOC NR:	569-DB7B-PRO-500-002	CLIENT NR: PRD-PRO-MDE-005
TITLE:		SHEET 3 of 12
HEATING HOT WATER SYSTEM (HVAC) – DESCRIPTION REPORT		REV.: 0

1. REVISION HISTORY

Rev	Reason For Change
A	90% DD ISSUE
0	REHEAT COIL UNIT'S FLOW RATES AND DIAMETERS HAVE BEEN UPDATED. AS WELL AS CALCULATIONS AND EQUIPMENT, ALL DATA WERE UPDATED ACCORDING TO HVAC EQUIPMENT LIST

2. PURPOSE

This document is intended to describe the process characteristics for the Heating Hot Water System, Building 7B – Bulk Drug Substance – BDS, intended to Takeda unit - Buriti Project, located at Hemobrás site in Goania – Pernambuco state, Brazil.

3. REFERENCE

The following documents were used as reference:

Item	Number	Documents List – Building 7B
01	PRD-MEC-CLC-006	HEATING HOT WATER SYSTEM (HVAC) – CALCULATION REPORT
02	7B-M-0-5-46	P&I DIAGRAM DRUG SUBSTANCE HEATING HOT WATER - SYSTEM (HVAC) (1/4)
03	7B-M-0-5-47	P&I DIAGRAM DRUG SUBSTANCE HEATING HOT WATER - SYSTEM (HVAC) (2/4)
04	7B-M-0-5-48	P&I DIAGRAM DRUG SUBSTANCE HEATING HOT WATER - SYSTEM (HVAC) (3/4)
05	7B-M-0-5-49	P&I DIAGRAM DRUG SUBSTANCE HEATING HOT WATER - SYSTEM (HVAC) (4/4)

4. PROCESS DESCRIPTION

The building 7B has a Heating Hot Water Skid, located on the first floor to meet the demand at HVAC equipment located on the first and the ground floor of this building.





The water heating system consists by:

- 1 Heating skid (air separator + pumps + heat exchanger with temperature control)
- 1 Expansion tank
- 1 Chemical dosing system + make-up.

The system is sized for the following thermal load, required by HVAC:

- Design Capacity: 666,541.52 kcal/h – considering future expansion with TIE-IN-M-1-21 and TIE-IN-M-1-22
- Maximum Capacity: 522,661.55 kcal/h.
- Minimum Capacity (50% Diversity): 260,818.21 kcal/h.

The energy source to heat the water is Plant Steam through a 4" line (line 4" -IS1B-790106-CS1-HC) at 2.0 barg and to attend the thermal loads indicated above, there is a temperature control valve (TV-970001) with the following flow rates:

 		 	
DOC NR:	569-DB7B-PRO-500-002	CLIENT NR:	PRD-PRO-MDE-005
TITLE:			SHEET 4 of 12
HEATING HOT WATER SYSTEM (HVAC) – DESCRIPTION REPORT			REV.: 0

- Design Condition: 1,280.1 kg/h
- Maximum Operating Condition: 1,003.8 kg/h
- Minimum Operating Condition: 500.9 kg/h

This valve is controlled by the Temperature Transmitter (TIT/TIC- 970001) to keep the hot water flow rate after the heat exchanger HX-7B-1 at 61.1°C.

The skid has two pumps where one is operating, and the other is stand-by with the following conditions:

- Design Condition – Flow rate = 80.66 m³/h / Head = 35 mlc
- Maximum Operating Condition – Flow rate = 67.36 m³/h / Head = 33 mlc
- Minimum Operating Condition for the Heating Hot Water Skid (50% Diversity) – Flow rate = 44.15 m³/h / Head = 30 mlc
- Minimum Operating Condition for Valves (10% Diversity) – Flow rate = 25.43 m³/h / Head = 28 mlc

These pumps are controlled by the differential pressure transmitter PDIT-970001 maintaining constant the pressure drop of 1.596 bar at the main distribution header. This instrument is installed at a distance of 2/3 of the main distribution pipe total length, to guarantee a good control.

The hot water circulates through the system, feeding the coils used in HVAC. The return temperature is 52.7°C at design condition and 55.1°C at minimum condition for the Heating Hot Water Skid (50% diversity). At the suction of the pumps is installed an air separator with a capacity of 81 m³/h.

The characteristics of each equipment / system are shown below.

4.1 Chemical Feeding System and Make-up





The chemical feeding system is formed by chemical dosing tank (TK-7B-6), chemical dosing pump (BM-7B-5 / M-BM-7B-5) and a spill containment pallet (CN-7B-5).

The system is efficient in the prevention of slime generation, scaling and corrosion. It is used when make-up of industrial water is required. The chemical dosing is made by flexible hose connected to the manual block valve (HV-9700279) in the inlet line of industrial water (line 1"-DW-9700154-CS1-NI).

The chemical feeding system has the following instruments:

CHEMICAL DOSING SYSTEM	INSTRUMENT	FUNCTION
Containment Pallet	LSH-9700283	High Level Alarm (Chemical spill)
Motor Pump	HS-970002	ON/OFF – Hand Switch
Chemical Dosing Tank	LSL-9700282	Low Level Alarm

The Heating Hot Water Distribution System is a closed system with make-up of Industrial Water. The make-up is supplied on the first floor from Water for Industrial System (line 1"-DW-610055-PP1-

 		 	
DOC NR:	569-DB7B-PRO-500-002	CLIENT NR:	PRD-PRO-MDE-005
TITLE:			SHEET 5 of 12
HEATING HOT WATER SYSTEM (HVAC) – DESCRIPTION REPORT			REV.: 0

NI) with a flow rate of 67LPM (4 M3/HR), a pressure of 1.6 barg at ambient temperature. There is a manual battery limit valve with a diameter of 1" (HV-9700154).

The make-up system has the following instruments:

MAKE-UP SYSTEM	INSTRUMENT	FUNCTION
Industrial Water - Inlet Line	XV-9700154	Automatic on-off valve to be opened at the low pressure (PSL-970002) and closed at high pressure (PSH-970002)

4.2 Expansion Tank

Pressurized expansion tank (TK-7B-5) with nominal capacity of 0,14 m³ to compensate the fluid thermal expansion due to increase of temperature in the system.

In case of loss fluid in the system, it is necessary to supply water through the make-up system.

The expansion tank has the following instruments:

PRESSURIZED EXPANSION TANK	INSTRUMENT	FUNCTION
Pressurized Expansion Tank - Outlet Line	PSV-9700154	Pressure Safety Valve for relief system

4.3 Heating Hot Water Skid

The Heating Hot Water Skid (HX-7B-1) consists by:





- 1 Heat Exchanger – Plate Heat Exchanger,
- 2 pumps (one operating and the other stand-by),
- 1 Air Separator
- 1 Control panel PLC for temperature and speed pump control.

4.3.1 - Heat Exchanger

The plate heat exchanger has the conditions indicated below.

- Design Condition:

HEAT EXCHANGER - HX-7B-1		
SIDE - WATER		
Thermal Load	666,541.52	kcal/h
Flow rate	79,598.45	kg/h
Temperature Inlet	52.73	°C
Temperature Outlet	61.1	°C
SIDE - PLANT STEAM		

 		 	
DOC NR:	569-DB7B-PRO-500-002	CLIENT NR:	PRD-PRO-MDE-005
TITLE:	HEATING HOT WATER SYSTEM (HVAC) – DESCRIPTION REPORT		SHEET 6 of 12
			REV.: 0

HEAT EXCHANGER - HX-7B-1		
Operating Pressure	1.5	barG
Enthalpy of Vaporization	520.7	kcal/kg
Flow rate	1,280.09	kg/h

- Maximum Operating Condition:

HEAT EXCHANGER - HX-7B-1		
SIDE - WATER		
Thermal Load	522,661.55	kcal/h
Flow rate	66,458.33	kg/h
Temperature Inlet	53.24	°C
Temperature Outlet	61.1	°C
SIDE - PLANT STEAM		
Operating Pressure	1.5	barG
Enthalpy of Vaporization	520.7	kcal/kg
Flow rate	1,003.77	kg/h

- Minimum Operating Condition For Heating Hot Water Skid (50% diversity):

HEAT EXCHANGER - HX-7B-1		
SIDE - WATER		
Thermal Load	260,818.21	kcal/h
Flow rate	43,518.30	kg/h
Temperature Inlet	55.11	°C
Temperature Outlet	61.1	°C
SIDE - PLANT STEAM		
Operating Pressure	1.5	barG
Enthalpy of Vaporization	520.7	kcal/kg
Flow rate	500.90	kg/h

4.3.2 Pumps





The pumps are horizontal centrifugal type designed for a flowrate of 81 m³/h and a manometric height of 35m. For these operating conditions the selected pump was selection with a motor of 15kW.

The pump has a pressure control with shut down in case of the low low pressure.

4.3.3 Air Separation

Air separator flow rate is the same from the pump 81 m³/h, located in the inlet line of the pump (line 4"-HHWR-970002-CS1-HC).

The air separator prevents the accumulation of air in the system, and keeps the system running efficiently, avoiding downtime and maintenance cost.

 		 	
DOC NR: 569-DB7B-PRO-500-002		CLIENT NR: PRD-PRO-MDE-005	
TITLE:			SHEET 7 of 12
HEATING HOT WATER SYSTEM (HVAC) – DESCRIPTION REPORT			REV.: 0

4.3.4 Temperature Control

Hot water heating skid is controlled by temperature control valve (TV-970001), controlled by the temperature transmitter (TIT-970001) at the heat exchanger outlet to maintain constant the temperature of 61.1°C. In case of high temperature, the ON-OFF valve (XV-9700155) blocks the steam inlet until the temperature returns to the normal condition.

The Heating Hot Water Skid (HX-7B-1) has the following instruments:

HEATING HOT WATER SKID	INSTRUMENT	FUNCTION
Suction Line - 4"-HHWR-970002-CS1-HC	PIT-970002	Pressure Indication Transmitter - Low Pressure Switch – open the make-up valve (XV-9700154) and start the dosing pump BM-7B-5 - High Pressure Switch – close the make-up valve (XV-9700154) and shut down the dosing pump BM-7B-5 - High High Pressure – alarm - Low Low Pressure switch - shut down the hot water pump
	TI-970002	Temperature Indication
	TIT-970002	Temperature Indication Transmitter - High Temperature - Alarm - Low Temperature - Alarm
	PI-970002	Pressure indication
	PI-9700151	Pressure indication

DOC NR: **569-DB7B-PRO-500-002**

 CLIENT NR: **PRD-PRO-MDE-005**





TITLE:

 SHEET
8 of 12

HEATING HOT WATER SYSTEM (HVAC) – DESCRIPTION REPORT

 REV.:
0

HEATING HOT WATER SKID	INSTRUMENT	FUNCTION
Motor Pump	SC-97001	Control Speed - Controlled by Differential Pressure Transmitter PDIT-970001.
Discharge Pump	PI-9700152	Pressure indication
Motor Pump (stand-by)	SC-970002	Control Speed - Controlled by Differential Pressure Transmitter PDIT-970001.
Discharge Pump	PI-9700153	Pressure indication
Heat Exchanger – Steam Side	TV-97001	Control Valve to keep constant the water temperature.
	XV-9700155	Automatic on-off valve - High Temperature Blocks the steam (TIT-970001)
Heat Exchanger – Hot Water Side	PIT-970001	Pressure Indication Transmitter - High Pressure - Alarm - Low Pressure - Alarm
	TI-970001	Temperature Indication
	TIT/TIC-970001	Temperature Indication Transmitter - Temperature Control - to keep constant the water temperature. - High Temperature - Alarm - Low Temperature - Alarm
	PSV-970001	Pressure Safety Valve for system relief

 		 	
DOC NR: 569-DB7B-PRO-500-002		CLIENT NR: PRD-PRO-MDE-005	
TITLE:			SHEET 9 of 12
HEATING HOT WATER SYSTEM (HVAC) – DESCRIPTION REPORT			REV.: 0

5. CONSUMERS

The Heating Hot Water Distribution System of HVAC has the following consumers in the Building 7B with their respective operational characteristic:

TAG	Vol. Flow Rate (m³/h)	Mass Flow Rate (kg/h)	P Static In (barG)	P Static Out (barG)	Pressure Drop (bar)
RH-B2028-2	2.42	2,379.61	3.13	2.63	0.50
RH-B2026-1	0.17	167.97	3.08	2.58	0.50
RH-B2025-1	0.23	223.96	3.09	2.59	0.50
RH-B2024-1	0.23	223.96	3.04	2.54	0.50
RH-B2023-1	0.19	181.97	3.03	2.53	0.50
RH-B2003-1	0.14	139.98	3.02	2.52	0.50
RH-B2004-1	0.34	335.94	3.02	2.52	0.50
RH-B2011-1	0.17	167.97	2.97	2.47	0.50
RH-B2012-1	0.23	223.96	2.95	2.45	0.50
RH-B2013-1	0.23	223.96	2.94	2.44	0.50
RH-B2014-1	0.17	167.97	2.93	2.43	0.50
RH-B2029-1	0.19	181.97	2.84	2.34	0.50
RH-B2008-1	0.17	168.97	2.89	2.39	0.50
RH-B2010-1	0.17	167.97	2.90	2.40	0.50
RH-B2056-1	1.97	1,931.68	2.83	2.33	0.50
RH-B2056-2	1.97	1,931.68	2.75	2.25	0.50
RH-B2043-1	0.17	167.97	2.86	2.36	0.50
RH-B2042-1	0.23	223.96	2.87	2.37	0.50
RH-B2041-1	0.17	167.97	2.89	2.39	0.50
RH-B2040-1	0.23	223.96	2.91	2.41	0.50
RH-B2044-1	1.34	1,319.66	2.88	2.38	0.50
RH-B2044-2	0.67	659.71	2.88	2.38	0.50
RH-B2046-1	0.20	195.97	2.86	2.36	0.50
RH-B2047-1	0.37	363.94	2.84	2.34	0.50
RH-B2051-1	0.09	83.99	2.85	2.35	0.50
RH-B2045-1	0.57	559.91	2.84	2.34	0.50
RH-B2039-1	1.78	1,750.05	3.03	2.53	0.50
RH-B2039-2	1.60	1,575.05	3.03	2.53	0.50
RH-B2015-1	0.26	251.96	3.00	2.50	0.50
RH-B2038-1	0.20	195.97	2.97	2.47	0.50
RH-B2039-4	2.14	2,100.06	2.95	2.45	0.50
RH-B2039-3	1.60	1,575.05	2.96	2.46	0.50
RH-B2037-1	1.57	1,539.75	2.98	2.48	0.50
RH-B2036-1	0.34	335.94	3.09	2.59	0.50
RH-B2048-2	1.97	1,931.09	3.08	2.58	0.50
RH-B2035-1	0.34	335.94	3.10	2.60	0.50

DOC NR: **569-DB7B-PRO-500-002**

CLIENT NR: **PRD-PRO-MDE-005**




TITLE:

SHEET
10 of 12

HEATING HOT WATER SYSTEM (HVAC) – DESCRIPTION REPORT





REV.:
0

TAG	Vol. Flow Rate (m³/h)	Mass Flow Rate (kg/h)	P Static In (barG)	P Static Out (barG)	Pressure Drop (bar)
RH-B2048-1	3.14	3,089.75	3.06	2.56	0.50
RH-B2048-5	0.88	868.99	3.04	2.54	0.50
RH-B2048-4	1.47	1,448.32	3.00	2.50	0.50
RH-B2034-1	0.17	167.97	3.13	2.63	0.50
RH-B2033-1	0.17	167.97	3.13	2.63	0.50
RH-B2032-1	0.23	223.96	3.11	2.61	0.50
RH-B2031-1	0.30	293.95	3.04	2.54	0.50
RH-B2057-1	0.20	195.97	3.02	2.52	0.50
RH-B2054-1	0.37	363.94	3.01	2.51	0.50
RH-B2053-1	0.68	671.89	2.99	2.49	0.50
RH-B2052-1	0.06	55.99	3.02	2.52	0.50
RH-B2050-1	0.26	251.96	2.99	2.49	0.50
RH-B2027-1	0.31	307.95	3.03	2.53	0.50
RH-B2028-1	2.42	2,379.61	3.05	2.55	0.50
RH-B2030-1	0.30	293.95	3.03	2.53	0.50
RH-B2017-1	0.28	279.95	3.02	2.52	0.50
RH-B2018-1	0.20	195.97	3.01	2.51	0.50
RH-B2019-1	0.20	195.97	3.01	2.51	0.50
RH-B2001-1	1.25	1,231.80	2.97	2.47	0.50
RH-B2021-1	1.05	1,035.83	2.99	2.49	0.50
RH-B2001-2	0.17	167.97	2.98	2.48	0.50
RH-B2002-1	0.46	447.93	2.97	2.47	0.50
RH-B1019-1	0.27	260.7	3.84	3.34	0.50
RH-B1021-1	0.17	167.97	3.83	3.33	0.50
RH-B1024-1	0.20	195.97	3.82	3.32	0.50
RH-B1026-1	0.17	167.97	3.82	3.32	0.50
RH-B1025-1	0.20	195.97	3.82	3.32	0.50
RH-B1023-1	1.92	1,889.69	3.82	3.32	0.50
RH-B2048-3	1.47	1,448.32	3.04	2.54	0.50
RH-B2020-1	0.20	193.11	2.99	2.49	0.50
RH-B2037-2	1.57	1,539.75	3.08	2.58	0.50
RH-B2016-1	2.19	2,155.64	2.99	2.49	0.50
RH-B2016-2	0.17	167.97	2.99	2.49	0.50

 		 	
DOC NR: 569-DB7B-PRO-500-002		CLIENT NR: PRD-PRO-MDE-005	
TITLE:			SHEET 11 of 12
HEATING HOT WATER SYSTEM (HVAC) – DESCRIPTION REPORT			REV.: 0

The Reheat Coils are controlled by the following control valves, to be supplied by the HVAC package:

Jct	TAG	Vol. Flow (m3/hr)	Mass Flow (kg/hr)	dP Stag. (bar)	P Static In (barG)	P Static Out (barG)
13	TV-9700547	2.41	2,379.61	1.25	2.63	1.38
15	TV-970016	0.17	167.97	1.09	2.58	1.49
17	TV-970012	0.23	223.96	1.11	2.59	1.48
19	TV-970018	0.23	223.96	1.03	2.54	1.50
21	TV-970014	0.18	181.97	1.01	2.53	1.51
23	TV-970026	0.14	139.98	1.00	2.52	1.53
25	TV-970024	0.34	335.94	1.02	2.52	1.50
27	TV-970042	0.17	167.97	0.87	2.47	1.60
29	TV-970046	0.23	223.96	0.82	2.45	1.63
31	TV-970040	0.23	223.96	0.80	2.44	1.64
33	TV-970044	0.17	167.97	0.78	2.43	1.65
34	TV-9700460	0.18	181.97	0.82	2.43	1.61
37	TV-970054	0.17	168.97	0.74	2.39	1.66
39	TV-970052	0.17	167.97	0.71	2.40	1.68
41	TV-9700464	1.96	1,931.68	0.45	2.33	1.87
43	TV-9700530	1.96	1,931.68	0.36	2.24	1.88
44	TV-970025	0.17	167.97	0.65	2.36	1.71
46	TV-970066	0.23	223.96	0.67	2.37	1.70
48	TV-970064	0.17	167.97	0.70	2.39	1.68
51	TV-970060	0.23	223.96	0.78	2.41	1.63
53	TV-970068	1.34	1,319.66	0.70	2.37	1.68
55	TV-9700470	0.67	659.71	0.69	2.37	1.68
57	TV-970074	0.20	195.97	0.66	2.36	1.70
59	TV-970072	0.37	363.94	0.62	2.34	1.73
61	TV-9700472	0.09	83.99	0.63	2.35	1.72
63	TV-970070	0.57	559.91	0.61	2.33	1.72
65	TV-970036	1.77	1,750.05	1.04	2.53	1.49
67	TV-9700454	1.59	1,575.05	1.03	2.53	1.50
69	TV-970048	0.26	251.96	1.01	2.50	1.48
71	TV-970032	0.20	195.97	0.93	2.47	1.54
73	TV-9700452	2.13	2,100.06	0.88	2.45	1.57
75	TV-9700450	1.59	1,575.05	0.91	2.46	1.56
77	TV-970030	1.56	1,539.75	0.95	2.48	1.52
79	TV-970028	0.34	335.94	1.15	2.59	1.44
81	TV-9700438	1.95	1,931.09	1.05	2.58	1.53
83	TV-970008	0.34	335.94	1.16	2.60	1.43
85	TV-970084	3.13	3,089.75	1.08	2.56	1.48
87	TV-9700432	0.88	868.99	1.01	2.53	1.52
89	TV-9700436	1.47	1,448.32	0.93	2.50	1.56

 		 	
DOC NR: 569-DB7B-PRO-500-002		CLIENT NR: PRD-PRO-MDE-005	
TITLE:			SHEET 12 of 12
HEATING HOT WATER SYSTEM (HVAC) – DESCRIPTION REPORT			REV.: 0

Jct	TAG	Vol. Flow (m3/hr)	Mass Flow (kg/hr)	dP Stag. (bar)	P Static In (barG)	P Static Out (barG)
91	TV-970082	0.17	167.97	1.26	2.63	1.36
93	TV-970080	0.17	167.97	1.22	2.63	1.40
95	TV-970078	0.23	223.96	1.18	2.61	1.42
97	TV-9700104	0.30	293.95	1.02	2.53	1.51
99	TV-9700478	0.20	195.97	1.00	2.52	1.52
101	TV-970086	0.37	363.94	0.98	2.51	1.53
103	TV-9700109	0.68	671.89	0.94	2.49	1.54
105	TV-9700462	0.06	55.99	1.00	2.52	1.52
107	TV-9700106	0.26	251.96	1.00	2.52	1.52
109	TV-9700114	0.31	307.95	1.01	2.53	1.52
111	TV-970034	2.41	2,379.61	1.06	2.55	1.49
113	TV-9700102	0.30	293.95	1.00	2.52	1.52
115	TV-9700116	0.28	279.95	0.99	2.52	1.54
117	TV-9700120	0.20	195.97	0.97	2.51	1.54
119	TV-9700118	0.20	195.97	0.97	2.51	1.54
121	TV-970098	1.25	1,231.80	0.89	2.47	1.58
123	TV-970094	1.05	1,035.83	0.94	2.49	1.54
125	TV-9700476	0.17	167.97	0.91	2.48	1.57
127	TV-970096	0.45	447.93	0.89	2.47	1.58
129	TV-9700466	0.26	260.70	1.07	3.34	2.26
131	TV-9700126	0.17	167.97	1.07	3.33	2.27
133	TV-9700130	0.20	195.97	1.05	3.32	2.28
135	TV-9700134	0.17	167.97	1.03	3.32	2.29
137	TV-9700132	0.20	195.97	1.03	3.32	2.29
139	TV-9700128	1.91	1,889.69	1.03	3.32	2.29
141	TV-9700424	1.47	1,448.32	1.02	2.54	1.52
143	TV-970092	0.20	193.11	1.13	2.49	1.35
145	TV-9700440	1.56	1,539.75	1.04	2.58	1.54
147	TV-9700122	2.18	2,155.64	0.92	2.49	1.57
149	TV-9700464	0.17	167.97	0.92	2.49	1.57