







DOC NUMBER:

569-DB7B-AIC-714-001

CLIENT NUMBER: PRD-AIC-DSH-035

CLIENT:

TAKEDA/BAXALTA

PROJECT:

BURITI EPCVM PROJECT

DATA SHEET LEVEL INDICATING TRANSMITTER

1	17NOV2021	ISSUED FOR CONSTRUCTION UPDATED AS PER NOTES	MAB	MAF	RSP
0	13SEP2021	ISSUED FOR CONSTRUCTION	MAB	MAF	RSP
Α	31MAR2021	60% DD ISSUE	MAB	MAF	RSP
REV	DATE	DESCRIPTION	EXEC	CHECK	APPROV









PRD-AIC-DSH-035 NUMBER: CLIENT NR: 569-DB7B-AIC-714-001 TITLE

2 de 3 REV.:

LEVEL INDICATING TRANSMITTER

DOCUMENT REVIEW CONTROL

Revision	Α	0	1	2	3	4	Revision	Α	В	0	1	2	3	Revision	Α	В	0	1	2	3
Page							Page							Page						L
1	Х	Х	Х				26							51						L
2	Х	Х	Χ				27							52						
3	Х	Х	Χ				28							53						
4	Х	Х					29							54						L
5	Х	Х					30							55						
6	Х	Х					31							56						
7	Х	Х					32							57						
8	Х	Χ					33							58						
9	Х	Х					34							59						
10	Х	Х					35							60						
11	Х	Х					36							61						
12	Х	Χ					37							62						
13	Х						38							63						
14							39							64						Г
15							40							65						
16							41							66						Γ
17							42							67						Г
18							43							68						Γ
19							44							69						Γ
20							45							70						Γ
21							46							71						Γ
22							47							72						Γ
23							48							73						Γ
24							49							74						Γ
25							50							75						Γ

The information contained in this document is the property of TESSLER Engenharia and is provided to the customer under the condition that they are not used for other purposes other than those contractually established.









NUMBER: 569-DB7B-AIC-714-001 CLIENT NR: PRD-AIC-DSH-035

TITLE 'SHEET:

LEVEL INDICATING TRANSMITTER

3 de 3

1

REFERENCE DOCUMENTS

7B-Z-0-2-03	DRUG SUBSTANCE - 3800L MEDIA HOLD TANK - TQ-5201
7B-Z-0-2-04	DRUG SUBSTANCE - 3800L MEDIA HOLD TANK - TQ-5202
7B-Z-0-2-21	DRUG SUBSTANCE - 3400L COLLECTION - TANK N°1, TQ-5701
7B-Z-0-2-22	DRUG SUBSTANCE - 3400L COLLECTION - TANK N°2, TQ-5702
7B-Z-0-2-10	DRUG SUBSTANCE - 320L BIOREACTOR, BRE-5501 VESSEL
7B-Z-0-2-12	DRUG SUBSTANCE - 2500L BIOREACTOR BRE-5601 - VESSEL
7B-Z-0-2-14	DRUG SUBSTANCE - 2500L BIOREACTOR N°2, BRE-5602 - VESSEL
7B-Z-0-2-57	DRUG SUBSTANCE - PURIFIED WATER STORAGE TANK, TQ-6302
7B-Z-0-2-60	DRUG SUBSTANCE - HOT WFI STORAGE TANK TQ-6401
PRD-AIC-LIS-046	INTEGRATED PROJECT SERVICES - INSTRUMENT SUGGESTED SUPPLIER LIST

GENERAL NOTES

- 1 Transmitters must have the following characteristics:
- a) They must be electronic, intelligent and programmable, with signal transmission from 4 to 20mA to two galvanically isolated wires from the power supply;
- b) Withstand the respective maximum static design pressures;
- c) They must be able to identify internal failures;
- d) Be able to define the output signal value, programmable in 0% or 100% of the range, in case of failure of the sensor element;
- 2 All transmitters must have enclosures, whose parts exposed to the atmosphere are resistant to environmental conditions, including those generated by the condition of the process, enabling light external cleaning.
- 3 The identification plates must be manufactured in stainless steel AISI 304, permanently attached to the instruments with tag and serial number. The serial number of the instrument, when possible, can be engraved on the body itself.
- 4 The identification plates must be manufactured in stainless steel AISI 304, permanently attached to the instruments with tag and serial number. The serial number of the instrument, when possible, can be engraved on the body itself.
- 5 The manufacturer must inform in the catalog of the transmitter the dimensions of the same for installation in the place indicated in the project.
- 6 The liquid crystal instrument display with internal illumination for all the information that is necessary for its calibration and indication of necessary variables.
- 7 All transmitters must be provided with protection type certificates compatible with the respective area classification. If the enclosure requires certificates regarding type and degree of protection, both proofs must be explicit in the same certificate. The certificates must be issued by INMETRO or an accredited body.
- 8 Grounding rings must be provided in compatible material, with the instrument box and easy access for assembly, being at least AISI 316.

REVISION 0 - NOTES

1- REVISED AS PER INSTRUMENT LIST NUMBER PRD-AIC-LIS-010_B_PCS_INSTRUMENT_INDEX AND BACKLOG NUMBER 99000-184.0 2021.03.30 - A&IC DOCUMENTS - COMMENTS_REV.01

REVISION 1 - NOTES

1 - ACCORDING NEW ARQUITECTURE UPDATED