

- TILIZADAS AS MESMAS VÁLVULAS COM CONTROLE TIPO PROPORCIONAI 6. PROVIDE AIR VENT AT THE HIGH POINT OF EACH HOSE END DRAIN VALVES AT THE BOTTOM OF ALL PREVER ELIMINADOR DE AR EM PONTO ALTO NO SISTEMA DE ÁGUA
- IN THE LINE TAG, THE BUILDING NUMBER (7B) MUST NO TAGUEAMENTO DE LINHAS, DEVE SER CONSIDERADO O NÚMERO DO

Project 721 Arbor Way **Services** BLUE BELL, PA 19422 Engineerin PHONE: (610) 828-4090 Design/Build FAX: (610) 828-3656 Compliance Consulting www.ipsdb.com

IPS Professional Engineers and Architects, LLC. REV DATE DESCRIPTION A 28AUG2020 90% BD ISSUE B 27NOV2020 FINAL BD ISSUE 07JUN2021 90% DD ISSUE 0 30JUL2021 ISSUED FOR CONSTRUCTION

Suite 100



R. Dr. Cesário Mota Júnior, 424 - Vila Buarque, São Paulo - SP, 01221-020

TODOS OS DADOS FORAM ATUALIZADOS DE ACORDO COM A LISTA DE

REVISION C NOTES ALL DATA WERE UPDATED ACCORDING TO HVAC EQUIPMENT

REVISION 0 NOTES

LIST AND CALCULATION REPORT.

EQUIPAMENTOS DE HVAC E MEMORIAL DE CÁLCULO.

• ALL DATA WERE UPDATED ACCORDING TO HVAC EQUIPMENT LIST AND CALCULATION REPORT. TODOS OS DADOS FORAM ATUALIZADOS DE ACORDO COM A LISTA DE

• SHEET NOTE NUMBER 7 WAS ADDED. NOTA 7 FOI ADICIONADA,

EQUIPAMENTOS DE HVAC E MEMORIAL DE CÁLCULO,

HOLD LIST

CONFIDENTIAL THE INFORMATION CONTAINED HEREIN MAY NOT BE USED OR REPRODUCED IN ANY MANNER WITHOUT WRITTEN PERMISSION OF INTEGRATED PROJECT SERVICES.



BURITI EPCMV

P&I DIAGRAM DRUG SUBSTANCE **HEATING HOT WATER**

NONE

SYSTEM (HVAC) (2/4) ARCHITECT DESIGNER IPS PROJECT # ENGINEER ITD19439.01 REVIEWED BY SCALE DRAWN BY CADD FILE NAME

MPA CCO XREF FILE(S) DRAWING NUMBER

7B-M-0-5-47

7B-M-0-5-47=0