





















FIRE ALARM SYSTEM
EQUIPMENT & DEVICES SCHEDULE





											<div><div></div><div></div></div>		<div><div></div><div></div></div>	
0	ISSUE FOR CONSTRUCTION										DOC NR: 569-DB07-AIC-300-006		CLIENT NR: PRD-AIC-LIS-024	
A	90% DD ISSUE													
REV	DESCRIPTION										CLIENT: TAKEDA/BAXALTA PROJECT: BURITI EPCMV PROJECT <div>REV.: 0</div>			
REVIEW	REV. A	REV. 0	REV. 1	REV. 2										
DATE	23ABR2021	20OCT2021												
EXEC	MAF	MAF												
CHECK	MAV	MAV												
APPROV	RSP	RSP												





<div><div></div><div></div></div>			<div><div></div><div></div></div>			TITLE: EQUIPMENT & DEVICES SCHEDULE					DOC NR: 569-DB07-AIC-300-006		SHEET: 3 de 8	
					CLIENT NR: PRD-AIC-LIS-024						REV.: 0			
TAG	STATUS	EQUIPMENT NAME	TYPE	MANUFACTURER	MODEL	CAPACITY	DIMENSIONS (mm)	MATERIAL	REMARKS	QUANTITY	LOCATION			
BUILDING 7A														
B07-FACP-01	NEW	FIRE ALARM CONTROL PANEL	--	NOTIFIER	CPU2-3030D-PO	3.180 TOTAL DEVICES; 159 DETECTORS/159 MODULES PER SLC	--	--	COMMON FOR BUILDING 7A, 7B, 7C, 7F, WWT. 9x SLC WILL BE PROVIDED	1	7A-I-3-3-33			
	NEW	FACP BOM PARTS	--	NOTIFIER	SBB-B4R	--	727 x 613 x 170	--	BOX FOR HOUSING FACP, B SERIES, RED, TWO BAYS, CAB-4 SERIES ENCLOSURES	1				
	NEW	FACP BOM PARTS	--	NOTIFIER	DR-B4R	--	--	--	PANEL CHASSIS SBB-B4R	1				
	NEW	FACP BOM PARTS	--	NOTIFIER	AMPS24E	--	--	--	FONTE DE ALIM. 220 VAC, 50/60Hz, 2.5 A	1				
	NEW	FACP BOM PARTS	--	NOTIFIER	LCM-320	--	--	--	LOOP CONTROL MODULE	1				
	NEW	FACP BOM PARTS	--	NOTIFIER	LEM-320	--	--	--	LOOP EXPANDER MODULE	1				
	NEW	FACP BOM PARTS	--	NOTIFIER	BMP-1	--	--	--	BLANK MODULE PLATE (01 MODULE)	2				
	NEW	FACP BOM PARTS	--	NOTIFIER	BACNET-GW-3	--	--	--	BACNET GATEWAY	1				
	NEW	FACP BOM PARTS	--	NOTIFIER	NCM-F	--	--	--	NETWORK COMMUNICATIONS MODULE. 1x BACNET GATEWAY + 1x NFS2-3030 CONTROL PANEL	2				
	NEW	FACP BOM PARTS	--	NOTIFIER	CHS-4L	--	--	--	BACNET MOUNTING CHASSIS	1				
	NEW	FACP BOM PARTS	--	-	BATERIA 18AH	--	--	--	BATTERY 30min IN ALARM/ 24h IN STANDBY	2				
	NEW	FACP BOM PARTS	--	NOTIFIER	BP2-4	--	--	--	BATTERY DRESS PANEL	1				
B07-NCA-01	NEW	NETWORK CONTROL ANNUNCIATOR	--	NOTIFIER	NCA-2	Enhanced-format 640-character LCD display with backlighting	--	--	COMMON FOR BUILDING 7A, 7B, 7C, 7F, WWT.	1	7A-I-1-3-13			
	NEW	NCA BOM PARTS	--	NOTIFIER	AMPS24E	--	--	--	FONTE DE ALIM. 220 VAC, 50/60Hz, 2.5 A	1				
	NEW	NCA BOM PARTS	--	-	BATERIA 18AH	--	--	--	BATTERY 30min IN ALARM/ 24h IN STANDBY	1				

 		 		TITLE: EQUIPMENT & DEVICES SCHEDULE					DOC NR: 569-DB07-AIC-300-006		SHEET: 4 de 8
									CLIENT NR: PRD-AIC-LIS-024		REV.: 0
TAG	STATUS	EQUIPMENT NAME	TYPE	MANUFACTURER	MODEL	CAPACITY	DIMENSIONS (mm)	MATERIAL	REMARKS	QUANTITY	LOCATION
	NEW	NCA BOM PARTS	--	NOTIFIER	BP2-4	--	--	--	BATTERY DRESS PANEL	1	7A-I-1-3-13
	NEW	ADDRESSABLE MANUAL PULL STATION	--	NOTIFIER	NBG-12LXP4	--	--	--	ADDRESSABLE NBG-12L PULL STATION WITH FLASHCAN. PORTUGUESE. ALREADY HAVE MONITOR MODULE INSIDE	35	7A-I-0-3-03 7A-I-0-3-13 7A-I-1-3-13 7A-I-2-3-23 7A-I-3-3-33
	NEW	AUXILIAR POWER SUPPLY	--	NOTIFIER	FCPS-24S8	--	--	--	--	1	
	NEW	ADDRESSABLE SMOKE DETECTOR WITH SOUNDER BASE	PHOTOELECTRIC	NOTIFIER	FSP-951	--	--	--	--	276	
	NEW	ADDRESSABLE HEAT DETECTOR WITH SOUNDER BASE	THERMAL	NOTIFIER	FST-951	--	--	--	--	8	
	NEW	STANDARD BASE	--	NOTIFIER	B501-WHITE	--	--	--	STANDARD BASE FOR DETECTORS	284	
	NEW	ADDRESSABLE SMOKE DETECTOR BY LASER BEAM	--	NOTIFIER	FSL-751	--	--	--	FIRE DETECTOR ADDRESSABLE BY LASER, FLASHSCAN - NOTIFIER	7	
	NEW	BASE FOR FSL-751	DUCT	NOTIFIER	DNR	--	--	--	BASE FOR DUCT DETECTOR	7	
	NEW	SAMPLE PIPE	--	NOTIFIER	DST5	--	--	--	SAMPLE PIPE 5"	7	
	NEW	ISOLATOR MODULE	--	NOTIFIER	ISOX	--	--	--	--	27	
	NEW	INTELLIGENT RELAY MODULES	--	NOTIFIER	FRM-1	--	--	--	--	30	
	NEW	INTELLIGENT MONITOR MODULES	--	NOTIFIER	FMM-1	--	--	--	--	13	
	NEW	WALL HORN STROBES	--	NOTIFIER	P2RL	--	--	--	--	96	

<div><div></div><div></div></div>			<div><div></div><div></div></div>		TITLE: EQUIPMENT & DEVICES SCHEDULE				DOC NR: 569-DB07-AIC-300-006		SHEET: 5 de 8	
CLIENT NR: PRD-AIC-LIS-024		REV.: 0										
TAG	STATUS	EQUIPMENT NAME	TYPE	MANUFACTURER	MODEL	CAPACITY	DIMENSIONS (mm)	MATERIAL	REMARKS	QUANTITY	LOCATION	
	NEW	FLOW SWITCH	--	FLUK	F-01 SPRINK	--	--	--	--	6	7A-I-1-3-13	
	NEW	TAMPER SWITCH	--	HONEYWELL	OSY2	--	--	--	--	6		
	NEW	PRESSURE SWITCH	--	POTTER	PS10-2	--	--	--	--	1		
BUILDING 7B												
	NEW	VERY EARLY FIRE ALARM	ASPIRATION SMOKE DETECTOR	NOTIFIER	VLF-250	250m²	185 x 255 x 90	--	REQUIRES 03 FMM-101 FOR SUPERVISION, 01 FRM-1 FOR GLOBAL RESET POWER IT UP STRAIGHT TO FACP-PW. IT CAN BE POWERED 18-30VDC AND CONSUMES 220mA NORMAL, 205mA IN ALARM	1	7B-I-3-3-33	
	NEW	VEFA PARTS	--	NOTIFIER	FMM-101	--	--	--	MINI SUPERVISION MODULE	5		
	NEW	VEFA PARTS	--	NOTIFIER	FRM-1	--	--	--	RELAY MODULE	1		
	NEW	RELEASE ZONE PARTS	--	NOTIFIER	FCM-1-REL	--	--	--	TRIAC MODULE FOR RELEASE ZONES, ONE FOR MANUAL RELEASE STATION AND OTHER FOR NOVEC RELEASE	2		
	NEW	RELEASE ZONE PARTS	--	NOTIFIER	NBG-12LRA	--	--	--	DUAL ACTION RELEASING STATION WITH ABORT, RED, TERMINAL BLOCK, NOTIFIER KEY LOCK. REQUIRES 01 FCM-1-REL AND 02 FMM-101	1		
	NEW	RELEASE ZONE PARTS	--	NOTIFIER	P2GWL	--	--	--	PRE-ALARM HORN FOR NOVEC RELEASE	1		
	NEW	ADDRESSABLE MANUAL PULL STATION		NOTIFIER	NBG-12LX	--	--	--	--	30	7B-I-0-3-03 7B-I-0-3-13 7B-I-1-3-13 7B-I-2-3-23 7B-I-3-3-33	
	NEW	AUXILIAR POWER SUPPLY		NOTIFIER	FCPS-24S8	--	--	--	--	1		
	NEW	ADDRESSABLE SMOKE DETECTOR WITH SOUNDER BASE	PHOTOELECTRIC	NOTIFIER	FSP-951	--	--	--	--	243		

 		 		TITLE: EQUIPMENT & DEVICES SCHEDULE					DOC NR: 569-DB07-AIC-300-006		SHEET: 6 de 8
									CLIENT NR: PRD-AIC-LIS-024		REV.: 0
TAG	STATUS	EQUIPMENT NAME	TYPE	MANUFACTURER	MODEL	CAPACITY	DIMENSIONS (mm)	MATERIAL	REMARKS	QUANTITY	LOCATION
	NEW	ADDRESSABLE HEAT DETECTOR WITH SOUNDER BASE	THERMAL	NOTIFIER	FST-951	--	--	--	--	6	7B-I-0-3-03 7B-I-0-3-13 7B-I-1-3-13 7B-I-2-3-23 7B-I-3-3-33
	NEW	STANDARD BASE	--	NOTIFIER	B501-WHITE	--	--	--	STANDARD BASE FOR DETECTORS	249	7B-I-0-3-03 7B-I-0-3-13 7B-I-1-3-13 7B-I-2-3-23 7B-I-3-3-33
	NEW	ADDRESSABLE SMOKE DETECTOR BY LASER BEAM	--	NOTIFIER	FSL-751	--	--	--	FIRE DETECTOR ADDRESSABLE BY LASER, FLASHSCAN - NOTIFIER	10	7B-I-0-3-03 7B-I-0-3-13 7B-I-1-3-13 7B-I-2-3-23 7B-I-3-3-33
	NEW	BASE FOR FSL-751	DUCT	NOTIFIER	DNR	--	--	--	BASE FOR DUCT DETECTOR	10	7B-I-0-3-03 7B-I-0-3-13 7B-I-1-3-13 7B-I-2-3-23 7B-I-3-3-33
	NEW	SAMPLE PIPE	--	NOTIFIER	DST5	--	--	--	SAMPLE PIPE 5"	10	
	NEW	ISOLATOR MODULE	--	NOTIFIER	ISOX	--	--	--	--	27	
	NEW	INTELLIGENT RELAY MODULES	--	NOTIFIER	FRM-1	--	--	--	--	94	
	NEW	INTELLIGENT MONITOR MODULES	--	NOTIFIER	FMM-1	--	--	--	--	11	
	NEW	WALL HORN STROBES	--	NOTIFIER	P2RL	--	--	--	--	34	
	NEW	FLOW SWITCH	--	FLUK	F-01 SPRINK	--	--	--	--	5	7B-I-1-3-13
	NEW	TAMPER SWITCH	--	HONEYWELL	OSY2	--	--	--	--	5	
	NEW	PRESSURE SWITCH	--	POTTER	PS10-2	--	--	--	--	1	

<div><div></div><div></div></div>			<div><div></div><div></div></div>		TITLE: EQUIPMENT & DEVICES SCHEDULE					DOC NR: 569-DB07-AIC-300-006		SHEET: 7 de 8	
										CLIENT NR: PRD-AIC-LIS-024		REV.: 0	
TAG	STATUS	EQUIPMENT NAME	TYPE	MANUFACTURER	MODEL	CAPACITY	DIMENSIONS (mm)	MATERIAL	REMARKS	QUANTITY	LOCATION		
BUILDING 7C													
	NEW	ADDRESSABLE MANUAL PULL STATION		NOTIFIER	NBG-12LX	--	--	--	--	1	7C-I-1-3-13		
	NEW	ADDRESSABLE SMOKE DETECTOR WITH SOUNDER BASE	PHOTOELECTRIC	NOTIFIER	FSP-951	--	--	--	--	3			
	NEW	ADDRESSABLE HEAT DETECTOR WITH SOUNDER BASE	THERMAL	NOTIFIER	FST-951	--	--	--	--	4			
	NEW	STANDARD BASE	--	NOTIFIER	B501-WHITE	--	--	--	STANDARD BASE FOR DETECTORS	7			
	NEW	ADDRESSABLE GÁS DETECTOR	NGV	HONEYWELL	Sensepoint XCD	--	--	--	--	1	7C-I-1-3-13		
	NEW	INTELLIGENT MONITOR MODULES		NOTIFIER	FMM-1	--	--	--	--	1			
	NEW	WALL HORN STROBES		NOTIFIER	P2RL	--	--	--	--	1			
BUILDING 7F													
	NEW	ADDRESSABLE MANUAL PULL STATION	--	NOTIFIER	NBG-12LX	--	--	--	--	1	7F-I-1-3-13		
	NEW	ADDRESSABLE HEAT DETECTOR WITH SOUNDER BASE	THERMAL	NOTIFIER	FST-951	--	--	--	--	8			
	NEW	STANDARD BASE	--	NOTIFIER	B501-WHITE	--	--	--	STANDARD BASE FOR DETECTORS	4			
	NEW	WALL HORN STROBES		NOTIFIER	P2RL	--	--	--	--	1			

<div><div></div><div></div></div>			<div><div></div><div></div></div>			TITLE: EQUIPMENT & DEVICES SCHEDULE				DOC NR: 569-DB07-AIC-300-006		SHEET: 8 de 8	
CLIENT NR: PRD-AIC-LIS-024										REV.: 0			
TAG	STATUS	EQUIPMENT NAME	TYPE	MANUFACTURER	MODEL	CAPACITY	DIMENSIONS (mm)	MATERIAL	REMARKS	QUANTITY	LOCATION		
WASTE WATER TREATMENT PLANT (WWT)													
	NEW	ADDRESSABLE MANUAL PULL STATION	--	NOTIFIER	NBG-12LOB	--	--	--	PULL STATION FOR OUTDOOR APPLICATIONS	1	WWT		
WWT-NCA-01	NEW	NETWORK CONTROL ANNUNCIATOR	--	NOTIFIER	NCA-2	Enhanced-format 640-character LCD display with backlighting	--	--	COMMON FOR BUILDING 7A, 7B, 7C, 7F, WWT.	1			
	NEW	NCA BOM PARTS	--	NOTIFIER	AMPS24E	--	--	--	FONTE DE ALIM. 220 VAC, 50/60Hz, 2.5 A	1			
	NEW	NCA BOM PARTS	--	-	BATERIA 18AH	--	--	--	BATTERY 30min IN ALARM/ 24h IN STANDBY	1			
	NEW	NCA BOM PARTS	--	NOTIFIER	BP2-4	--	--	--	BATTERY DRESS PANEL	1			