

DROP IN THE CHILLED WATER PIPING SYSTEM. ALL PIPING SHALL GRADE TO LOW POINTS. PROVIDE HOSE END DRAIN VALVES AT THE BOTTOM OF ALL RISERS PREVER ELIMINADOR DE AR EM PONTO ALTO NO SISTEMA DE ÁGUA GELADA. TUBULAÇÃO COM CAIMENTO PARA PONTOS BAIXOS. PREVER VÁLVULAS DE

VÁLVULA DE BY-PASS - VÁLVULA BALANCEADORA PARA MANTER A VAZÃO 3. SYMBOLS REFERENCE - SEE DOCUMENT 07-M-0-5-01.

Project 721 Arbor Way Services Suite 100 BLUE BELL, PA 19422 Engineering Design/Build PHONE: (610) 828-4090 FAX: (610) 828-3656 Compliance Consulting www.ipsdb.com

IPS Professional Engineers and Architects, LLC.

| REV | DATE | DESCRIPTION | BY | CHECK | APPR |
|-----|-----------|-------------------------|-----|-------|------|
| Α | 28AUG2020 | 90% BD ISSUE | LFF | - | - |
| В | 27NOV2020 | DESIGN ISSUE | LFF | - | - |
| С | 17MAY2021 | 90% DD ISSUE | LID | cco | MSS |
| 0 | 18AUG2021 | ISSUED FOR CONSTRUCTION | JRM | LFF | MSS |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | · | | |
| | | | | | |



R. Dr. Cesário Mota Júnior, 424 - Vila Buarque, São Paulo - SP, 01221-020

REVISION C NOTES

FLOWRATES AND DIAMETERS HAVE BEEN UPDATED, AS WELL AS CALCULATIONS. THE EQUIPMENT AND DATA HAVE BEEN UPDATED ACCORDING TO IPS INFORMATION. VAZÕES E DIÂMETROS FORAM ATUALIZADOS, ASSIM COMO OS CÁLCULOS. OS EQUIPAMENTOS E DADOS FORAM ATUALIZADOS CONFORME INFORMAÇÕES

REVISION 0 NOTES

 SHEET NOTES NUMBER 3 WAS ADD. NOTA 3 ADICIONADA.

CONFIDENTIAL THE INFORMATION CONTAINED HEREIN MAY NOT BE USED OR REPRODUCED IN ANY MANNER WITHOUT WRITTEN PERMISSION OF INTEGRATED PROJECT SERVICES.



BURITI EPCMV

P&I DIAGRAM DRUG SUBSTANCE **CHILLED WATER**

REVIEWED BY SCALE

DRAWING NUMBER

DISTRIBUTION SYSTEM (2/4) ARCHITECT DESIGNER IPS PROJECT #

XREF FILE(S)

DRAWN BY

7B-M-0-5-52

CADD FILE NAME

7B-M-0-5-52=0