

RATING VES / JKT: 4 BARG, FV / 4 BARG, FV

DP/DT: ≤ 0.14 BAR

DP/DT: ≤ 0.14 BAR

DP/DT: ≤ 0.34 BAR

RATING VES / JKT: 4 BARG, FV / 4 BARG, FV

DP/DT: ≤ 0.14 BAR

RATING VES / JKT: 4 BARG, FV / 4 BARG, FV

Project

Services Engineering

721 Arbor Way BLUE BELL, PA 19422

Suite 100

PHONE: (610) 828-4090 Design/Build FAX: (610) 828-3656 Compliance Consulting www.ipsdb.com

REVISION	DATE	DESCRIPTION	BY
Α	28AUG2020	90% BD ISSUE	JJR
В	27NOV2020	DESIGN ISSUE	JJR
С	12FEB2021	30% DD ISSUE	RLD
D	16JUL2021	90% DD ISSUE	RLD
0	16AUG2021	CONSTRUCTION ISSUE	RLD
·			



R. Dr. Cesário Mota Júnior, 424 - Vila Buarque, São Paulo - SP, 01221-020

REVISION HISTORY

- 1 REV 0 ADDED SHEET NOTE 7 2 REV. 0 - ADDED DRIP PANS AND DRAIN VALVES TO
- UTILITY PANELS. 3 REV. 0 - ADDED PRESSURE SAFETY VALVES TO UTILITY
- 4 REV. 0 ADDED HIGH POINT AND LOW POINT DRAINS ON CHILLED/TEMPERED WATER SUPPLY AND RETURN AT UTILITY PANEL.
- 5 REV. 0 ADDED PORTED MANUAL VALVE ON TOP OF BUFFER PREP TANK FOR WFI FLUSHING PRIOR TO DOSING. 6 REV. 0 - ADDED EQUIPMENT TAGS FOR AGITATORS.

CONFIDENTIAL THE INFORMATION CONTAINED HEREIN MAY NOT BE USED OR REPRODUCED IN ANY MANNER WITHOUT WRITTEN PERMISSION OF INTEGRATED PROJECT SERVICES.



BURITI EPCMV

P&I DIAGRAM DRUG PRODUCT BLIEFED DDED

BUFFER PREP					
ENGINEER	ARCHITECT	DESIGNER	IPS PROJE		
JJR	BJE	RBN	ITD1943		

CONSTRUCTION

439.01 REVIEWED BY SCALE CADD FILE NAME NONE 7A-Z-0-2-01 DRAWING NUMBER

7A-Z-0-2-01