

Maintenance SOP 12 - Rotating Equipment

Section 7.4 Vibration Limits

Overall vibration shall not exceed 6.0 mm/s RMS. Above 9.0 mm/s requires removal from service.

Maintenance SOP 12 - Rotating Equipment

Section 7.5 Bearing Temperature

Normal bearing temperature is up to 80 C. Above 90 C requires shutdown and inspection.

Maintenance SOP 12 - Rotating Equipment

Section 7.6 Discharge Pressure

Pump-102 normal discharge pressure is 4.8 to 5.5 bar.

Maintenance SOP 12 - Rotating Equipment

Section 8.2 Replacement Decision

Replace only for irreparable casing damage, repeated critical vibration, or repair cost above 60 percent.