

Gautam Buddha University

Greater Noida - 201 310

Website: www.gbu.ac.in

BID FORM

FOR THE SUPPLY OF EQUIPMENTS FOR POWER SYSTEM LABORATORY

OF

SCHOOL OF ENGINEERING

Gautam Buddha University Greater Noida - 201 310

TENDER FOR SUPPLY OF EQUIPMENT FOR POWER SYSTEM LABORATORY OF SCHOOL OF ENGINEERING

Tender	Supply of Equipment for Power System Lab.					
Opening Date	13 th May, 2011					
Closing Date	13th June 2011 upto 3.00 p.m.					
Last date of Bid	13th June 2011 upto 5.00 p.m.					
Submission						
Technical Bid Opening Date, Time & Place	14th June 2011 at 3.00 p.m.					
	Venue : Conference Room of the Registrar Office, 1st Floor,					
	Administrative Building, G.B.U., Gr. Noida.					
Earnest Money Deposit	2% of the offered cost					
Completion Period	Within 10-12 weeks from the date of Purchase Order issued					
Bid System	Two Tier: 1) Technical Bid 2) Financial Bid					
Technical Bid Shall Contain	i. Technical specifications of each equipment quotedii. All documents in support of commercial terms &					
Contain	conditions and eligibility criteria.					
	iii. Bidders Proforma iv. EMD & Tender Fee demand drafts / pay orders.					
Financial Bid	The Financial Bid shall contain rate schedule only. The price shall be in words as well as in numeric numbers.					
	shan be in words as wen as in numeric numbers.					

"TECHNICAL BID (BIDDER'S PROFORMA)" (To be submitted in separate envelope)

1.	Name of the firm:								
2.	Date of incorporation								
3.	Name of the company – Government / Public Ltd. / Private Ltd. / Partnership /								
	Proprietorship:								
4.	Specify the number of years in this line of activity by the company:								
5.	Sales Tax/VAT registration No. (please attach certificate) :								
6.	. Experience (in year) of supplying & installation for similar software to IITs, NIT's or								
	Central Universities or any	Academic Institute of Nation	al Repute (please attached						
	certificate/P.O.):								
7.	Lakhs; please attach the cer	financial years (Figures shou tified copies of balance sheet 10-11 are not available ther	with trading, profit & loss						
	2008-09	2009-10	2010-11						
8.	Provide the postal address.	telephone & fax numbers,	and email address of the						
	-								
9.		n the date of the placement of	-						
10		s to whom you have supplied							
10		with full postal address and n	,						
		and E-mail-id, billing amoun							
		om the minimum three end us							
11									
11	1. Are you the manufacturer / authorized dealer / distributor/ reseller for the product quoted (please attached relevant certificate):								
12		y in supplying the goods ord							
1.2		eriod for the products supplie	-						
		•							
17	•	ng last three years? If yes, prov							
	-	if yes, please mention in separtion are attached with Technic							
_14	. vvnemer tetimitai spetimta	uun are aualieu willi reciiiil	ai Diu di IIdi I ES/ NO						

DECLARATION

- 1. The rates quoted in financial bid are inclusive of all taxes, packing, handling and installation charges.
- 2. The information given in the financial bid by the undersigned is correct.

	(SIGNATURE OF THE BIDDER)
	WITH SEAL
NAME :	
ADDRESS :	
:	
:	
Tel./Mobi	le No. :

Note: The financial bid is required to be submitted separately in a sealed cover super scribing as 'Supply of Equipments for Power System Lab. of School of Engineering.

Gautam Buddha University

School of Engineering

TECHNICAL SPECIFICATIONS: POWER SYSTEM LABORATORY

S.N.	ITEM	TECHNICAL SPECIFICATIONS
1.	Microcontroller based IDMT over current relay trainer	This test set-up should consists of (1) Micro controller based over current-relay (2) Current Injection source:
		 Micro controller Based Over-Current Relay. One number of 20A CT used to sense fault current. * One number of 12V auxiliary relay used for contactor operation. * Specification: Current input: 0-20Amp Number of contacts: One number "NC" contact @ 220V,10Amp rating one number of "NO" contacts @ 220V, 10Amp rating. Auxiliary supply: 230VAC, 50 Hz
		 Current Injection Unit One number of auto transformer used for current adjustment. One number of loading transformer used for current source. Current output terminated in the banana-sockets. One number of digital meter used to indicate current. Specification: Current Range: 0-20Amp AC (Continuously variable)
2.	Electromechanical type IDMT Relay trainer	This test set-up should consist of (1) Electro-mechanical Over Current Relay (2) Current Injection source with meter. Current rating:5 Amp # Current setting multiplier # Time setting multiplier # One number of NO contacts @ 220V ,10Amp rating # One number of NC contacts @ 220V ,10Amp rating
		Current Injection source:
		 One no. of auto transformer provided for current adjustment One no. of loading transformer used for current source # Current output applied to relay coil. # One no. of digital ammeter used to indicate current # Specification: current range: 0-20 Amp AC. (continuously variable) # One no. of automatic relay tripping time measurement circuit. # One no. of Digital timer provided to measure relay tripping time. # One number of reset switch provided for timer reset.
3.	Microcontroller based Over / Under Voltage relay Trainer	This test set-up should consist of (1) Micro controller based Over / Under Voltage Relay (2) Voltage Injection Source. Voltage input: 0 - 220volt Number of contacts:

		One number "NC" contact @ 220V,10Amp rating One number of "NO" contacts @ 220V, 10Amp rating Auxiliary supply: 230 V AC,50Hz * PC interfacing facility, Power ON/OFF switch with indicator VOLTAGE INJECTION SOURCE * One no. of auto transformer used for voltage adjustment. * Voltage output terminated in the banana-sockets * One number of digital meters used to indicate output voltage. * Specification: Voltage range: 0-300V AC. (Continuously variables)
4.	Electromechanical type Over / Under Voltage Relay trainer	This set-up should consists of (1) Electro mechanical type Over voltage-relay, (2) relay test setup with meter Voltage setting multiplier.(121v,132,143,154,165,176,187v) # Time setting multiplier. # One number of "NO" contacts @ 220V,10Amp rating. # One number of "NC" contacts @ 220V,10Amp rating. Electro Mechanical Type Under Voltage Relay Voltage setting multiplier.(55V,66,77,88,99V) # Time setting multiplier # One number of "NO" contacts @ 220V, 10Amp rating # One number of "NC" contacts @ 220V, 10Amp rating # One number of "NC" contacts @ 220V, 10Amp rating
5.	Electromechanical type Earth Fault Relay	This test set-up should consists of (1) Electromechanical earth-fault-relay. (2) Transformer test setup with meter # Current rating: 5V or 1Amp # Current setting multiplier # Time setting multiplier # One number of NO contacts @ 220V, 10Amp rating # One number of NC contacts @ 220V 10Amp Rating Current Injection Source * One number of 24/24V, 3Amp three phase delta-star transformer provided with secondary midpoint tapping * Midpoint provided for earth fault creation * One number of variable rheostat provided for variation of short-circuit earth resistance * 24V,3Amp three phase ac source provided for transformer primary input * One number of digital ammeter used to indicate current * One number of automatic relay tripping time measurement * One number of automatic relay tripping time measurement circuit * One number of reset switch provided for timer reset
6.	Reverse Power Relay	One number of 230/5V PT used to sense voltage * One number of ZCD for phase angle measurement * One number of 12V auxiliary relay used for contractor operation * Specification: # Current input: 0-20 Amp # Voltage input: 0-230V # Phase diff: 0-89 degree # Number of contacts: One number NC contact @ 220V,10Amp rating # One number of NO contacts @ 220V, 10Amp rating. # Auxiliary supply: 230VAC,50Hz * PC interfacing facility power ON/OFF switch with indicator.

Gautam Buddha University

School of Engineering

TECHNICAL SPECIFICATIONS: POWER SYSTEM LABORATORY

S.N.	ITEM	TECHNICAL SPECIFICATIONS
1.	Power System Simulator	Operating temperature range:
		+5°C to +40°C
	Power System Simulator	Operating relative humidity range:
	should be consisting of the	80% at temperatures < 31°C decreasing linearly to 50% at 40°C
	following three modules:	
	1.Power Plant Module 2. Transmission line and	Simulator voltages:Distribution: 415 V three-phase line to line
	distribution module	Utilisation: 415 V three-phase line to line
	3.Receiving Substation Module	Grid transformer:
	Sixceetving Substation Flourie	• 5 kVA delta to star (Dy11)
	It should come with the	Primary is matched to the incoming three-phase supply to give the 415 V
	complete SCADA package	three-phase line-to-line secondary distribution voltage.
	connected with minimum 20	Includes earth link for the secondary star point and a selectable tapping earth
	computers.	resistor for restricted earth fault protection tests.
		Generator and prime mover:
	Also, a second generator set	6 kVA maximum, Voltage 415V, 4-Pole, salient pole a.c generator with
	should be included to enable	automatic and manual excitation.
	the various experiments	• 7 kVA maximum induction motor with shaft encoder
	related to synchronization and	and electronic four-quadrant a.c vector-drive control,
	parallel operation of	with a four-position drive inertia switch.
	alternator.	 Generator transformer: 5 kVA, 1:1 ratio delta-to-star (Dy11) impedance matching with adjustable
		secondary tapping
	Each module should have an	Transmission lines:
	arrangement for emergency	Transmission voltage: 132kV, on 100MVA base
	stop.	Line reactances simulate 'per unit' (pu) values of
		impedance:
	The system should be able	• Line 1: 0.10 pu
	to perform the following	• Lines 2 and 3: 0.15 pu
	experiments:	• Lines 4 and 5: 0.25 pu
	System Level Experiments:	• Line 6: 5 x 0.1 pu length with four test points and
	• Load flow	dedicated three-zone distance protection
	Symmetrical faults	• Line 7: 4 x 0.01 pu (cable)
	Unbalanced faults	Capacitors should be provided adjacent to the lines. Each capacitor should have selectable values and should have option of getting
	Unsymmetrical faults	inserted in circuit to give π or T-line configurations for studies of losses.
	Circuit interruption	Distribution transformers:
	Generator:	• Two identical 2 kVA transformers.
	Synchronisation	With adjustable primary tappings and matched impedances
	Characteristics and	Switched busbar:
	performance	• Six bi-directional feeders, each with circuit-breakers –
	Voltage variation and control Voltage regulation	one circuit breaker is a 'point-on-wave' device
	Voltage regulationStability studies	• Two circuit-breakers to break each half of each bus
	Transformer:	• Twelve bus isolators, six on each half of the bus
	• Unequal taps	Two circuit-breakers that break the coupling between the main and reserve
	Unequal impedances	bus
	Unbalanced loads	

S.N.	ITEM	TECHNICAL SPECIFICATIONS			
	Protection:	Protection relays:			
	Overcurrent protection:	Grid transformer protection			
	Relay grading	Grid bus protection			
	Auto-reclose	Generator protection			
	High-set instantaneous	Generator bus protection			
	Back-tripping	Distance protection			
	• Directional control	• 2 x double bus protection			
	General protection:	• 4 x distribution transformer protection			
	Phase faultsEarth faults	Loads:			
	Distance protection	• Two separate 415 V (distribution) loads, each with delta-connected variable resistors and inductors;			
	Distance protection Differential protection of	One load should be near to the generator and the other near to the distribution			
	transformers	bus.			
	Differential protection of	Two sets of 415 V (utilisation) loads at the utilization bus; each should have			
	generators	delta-connected variable resistors, inductors and capacitor banks.			
	Busbar protection	One dynamic load – an induction motor at the utilisation bus			
	Generator protection	SCADA			
	Extra studies:	Software:			
	Central and embedded	Industry-standard supervisory control and data			
	generation	acquisition (SCADA)			
	 Synchronising and 	Full colour, compatible with Microsoft® Windows® XP			
	parallelling with another	(Professional)			
	three-phase source (mains or	Multi-level security features			
	generator)	Real-time display of voltages, currents and powers			
	• Load sharing	Event logging and alarm functions			
	Stiff/weak systems	Emergency stop			
	Circulating current	Hardware:			
	monitoring	High-specification computer, keyboard and mouse			
	• Three-source systems:	• Large full-colour, high-resolution LCD monitor			
	connecting the generator at the central generation or	• RS232 (serial port) to RS485 and K bus converters Communications standard:			
	embedded generation level	Modbus and K bus (converter to simulator)			
	Automatic voltage regulator	Second Generator			
	operation in constant reactive	Generator and motor:			
	power and constant power	6 kVA maximum , four pole salient pole a.c generator. Brushless, with			
	factor modes	automatic and manual excitation.			
		• 7 kVA maximum induction motor with shaft encoder			
		and electronic four-quadrant a.c vector drive control.			
		Relays:			
		Generator bus protection: overcurrent and earth fault			
		Generator protection: over speed and under speed,			
		overvoltage and overcurrent, and loss of mains (from			
		rate of change of frequency and voltage vector shift)			
		Meters:			
		• 2 x multi-function meters to show voltage, current and			
		power			
		• 4 x digital meters to show generator excitation voltage			
		and current, prime mover speed and generator load angle Distribution transformer:			
		• 415 V to 415 V delta-to-delta (Dd) with adjustable			
		primary tappings and an earthing transformer to the			
		secondary windings			
		Generator transformer:			
		• 415 V to 415 V delta-to-star (Dy) with adjustable			
		secondary tapping and an earth link for the secondary star point			
		* *			

GENERAL TERMS AND CONDITIONS

- 1. Detailed information about the Equipments/Instruments and their specifications are available in tender document, which can be downloaded from the University website www.gbu.ac.in.
- 2. Two bids system of tender will be adopted.
 - (i) The bid containing technical specifications and EMD
 - (ii) Bid containing financial offer

Technical and financial bids should be submitted in separate covers. The envelopes should be marked as technical bid and financial bid with reference numbers. These two envelops shall be sealed in a common cover and addressed to **The Registrar, Gautam Buddha University, Greater Noida, Gautam Budh Nagar -201310 (U.P.)** superscribing "**Tender against Notification Advt. GBU/S&P/02/2011, Name of supply: Laboratory Equipments/Instruments for the Power System Lab. in School of Engineering**" so as to reach us on or before last date of bid submission.

- 3. The Technical Bid and Financial Bid should be duly filled-up.
- 4. These bids will be opened in two stages. The bid containing technical specifications and EMD will be opened at first stage and if same is found according to required specifications, the bid containing financial offer shall be opened in second stage.
- 5. The "**Technical Bid"** shall contain all documents in support of quoted Equipments/Instruments, their specifications, commercial terms & conditions and eligibility criteria along with the page number for cited specifications in the company brochure for the particular item.
- 6. The **"Financial Bid"** shall contain price schedule only. The rates and units shall not be overwritten in the price schedule. The price shall be both in words and figures.
- 7. **Eligibility Criteria**: All the participating suppliers/firms or principal manufacturer-should meet the following qualifying criteria. The firm should be a registered supplier for such supplies. Following documents are required to be submitted with Technical Bid, to qualify eligibility criteria:
 - (a) Sales Tax/VAT registration certificate.
 - (b) PAN and TIN number should be mentioned.
 - (c) The firm should have experience of supplying & installation for similar Equipments/Instruments to institute of National repute such as IIT, AIIMS, CSIR labs etc. The company should also furnish a list of clients of last 3 years.
 - (d) Certified copy of balance sheet with trading, profit & loss account for the last three financial years should be submitted.
 - (e) Name of branch offices & service centres after sales arrangements.
 - (f) Earnest Money Deposit (EMD) **as 2% of the offered cost** is required to be submitted in the form of DD/Banker's Cheque only drawn in favour of "Finance Officer, Gautam Buddha University" payable at "Greater Noida" along with the Technical Bid. If supply is not made within the prescribed period EMD would be forfeited.
 - (g) Authorized signatory should sign on all pages. Bids without authorized signature will be rejected.
 - (h) *Minimum turnover required to procure the equipments/instruments :* Rupees One Crore for Annexure 'A' and Rupees Two Crore for Annexure 'B'.
 - (i) The bidder must be either sole Manufacturer of the Equipments/Instruments or the authorized agent/representative of the OEM. In the case of agent/representative, certified copy of the agency/authorization issued by the OEM should be enclosed with the tender.

- 8. Offer should be sent in a sealed envelope, submitted either in person or by post on which name and address of the supplier/firm shall be written. Tenders received through Emails or FAX will not be considered.
- 9. The technical bids will be opened on scheduled date and time in the presence of the vendors present possessing authorization letter from the respective companies/firms. Suppliers intending to attend the tender opening should intimate in advance.
- 10. The rate quoted should be F.O.R. Gautam Buddha University (Gautam Budh Nagar, Greater Noida, UP) in rupees inclusive of all charges e.g. packing, forwarding local taxes, railway freight, transit insurance, for outside firms and free delivery at University stores in the case of local firms. The total price should include all accessories required for final installation of the Equipments/Instruments.
- 11. The Equipments/Instruments should have USEPA/International/National validation certificates, wherever applicable.
- 12. The cost of the tender is Rs.1000/- (Rupees One Thousand) inclusive of taxes (Non-refundable) and it shall be paid separately in the form of DD/Banker's Cheque only drawn in favour of "Finance Officer, Gautam Buddha University" payable at "Greater Noida" and should be attached with technical bid envelope.
- 13. The EMD of the successful bidder will be refunded after two months of the completion of the supply and installation of the Equipments/Instruments to the satisfaction of the Gautam Buddha University. The EMD of the unsuccessful bidders will be returned to the concerned immediately after finalization of the tenders. No interest will be paid on EMD in any case.
- 14. The required delivery period must be mentioned against each item. Tenders should preferably be given only for those equipments/items/articles, which are available exstock. Rates of imported goods should be quoted excluding custom duty, as this University is exempted from payment of custom duty (by letter of Department of Scientific and Industrial Research, Ministry of Science & Technology, GOI).
- 15. Detailed specifications with the mention of make and model/Version of each item should be clearly given supported by the illustrated pamphlets wherever possible. Quotations without specified make and Model/Version and other particulars may be rejected. The payment will be made after the goods have been received, opened, checked, installed and found to be working satisfactorily as per the specifications and requirements. The accessories included in the Equipments/Instruments should also be clearly mentioned.
- 16. Losses or damage in transit will be borne by the Supplier. The supplier may, if he so desires, get the goods insured and include such charges in the tendered rate.
- 17. Offered prices should be valid at least for two months from the last date of receipt of tenders.
- 18. All legal proceedings, if necessity arises to the University may be any of the parties (University or Contractor/Supplier) shall have to be lodged in the courts situated at Gautam Buddha Nagar and not elsewhere.
- 19. (a) The Equipments/Instruments delivery time should be preferably within 10-12 weeks after the date of issuance of the purchase order. If the delivery time is quoted more than 10-12 weeks, GBU reserves all rights to permit the bidder to compete.
 - (b) The Penalty Clause is as under:-

Should the bidder fail to deliver the goods within stipulated period, the Competent Authority may, at his discretion, allow an extension in time subject to recovery from the bidder as agreed liquidated damages, and not by way of penalty, a sum equal to the percentage of the value of tender amount which the bidder has failed to supply for period of delay as stated below:-

i.Delay up to one week 1%

ii.Delay exceeding one week but not 2%

exceeding two weeks

iii.Delay exceeding two weeks but not exceeding one month

5%

iv.Delay exceeding one month

5% for each month and part there of

subject to maximum 10%

- (c) In case of failure to supply the goods within stipulated delivery period and in accordance with the specifications given in the quotations, the University shall be free to cancel the order.
- 20. Supply of the placed order in part will not be accepted.
- 21. The University's term for payment: 90% against delivery of items in good condition, installation and putting those in satisfactory working conditions; balanced 10% payment shall be released after 60 days of satisfactory working of the items. For balance 10% payment, the firm has to raise bill/letter for balance payment. No advance payment shall be released.
- 22. The AMC cost, wherever applicable, after warranty period shall be made in equal installments at the end of each quarter subject to satisfactory service rendered.
- 23. The price quoted should be in Indian Rupees.
- 24. No revision of price bid will be allowed once the price bids are opened.
- 25. No increase in price will be allowed after our purchase order(s) are placed.
- 26. Warranty certificate against all the Equipments/Instruments developed defects covering warranty period, which commences from the date of installation shall be given at the time of supply of the Equipments/Instruments.
- 27. Inspection certificates of the equipments/instruments inspected by the qualified engineer of the manufacturer and packed in accordance with the terms and conditions of this order must be enclosed.
- 28. During the warranty period whenever the firm is called upon to attend to the rectification of the defects/faults in the consignments, the firm shall attend to the repair work within a period of a week. They should render timely back up service whenever called upon. A certificate to the effect should be attached to the tender.
- 29. A certificate to the effect that Equipments/Instruments supplied is fully operational and no additional accessory or space is required to fully functioning the Equipments/Instruments should be issued along with the delivery challans/invoice. GBU reserves the right to refuse payment in the event of not furnishing this certificate at the time of supply.
- 30. Complete user, technical and service manuals/installation drawings/documentation and spare parts catalogue are to be provided along with the supply of the item.
- 31. Failure to comply with all the terms and conditions mentioned herein would result in the tender being summarily rejected.
- 32. Vendors are informed that once the firms are shortlisted based on the eligibility criteria and technical specifications, only then the financial bids of the firms meeting eligibility criteria, technical specifications / requirements would be opened.
- 33. Conditional tenders will not be accepted.
- 34. Any cutting and overwriting in the financial bid will not be accepted.
- 35. GBU reserves the right to change the order quantity or split the orders among multiple vendors without assigning any reason (s) whatsoever.
- 36. GBU reserves the right to reject any or all the tenders without assigning any reasons whatsoever.

SPECIAL TERMS AND CONDITIONS

- 1. Warranty period of equipments should be of two years.
- 2. Quote for three year extensive Annual Maintenance Contract (AMC) should be submitted separately in financial bid.
- 3. Price quoted shall include all necessary component parts, accessories and software required to run the equipments for successful intended experiments.
- 4. To verify the technical specifications and capabilities while evaluating technical bids, the firm may be asked to demonstrate the equipment in the University. If demonstration of the equipments in the University is not possible the firm shall arrange a visit of university officials to the nearby location for the same
- 5. Successful bidders shall arrange training programmes for the faculty and staff for the period decided by the University.
- 6. All equipments shall be compatible for Indian environmental conditions.

Registrar Gautam Buddha University

ACCEPTANCE

We accept the above terms and conditions and shall comply with them strictly.				
SIGNATURE OF THE AUTHORISED SIGNATORY	:			
NAME OF THE SUPPLIER	:			
ADDRESS	:			
	:			
	:			

Annexure: 'A'

FINANCIAL BID Name of Laboratory: Power System Laboratory

Name of the School: School of Engineering

S.N.	Item	Qty.	Unit Price (Rs. In figure)	Unit Price (Rs. in words)	Total Cost (Rs.)
1.	Microcontroller based IDMT over current relay trainer	01			
2	Electromechanical type IDMT Relay trainer	01			
3	Microcontroller based Over / Under Voltage relay Trainer	01			
4	Electromechanical type Over / Under Voltage Relay trainer	01			
5	Electromechanical type Earth Fault Relay	01			
6	Reverse Power Relay	01			

FINANCIAL BID Name of Laboratory: Power System Laboratory

Name of the School: School of Engineering

S.N.	ITEM	Qty.	Unit Price (Rs. In figure)	Unit Price (Rs. in words)	Total Cost (Rs.)
1	Power System Simulator	01	(RS. III ligure)	(RS. III WOLUS)	
	Power System Simulator should be consisting of the following three modules: 1.Power Plant Module 2. Transmission line and distribution module 3.Receiving Substation Module				
	It should come with the complete SCADA package connected with minimum 20 computers.				
	Also, a second generator set should be included to enable the various experiments related to synchronization and parallel operation of alternator.				
	Each module should have an arrangement for emergency stop.				
	The system should be able to perform the following experiments:				
	System Level Experiments: Load flow Symmetrical faults Unbalanced faults Unsymmetrical faults Circuit interruption Generator: Synchronisation Characteristics and performance Voltage variation and control Voltage regulation Stability studies Transformer: Unequal taps Unequal impedances Unbalanced loads Protection: Overcurrent protection: Relay grading Auto-reclose High-set instantaneous Back-tripping Directional control General protection: Phase faults Earth faults				

• Diff • Diff • Bus • Gen Extra Cent • Syr anot gene • Loa • Stiff • Cir • The gene embe • Aut cons	tance protection ferential protection of transformers ferential protection of generators shar protection nerator protection a studies: tral and embedded generation achronising and parallelling with ther three-phase source (mains or rator) ad sharing ff/weak systems culating current monitoring ree-source systems: connecting the rator at the central generation or edded generation level tomatic voltage regulator operation in tant reactive power and constant er factor modes Extensive Annual Maintenane shoot for each item congrately		act cost (three	years) should be	e mentioned on a
	sheet for each item separately Total cost of the offer is Rs	i			
	& conditions of the tender.			I abio	de by all the terms
	1. The information given		CLARATION nancial bid by t	he undersigned	is correct.
	SIGNATURE OF THE AU	THORISE	D SIGNATORY: _		
	NAME OF THE SUPPLIE	R :			
	ADDRESS :				