

Project:  
Location:  
Contract:  
Engineer:  
Filename: Power System

**ETAP**  
19.0.1C

Page: 1  
Date: 04-03-2024  
Revision: Base

### **Protective Device Settings**

<b>CB: CB117</b>				
MFR:	Square-D	Tag #:		3-Phase kA: 0.00 Sym. (Calc.)
Model:	FA 240V	Rating:	10 kA, 0.24 kV	LG kA: 0.00 Sym. (Calc.)
Size:	15	Cont. Amp:	15.000	Base kV: 0.000 (Calc.)
<b>Thermal Magnetic Trip Device</b>				
MFR:	Square-D	Thermal Trip:	FIXED	
Model:	FA	Magnetic Trip:	FIXED	
ID:	15			