Power System Report for 26-Aug-20

page 1 of 2

Energy Generation							
Complex wise generation and energy mix							
K-M Complex	5.38 GWh	11.83%					
Mahaweli Complex	9.29 GWh	20.45%	- Hydro	15.39	GWh	33.87%	
Samanala Complex	0.72 GWh	1.58%] '				
Thermal Complex	4.14 GWh	9.11%					
Coal	11.23 GWh	24.72%	- Thermal	29.00	GWh	63.84%	
IPP Thermal	13.64 GWh	30.02%]				
Solar PV (Bulk)	0.32 GWh	0.69%	Solar(Bulk)	0.32	GWh	0.69%	
Wind	0.73 GWh	1.60%	Wind	0.73	GWh	1.60%	

Total Energy Generation¹ 45.43 GWh


Power Generation/ Demand

Night Peak Ge	eneration at	19:00	hrs on 26-Aug-20		2507.0	MW		
Complex/Location wise contribution			Technology wise contribution of MW					
	MW	MVAr		MW	MVAr	MW %		
K-M Complex Hydro	281.3	63.9	Hydro ²	1223.6	143.0	48.8%		
Mahaweli Complex Hydro	689.2	52.3	Thermal Coal	466.2	72.2	18.6%		
Samanala Hydro	154.5	26.8	Thermal Oil	192.0	70.5	7.7%		
CEB Small Hydro	8.7	0.0	IPP Thermal	617.2	114.9	24.6%		
CEB Thermal - Coal	466.2	72.2	Wind	8.0	0.0	0.3%		
CEB Thermal- Oil	192.0	70.5	Solar PV(Bulk)	0.0	0.0	0.0%		
IPP Thermal	617.2	114.9	Capacitors		79.2			
IPP ² (MHP+BMP)	89.9	N/A	Total	2507.0	479.8	pf -	0.98 @	19:00 h
Wind	8.0	0.0	Day Peak ² and Minimum ² Generation					
				MW	MVAr			
Capacitors	-	79.2	Minimum Generation ²	1379.4	-31.1	pf -	1.00 @	3:15 h
Total Night Peak	2507.0	479.8	Day peak Generation ²	2159.4	728.3	pf -	0.95 @	16:00 h

Hydrology- Hydro Storage, Rainfall, Inflow

Reservoir Storage status and Rainfall record of major CEB Reservoirs.

Major Reservoirs	MOL below spill (m)	Current level below spill (m)	Storage in GWh	% of the total capacity	Rainfall in mm	Location	Rainfall in mm
Castlereigh	19	1.17	79.7	84.1	11.0	Norton	3.2
Maussakalle	22.4	4.46	202.5	71.3	4.5	Canyon	8.2
Kotmale⁵	38	6.85	102.7	71.8	0.0	Laxapana	17.0
Victoria ⁵	68	8.24	313.6	70.8	24.7	Ukuwela	0.0
Randenigala ⁴	23	14.98	30.4	28.3	22.0	Rantambe	13.5
Samanala Wewa⁴	31	12.20	65.7	49.3	0.0	Bowatenna	0.0
Total Hydro Storage on	27-08-20	at 06:00 hrs.	794.6	65.94	%	Kukule	0.0
						Upper Koth.	47.8



Maximum Voltages :								
Station	220 kV	Time	132 kV	Time				
Biyagama	226	3:00	135	2:30				
New Anu	228	3:00	133	2:15				
Rantabe	0	0:00	136	0:00				
Minimum Voltages :								
Biyagama	216	11:00	132	9:00				
Kotugoda	215	11:00	133	9:30				
Pannipitiya	212	11:00	130	8:15				
Kolonnawa			130	9:30				
New Galle			124	11:00				
25-Aug	26-Aug	Weekly A	Avg.					
8.17	11.02	8.41						

1) N/Anu -Haba both ccts tripped from N/Anu end at 13:58 hrs causing Haba,valach,Polon and Naula GSS to be dead. At the same time Haba -Naula cct,Bow-Uku cct and Haba T/F 03 tripped .Haba-N/Anu cct 02 tripped and A/R from Haba end.N/Anu-Haba ccts restored at 14:15 hrs.All efected GSS energized by 14:21 hrs. Haba T/F 03 energized at 18:06 hrs.

Dhanushka Bandara

Major Incidents

System Control Engineer

- (1) Excluding contribution from Non Conventional Renewable Energy, other than Wind and Solar.
- (2) Excluding contribution from Non Conventional Renewable Energy, other than Moragahakanda, Wind and Solar.
- $(3) Including\ data\ from\ 88\ mini\ hydro\ plants (MHP)\ \&\ 00\ biomass\ plants (BMP)\ having\ total\ Installed\ Capacity\ of\ 225.35MW.$
- (4) Randenigala MOL has been revised to 209 masl from 199.5 masl and Samanalawewa Spill level has been revised to 455 masl from 460 masl with effect from 01st Feb. 2018 considering reservoir operation restrictions.
- (5)- Percentage of the total capacity of Vict and Koth storage is calculated by considering downstream reservoir storage

Laxapana Complex Wimalasurendra 1 10 2 102 25 25 25 25 25 25 25	Turbine vibration Fire hazard inspection GT Rotor failure ST and STG major overhaul 20 24000hrs maintenance Air distributor breakdown
Wimalasurendra	Fire hazard inspection GT Rotor failure ST and STG major overhaul
Wimalasurendra	Fire hazard inspection GT Rotor failure ST and STG major overhaul
1	Fire hazard inspection GT Rotor failure ST and STG major overhaul
1 0.0 0 0 0 FO 24.08.20 - Unit TF testing	Fire hazard inspection GT Rotor failure ST and STG major overhaul
Old Laxapana	GT Rotor failure ST and STG major overhaul
A 9.9 2 240 12.5	ST and STG major overhaul 20 24000hrs maintenance
Canyon 1 30 3 621 30 Plant availability is limited to 30 MW due to problem in headrace tunnel. CCP STEAM 1 0 0 0 0 0 PM 28.06.19 -	ST and STG major overhaul 20 24000hrs maintenance
Canyon	ST and STG major overhaul 20 24000hrs maintenance
Canyon 2 0 0 0 30 to problem in headrace tunnel. New Laxapana 1 56 19 972 58	20 24000hrs maintenance
New Laxapana	
New Laxapana 2 48 20 913 50	
Polpitiya 2 48 20 913 50	
Polpitiya	Air distributor breakdown
2 42.0 6 797 45 4 0 0 0 0 PM 27.07.20 02.09.2	
TOTAL (Laxapana) 281 64 5376 3522	20 3000 hrs maintenance
Mahaweli Complex 6 0 0 0 0 PM 06.08.20 07.09.2	20 24000 hrs maintenance
1 38 -1 630 67 7 9 5 215 9	
Votralo 2 41 2 920 67	
Sapu. Station - B 0 / 4 1/0 9 Sapu. Station - B 0 / 4 1/0 9	1
1 78 10 1273 80 10 8 5 196 9	1
Victoria 2 78 20 1140 80 11 9 2 208 9	1
3 80 14 1207 80 12 8 5 187 9	+
1 41 1 22 35 Iakvijava PS	
Randenigala 2 39 1 97 35 1 0 0 0 0 FO 17.08.20 -	Turbine LP side diaphragm repairing
1 15 2 22 25 Jakyijaya PS 2 269 40 6477 270	
Rantambe 2 14 0 16 25 3 197 32 4752 200 PA 24.08.20 -	CW pump failure
1 19 0 438 18 Other	T. P. P. S.
Ukuwela 2 17 8 395 18 Uthuru Janani 22 0 516 23 Uthuru Janani 22 0 516	
Bowathenna 39 11 462 40 Power Barge 60 29 1448 60	1
1 76 -2 944 75 Sup-Thulbiriya 6.4 0 86 8.0	
Upper Kotmale 2 76 -2 1063 75 Sup-Kolonnawa 15.2 0 198 16.0	
Nillambe 3.2 0 2 3.2 Sup-Matugama 14.4 0 180 16.0	
TOTAL(CEB Thermal) 658 143 15367 824	
IPP THERMAL	
Total (Mahaweli) 692 52 9291 790 ACE Matara 24 0 569 24	1
Samanala Complex Asia Power 39 11 704 45	
Samanalawewa 1 61 14 171 60 Sojitz Kelanitissa 130 1 3033 130 PA 25.08.20 -	Commercial issue as per letter SKPL/CEB/KF/110821
2 41 0 52 40 PA 18.12.19 - Due to operational restrictions West Coast 276 87 6419 270	, , , , , , , , , , , , , , , , , , , ,
Kukule 1 26.2 6 311 37.5 Nothern Power 0 0 0 0 0	Unavailable due to court order
2 26.7 7 79 37.5 ACE-Embilipitiya 89 5 2054 79	†
Inginiyagala 5.5 0 106 11.25 Vpower-Pallekele 24 6 348 24	†
Udawalawe 0 0 0 0 4 Vpower-Galle 10 1 152 10	
Vpower-Hamba. 0 0 0 0	PPA expired at 24:00hrs on 24/08/2020
TOTAL (Samanala) 160 27 719 190 Vpower-Horana 24 4 358 24	1
PP MHP +BMP 2 90 0.00 N/A N/A	PPA expired at 24:00hrs on 24/08/2020
Wind 8 0.00 727 N/A Altaaga-Polon. 0 0 0 0	PPA expired at 24:00hrs on 24/08/2020
Solar PV (Bulk) 0 0 316 N/A	
Breaker Switch Capacitors 79 TOTAL(IPP Thermal) 617 115 13637 606	•
Total Hydro 1134 143 15,387 1333	
Total NCRE	
Total Energy during 24h 45,433 MWh Abbreviations	

(1) Available Capacity as at 6:00hrs on

27-Aug-20

SYSTEM CONTROL ENGINEER
System Control Centre
27-Aug-20

480 MVAr

2,507.0 MW 2,763 MW FO = Forced Outage
PM = Planned Maintenance
PA = Partially Available