

Hazard · workspace 54f4dcaa · created 2026-06-16 · id 9a715a5d

OVERVIEW

Title	Unguarded penetration — bay 4 floor
Severity	critical
Status	open
Location	Level 2
Owner	—

DESCRIPTION

Detected on site walk on day -1.

CONTROLS

- Cover penetration
- Add hi-vis signage
- Notify all crews