HIGH DESERT ROOFING & GUTTERS
License #RC-448120 | Fully insured
"We fix it right the first time"

INVOICE #4471
Date: February 11
Due: Upon receipt (net 15 accepted)

Bill to:
Mira Kowalczyk & Lena Ortiz
87 Willow Ct

Job site: same

Description of work:
Emergency repair following wind storm of Feb 3. Customer reported water staining on bedroom ceiling (NE corner).

Item	Qty	Rate	Amount
Roof inspection & leak diagnosis	1	$95.00	$95.00
Remove & replace damaged architectural shingles	2 sq	$310.00	$620.00
(approx. 2 squares, NE slope; color matched as close as possible - Weathered Wood)			
Replace torn underlayment, synthetic	2 sq	$65.00	$130.00
Re-seal plumbing vent boot (cracked rubber collar)	1	$145.00	$145.00
Replace bent drip edge, 16 ft	16 ft	$8.50	$136.00
Gutter re-hang & reseal, east side	1	$110.00	$110.00
Debris haul-away	1	$45.00	$45.00

Subtotal:	$1,281.00
Discount (repeat customer referral):	-$41.00
TOTAL DUE:	$1,240.00

Notes from technician (Ray B.):
- Leak source was the cracked vent boot, not the shingles — shingles were damaged too but the boot is what let water in.
- Remaining roof is about 14 yrs old, in fair condition. Recommend full replacement within 3-5 yrs. Happy to quote.
- Interior ceiling stain is cosmetic once dry; recommend stain-blocking primer before repainting.
- Did NOT see damage elsewhere. Photos emailed to customer.

Warranty: 2 years labor on repaired areas. Manufacturer warranty on materials.

Payment: check payable to High Desert Roofing, or card (3% fee), or Zelle.
Thank you for your business!

-- PAID 02/14 via Zelle, conf #ZL8830125 (handwritten)