



Front bottom cable input:
Staggered busbars are
provided for input phase
cables.

With a front-facing transformer, there is no
Component Mounting Plate. Customer ground
connection is typically provided in the Main
Cabinet input cable tray.

Customers can alternatively ground to
the PDU Input Terminal Block.

NOTE: Cut-outs behind PDU Input Terminal
Block and the front-facing transformer facilitate
infrared scanning.

