



1. Open Input Section door.

2. Remove 1/4-20 bolts from Transformer Front-Access Panel using 9-16 socket wrench.

3. Remove main section of Transformer Front-Access Panel.



4. Slide out small section of Transformer Front-Access Panel.

5. Transformer can be accessed for front-IR scans.

