

## Event Log

Mon Jan 16 2006 12:15:55.333	Analog Alarm S2 Volts BC	Low	
Mon Jan 16 2006 12:15:55.333	Analog Alarm S2 Volts CA	Low	
Mon Jan 16 2006 12:15:55.033	Digital Alarm DCPS S2V		Alarm
Mon Jan 16 2006 12:16:03.144	Analog Clear S2 Volts AB	OK	
Mon Jan 16 2006 12:16:03.144	Analog Clear S2 Volts BC	OK	
Mon Jan 16 2006 12:16:03.144	Analog Clear S2 Volts CA	OK	
Mon Jan 16 2006 12:16:03.144	Source 2 Good		
Mon Jan 16 2006 12:16:06.101	Digital Clear DCPS S2V	OK	
Mon Jan 16 2006 12:16:08.478	Digital Alarm SAS D DC	Alarm	
Mon Jan 16 2006 12:16:19.852	Digital Clear On Source	Preferred	
Mon Jan 16 2006 12:16:19.852	Digital Clear SAS D DC	OK	
Mon Jan 16 2006 12:19:28.088	Digital Alarm ROI in Control	Yes	
Mon Jan 16 2006 12:19:28.088	Digital Alarm Summary	Alarm	
Mon Jan 16 2006 12:42:30.703	Digital Clear ROI in Control	No	
Mon Jan 16 2006 12:42:30.703	Digital Clear Summary	OK	
Mon Jan 16 2006 12:43:29.957	Operator Log In Administrator		
Mon Jan 16 2006 13:05:17.045	Digital Alarm Transfer	Done	
Mon Jan 16 2006 13:05:17.045	Digital Alarm Summary	Alarm	
Mon Jan 16 2006 13:05:46.488	Operator Log Out		
Mon Jan 16 2006 13:06:11.287	Operator Log Out		
Mon Jan 16 2006 13:06:29.569	Operator Log In PDI		
Mon Jan 16 2006 13:07:09.927	Operator Log Out		

Clear

Home

Next>

Alarms

Log

Plots

Analog

Digital

Settings