

 ALARMS 5
WARNINGS 0

PDI DISPLAY

PDI

HOME ALARM DEVICES SETUP HELP

BCMS Over Volt Main	
-- 4/22/2013 15:13:16	
BCMS Over Volt Main	
-- 4/22/2013 15:13:20	
BCMS KW Under Volt Main	
-- 4/22/2013 15:13:24	

CLEAR ALL

SILENCE HORN

Touching **CLEAR ALL** clears all outstanding warnings and alarms on screen and resets corresponding Modbus registers in the device points list. It takes several seconds for alarms to clear. If a warning/alarm condition remains outstanding, the warning/alarm will remain on the ALARM screen.

Device Name

BCMS KW = device (generic panelboard device with KWH points list).
Device Name should be changed from generic name to user-specified name on the device's **SETTINGS** screen.

Alarm or Warning Name

"Under Volt Main" locates the problem to the main voltage source to the panelboard.

Touching **SILENCE HORN** silences the Color Monitor's audible alarm, which sounds when an alarm is issued.