

J1: Modbus **RTU Upstream** Connection

Pin J1, J3 Ground 2 RX-RX+ 3 TX-TX+

Ethernet Port

Note: Customer Modbus RTU connections are made to a Contractor Board, not to the Color Monitor.

Jumper W3, W4 for 2-wire Modbus downstream **Ethernet Port**

J3: Modbus RTU Downstream Connection