

PDU frame **input**
section bottom
cable entry

PDU frame **output**
section bottom
cable exit

There are (2)
removable
ramps. Roll PDU
with casters into
place over
ramps. Lock
casters. Bolt
PDU to floor
stand.

Adjust floor
stand height
with adjustment
screws.

Attach base plates to
subfloor

Attach PDU to
floor stand at this
short bracket.

Removable
floor stand
plate for cable
entry/exit

