


- 7 RECOMMENDED INPUT CABLE SIZE: (4) x 500CM, CU.
 6 APPROXIMATE WEIGHT: 6,500 lb.
 5 MINIMUM CLEARANCE FOR DOORS 36".
 4 MINIMUM VENTILATION CLEARANCE FOR REAR
 AND ONE SIDE OF UNIT 6" MINIMUM.
 3 ALL OPERATOR CONTROLS ARE FRONT ACCESS
 WITHOUT EXPOSURE TO LIVE PARTS.
 2 ALL ROUTINE MAINTENANCE IS FRONT AND SIDE ACCESS.
 1 ALL DIMENSIONS ARE IN INCHES.

NOTES: UNLESS OTHERWISE SPECIFIED:

THIS DRAWING CONTAINS CONFIDENTIAL & PROPRIETARY INFORMATION AND SHALL NOT BE DISCLOSED OR COPIED WITHOUT THE EXPRESSED, WRITTEN PERMISSION OF PDI POWER DISTRIBUTION, INC.				PDI	
		THIRD ANGLE PROJECTION		TITLE: PDU, 750KVA, (208V)	
APPROVALS			DATE		
DRAWN	KM			11/6/17	
DESIGNED	AD			11/6/17	
CHECKED	JS			11/6/17	
ENG. APPR.					
MFG. APPR.					
SCALE: NTS				SHEET 1 OF 2	