

PDU's with distribution panelboards have pre-punched cable exit trays.

Pre-punched knock-outs are 7/8" dia.
for 1/2" dia. conduit.

NOTES:

1. OPERATOR INTERFACE PANEL.
2. MAIN INPUT CIRCUIT BREAKER.
3. 225A SECONDARY MAIN CIRCUIT BREAKER.
4. (42) POLE DISTRIBUTION PANELBOARDS.
5. CT STRIP FOR BCMS (OPTIONAL).
6. RECOMMEND A MINIMUM OF 36" IN REAR OR SIDE OF UNIT FOR MAINTENANCE.
7. MINIMUM OF 36" CLEARANCE FOR DOOR SWING.
8. RECOMMEND 6" CLEARANCE BETWEEN VENTILATED SIDES AND WALL FOR PROPER COOLING.
9. BCMS CIRCUIT BOARD (OPTIONAL).

