Touching **CLEAR ALL** clears all outstanding warnings and alarms on screen and resets corresponding Modbus registers in the device points list. It takes several seconds for alarms to clear.

If a warning/alarm condition remains outstanding, the warning/alarm will remain on the ALARM screen.

Touching **SILENCE HORN** silences the Color Monitor's audible alarm, which sounds when an alarm is issued.

Device Name
BCMS KW = device (generic panelboard device with KWH points list).
Device Name should be changed from generic name to user-specified name on the device's **SETTINGS** screen.

Alarm or **Warning Name**
"Under Volt Main" locates the problem to the main voltage source to the panelboard.