

## Switch Settings

### Fast

120 High

80 Low

0 Delay

0 Ratchet

### Delayed

110 High

90 Low

256 Delay

### Controls

VSS POG



Mode

Cancel

No Yes



Retransfer

Execute

### Retransfer

10 Delay

25.-25 Phase

### VSS

1000 OverFlux

87 VSS Time

## User Controls

Transfer Algorithm  
Retransfer Behavior

Touch control to toggle choice.  
Confirm with **Execute**  
or revert with **Cancel**.

## Optimization for Sense and Transfer Algorithms:

**Fast** Algorithm  
**Delayed** Algorithm  
**Retransfer**  
**VSS**

Do not change  
these settings. PDI  
has experimentally  
optimized these  
parameters.